

CATALOGED BY ASTIA
AS AD NO.

258753

XEROX

Technical Report

151

LITHIUM HYDROXIDE CANISTERS FOR
PERSONNEL SHELTERS

13 June 1961

19991004189



U. S. NAVAL CIVIL ENGINEERING LABORATORY
Port Hueneme, California

Reproduced From
Best Available Copy

\$2.60

AD 258 753

258 753

Errata Sheet

U. S. NAVAL CIVIL ENGINEERING LABORATORY

Technical Report R-151

"Lithium Hydroxide Canisters for Personnel Shelters"

On page 13, paragraph 1, line 6,
change 0.9 pound of CO₂ per hour to .09 pound.

NOTICE: When government or other drawings, specifications or other data are used for any purpose other than in connection with a definitely related government procurement operation, the U. S. Government thereby incurs no responsibility, nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use or sell any patented invention that may in any way be related thereto.

LITHIUM HYDROXIDE CANISTERS FOR PERSONNEL SHELTERS

APWO 59-00-15

Type C Final Report

by

R. J. Zablodil, J. M. Stephenson, R. S. Chapler

OBJECT OF TASK

To develop a hand-operated blower for the standard lithium hydroxide canister for use in personnel shelters.

ABSTRACT

Because present hand-operated blowers at low crank speeds would not deliver enough air for a personnel shelter through the standard lithium hydroxide canister, a canister-blower device with two canisters paralleled was developed by NCEL. The device will deliver 15 cfm of air with 3-percent CO_2 at a crank speed of 29 rpm.

The unit reduced the CO_2 in a 500-cubic-foot sealed room from about 3 to 1/2 percent during the first hour's run; in subsequent runs the reduction from 3 percent became successingly less. During the eighth and final run the concentration was reduced to just 2 percent.

Good performance was obtained when air with 3-percent CO_2 was passed through a canister at 7-1/2 cfm. When CO_2 is removed at this rate, one canister per eight people will last six hours; this will maintain about a 3-percent CO_2 level in shelters. About 5000 Btu of heat and 2 pounds of water were released per canister for this period. The 3-percent CO_2 concentration is satisfactory for a day or two; however, NRL reports a limit of 1-percent CO_2 for longer periods.

Desiccant canisters are needed to remove water vapor. A ratio of two silica gel canisters to five lithium hydroxide canisters will remove water from the CO_2 reaction; a ratio of two to one will remove additional water generated by occupants.

Operational instructions are appended, with a chart showing when and how to use the equipment.

Qualified requesters may obtain
copies of this report from ASTIA

CONTENTS

	page
INTRODUCTION	1
DESCRIPTION	1
Lithium Hydroxide Canisters	1
Blowers	1
Canister-Blower Device	2
Test Chamber	2
METHOD OF TEST AND INSTRUMENTATION	3
Canister Air Flow	3
Blower Capacity	3
Sealed Chamber Tests (Diminishing CO ₂ Concentration)	3
Canister CO ₂ Absorption (Steady 3-Percent Concentration)	3
RESULTS OF TESTS	4
Canister Air Flow and Blower Capacity	4
Sealed Chamber (Diminishing CO ₂ Concentration)	4
Canister CO ₂ Absorption (Steady 3-Percent Concentration)	12
DISCUSSION OF RESULTS	13
CANISTER OPERATING PROCEDURE	19
FINDINGS	19
CONCLUSIONS	19
RECOMMENDATIONS	20
REFERENCES	20
APPENDIX - PROCEDURE FOR LiOH CANISTER USAGE	21
DISTRIBUTION LIST	22
LIBRARY CATALOG CARD	25




Figure 1. Lithium hydroxide canister-blower device with canisters in place.

INTRODUCTION

The Potomac River Naval Command has a personnel shelter program which needs a hand-operated blower for use with the Navy standard lithium hydroxide (LiOH) canister. The task of selecting or developing a suitable blower, fitting it to the canister, and testing the completed device in air of known CO₂ concentrations was assigned to the U. S. Naval Civil Engineering Laboratory. Desirable features were compactness, portability, and that it be reasonably easy for one man to operate. It was suggested that performance tests of the device be conducted with CO₂ concentrations in the range of 2 to 3 percent and that blower crank speeds should be about 20 rpm.

DESCRIPTION

Lithium Hydroxide Canister

The canister is a metal can approximately 6-1/2 inches in diameter and 11-3/4 inches high, with perforated ends for the passage of air. It holds approximately 6.4 pounds of anhydrous LiOH (4 to 14 sieve). A pressed-fit lid on each end, much like the lid on a paint can, keeps the LiOH sealed from the atmosphere while in storage. The canister specification is MIL-C-21004(SHIPS); the LiOH specification is MIL-L-20213C(SHIPS).

Blowers

It was decided that a hand-operated blower which would deliver 15 cfm through the canister would be satisfactory for shelter use. (The Naval Research Laboratory stated that air can be drawn through a canister at rates from 10 to 14 cfm at suction pressures of about 3 inches water gauge.*)

Although air delivery rates versus static pressures of commercial hand-operated blowers were not given in manufacturers' catalogs, three blowers appeared to be satisfactory and were purchased:

1. Champion Blower and Forge with a 6-inch-diameter wheel
2. Champion Blower and Forge with a 10-inch-diameter wheel
3. Buffalo Forge with a 10-inch-diameter wheel

* U. S. Naval Research Laboratory letter, 6130-165A:RRM:be, NRL Prob C08-05, of 13 January 1959.

These were tested with a canister attached and found unsatisfactory. The 6-inch Champion was unable to deliver the desired air flow of 15 cfm. The other two delivered the desired flow rates, but only at crank speeds above 50 rpm; much higher than the suggested 20 rpm. The 10-inch Champion was then modified by placing 1-inch extensions on the fan blades, thus making essentially a 12-inch wheel. The crank speed was further reduced, but it was still above 40 rpm.

NCEL then fabricated its own blower. It is similar to the unmodified 10-inch Champion, except the wheel is 12 inches in diameter and the clearance between the blade tips and the scroll housing is reduced. Again performance was improved, but yet a crank speed of 34 rpm was necessary to obtain 15 cfm.

Canister-Blower Device

The NCEL prototype lithium hydroxide canister-blower device was then developed, as shown in Figure 1. It consists of two paralleled canisters, a blower, a small plenum which holds the canisters, a jet aircraft type fuel filter, and a collapsible stand. The assembly is 4 feet high and weighs 46 pounds. When the blower is operated, room air is drawn into the canisters, passed through the plenum, discharged into the filter, and then returned to the room. Filtering keeps any lithium hydroxide dust from being discharged into the shelter; this dust irritates the respiratory system. A cork in the bottom of the filter is removed when no more dust is being generated, after about 5 minutes of operation, allowing the air to by-pass the filter.

The device with the NCEL blower delivered 15 cfm (7-1/2 cfm per canister) at a crank speed of 21 rpm when the filter was by-passed. The CO₂ reaction increased the speed to 29 rpm, but this performance was accepted as satisfactory. (The modified Champion delivered 15 cfm at 21 and 33 rpm, respectively.) With the filter, the crank speeds are increased from 10 to 20 percent, depending upon the blower used.

Test Chamber

Performance tests of the canister-blower device were made in a sealed test chamber. The chamber, which was nearly cubicle, with a volume of approximately 500 cubic feet, was sealed by spraying the interior surface with a Saran plastic. During tests the 2-foot by 6-foot door was held tightly closed by three bar-and-wedge type latches. CO₂ leak tests of the sealed chamber, with all instruments and equipment in place, gave a half-life of 20 hours.

METHOD OF TEST AND INSTRUMENTATION

Canister Air Flow

The canister-blower device was used to determine air flows through the canisters. A venturi tube attached to the blower outlet measured the air flow and a micromanometer on the plenum measured the static pressure. The blower was operated at several speeds and the resultant cfm and static pressures were tabulated. When one canister was being tested, the plenum hole for the other canister was sealed shut.

Blower Capacity

The capacity of each blower was determined by measuring the air volume and static pressure at fixed wheel speeds. The blower, with a duct 4 feet long and 4 inches in diameter attached, was operated by a variable-speed motor. The tests began at a crank speed of 15 rpm as determined by a tachometer. This meant a blower speed of 720 rpm since the gear ratio was 48 to 1. With the duct outlet closed, i.e. at zero air flow, the resultant static pressure in the duct was measured with the micromanometer. Then, keeping the wheel speed constant, the duct outlet was gradually opened, measuring static pressures and air flow rates in steps, until the blower was delivering about 60 cfm. An anemometer at the duct outlet measured the air flow rates. Blower capacities at crank speeds of 20, 25, 30, and 35 rpm were measured in the same way.

Sealed Chamber Tests (Diminishing CO₂ Concentration)

The sealed chamber tests were also made with the canister-blower device. The CO₂ concentration in the chamber was increased to 3 percent and the device, which was operated remotely, was adjusted to deliver about 20 cfm. Each test was for 60 minutes; CO₂ concentrations were read every 5 minutes from a Dwyer CO₂ analyzer, and wet- and dry-bulb temperatures were read from a motorized psychrometer. Blower tachometer and plenum micromanometer readings were also checked occasionally to be assured that air delivery rates remained constant. At the end of each hour the chamber was recharged to 3 percent and the test was repeated until the canister could no longer efficiently absorb CO₂. The hour or so needed to recharge the room to 3 percent precluded more than three tests per day.

Canister CO₂ Absorption (Steady 3-Percent Concentration)

Canister CO₂ absorption tests were made with single canisters. Figure 2 shows the test setup. Tests were made at 5, 7-1/2, and 10 cfm with a steady 3-percent CO₂ concentration. Two 30-cfm rotameters measured the air flow and CO₂ rates, and a Hayes Orsat, using a two-way cock, measured the inlet and outlet CO₂ concentrations. To determine the water generated by the canister, a thermocouple and a dew-point temperature

recorder measured the inlet air psychrometry and another thermocouple and dew-point recorder measured the outlet's psychrometry. Air for the test was supplied by an air compressor; the CO₂ by a standard 50-pound cylinder. The air and CO₂ were well mixed and their pressures were reduced to almost zero gauge before entering the canister.

Two preliminary 7-hour tests made at 10 cfm revealed the reaction pattern and the degree of saturation that could be expected. The tests indicated that after 4-1/2 hours of operation the rate of CO₂ absorption was poor. It was discovered that if the canisters were then allowed to rest for 30 minutes, they reacted sharply when put back into operation. It was therefore decided that each canister would be operated for 4-1/2 hours and then be given a 30-minute rest period, followed by a second phase of operation which would continue until the efficiency again dropped off. The results later revealed that all three runs required virtually the same time cycle. The canisters were weighed before and after testing and also during the rest period.

RESULTS OF TESTS

Canister Air Flow and Blower Capacity

The curves shown in Figures 3 through 6 illustrate the results of the blower capacity tests. Superimposed on the fan curves are the system curves for one and two canisters for pure air and for air containing 3-percent CO₂. The pure air curves have a parabolic shape characteristic of ductwork systems, but the 3-percent curves have a different shape, showing considerable increase in static pressure and rpm for the same cfm. When two canisters operate in parallel, the static pressure is somewhat higher than with a single canister under similar conditions, presumably because of additional air turbulence.

Sealed Chamber Tests (Diminishing CO₂ Concentration)

Figures 7 and 8 show the results of operating the canister-blower unit (with two canisters) in the sealed chamber. Figure 7 shows that the unit readily reduced the CO₂ concentration from about 3 to 1/2 percent during the first hour's operation. Ability to reduce the concentration diminished as the test progressed, until during the eighth hour the unit could reduce the concentration to only about 2 percent. Figure 8 shows the effect the canister operation had on chamber relative humidity and dry-bulb temperature. The relative humidity increased rapidly during the first half-hour and then decreased moderately during the remainder of the hour, while the dry-bulb temperature continued to rise throughout the run. The canister recuperated during chamber recharging, which accounts for the similar hourly test patterns. Little change occurred in the relative humidity during the eighth hour, indicating that the canister was nearly spent.




Figure 2. Test setup for canister absorption of CO_2 at a steady 3-percent level.




Figure 3. Flow characteristics of the 10-inch Champion blower.




Figure 4. Flow characteristics of the 10-inch Buffalo-Forge blower.




Figure 5. Flow characteristics of the 12-inch (modified) Champion blower.




Figure 6. Flow characteristics of the 12-inch NCEL blower.




Figure 7. CO₂ concentrations in sealed chamber tests.




Figure 3. Psychrometric changes in sealed chamber tests.

Canister CO₂ Absorption (Steady 3-Percent Concentration)

Significant results of the steady 3-percent CO₂ flow tests are listed in Table I. The tabulations are either from direct measurements or were obtained by computation.

Table I. Results of Canister CO₂ Absorption Tests
(Steady 3-Percent Concentration)

1. Air flow rate, cfm	M*	10	7.5	5
2. Length of test, hr	M	6.1	5.8	6.0
3. LiOH originally in canister, lb	M	6.4	6.4	6.4
4. CO ₂ to canister, total for run, lb	M	13.10	10.46	6.00
5. CO ₂ absorbed by canister, lb	C	5.00	5.19	4.25
6. CO ₂ which theoretically can be absorbed, lb	C	5.86	5.86	5.86
7. Degree of saturation (5 + 6), percent	C	85.4	88.6	72.5
8. Water generated (based on 5), lb	C	2.05	2.13	1.74
9. Water generated (based on dew-point temp.), lb	C	1.69	1.78	1.74
10. LiOH remaining in canister (based on 5), lb	C	0.94	0.73	1.76
11. Li ₂ CO ₃ formed in canister (based on 5), lb	C	8.41	8.74	7.14
12. Weight of empty canister, lb	M	1.81	1.79	1.85
13. Final weight (LiOH, Li ₂ CO ₃ , and canister), lb	M	11.56	11.31	10.69
14. Weight unaccounted for [13 - (10 + 11 + 12)], lb	C	+0.40	+0.05	-0.06
15. Maximum dry-bulb temperature of effluent, F	M	199.5	234.5	184.5
16. Maximum dew-point temperature of effluent, F	M	83.0	98.3	89.5
17. Maximum pressure difference across canister, in. H ₂ O	M	2.10	1.58	0.77
18. Total heat released to effluent, Btu	C	5056	5022	4310

* M - measured
C - computed

Item 4 is the weight difference of the CO₂ cylinder before and after each run. Item 5, the CO₂ absorbed by the canister as computed from the Orsat analysis, shows that 7-1/2 cfm is the best rate. From this rate it can be determined that one canister is needed for every eight persons (operator figures as two), assuming the canister life to be 6 hours and that each person produces 0.9 pound of CO₂ per hour. Item 6, the weight of carbon dioxide which theoretically can be absorbed, is based on the formula $2 \text{ LiOH} + \text{CO}_2 \longrightarrow \text{Li}_2\text{CO}_3 + \text{H}_2\text{O}$. Items 8 and 9, water generated by the chemical reaction, show fairly good correlation although each was computed differently. Item 8 was determined by plugging item 5 into the chemical formula, and item 9 was determined psychrometrically by using the measured inlet and outlet dew-point temperatures. The heat released per canister, item 18, was calculated from the change in enthalpy of the inlet and outlet air. This heat, on an hourly basis, was approximately 720 Btu at 5 cfm and 840 Btu at 7-1/2 and 10 cfm.

The results also have been plotted as curves, Figures 9 through 12. The reaction pattern is best illustrated by Figure 9. During the first hour a strong reaction occurred followed by a steep decline, and then at the beginning of the third hour a second strong reaction occurred. From this point the reaction dropped off rather sharply until practically no CO₂ was being absorbed; after about 4-1/2 hours. Following the 30-minute rest period, another moderate reaction occurred which tailed off after 1-1/2 hours. This pattern was similar to the preliminary runs and occurred regardless of the air velocity or the mass flow of CO₂.

The dew-point curves, Figure 10, are rather erratic, but presumably the water was not released from the canister at the same rate at which it was formed.

DISCUSSION OF RESULTS

Crank speeds must be considered in relationship to crank length, gear ratio, and blower speed. Cranking the NCEL blower at a speed of 29 rpm was very convenient using the 48-to-1 gear ratio and a 10-inch crank. Cranking at the suggested 20 rpm is possible with a 70-to-1 gear ratio, but this would require a crank length of 14.3 inches. Crank lengths are based on a hand velocity of 2.5 feet per second as recommended by Marks.

Lower flow rates through the canister result in more efficient absorption, but a minimum rate must be maintained to obtain the required mass flow of CO₂. Higher flow rates are limited by the static pressure, so a compromise must be reached between efficiency, pressure, and mass flow. The flow rate of 7-1/2 cfm seems to be best for the canister.




Figure 9. CO₂ concentrations entering and leaving the canister.




Figure 10. Dew-point temperatures of air-CO₂ mixture entering and leaving the canister.




Figure 11. Dry-bulb temperatures of canister effluent.




Figure 12. Pressure differentials of the canister.

If it is considered necessary to collect the water released by the LiOH, a desiccant must be used. Assuming the canister could also be used for silica gel (SiO₂), about 16 pounds of SiO₂ (4 to 14 sieve - same as LiOH) would fill it. Based on the ASHRAE guide,² 16 pounds of SiO₂ would adsorb about 5 pounds of water; the amount generated by 2-1/2 LiOH canisters. If the water generated by shelter occupants is also collected, ten SiO₂ canisters would be needed for every five LiOH canisters. For example, a fully occupied 50-man shelter would require 25 LiOH canisters and 50 SiO₂ canisters for 24 hours. The cost of these canisters would be \$1500, assuming \$28 for a LiOH canister and \$15 for a SiO₂ canister. The number of blower units needed for the 50-person operation would be nine, which, at an estimated cost of \$100 each in quantity production, would cost \$900. Thus, the total cost to control CO₂ and water for 24 hours for 50 people would be \$2400. Costs for other time periods are listed in Table II.

Table II. Approximate Cost to Remove CO₂ and Water for 50 Persons

Time Period	LiOH Canisters Needed	LiOH Canister Cost	SiO ₂ Canisters Needed	SiO ₂ Canister Cost	Blower Units Needed	Blower Unit Cost	Total Cost
6 hr	6	\$ 150	12	\$ 180	9	\$900	\$1230
12 hr	12	300	24	360	9	900	1560
24 hr	25	750	50	750	9	900	2400
48 hr	49	1370	98	1470	9	900	3740

The above table shows that cost of canisters becomes an important factor. The heat released is important also, particularly in warm climates. Fifty persons at rest produce approximately 20,000 Btu's per hour of total heat, and the canisters increase this to 25,040 Btu's per hour. The table is based on a 3-percent CO₂ level, which is the acceptable limit for a day or two according to the Chemical Warfare Laboratories.³ For longer periods, the maximum limit is 1 percent, which is the upper level maintained in nuclear-powered submarines.⁴

The ordering, stocking, and inventorying of many canisters may be burdensome. The SiO₂ canisters perhaps could be eliminated by a single desiccant machine. A dehumidification machine has been developed which utilizes a corrugated asbestos-fiber wheel impregnated with a hygroscopic salt. This machine could be modified for hand-crank operation and easy renewal of the asbestos-fiber wheel. Cranking energy would not be excessive, perhaps 1/8 horsepower for a fully occupied 50-man shelter.

CANISTER OPERATING PROCEDURE

A proposed method of LiOH canister usage is given in the Appendix.

Although each canister requires at least a 30-minute rest after 4-1/2 hours of operation, there would be no discontinuity in the CO₂ removal because canisters from the stockpile could be substituted for those being rested. After 6 hours of operation, a canister is still capable of absorbing about 3/4 pound of CO₂, so that in a dire emergency the canisters could be used until they are completely spent. Evidence of reaction can be detected with the bare hand by feeling the can or effluent, since the heat evolved is proportional to the rate of absorption.

FINDINGS

1. A commercial hand-operated blower which would work satisfactorily with the standard lithium hydroxide canister could not be found. One built by NCEL worked better, but it too was unable to meet requirements.
2. The prototype canister-blower device using two canisters in parallel and the NCEL blower gave acceptable performance by delivering 15 cfm at a crank speed of 21 rpm with air, and 29 rpm with the CO₂ canister reaction. The device with the modified Champion blower would deliver 15 cfm at 21 rpm and 33 rpm, respectively.
3. The canister increases its static pressure as much as 100 percent when absorbing CO₂.
4. The canister does not remove CO₂ at a steady rate. Its most useful period is during the first 4-1/2 hours, but if allowed to rest for at least 30 minutes it will adsorb for another 1-1/2 hours.
5. Of the tests made, the canister absorbed best at 7-1/2 cfm.
6. If water from the CO₂ reaction is collected, a ratio of two silica gel canisters to five lithium hydroxide canisters is required. If water from the CO₂ reaction and occupants is collected, a ratio of two silica gel canisters to one lithium hydroxide canister is required.

CONCLUSIONS

1. The NCEL blower performed better than the others tested by delivering 15 cfm at 29 rpm during the CO₂ reaction. The suggested rate of 20 rpm could be obtained by using a speed reducer with a higher gear ratio (70 to 1), but with less favorable size and weight.

2. It would not be advisable to attach desiccant canisters in series to lithium hydroxide canisters because of the increase in static pressure. High static pressures are difficult to overcome with hand-operated equipment. If it is necessary to remove moisture, separate units containing paralleled desiccant canisters could be used; crank speed would be 21 rpm.

3. Because of the decreasing reaction pattern, a lithium hydroxide canister should not be used longer than 6 hours, with a 30-minute rest period at the end of 4-1/2 hours.

4. The canisters will absorb CO₂ satisfactorily if the method outlined in the Appendix is followed.

RECOMMENDATIONS

1. That a set of design drawings and specifications be prepared and a blower unit be built by a commercial manufacturer.

2. That the above blower unit be tested at NCEL preparatory to quantity production.

3. If desiccant canisters are to be required, that they be the same size as the lithium hydroxide canisters.

REFERENCES

1. Lionel S. Marks. Mechanical Engineer's Handbook, 5th Edition. McGraw-Hill, New York, 1951. Page 1079.

2. Heating Ventilating Air-Conditioning Guide, 38th Edition, Vol 38. American Society of Heating, Refrigerating and Air-Conditioning Engineers, New York, 1960. Page 622.

3. Chemical Warfare Laboratories. Report No. 2177, Physiological Evaluation of a Diffusion Board Protective Shelter, by A. A. Woodward, et al. Army Chemical Center, Maryland, 3 April 1957. Page v.

4. Naval Research Laboratory. Report No. 5465, The Present Status of Chemical Research in Atmospheric Purification and Control on Nuclear-Powered Submarine, by R. R. Miller, et al. Washington, D. C., 21 April 1960. Page 19.

Appendix


PROCEDURE FOR LiOH CANISTER USAGE

The canisters are not to be used until the CO₂ concentration in the shelter reaches 3 percent. Then the correct number of canisters are to be placed in operation to remove further additions of CO₂ at approximately the same rate at which it is generated by the occupants.

The chart below shows when and how to use the canisters. On the chart's left side, the "population density" (cubic feet per person) is connected vertically up to the sloping line and then horizontally right to the "waiting period." This gives the time period from initial occupancy until the 3-percent level is reached in the shelter. Moving to the chart's right side, the "shelter population" is connected horizontally right to the sloping line and then vertically down to the base, which gives the number of canisters to be used every 6 hours.

Example:

- a. To find waiting period to 3-percent CO₂ level with a population density of 150, start at ① and follow broken line to ② . (5-1/2 hours.)
- b. To find rate of canister usage with 50 persons in shelter, start at ③ and follow broken line to ④ . (Six-plus canisters. Use seven.)



DISTRIBUTION LIST

No. of Copies	SNDL Code	
25		Area Public Works Office, Chesapeake, U. S. Naval Weapons Plant, Washington, D. C.
10		Chief, Bureau of Yards and Docks
		<u>BuDocks Standard Distribution</u>
1	23A	Naval Forces Commanders (Taiwan Only)
2	39B	Construction Battalions
9	39D	Mobile Construction Battalions
3	39E	Amphibious Construction Battalions
2	39F	Construction Battalion Base Units
1	A2A	Chief of Naval Research - Only
2	A3	Chief of Naval Operations (Op-07, Op-04)
5	A5	Bureaus
3	B3	Colleges
2	F4	Laboratory ONR (Washington, D. C. Only)
1	E16	Training Device Center
8	F9	Station - CNO (Boston; Key West; New Orleans; San Juan; Long Beach; San Diego; Treasure Island; and Rodman, C. Z. Only)
5	F17	Communication Station (San Juan; San Francisco; Pearl Harbor; Adak, Alaska; and Guam only)
1	F21	Administration Command and Unit CNO (Saipan only)
2	F40	Communication Facility (Pt. Lynautey and Japan only)
1	F41	Security Station
2	F42	Radio Station (Oso and Cheltenham only)
2	F48	Security Group Activities (Winter Harbor only)
8	H3	Hospital (Chelsea; St. Albans; Portsmouth, Va; Beaufort; Great Lakes; San Diego; Oakland; and Camp Pendleton only)
1	H6	Medical Center
2	J1	Administration Command and Unit-BuPers (Great Lakes and San Diego only)
1	J3	U. S. Fleet Anti-Air Warfare Training Center (Virginia Beach only)
2	J4	Amphibious Bases
1	J19	Receiving Station (Brooklyn only)
1	J34	Station - BuPers (Washington, D. C. only)
1	J37	Training Center (Bainbridge only)
1	J46	Personnel Center
1	J48	Construction Training Unit
1	J60	School Academy

Distribution List (Cont'd)

No. of copies	SNDL Code	
1	J65	School CEC Officers
1	J84	School Postgraduate
1	J90	School Supply Corps
1	J95	School War College
1	J99	Communication Training Center
11	L1	Shipyards
4	L7	Laboratory - BuShips (New London; Panama City; Carderock; and Annapolis only)
5	L26	Naval Facilities - BuShips (Antigua; Turks Island; Barbados; San Salvador; and Eleuthera only)
1	L30	Submarine Base (Groton, Conn. only)
2	L32	Naval Support Activities (London & Naples only)
2	L42	Fleet Activities - BuShips
4	M27	Supply Center
7	M28	Supply Depot (Except Guantanamo Bay; Subic Bay; and Yokosuka)
2	M61	Aviation Supply Office
3	N1	BuDocks Director, Overseas Division
42	N2	Public Works Offices
7	N5	Construction Battalion Center
5	N6	Construction Officer-in-Charge
1	N7	Construction Resident-Officer-in-Charge
12	N9	Public Works Center
1	N14	Housing Activity
2	R9	Recruit Depots
2	R10	Supply Installations (Albany and Barstow only)
1	R20	Marine Corps Schools, Quantico
3	R64	Marine Corps Base
1	R66	Marine Corps Camp Detachment (Tengan only)
7	W1A1	Air Station
35	W1A2	Air Station
9	W1B	Air Station Auxiliary
4	W1C	Air Facility (Phoenix; Monterey; Oppama; Naha; and Naples only)
3	W1E	Marine Corps Air Station (Except Quantico)
1	W1F	Marine Corps Auxiliary Air Station
8	W1H	Station - BuWeps (Except Rohn)

Distribution List (Cont'd)

No. of
copies

- 1 Chief of Staff, U. S. Army, Chief of Research and Development, Department of the Army, Washington 25, D. C.
- 1 Office of the Chief of Engineers, Asst. Chief of Engineering for Civil Works, Department of the Army, Washington 25, D. C.
- 1 Chief of Engineers, Department of the Army, Attn: Engineering R & D Division, Washington 25, D. C.
- 1 Commanding Officer, Engineering R & D Laboratories, Attn: Technical Intelligence Branch, Fort Belvoir, Virginia
- 1 Commanding General, Wright Air Development Center, Air Research and Development Command, Wright-Patterson Air Force Base, Ohio
- 1 Deputy Chief of Staff, Development, Director of Research and Development, Department of the Air Force, Washington
- 1 President, Marine Corps Equipment Board, Marine Corps Schools, Quantico, Virginia
- 1 Director, National Bureau of Standards, Department of Commerce, Connecticut Avenue, Washington, D. C.
- 10 Armed Services Technical Information Agency, Arlington Hall Station, Arlington 12, Virginia
- 1 Deputy Chief of Staff, Research and Development Headquarters, U. S. Marine Corps
- 3 Headquarters, USAF, Directorate of Civil Engineering, Attn: AFOCE-ES, Washington 25, D. C.
- 2 Commander, Headquarters, Air Research and Development Command, Andrews Air Force Base, Washington 25, D. C.
- 2 Office of the Director, U. S. Coast and Geodetic Survey, Washington 25, D. C.
- 2 Library of Congress, Washington 25, D. C.
- 10 Director, Office of Technical Services, Department of Commerce, Washington 25, D. C.

NCEL Standard Distribution

- 1 Capt. A. B. Chilton, CEC, USN, U. S. Naval Civil Engineering Laboratory, Port Hueneme, Calif.
- 2 Director of Defense Research and Engineering, Department of Defense, Washington 25, D. C.
- 2 Director, Division of Plans and Policies, Headquarters, U. S. Marine Corps, Washington 25, D. C.
- 2 Director, Bureau of Reclamation, Washington 25, D. C.
- 2 Commanding Officer, U. S. Naval Construction Battalion Center, Attn: Technical Division, Code 141, Port Hueneme, California
- 2 Commanding Officer, U. S. Naval Construction Battalion Center, Attn: Materiel Department, Code 142, Port Hueneme, California
- 1 Commanding Officer (Patent Dept.), Office of Naval Research Branch Office, 1030 E. Green Street, Pasadena, California
- 1 Commanding Officer, Yards and Docks Supply Office, U. S. Naval Construction Battalion Center, Port Hueneme, Calif.

Distribution List (Cont'd)

No. of
copies

NCEL Supplemental Distribution

1	Commandant, Industrial College of the Armed Forces, Washington, D. C.
1	Chief, Bureau of Ships, Attn: Chief of Research and Development Division, Navy Department, Washington, D. C.
1	Chief, Bureau of Medicine and Surgery, Attn: Research Division, Navy Department, Washington, D. C.
1	Officer in Charge, U. S. Naval Supply Research and Development Facility, Naval Supply Center, Attn: Library, Bayonne, N. J.
1	Officer in Charge, U. S. Naval Supply Research and Development Facility, Naval Supply Center, Bayonne, N. J.
1	Commander, Norfolk Naval Shipyard, Attn: Chemical Laboratory, Portsmouth, Va.
1	Commander, U. S. Naval Shipyard, Attn: Materials and Chemical Lab, Boston, Mass.
1	Commander, U. S. Naval Shipyard, Attn: Material Laboratory, Brooklyn, N. Y.
1	Office of Naval Research, Branch Office, Navy No. 100, Box 39, FPO, New York
1	Commanding Officer, U. S. Naval Unit, U. S. Army Chemical Corps School, Fort McClellan, Ala.
1	U. S. Naval Research Laboratory, Chemistry Division, Washington, D. C.
1	Commanding Officer, Field Research Laboratory, Bureau of Medicine and Surgery, Camp Lejeune, N.C.
1	Deputy Chief of Staff, Research & Development Headquarters, U. S. Marine Corps, Washington, D. C.
1	Deputy CCMLD for Scientific Activities, Washington, D. C.
1	Chief of Ordnance, U. S. Army, Attn: Research & Development Laboratory, Washington, D. C.
1	U. S. Army, Attn: Director of Research and Development Group, Washington, D. C.
1	President, Chemical Warfare Board, Army Chemical Center, Md.
1	Directorate of Medical Research, Chemical Warfare Laboratory, Army Chemical Center, Md.
1	Arctic Health Research Center, P. O. Box 960, Anchorage, Alaska
1	Air Force Cambridge Research Center, Hanscom Field, Bedford, Mass.
1	Commander, Air Research & Development Command, Attn: Library, Andrews Air Force Base, Washington, D. C.
1	Arctic Aeromedical Laboratory, United States Air Force, APO 731, Seattle, Wash.
1	Commanding Officer, Biological Warfare Laboratories, Fort Detrick, Frederick, Md.
1	Chief, Physical Research Branch, Research Division, U. S. Department of Commerce, Bureau of Public Roads, Washington, D. C.

U. S. Naval Civil Engineering Laboratory.

Technical Report R-151.

LITHIUM HYDROXIDE CANISTERS FOR PERSONNEL SHELTERS, by R. J. Zablodil, J. M. Stephenson, and R. S. Chapler.

25 p. illus. 13 June 1961. UNCLASSIFIED

A canister-blower device with two lithium hydroxide canisters in parallel was developed to reduce the CO₂ in personnel shelters. Operational instructions are provided, with a chart showing when and how to use the equipment.

I. Ventilation -- Personnel shelters

- I. Zablodil, R. J.
- II. Stephenson, J. M.
- III. Chapler, R. S.
- IV. APWO 59-00-15

U. S. Naval Civil Engineering Laboratory.

Technical Report R-151.

LITHIUM HYDROXIDE CANISTERS FOR PERSONNEL SHELTERS, by R. J. Zablodil, J. M. Stephenson, and R. S. Chapler.

25 p. illus. 13 June 1961. UNCLASSIFIED

A canister-blower device with two lithium hydroxide canisters in parallel was developed to reduce the CO₂ in personnel shelters. Operational instructions are provided, with a chart showing when and how to use the equipment.

I. Ventilation -- Personnel shelters

- I. Zablodil, R. J.
- II. Stephenson, J. M.
- III. Chapler, R. S.
- IV. APWO 59-00-15

U. S. Naval Civil Engineering Laboratory.

Technical Report R-151.

LITHIUM HYDROXIDE CANISTERS FOR PERSONNEL SHELTERS, by R. J. Zablodil, J. M. Stephenson, and R. S. Chapler.

25 p. illus. 13 June 1961. UNCLASSIFIED

A canister-blower device with two lithium hydroxide canisters in parallel was developed to reduce the CO₂ in personnel shelters. Operational instructions are provided, with a chart showing when and how to use the equipment.

I. Ventilation -- Personnel shelters

- I. Zablodil, R. J.
- II. Stephenson, J. M.
- III. Chapler, R. S.
- IV. APWO 59-00-15

U. S. Naval Civil Engineering Laboratory.

Technical Report R-151.

LITHIUM HYDROXIDE CANISTERS FOR PERSONNEL SHELTERS, by R. J. Zablodil, J. M. Stephenson, and R. S. Chapler.

25 p. illus. 13 June 1961. UNCLASSIFIED

A canister-blower device with two lithium hydroxide canisters in parallel was developed to reduce the CO₂ in personnel shelters. Operational instructions are provided, with a chart showing when and how to use the equipment.

I. Ventilation -- Personnel shelters

- I. Zablodil, R. J.
- II. Stephenson, J. M.
- III. Chapler, R. S.
- IV. APWO 59-00-15