

UNCLASSIFIED

AD NUMBER

AD292675

LIMITATION CHANGES

TO:

Approved for public release; distribution is unlimited.

FROM:

Distribution authorized to U.S. Gov't. agencies and their contractors; Foreign Government Information; 17 AUG 1962. Other requests shall be referred to British Embassy, 3100 Massachusetts Avenue, NW, Washington, DC 20008.

AUTHORITY

DSTL, AVIA 37/793, 8 Dec 2008

THIS PAGE IS UNCLASSIFIED

✓ TM# 10/M/62



MINISTRY OF AVIATION

EXPLOSIVES RESEARCH & DEVELOPMENT ESTABLISHMENT

TECHNICAL MEMORANDUM No. 10/M/62

Calorimetry of Double - Base Propellants: An Account of the E.R.D.E. Propellant Calorimeter Installation and Determination of Energy Equivalent

20080801 105

ARMY STANDARDIZATION GROUP UNITED KINGDOM SN 100 FPO, New York, N.Y.

G. Colley L.E. Grindrod D.L. Hodge J.H. Littlefair

TECHNICAL LIBRARY BLDG. 318 ABERDEEN PROVING GROUND MD. STEAP-TL COUNTED IN

~~UNCATALOGED~~ RETURN RM. 21, BLDG. 313

THIS DOCUMENT IS THE PROPERTY OF H.B.M. GOVERNMENT AND ATTENTION IS CALLED TO THE PENALTIES ATTACHING TO ANY INFRINGEMENT OF THE OFFICIAL SECRETS ACTS It is intended for the use of the recipient only, and for communication to such officers under him as may require to be acquainted with its contents in the course of their duties. The officers exercising this power of communication are responsible that such information is imparted with due caution and reserve. Any person other than the authorised holder, upon obtaining possession of this document, by finding or otherwise, should forward it together with his name and address in a closed envelope to:- THE SECRETARY, MINISTRY OF AVIATION, ADELPHI, LONDON, W.C.2 Letter postage need not be prepaid, other postage will be refunded. All persons are hereby warned that the unauthorised retention or destruction of this document is an offence against the official Secrets Acts.

THE RECIPIENT IS WARNED THAT INFORMATION CONTAINED IN THIS DOCUMENT MAY BE SUBJECT TO PRIVATELY OWNED RIGHTS.

Waltham Abbey Essex

UNCLASSIFIED

ERDE TM/10/M/62

AD-292675

MINISTRY OF AVIATION

EXPLOSIVES RESEARCH AND DEVELOPMENT ESTABLISHMENT

TECHNICAL MEMORANDUM NO. 10/M/62

*I*  
Calorimetry of Double-Base Propellants:  
An Account of the E.R.D.E. Propellant Calorimeter  
Installation and Determination of Energy Equivalent

by

*II*  
G. Colley, L.E. Grindrod, D.L. Hodge and J.H. Littlefair

*1. Propellants, Double base.*

Approved: G.K. Adams  
G.K. ADAMS  
S.P.R.

Approved for  
Circulation: C.H. Johnson  
C.H. JOHNSON  
DIRECTOR

17th August, 1962

WALTHAM ABBEY  
ESSEX

TECHNICAL LIBRARY  
U S ARMY ORDNANCE  
ABERDEEN PROV'NG GROUND, MD.  
ORDEG-TL

CONTENTS

|  | <u>Page No.</u> |
|--|-----------------|
| 1. Summary   | 1               |
| 2. Introduction  | 1               |
| 3. Description of the E.R.D.E. Calorimeter Installation  | 1               |
| 4. Operation of Apparatus  | 2               |
| 5. Computing the Equivalent Temperature Rise   | 2               |
| 6. Calibration of Apparatus  | 3               |
| 7. Precision Error and Estimation of Uncertainty of Final Experimental Values  | 4               |
| 8. Series 1 - The Energy Equivalent of the Calorimeter by Burning Standard Benzoic Acid in Oxygen using Stainless Steel Bomb   | 5               |
| 9. Series 2 - Calorimetric Value of a Standard SC Propellant   | 7               |
| 10. Series 3 - Determination of the Energy Equivalent of the Calorimeter Unit with Standard SC Propellant (Lot RNP 1141S) in 150 ml. W.A. I High-Tensile Steel Bombs | 8               |
| 11. Bibliography   | 9               |
| Tables 1 - 6   | 10 - 14         |
| Figures 1 to 9   |                 |

Reference: WAC/139/09

1. SUMMARY

An account is given of a 150 ml. bomb calorimeter developed in E.R.D.E. and installed in Government propellant factories and Service Inspectorate laboratories for quality control and inspection in double-base propellant manufacture.

The preparation of a standard SC propellant and the measurement of its calorimetric value, using the combustion of benzoic acid in oxygen in a stainless steel bomb as standardising reaction, and the determination of the energy equivalent of the calorimeter with normal high-tensile steel bombs using this standard SC propellant are described.

Precision errors are of the order of 0.1 per cent.

2. INTRODUCTION

The rapid estimation by infrared gas analysis of the minor product methane in the combustion products enables the determination of calorimetric value to be used as a quality control test in the inspection of double-base rocket propellants.

By applying a correction for the methane and ammonium compounds formed, a 'corrected' calorimetric value can be computed which is independent of the particular installation involved in the measurement.

This memorandum describes the calorimetric apparatus developed in this Establishment and installed in the Government propellant factory and Service Inspectorate laboratories. An account is also given of work carried out two years ago in determining the energy equivalent of the E.R.D.E. calorimeters and in preparing a standard calorimetric propellant for distribution to other laboratories as a means of determining the energy equivalents of their own calorimeters.

3. DESCRIPTION OF THE E.R.D.E. CALORIMETER INSTALLATION

The routine calorimeter installation at Waltham Abbey consists of two twin-unit calorimeters. Photographs showing details of one of these twin-units are given in Figs. 1 - 9. Measurement of temperature is by platinum resistance thermometers of 40-ohm fundamental interval in conjunction with a Smith's No. 3 Difference Bridge (3). The whole installation is housed in rooms maintained at a constant temperature (20°C) and constant humidity (45 per cent r.h.).

The calorimeter bombs are of high-tensile steel and have a capacity of 150 ml. Fig. 2 gives the outside view, Fig. 3 shows the head and bomb interior and Fig. 4 the valve, insulated electrode and O-ring seal.

Fig. 5 shows the platinum resistance thermometer. The calorimeter can with stirrer and platinum resistance thermometer are shown in Fig. 6.

/The .....

The outer jacket or thermal shield with the bomb and resistance thermometer in position is shown in Fig. 7, whilst Fig. 8 gives a view of the interior of the water jacket, with heater, contact thermometer and thermostat.

Fig. 9 shows the firing panel, a Smith's No. 3 Difference Bridge and a Tinsley photocell galvanometer amplifier.

#### 4. OPERATION OF APPARATUS

A propellant charge of  $14.9 \pm 0.001$  g. is weighed into the bomb. A 2-inch length of 40 s.w.g. platinum wire is soldered to the electrode and underside of the bomb head and looped round 0.1 g. Mk. I cordite. The head is then screwed into the body with the valve open to release air. The valve is then closed.

The calorimeter can is placed in position. The bomb and resistance thermometer are placed in the can and the ignition leads connected. The firing circuit is tested for continuity and the resistance thermometer connected to the Smith's Bridge. Exactly 2,600 ml. water at  $13^{\circ}\text{C}$  are added from a calibrated measuring flask. The stirrers are started and the water in the calorimeter is raised to the initial temperature of firing by means of a small immersion heater. The initial temperature depends on the expected temperature rise for the propellant under test and is so chosen that the final temperature after firing is about  $22^{\circ}\text{C}$ , 1 degree below the outer jacket temperature.

The bridge is brought into balance and left for about 20 minutes until a steady rate of rise of temperature has been attained (about 0.010 deg.C per minute) then a stopclock is started and bridge readings recorded at one minute intervals. On the 10th minute the bomb is fired. No further bridge readings are taken until the 33rd minute when the bridge is re-balanced and readings are taken at minute intervals for a further 20 minutes. The rate of temperature rise during this period is of the order of 0.004 deg.C per minute.

On completion of the run, the calorimeter is dismantled and the bomb removed. The volume of gas in the bomb is measured by passing through a gas meter and the methane content determined with the infrared gas analyser (2). The bomb head is then removed, the liquid content is washed into a flask and the ammonium compounds estimated by titration with N/10 HCl solution.

#### 5. COMPUTING THE EQUIVALENT TEMPERATURE RISE

The equivalent or true temperature rise which is the observed temperature rise corrected for heat of stirring and heat leakage is calculated from the initial and final temperature readings as described by Beck ((1) p. 6 and Appendix IV) for mercury-in-glass thermometers. A similar procedure is used for platinum resistance thermometers, the initial and final temperatures being recorded as resistance bridge readings. The equivalent temperature rise in bridge ohms is converted to degrees C, using the calibration factor of the resistance thermometer.

/The .....

The extrapolation time was determined for each of the series of firings referred to in Section 6 from the temperature/time curves of typical firings. Table 4 (p. 13) gives a summary of these times: the mean values so obtained were used in computing the equivalent temperature rise for all firings of the series.

In determining the extrapolation time from a particular firing, it is necessary to read temperatures throughout the experiment.

## 6. CALIBRATION OF APPARATUS

The energy equivalent of the calorimeters can most easily be determined by the combustion of a known weight of benzoic acid in oxygen. Since the high-tensile steel of the working bomb would be attacked by oxygen under the firing conditions, a more extended procedure is necessary involving the use of a stainless steel bomb for the benzoic acid combustion and the preparation of a standard SC propellant for calibrating calorimeter systems using high-tensile steel bombs.

Three series of firings were therefore carried out:

Series 1: Determination of the energy equivalent of the calorimeter by burning standard benzoic acid in oxygen in a stainless steel bomb.

Series 2: Determination of the calorimetric value of a standard SC propellant in the stainless steel bomb.

Series 3: Determination of the energy equivalent of the calorimeter with high-tensile steel bombs using the SC propellant as standard.

The means and precision errors of each series of 12 - 15 firings were then calculated.

Series 1 and 2 were carried out in the same bomb and calorimeter unit. To avoid unnecessary labour, the weights of the different bomb components, calorimeters and resistance thermometers of both twin-units were adjusted to be equal within narrow limits and could therefore be interchanged without altering the energy equivalent of any one combination (see Table 5, p.14). In Series 3, bombs, calorimeters and resistance thermometers were interchanged so that the energy equivalent finally obtained was a mean of all combinations used.

In Series 1, the Smith's Bridge was operated manually, whilst in Series 2 and 3 it was maintained in balance and the resistance readings recorded by means of an automatic device developed in this Establishment.

A more detailed account of the three series of experiments is given below.

/7. ....

7. PRECISION ERROR AND ESTIMATION OF UNCERTAINTY OF FINAL EXPERIMENTAL VALUES

The precision of the final experimental measurements was assessed according to the method described by Rossini (4).

The error of the calorimetric value of the SC propellant is a combination of the errors of the standard benzoic acid and of the measurements in Series 1 and 2.

The calibration error in Series 1:

$$c_1 = \pm 100 \times \frac{2(\Sigma\Delta^2/m(m-1))^{\frac{1}{2}}}{\text{energy equivalent (mean)}} \text{ per cent}$$

and the error in Series 2:

$$b = \pm 100 \times \frac{2(\Sigma\Delta^2/n(n-1))^{\frac{1}{2}}}{\text{calorimetric value (mean)}} \text{ per cent}$$

where  $\Sigma\Delta^2$  = sum of the squares of the deviations of each measurement from the mean,

m = number of observation in Series 1,

n = " " " " Series 2.

The assigned precision error for the SC propellant is

$$d = \pm (e^2 + c_1^2 + b^2)^{\frac{1}{2}} \text{ per cent}$$

where e = "assigned error" of the standard benzoic acid.

A similar procedure is used in the determination of the energy equivalent of the calorimeters with the high-tensile steel bombs (Series 3) but in this case the SC propellant, of which the calorimetric value was obtained above, is used as the standard.

Calibration error in Series 3:

$$c_2 = \pm 100 \times \frac{2(\Sigma\Delta^2/p(p-1))^{\frac{1}{2}}}{\text{energy equivalent (mean)}} \text{ per cent}$$

where p is the number of observations in Series 3 and the corresponding precision error is

$$(d^2 + c_2^2)^{\frac{1}{2}} \text{ per cent.}$$

/The .....

The benzoic acid had been standardised at the National Physical Laboratory, Teddington and had a calorific value of 26,435 joules per gram with a standard error of 3 J/g.

From this it follows that the assigned error

$$e = 100 \times 2 \times \frac{3}{26435}$$
$$= 0.0227 \text{ per cent}$$

8. SERIES 1 - THE ENERGY EQUIVALENT OF THE CALORIMETER BY BURNING STANDARD BENZOIC ACID IN OXYGEN USING STAINLESS STEEL BOMB

This was determined by burning standard benzoic acid in oxygen in a 130 ml. Mk. XVI stainless steel bomb.

The standard benzoic acid was supplied by Messrs. British Drug Houses Ltd., (Batch No. 710,726) in the form of 0.19 g. pellets. The assigned calorific value was stated to be 26,425 joules per gram with a standard error of 3 J/g. corresponding to 6,318.1 thermochemical calories per gram with a standard error of 0.72 cal/g.

Oxygen, free of combustible impurities, was obtained by passing the normal commercial supply over copper oxide at 500°C, any combustion products being removed by Carbosorb. The purified oxygen was stored in 40 ft.<sup>3</sup> gas cylinders.

1.1 - 1.2 gram (6 pellets) of benzoic acid was weighed into a platinum crucible. 1 ml. distilled water was added to the bomb from a pipette. A short piece of 40 s.w.g. platinum wire was connected across the electrodes and 4 inches of cotton thread weighed and looped over this wire. The crucible with benzoic acid was then fixed in its support and the cotton placed in contact with the pellets. The head was then screwed into position with the valve open.

The air in the bomb was then "rinsed" out by pressurising three times with commercial oxygen at 15 atmospheres and releasing the pressure. It was then pressurised to 15 atmospheres with "purified" oxygen, the pressure released and finally re-pressurised to 40 atmospheres and the valve closed.

The bomb was then placed in position in the calorimeter and the appropriate volume of water added, the actual weight added being obtained by weighing the measuring flask before and after delivery. The temperature of the water was raised to 19°C. The firing was then carried out as described in Section 4. Bridge readings were taken at 1-minute intervals during the first 10 minutes. After firing, the main period resistances were recorded by progressively increasing the bridge setting by e.g. 1 bridge ohm and recording the times when the bridge came into balance. On the 23rd minute after firing, minute readings were again taken until the 53rd minute.

The bomb was removed from the calorimeter, the gases released, and the head removed. The liquid contents were washed into a titrating flask with

/distilled .....

distilled water and the nitric acid titrated with N/10 caustic soda solution. The gaseous products were checked in each case for complete combustion by testing with a carbon monoxide detecting tube. There was no evidence of carbon monoxide in any of the firings.

In some instances there was a small amount of residual carbon in the crucible. This was weighed and a correction applied in the final calculation.

The results of 15 firings are summarised in Table 1 (p. 10). Column 4 gives the heat of combustion of standard benzoic acid under the conditions existing for that particular firing obtained from the formula (5):

$$f = 1 + 10^{-6} [20(P - 30) + 42(m_s/V - 3) + 30(m_w/V - 3) - 45(\theta - 25)]$$

- where P = initial pressure of oxygen in atmospheres,  
 $\theta$  = temperature (C) to which the reaction is referred,  
 $m_s$  = mass of benzoic acid in bomb in grams,  
 $m_w$  = mass of water placed in the bomb in grams,  
V = internal volume of bomb in litres.

Column 5 gives the equivalent temperature rise using a figure of 3.2 minutes as extrapolation time. The extrapolation time was obtained from Firings 4, 5, 6 and 7. Column 6 is the product of the weight of benzoic acid burned (Column 3) and the heat of combustion (Column 4).

Columns 7 and 8 give the heats evolved by combustion of cotton thread and the formation of nitric acid. Column 9 gives the correction for any residual carbon.

Column 10 gives the total energy divided by the equivalent temperature rise. Column 11 is the energy equivalent of the platinum crucible plus benzoic acid plus the amount by which the water in the calorimeter was in excess of 2598 grams. Column 12 is the energy equivalent of the standard initial system = Column 10 - Column 11.

The calibration error,  $c_1$ , is obtained by substituting the values in Table 1 in the expression (Section 7)

$$\begin{aligned} c_1 &= \pm 100 \times \frac{2[\Sigma\Delta^2/m(m-1)]^{\frac{1}{2}}}{\text{energy equivalent (mean)}} \text{ per cent} \\ &= \pm 100 \times \frac{2 \times 0.93}{4023.3} \\ &= 0.0462 \text{ per cent.} \end{aligned}$$

/9. ....

9. SERIES 2 - CALORIMETRIC VALUE OF A STANDARD SC PROPELLANT

This was determined in the Mk. XVI stainless steel cordite bomb. 50 lb. SC propellant 0.125-inch diameter (Lot RNP 1141S) was cut into 0.125-inch lengths in a rotary cutter, blended and part stored in sealed 2-lb. glass preserving jars for use in E.R.D.E. and distribution as required to other laboratories. The remainder was stored in a rubber bag in a wooden box. 15 firings of this propellant were carried out using the same calorimeter and bomb as in Series 1. Since the bomb had a capacity of 130 ml., a propellant charge of 12.9 g. plus 0.1 g. Mk. I cordite as igniter gave a density of loading of 0.1 g/ml. The procedure described in Section 4 was used, except that the water added from the measuring flask was weighed by difference.

The results of firings are given in Table 2 (p. 11). Column 2 gives the energy equivalent corrected to working conditions after adjusting for propellant charge, water in the calorimeter, and differences in weight of those bomb components which it had been necessary to replace. Column 3 gives the equivalent temperature rise using an extrapolation time of 2.6 minutes. Column 4 gives the total energy liberated i.e. (Column 2) x (Column 3). Columns 5 - 7 are self explanatory. Columns 8 - 12 give corrections in calories for air in bomb, igniter, and minor products.

Column 13 = (Column 4) - (Column 12) and is the energy in calories produced by combustion of 12.9 g. standard SC.

Column 14 = Figure in Column 13 divided by the charge weight of 12.9 g.

The mean calorimetric value of the SC propellant obtained from this series of firings is 955.6 cal/g. (water liquid).

The error in Series 2 (Section 7) is

$$b = \pm 100 \times \frac{2(\Sigma\Delta^2/n(n-1))^{1/2}}{\text{calorimetric value (mean)}} \text{ per cent}$$

Substituting values given in Table 2:

$$b = \pm 100 \times \frac{2 \times 0.31}{955.6}$$

$$= 0.0648 \text{ per cent.}$$

$$\text{Since } e = 2 \times \frac{0.717}{6318.12} = \pm 0.0227 \text{ per cent,}$$

the overall precision error

$$\begin{aligned} &= (e^2 + c_1^2 + b^2)^{1/2} \\ &= [(0.0227)^2 + (0.0462)^2 + (0.0648)^2]^{1/2} \\ &= 0.0828 \text{ per cent.} \end{aligned}$$

(The uncertainty interval is  $\pm 0.8$  calorie).

/Thus .....

Thus the calorimetric value of the sample of standard SC propellant Lot RNP 1141S when burnt in an inert atmosphere at a loading density of 0.1 g/ml., so that the products of combustion contain no methane or ammonium compounds, is  $955.6 \pm 0.8$  thermochemical cal/g. (water liquid).

10. SERIES 3 - DETERMINATION OF THE ENERGY EQUIVALENT OF THE CALORIMETER UNIT WITH STANDARD SC PROPELLANT (LOT RNP 1141S) IN 150 ml. W.A. I HIGH-TENSILE STEEL BOMBS

A series of 11 firings was carried out using the procedure described in Section 4. The charge consisted of 14.9 grams standard SC propellant and an igniter of 0.1 gram Mk. I cordite. A 12th firing in which the air in the bomb was replaced by nitrogen, had a charge consisting of 15.0 grams SC cordite, 0.1 g. of which was used as igniter.

The water was added from the measuring flask but not weighed. The bomb, calorimeters and resistance thermometers were interchanged, each firing being carried out with a different combination. The combinations used in each firing are recorded in Table 6 (p. 14).

The results are summarised in Table 3 (p. 12). Column 12 is obtained from the corrected calorimetric value of the standard SC viz. 955.6 cal/g. Column 13 is obtained by adding total corrections to Column 12. Column 14 is obtained by dividing the figure in Column 13 by the equivalent temperature rise in Column 3. The energy equivalent of the initial system including the propellant charge is thus 3890.5 cal/deg.C.

The calibration error in the estimation of the energy equivalent of the calorimetric unit is

$$\begin{aligned} c_2 &= \pm 100 \times \frac{2(\Sigma\Delta^2/p(p-1))^{\frac{1}{2}}}{\text{energy equivalent (mean)}} \text{ per cent} \\ &= \pm 100 \times \frac{2 \times 1.36}{3890.2} \text{ per cent} \\ &= 0.0696 \text{ per cent.} \end{aligned}$$

Combining the calibration error of Series 3 with the precision error of the standard SC propellant (Section 9) gives the precision error of the energy equivalent of this calorimetric system:

$$\begin{aligned} \text{Precision error} &= [(0.0828)^2 + (0.0695)^2]^{\frac{1}{2}} \\ &= 0.1081 \text{ per cent} \end{aligned}$$

corresponding to an uncertainty interval of  $\pm 4.2$  cal/deg.C.

The energy equivalent of the system is therefore  $3890.2 \pm 4.2$  cal/deg.C.

/11. ....

11. BIBLIOGRAPHY

1. C.A. Beck, A.R.D.E. Memorandum (S) 18/56, "A Manual for the Operation of the Mark X Calorimetry System".
2. D.L. Hodge and L.E. Grindrod, E.R.D.E. Technical Memorandum No. 5/M/56.
3. F.E. Smith, Phil. Mag., 1912, 24, 541.
4. F.D. Rossini, Chem. Rev., 1936, 18, 233.
5. Idem, "Experimental Thermochemistry", Interscience Publishers Inc., New York, 1956, p. 38.

/TABLE 1 .....

Determination of Energy Equivalent of  
in Mk. XVI Sta

| Expt. No. | Oxygen Pressure, atm. | Benzoic Acid         |   | Equivalent Temperature Rise, T, deg.C | Total Energy Liberated in Experiment, (C x W) cal. | C<br>T |
|-----------|-----------------------|----------------------|---|---------------------------------------|--|--------|
|           |                       | Mass in Vacuo, W, g. | Heat of Combustion under Bomb Conditions, C, cal/g. |                                       |  |        |
| 1         | 42                    | 1.1684               | 6322.97   | 1.8408                                | 7387.76  |        |
| 2         | 42                    | 1.1564               | 6322.88   | 1.8237                                | 7311.78  |        |
| 3         | 43                    | 1.1868               | 6323.18   | 1.8664                                | 7504.35  |        |
| 4         | 43                    | 1.1602               | 6323.03   | 1.8261                                | 7335.98  |        |
| 5         | 43                    | 1.1622               | 6323.02   | 1.8310                                | 7348.61  |        |
| 6         | 42                    | 1.1637               | 6322.98   | 1.8313                                | 7358.05  |        |
| 7         | 41                    | 1.1708               | 6322.82   | 1.8420                                | 7402.76  |        |
| 8         | 38                    | 1.1650               | 6322.48   | 1.8326                                | 7365.69  |        |
| 9         | 42                    | 1.1574               | 6322.95   | 1.8204                                | 7318.18  |        |
| 10        | 43                    | 1.1559               | 6323.10   | 1.8188                                | 7308.87  |        |
| 11        | 41                    | 1.0911               | 6322.72   | 1.7173                                | 6898.72  |        |
| 12        | 41                    | 1.1021               | 6322.64   | 1.7381                                | 6968.18  |        |
| 13        | 35                    | 1.0868               | 6321.85   | 1.7120                                | 6870.59  |        |
| 14        | 43                    | 1.1148               | 6322.92   | 1.7552                                | 7048.79  |        |
| 15        | 43                    | 1.0899               | 6322.95   | 1.7156                                | 6891.38  |        |

Mean Energy Equivalent of Standard

Standard De

Ca.

①

## TABLE 1

Calorimeter Unit by Burning Benzoic Acid  
In stainless Steel Bomb

| Energy Produced by:     |  |                               | Energy Equivalent<br>of System<br>in Experiment,<br>$E_I$ ,<br>cal/deg.C | Correction<br>Term for<br>Standard<br>Conditions,<br>$E_C$ ,<br>cal. | Energy Equivalent<br>of Standard<br>Initial System,<br>$E_{SI}$ ,<br>cal/deg.C |
|-------------------------|--|-------------------------------|--|--|--|
| Weight<br>Read,<br>cal. | HNO <sub>3</sub><br>Formation,<br>cal. | Carbon<br>Deposition,<br>cal. |  |  |  |
| 6.30                    | 1.52                                   | -                             | 4023.02  | 2.75   | 4020.27  |
| 6.69                    | 1.17                                   | -                             | 4019.11  | 3.14   | 4015.97  |
| 9.41                    | 1.52                                   | -                             | 4031.97  | 2.80   | 4029.17  |
| 8.63                    | 1.11                                   | -                             | 4028.10  | 3.67   | 4024.43  |
| 8.24                    | 1.24                                   | -                             | 4024.09  | 3.79   | 4020.30  |
| 7.86                    | 0.97                                   | -                             | 4028.22  | 2.98   | 4025.24  |
| 7.08                    | 0.83                                   | 0.79                          | 4028.16  | 2.84   | 4025.32  |
| 6.03                    | 1.24                                   | 1.58                          | 4027.97  | 2.07   | 4025.90  |
| 7.47                    | 0.55                                   | 0.79                          | 4029.56  | 2.97   | 4026.59  |
| 7.47                    | 0.00                                   | 1.58                          | 4027.25  | 2.91   | 4024.34  |
| 6.30                    | 1.38                                   | -                             | 4027.49  | 2.34   | 4025.15  |
| 6.69                    | 1.11                                   | -                             | 4019.32  | 2.62   | 4016.70  |
| 8.63                    | 0.83                                   | -                             | 4024.56  | 2.64   | 4021.92  |
| 6.30                    | 0.97                                   | -                             | 4025.79  | 2.48   | 4023.31  |
| 7.86                    | 1.11                                   | 0.79                          | 4027.49  | 3.09   | 4024.40  |

Initial System = 4023.3 cal/deg.C

Standard Deviation of Mean = 0.93 "

Calibration Error = 0.0462 per cent

/TABLE 2 .....

(2)

Determination of the Calorimetric Value

Mk. XVI Stai

Charge Wei

| Expt. No. | Energy Equivalent of System Corrected for Firing Conditions, (E), cal/deg.C | Equivalent Temperature Rise, (T), deg.C | Total Energy Liberated in Experiment, (E x T), cal. | % Methane Formation by I.R.G.A. | Total Gas Volume, ml. | Total "Ammonia" Titration, ml. N/10 Acid |
|-----------|---|---|---|---------------------------------|-----------------------|--|
| 1         | 4029.05   | 3.1515                                  | 12697.55  | 0.24                            | 10,470                | 2.7                                      |
| 2         | 4029.25   | 3.1505                                  | 12694.15  | 0.26                            | 10,500                | 3.1                                      |
| 3         | 4029.75   | 3.1484                                  | 12687.26  | 0.26                            | 10,440                | 3.5                                      |
| 4         | 4028.95   | 3.1494                                  | 12688.77  | 0.30                            | 10,400                | 3.4                                      |
| 5         | 4028.95   | 3.1493                                  | 12688.37  | 0.27                            | 10,500                | 3.5                                      |
| 6         | 4029.25   | 3.1505                                  | 12694.15  | 0.32                            | 10,500                | 3.2                                      |
| 7         | 4028.95   | 3.1485                                  | 12685.15  | 0.34                            | 10,490                | 3.0                                      |
| 8         | 4028.95   | 3.1501                                  | 12691.59  | 0.31                            | 10,510                | 2.9                                      |
| 9         | 4030.26   | 3.1491                                  | 12691.69  | 0.29                            | 10,610                | 2.5                                      |
| 10        | 4030.26   | 3.1459                                  | 12678.79  | 0.30                            | 10,640                | 2.5                                      |
| 11        | 4030.57   | 3.1469                                  | 12683.80  | 0.35                            | 10,620                | 4.0                                      |
| 12        | 4030.84   | 3.1460                                  | 12681.02  | 0.34                            | 10,620                | 2.8                                      |
| 13        | 4029.64   | 3.1399                                  | 12652.66  | 0.30                            | 10,670                | 2.0                                      |
| 14        | 4030.24   | 3.1475                                  | 12685.18  | 0.29                            | 10,580                | 3.3                                      |
| 15        | 4030.64   | 3.1475                                  | 12686.44  | 0.34                            | 10,530                | 2.7                                      |

Mean Calorimetric Value (Water Liquid) o

①

TABLE 2

(W/L) of Standard SC Propellant Lot RNP 1141S

Inertless Steel Bomb

Weight = 12.9 g.

| Energy Produced by:          |                                      |                                |   |                             | Energy Liberated per 12.9 g. SC Propellant, cal. | Energy Liberated per g. SC Propellant cal. |
|------------------------------|--------------------------------------|--------------------------------|---|-----------------------------|--|--|
| Methane Formation, (A), cal. | Total "Ammonia" Formation, (B), cal. | Initial Air in Bomb, (C), cal. | Igniter (0.1 g. Mk. I Cordite), (D), cal. | Total (A + B + C + D), cal. |  |  |
| 65.01                        | 8.68                                 | 143.0                          | 123.6                                     | 340.29                      | 12357.26   | 957.93                                     |
| 70.64                        | 9.96                                 | 143.0                          | 123.6                                     | 347.20                      | 12346.95   | 957.13                                     |
| 70.22                        | 11.25                                | 143.0                          | 123.6                                     | 348.07                      | 12339.19   | 956.53                                     |
| 80.71                        | 10.92                                | 143.0                          | 123.6                                     | 358.23                      | 12330.54   | 955.86                                     |
| 73.36                        | 11.25                                | 143.0                          | 123.6                                     | 351.21                      | 12337.16   | 956.37                                     |
| 86.94                        | 10.28                                | 143.0                          | 123.6                                     | 363.82                      | 12330.33   | 955.84                                     |
| 92.37                        | 9.64                                 | 143.0                          | 123.6                                     | 368.61                      | 12316.54   | 954.77                                     |
| 84.22                        | 9.32                                 | 143.0                          | 123.6                                     | 360.14                      | 12331.45   | 955.93                                     |
| 79.61                        | 8.03                                 | 143.0                          | 123.6                                     | 354.24                      | 12337.45   | 956.39                                     |
| 82.61                        | 8.03                                 | 143.0                          | 123.6                                     | 357.24                      | 12321.55   | 955.16                                     |
| 96.20                        | 12.85                                | 143.0                          | 123.6                                     | 375.65                      | 12308.15   | 954.12                                     |
| 93.42                        | 9.00                                 | 143.0                          | 123.6                                     | 369.02                      | 12312.00   | 954.42                                     |
| 82.87                        | 6.43                                 | 143.0                          | 123.6                                     | 355.90                      | 12296.76   | 953.24                                     |
| 79.42                        | 10.60                                | 143.0                          | 123.6                                     | 356.62                      | 12328.56   | 955.70                                     |
| 92.66                        | 8.68                                 | 143.0                          | 123.6                                     | 367.94                      | 12318.50   | 954.92                                     |

of SC Propellant Lot RNP 1141S = 955.6 cal/g.

Standard Deviation of Mean = 0.31 cal/g.

Calibration Error in Series 2 = 0.0648 per cent

/TABLE 3 .....

②

Determination of the Energy Equivalents  
of Standard SC Propellant (Lot RN)

| Expt. No. | Mass of SC and of Mk.I Igniter, g. | Equivalent Temperature Rise, deg.C | Total Gas Volume at S.T.P., ml. | % Methane Formation by I.R.G.A. | Total "Ammonia" Titration, ml. N/10 Acid | Methane Formation, (A), cal. |
|-----------|------------------------------------|------------------------------------|---------------------------------|---------------------------------|--|------------------------------|
| 1         | 14.900<br>0.100                    | 3.7594                             | 12,040                          | 0.28                            | 3.8                                      | 87.23                        |
| 2         | 14.900<br>0.100                    | 3.7633                             | 12,060                          | 0.30                            | 3.2                                      | 93.62                        |
| 3         | 14.900<br>0.100                    | 3.7564                             | 11,600                          | 0.26                            | 4.0                                      | 78.07                        |
| 4         | 14.900<br>0.100                    | 3.7564                             | 12,090                          | 0.26                            | 4.0                                      | 81.36                        |
| 5         | 14.900<br>0.100                    | 3.7622                             | 12,120                          | 0.30                            | 3.0                                      | 94.13                        |
| 6         | 14.900<br>0.100                    | 3.7712                             | 12,190                          | 0.29                            | 3.6                                      | 91.47                        |
| 7         | 14.900<br>0.100                    | 3.7549                             | 12,100                          | 0.31                            | 3.1                                      | 97.09                        |
| 8         | 14.900<br>0.100                    | 3.7564                             | 11,900                          | 0.32                            | 3.0                                      | 98.56                        |
| 9         | 14.900<br>0.100                    | 3.7622                             | 12,260                          | 0.29                            | 2.3                                      | 92.02                        |
| 10        | 14.900<br>0.100                    | 3.7609                             | 12,260                          | 0.32                            | 2.7                                      | 101.54                       |
| 11        | 14.900<br>0.100                    | 3.7599                             | 12,140                          | 0.29                            | 3.2                                      | 91.10                        |
| 12        | 15.000                             | 3.7170                             | 12,270                          | 0.31                            | 4.2                                      | 98.40                        |

Mean Energy Equivalent  
Standard Deviation of  
Calibration Error  
Uncertainty Interval

①

TABLE 3

Equivalent of Calorimeter Unit by Combustion  
 (P 1141S) in 150 ml. W.A. I Gun Steel Bombs

| Energy Produced by:                |                                |  |                             | Energy Liberated per 14.9 g. SC Uncorrected for CH <sub>4</sub> & NH <sub>3</sub> , cal. | Total Energy Liberated in Firing, cal. | Energy Equivalent of Standard Initial System ESI, cal/deg.C |
|------------------------------------|--------------------------------|--|-----------------------------|--|--|---|
| Total Ammonia Formation, (B), cal. | Initial Air in Bomb, (C), cal. | Igniter O.1 g. Mk.I Cordite, (D), cal. | Total (A + B + C + D), cal. |  |  |   |
| 12.21                              | 165                            | 123.6                                  | 388.04                      | 14,238.44  | 14,626.48                              | 3891.06   |
| 10.28                              | 165                            | 123.6                                  | 392.50                      | 14,238.44  | 14,630.94                              | 3888.11   |
| 12.85                              | 165                            | 123.6                                  | 379.52                      | 14,238.44  | 14,617.96                              | 3891.90   |
| 12.85                              | 165                            | 123.6                                  | 382.81                      | 14,238.44  | 14,621.25                              | 3892.77   |
| 9.64                               | 165                            | 123.6                                  | 392.37                      | 14,238.44  | 14,630.81                              | 3888.90   |
| 11.56                              | 165                            | 123.6                                  | 391.63                      | 14,238.44  | 14,630.07                              | 3879.42   |
| 9.95                               | 165                            | 123.6                                  | 395.64                      | 14,238.44  | 14,634.08                              | 3897.33   |
| 9.64                               | 165                            | 123.6                                  | 396.80                      | 14,238.44  | 14,635.24                              | 3896.08   |
| 7.39                               | 165                            | 123.6                                  | 388.01                      | 14,238.44  | 14,626.45                              | 3887.74   |
| 8.67                               | 165                            | 123.6                                  | 398.81                      | 14,238.44  | 14,637.25                              | 3891.95   |
| 10.28                              | 165                            | 123.6                                  | 389.98                      | 14,238.44  | 14,628.42                              | 3890.64   |
| 13.49                              | Nil                            | Nil                                    | 111.89                      | 14,334.0   | 14,445.89                              | 3886.44   |

t of System = 3890.2 cal/deg.C  
 Mean = 1.36 "  
 = 0.108 per cent  
 = ± 4.2 cal/deg.C

/TABLE 4 .....

②

TABLE 4

Extrapolation Times of Different Experimental Series

| Series No. | Bomb                    | System                        | Experiment No. | Extrapolation Time, min. | Mean Extrapolation Time, min. |
|------------|-------------------------|-------------------------------|----------------|--------------------------|-------------------------------|
| 1          | Mk. XVI stainless steel | Benzoic acid in oxygen        | 2              | 4.0                      | ) 3.2                         |
|            |                         |                               | 4              | 3.2                      |                               |
|            |                         |                               | 5              | 3.2                      |                               |
|            |                         |                               | 6              | 3.2                      |                               |
|            |                         |                               | 7              | 3.2                      |                               |
| 2          | Mk. XVI stainless steel | Standard SC cordite RNP 1141S | 1              | 2.6                      | ) 2.6                         |
|            |                         |                               | 4              | 2.6                      |                               |
| 3          | W.A. I gun steel        | Standard SC cordite RNP 1141S | 3              | 1.55                     | ) 1.5                         |
|            |                         |                               | 4              | 1.45                     |                               |

/TABLE 5 .....

TABLE 5

Weights of the Interchangeable Items  
in the Calorimeter Units

| Item                            | Weight,<br>g. | Tolerance,<br>g. |
|---------------------------------|---------------|------------------|
| Bomb head (without accessories) | 1459.0        | ± 0.05           |
| Accessories:                    |               |                  |
| valve                           | 71.7          | ± 0.1            |
| electrodes                      | 10.5          | ± 0.05           |
| non-metallic parts              | 6.6           | ± 0.05           |
| Bomb body                       | 6442.75       | ± 0.15           |
| Platinum resistance thermometer | 388.6         | ± 0.05           |
| Calorimeter can                 | 4467.2        | ± 0.05           |


TABLE 6

Disposition of Apparatus in Series 3 Firings

| Experiment No. | Bomb |      |       | Calorimeter | Thermometer |
|----------------|------|------|-------|-------------|-------------|
|                | Body | Head | Valve |             |             |
| 1              | 4    | 2    | 1     | 1           | 1           |
| 2              | 1    | 4    | 2     | 1           | 1           |
| 3              | 3    | 4    | 5     | 1           | 1           |
| 4              | 4    | 4    | 1     | 2           | 1           |
| 5              | 1    | 5    | 2     | 3           | 3           |
| 6              | 1    | 5    | 2     | 1           | 1           |
| 7              | 4    | 1    | 4     | 2           | 2           |
| 8              | 3    | 3    | 3     | 1           | 1           |
| 9              | 3    | 3    | 3     | 3           | 3           |
| 10             | 1    | 1    | 1     | 4           | 4           |
| 11             | 1    | 1    | 1     | 3           | 3           |
| 12             | 3    | 3    | 3     | 4           | 4           |


Heaviest Combination used in Experiment No. 1  
Lightest Combination used in Experiment No. 2

S. No. 808/62/BL




TWIN CALORIMETER UNIT

FIG. 1




150mL CAPACITY HIGH-TENSILE STEEL CALORIMETER  
BOMB

FIG. 2




CALORIMETER BOMB - VIEW OF HEAD AND BOMB INTERIOR

FIG. 3




"O" RING, VALVE AND ELECTRODE ASSEMBLIES FOR CALORIMETER BOMB

FIG. 4




PLATINUM RESISTANCE THERMOMETER

FIG. 5




CALORIMETER CAN WITH PLATINUM RESISTANCE  
THERMOMETER AND CALORIMETER BOMB

FIG. 6




VIEW OF THERMAL SHIELD, SHOWING CALORIMETER BOMB  
AND PLATINUM RESISTANCE THERMOMETER IN PLACE

FIG. 7



INTERIOR VIEW OF THERMAL SHIELD, SHOWING DETAILS  
OF CONSTRUCTION

FIG. 8



SMITH'S N°3 DIFFERENCE BRIDGE, WITH TINSLEY PHOTOCELL GALVANOMETER  
AMPLIFIER AND FIRING PANEL

FIG. 9

UNCLASSIFIED

E.R.D.E. Technical  
Memorandum No. 10/M/62

Calorimetry of Double-Base Propellants:  
An Account of the E.R.D.E. Propellant Calorimeter  
Installation and Determination of Energy Equivalent

G.E. Colley, L.E. Grindrod, D.L. Hodge  
and J.H. Littlefair

November, 1962

An account is given of a 150 ml. bomb calorimeter developed in E.R.D.E. and installed in Government propellant factories and Service Inspectorate laboratories for quality control and inspection in double-base propellant manufacture.

The preparation of a standard SC propellant and the measurement of its calorimetric value, using the combustion of benzoic acid in oxygen in a stainless steel bomb as standardising reaction, and the determination of the energy equivalent of the calorimeter with normal high-tensile steel bombs using this standard SC propellant are described.

Precision errors are of the order of 0.1 per cent.

14 pp., 9 fig., 6 tables.

UNCLASSIFIED

UNCLASSIFIED

E.R.D.E. Technical  
Memorandum No. 10/M/62

Calorimetry of Double-Base Propellants:  
An Account of the E.R.D.E. Propellant Calorimeter  
Installation and Determination of Energy Equivalent

G.E. Colley, L.E. Grindrod, D.L. Hodge  
and J.H. Littlefair

November, 1962

An account is given of a 150 ml. bomb calorimeter developed in E.R.D.E. and installed in Government propellant factories and Service Inspectorate laboratories for quality control and inspection in double-base propellant manufacture.

The preparation of a standard SC propellant and the measurement of its calorimetric value, using the combustion of benzoic acid in oxygen in a stainless steel bomb as standardising reaction, and the determination of the energy equivalent of the calorimeter with normal high-tensile steel bombs using this standard SC propellant are described.

Precision errors are of the order of 0.1 per cent.

14 pp., 9 fig., 6 tables.

UNCLASSIFIED

UNCLASSIFIED

E.R.D.E. Technical  
Memorandum No. 10/M/62

Calorimetry of Double-Base Propellants:  
An Account of the E.R.D.E. Propellant Calorimeter  
Installation and Determination of Energy Equivalent

G.E. Colley, L.E. Grindrod, D.L. Hodge  
and J.H. Littlefair  
November, 1962

An account is given of a 150 ml. bomb calorimeter developed in E.R.D.E. and installed in Government propellant factories and Service Inspectorate laboratories for quality control and inspection in double-base propellant manufacture.

The preparation of a standard SC propellant and the measurement of its calorimetric value, using the combustion of benzoic acid in oxygen in a stainless steel bomb as standardising reaction, and the determination of the energy equivalent of the calorimeter with normal high-tensile steel bombs using this standard SC propellant are described.

Precision errors are of the order of 0.1 per cent.

14 pp., 9 fig., 6 tables.

UNCLASSIFIED

UNCLASSIFIED

E.R.D.E. Technical  
Memorandum No. 10/M/62

Calorimetry of Double-Base Propellants:  
An Account of the E.R.D.E. Propellant Calorimeter  
Installation and Determination of Energy Equivalent

G.E. Colley, L.E. Grindrod, D.L. Hodge  
and J.H. Littlefair  
November 1962

An account is given of a 150 ml. bomb calorimeter developed in E.R.D.E. and installed in Government propellant factories and Service Inspectorate laboratories for quality control and inspection in double-base propellant manufacture.

The preparation of a standard SC propellant and the measurement of its calorimetric value, using the combustion of benzoic acid in oxygen in a stainless steel bomb as standardising reaction, and the determination of the energy equivalent of the calorimeter with normal high-tensile steel bombs using this standard SC propellant are described.

Precision errors are of the order of 0.1 per cent.

14 pp., 9 fig., 6 tables.

UNCLASSIFIED

UNCLASSIFIED

E.R.D.E. Technical  
Memorandum No. 10/M/62

Calorimetry of Double-Base Propellants:  
An Account of the E.R.D.E. Propellant Calorimeter  
Installation and Determination of Energy Equivalent

G.E. Colley, L.E. Grindrod, D.L. Hodge  
and J.H. Littlefair  
November, 1962

An account is given of a 150 ml. bomb calorimeter developed in E.R.D.E. and installed in Government propellant factories and Service Inspectorate laboratories for quality control and inspection in double-base propellant manufacture.

The preparation of a standard SC propellant and the measurement of its calorimetric value, using the combustion of benzoic acid in oxygen in a stainless steel bomb as standardising reaction, and the determination of the energy equivalent of the calorimeter with normal high-tensile steel bombs using this standard SC propellant are described.

Precision errors are of the order of 0.1 per cent.

14 pp., 9 fig., 6 tables.

UNCLASSIFIED

UNCLASSIFIED

E.R.D.E. Technical  
Memorandum No. 10/M/62

Calorimetry of Double-Base Propellants:  
An Account of the E.R.D.E. Propellant Calorimeter  
Installation and Determination of Energy Equivalent

G.E. Colley, L.E. Grindrod, D.L. Hodge  
and J.H. Littlefair  
November 1962

An account is given of a 150 ml. bomb calorimeter developed in E.R.D.E. and installed in Government propellant factories and Service Inspectorate laboratories for quality control and inspection in double-base propellant manufacture.

The preparation of a standard SC propellant and the measurement of its calorimetric value, using the combustion of benzoic acid in oxygen in a stainless steel bomb as standardising reaction, and the determination of the energy equivalent of the calorimeter with normal high-tensile steel bombs using this standard SC propellant are described.

Precision errors are of the order of 0.1 per cent.

14 pp., 9 fig., 6 tables.

UNCLASSIFIED



*Defense Technical Information Center  
Knowledge Services  
(dstl) Partition Down  
Library  
DTIC  
2006-02-18  
DTIC 07930-6218  
1-800-445-1370*

Defense Technical Information Center (DTIC)  
8725 John J. Kingman Road, Suit 0944  
Fort Belvoir, VA 22060-6218  
U.S.A.

AD#: AD 292675

Date of Search: 8 December 2008

Record Summary: AVIA 37/793

Title: ERDE propellant calorimeter

Availability Open Document, Open Description, Normal Closure before FOI Act: 30 years

Former reference (Department) ERDE 10/M/62

Held by The National Archives, Kew

This document is now available at the National Archives, Kew, Surrey, United Kingdom.

DTIC has checked the National Archives Catalogue website (<http://www.nationalarchives.gov.uk>) and found the document is available and releasable to the public.

Access to UK public records is governed by statute, namely the Public Records Act, 1958, and the Public Records Act, 1967.

The document has been released under the 30 year rule.

(The vast majority of records selected for permanent preservation are made available to the public when they are 30 years old. This is commonly referred to as the 30 year rule and was established by the Public Records Act of 1967).

**This document may be treated as UNLIMITED.**