

AD703886

FTD-HT-23-73-70

FOREIGN TECHNOLOGY DIVISION



SOLUBILITY OF WATER IN FREONS

by

A. K. Chernyshev



APR 17 1970
JUL 15 1970

Distribution of this document is unlimited. It may be reissued to the Clearinghouse, Department of Commerce, for sale to the general public.

Reproduced by the
CLEARINGHOUSE
for Federal Scientific & Technical
Information Springfield Va 22151

**Best
Available
Copy**

ACCESSION for

OPDT WHITE SECTION

DDG DUPE SECTION

UNANNOUNCED

JUSTIFICATION

BY

DISTRIBUTION/AVAILABILITY CODE

DIST.	AVAIL. and/or SPECIAL	
/		

EDITED TRANSLATION

SOLUBILITY OF WATER IN FREONS

By: A. K. Chernyshev

English pages: 3

Source: Kholodil'naya Tekhnika
(Refrigeration Engineering)
Vol. 46, No. 1, 1969, p. 62.

Translated by: D. Koolbeck/TDBRS-3

THIS TRANSLATION IS A REPRODUCTION OF THE ORIGINAL FOREIGN TEXT WITHOUT ANY ANALYTICAL OR EDITORIAL COMMENT. STATEMENTS OR THEORIES ADVOCATED OR IMPLIED ARE THOSE OF THE SOURCE AND DO NOT NECESSARILY REFLECT THE POSITION OR OPINION OF THE FOREIGN TECHNOLOGY DIVISION.

PREPARED BY:

TRANSLATION DIVISION
FOREIGN TECHNOLOGY DIVISION
WP-APB, OSRD.

SOLUBILITY OF WATER IN FREONS

A. K. Chernyshev

Kemerov Branch of GIAP


Experimental data on the solubility of water in many Freons are given in the form of diagrams in contemporary reference literature [1-3].

On the basis of generalized experimental data we have constructed a simple nomogram (see figure) which permits rapid and accurate determination of the solubility of water in liquid Freons.

The points are arranged along a curve of a definite shape, which permits us to include that approximate determination of the solubility of water in liquid and vaporous Freons by means of data for the single temperature is possible.

For this purpose a straight line is drawn through points corresponding to known values of temperature and solubility on the left and right axes.

The point at which the straight line intersects the curve gives a nodal point for the given Freon. By drawing straight lines from other values of temperature through this point it is possible to find the solubility under these conditions.



We shall illustrate the use of the nomogram on the example of liquid Freon-11. According to Table 1, in which the points on the nomogram are listed, we find that for the given Freon point 12 is critical. We will draw a straight line through point 12 and through a given temperature (the nomogram shows construction for temperatures of -30° and $+10^{\circ}\text{C}$) up to intersection with the solubility scale. The point of intersection shows the values sought.

Table 1

Cooling point	Solubility of water in liquid Freon-11	
	liquid	vapor
Freon-11	12	1
-12	10	2
-13	15	11
-21	6	6
-22	5	5
-30	4	4
-40	2	2
-113	11	11
-114	14	14
Sulfur dioxide	2	2

The accuracy in determining the solubility of water in liquid Freons can be judged from the results which are presented in Table 2.

Table 2

Freon	Temp., °C	Solubility of water, g/g		
		in Freon-11	in Freon-21	in Freon-22
R11	-50	—	58.0	—
	-30	5.65	102.0	25.0
	-10	17.60	420.0	15.0
	10	50.00	940.0	30.0
R12	-50	—	50.0	—
	-30	5.60	108.0	20.0
	-10	18.00	400.0	21.0
	10	48.50	920.0	31.0

References

1. Entsiklopedicheskiy spravochnik. Kholodil'naya tekhnika. T. I. (Encyclopedic handbook. Refrigeration engineering. Vol. 1). Gostorgizdat, 1960.
2. Spravochnik po rastvorimosti (handbook on solubility). Izd. AN SSSR, 1961-1962.
3. Badyl'kes, I. S. Rabochiye vesnchestva i protsessy kholodil'nykh mashin (Working bodies and processes in refrigerating machines). Gostorgizdat, 1962.

DATA HANDLER'S PAGE

11-ACCESSION NO. TP0000406		12-DOCUMENT LOC		13-TOPIC TAGS water analysis, freon, temperature dependence, solubility	
14-TITLE SOLUBILITY OF WATER IN FREONS -U-					
15-SUBJECT AREA 07, 13					
16-AUTHOR 17-AUTHORS CHERNYSHEV, A. K.				18-DATE OF INFO --JAN69	
19-SOURCE KHOLODIL'NAYA TEKHNIKA (RUSSIAN)				20-DOCUMENT NO. HI-23-73-70	
				21-PROJECT NO. 72301-78	
22-SECURITY AND DOWNGRADING INFORMATION UNCL. 0			23-CONTROL MARKING NONE		24-HEADER CLASS UNCL
25-REEL/FRAME NO.	26-SUPERSEDES	27-CHANGES	28-GEOGRAPHICAL AREA UR		NO. OF PAGES 3
CONTRACT NO.	29-REF ACC. NO. AP9022127	PUBLISHING DATE 64-	TYPE PRODUCT TRANSLATION		REVISION FREQ NONE
STEP NO. 02-UR/0066/59/045/001/0062/0062					
ABSTRACT (UNCL, 0) ABSTRACT OF REPORT. A nomogram was constructed for a rapid and accurate detn. of the solubility of H ₂ O in Freons as a function of temp.					