

UNCLASSIFIED

AD NUMBER
AD866173
NEW LIMITATION CHANGE
TO Approved for public release, distribution unlimited
FROM Distribution authorized to U.S. Gov't. agencies and their contractors; Administrative/Operational Use; JAN 1970. Other requests shall be referred to Department of the Army, Fort Detrick, Attn: Technical Release Branch/TID, Frederick, MD 21701.
AUTHORITY
BDRL, D/A ltr, 29 Sep 1971

THIS PAGE IS UNCLASSIFIED

AD

AD 866173

TECHNICAL MANUSCRIPT 572

A PORTABLE CHAMBER FOR THE GROWTH AND ISOLATION OF INFECTED PLANTS

Robert G. Emge
J. Stanley Melching
Charles H. Kingsolver

JANUARY 1970

STATEMENT #2 UNCLASSIFIED

This document is subject to special export controls and each transmittal to foreign governments or foreign nationals may be made only with prior approval of Dept. of Army, Fort Detrick, ATTN: Technical Release Branch/TID, Frederick, Maryland 21701

DEPARTMENT OF THE ARMY
Fort Detrick
Frederick, Maryland

Reproduced by the
CLEARINGHOUSE
for Federal Scientific & Technical
Information Springfield Va. 22151

DDC
RECEIVED
MAR 17 1970
B

49562

Reproduction of this publication in whole or in part is prohibited except with permission of the Commanding Officer, Fort Detrick, ATTN: Technical Releases Branch, Technical Information Division, Fort Detrick, Frederick, Maryland, 21701. However, DDC is authorized to reproduce the publication for United States Government purposes.

DDC AVAILABILITY NOTICES

Qualified requesters may obtain copies of this publication from DDC.

Foreign announcement and dissemination of this publication by DDC is not authorized.

Release or announcement to the public is not authorized.

DISPOSITION INSTRUCTIONS

Destroy this publication when it is no longer needed. Do not return it to the originator.

The findings in this publication are not to be construed as an official Department of the Army position, unless so designated by other authorized documents.

CLASS	SECTION	<input type="checkbox"/>
DATE	OFF SECTION	<input checked="" type="checkbox"/>
UNCLASSIFIED		<input type="checkbox"/>
CLASSIFICATION		
BY		
APPROVING AUTHORITY CODE		
DOC.	AVAIL.	NO. OF COPIES
2		

DEPARTMENT OF THE ARMY
Fort Detrick
Frederick, Maryland, 21701

TECHNICAL MANUSCRIPT 572

A PORTABLE CHAMBER FOR THE GROWTH AND ISOLATION
OF INFECTED PLANTS

Robert G. Emge

J. Stanley Melching

Charles H. Kingsolver

Plant Pathology Division
PLANT SCIENCES LABORATORIES

Project 1B562602AD09

January 1969

ACKNOWLEDGMENT

The authors express their appreciation to Robert D. Boyer for his technical assistance in the fabrication of the subject chamber.

A PORTABLE CHAMBER FOR THE GROWTH AND ISOLATION OF INFECTED PLANTS

ABSTRACT

An easily portable unit, consisting of an aluminum tubular frame covered with transparent polyvinyl sheeting, has been developed to contain infected plants and exclude airborne fungal contaminants. A 100-cfm squirrel-cage blower supplies air through a filter to the interior of the chamber, maintaining an internal positive pressure that prevents the entrance of contaminants when the unit is opened. Air is exhausted through a filter at a rate that provides sufficient flow through the chamber to hold the interior air temperature at approximately that of the outside ambient air. This air flow causes no visible agitation of the plants.

In laboratory and greenhouse studies of physiologic races and single-spore isolates of various fungi on their hosts, the problem of cross contamination is always present. Lamp chimneys, bench dividers, and plastic bags, although commonly employed to provide some degree of isolation, often fail to accomplish the objective.

A chamber has been developed that is portable, inexpensive, and efficient in containing and in excluding particles 5 microns in diameter and larger. The assembled unit is 15½ inches wide, 24 inches long, and 24 inches high and accommodates 15 four-inch pots (Fig. 1). The frame is made of ½-inch aluminum tubing connected at the corners by friction joints (Fig. 2). The three-sided friction joints are made by soldering one half of a copper coupling joint to a copper 90-degree elbow joint. Transparent polyvinyl sheeting, 20 mil in thickness, is welded to form a one-piece enclosure with an opening in one side fitted with a plastic slide closure.

The frame sections, precut to proper lengths, are easily assembled within the plastic enclosure, using the friction joints. Holes are cut in the rear wall to accommodate the supply and exhaust filters. The filters are sized and placed to provide an adequate and uniform flow of air through the chamber with little or no visible agitation of the plants. Type 25 FG fiberglass filter medium is used for both the supply and exhaust filters. This material is classified as medium-efficiency with a 1- to 5- μ particle size retention of 60 to 90%.* The interior core of the filter is a tube

* Decker, Herbert M.; Buchanan, Lee M.; Hall, Lawrence B.; Goddard, Kenneth R. 1962. Air filtration of microbial particles. U.S. Public Health Service Publication 953. U.S. Government Printing Office, Washington, D.C.




FIGURE 1. Isolation Chamber, Operational in the Greenhouse.




FIGURE 2. Isolation Chamber, Showing Tubular Aluminum Frame, Polyvinyl Enclosure with Zipper Opening, Exhaust (Upper) Filter, Supply (Lower) Filter, Air Supply Blower, and Subirrigation Fan.

of $\frac{1}{2}$ -inch-mesh hardware cloth, 24 inches long; the supply filter diameter ($2\frac{1}{2}$ inches) is larger than that ($2\frac{1}{4}$ inches) of the exhaust filter, creating a slight positive pressure within the chamber during operation. A single layer of the filter medium is applied to the surface of the core and is held tightly in place by wrapping it with aluminum wire screening. The upper (exhaust) filter is sealed at one end with tape to a collar welded about the hole in the enclosure wall, and the opposite end is sealed airtight with an RTV* silicone rubber compound (transparent in the photographs). The lower (supply) filter is similarly sealed and attached to a collar, and the external blower is affixed to the collar by an adaptor. The capacity of the electrically powered blower unit is 100 cfm of free air delivery.

A galvanized pan (14 by $22\frac{1}{2}$ by $1\frac{1}{2}$ inches) is placed on the floor within the enclosure to protect the plastic and to permit subirrigation of the pots of plants.

To test the chamber, uredospores of Puccinia striiformis West were released into the blower inlet. Vaseline-coated glass slides placed within the chamber at various orientations surrounding the supply filter were free of spores when examined after an exposure time of 1 hour. When spores were aerosolized within the chamber, none was found on slides exposed to the exhaust air.

Several of these isolation chambers have performed satisfactorily for over a year. Within these and similar chambers the growth of wheat, tomato, and bean plants from seed germination to maturity has been vigorous and apparently "normal" compared with conventionally grown greenhouse plants. The unit could be adapted for working with particles of less than 5 microns diameter by utilizing a higher-density filter medium and increasing the blower capacity. A small, window-type air conditioner could be attached to one or more units when a temperature lower than that of the greenhouse ambient air was required.

* RTV = Room temperature vulcanizing.

Unclassified
Security Classification

DOCUMENT CONTROL DATA - R & D		
<i>(Security classification of title, body of abstract and indexing annotation must be entered when the overall report is classified)</i>		
1. ORIGINATING ACTIVITY (Corporate author)		2a. REPORT SECURITY CLASSIFICATION
Department of the Army Fort Detrick, Frederick, Maryland, 21701		Unclassified
		2b. GROUP
3. REPORT TITLE		
A PORTABLE CHAMBER FOR THE GROWTH AND ISOLATION OF INFECTED PLANTS		
4. DESCRIPTIVE NOTES (Type of report and inclusive dates)		
5. AUTHOR(S) (First name, middle initial, last name)		
Robert G. Enge J. Stanley Charles H. Kingsolver		
6. REPORT DATE	7a. TOTAL NO. OF PAGES	7b. NO. OF REFS
January 1970	9	1
8a. CONTRACT OR GRANT NO.		8b. ORIGINATOR'S REPORT NUMBER(S)
a. PROJECT NO. 1B562602AD09		Technical Manuscript 572
c. Task-Work Unit 01-007		8c. OTHER REPORT NUM(S) (Any other numbers that may be assigned this report)
d. DD 1498 Agency Accession DA OL 0426		CMs 6627 SMJFD-AE-T 49562
10. ABSTRACTION STATEMENT		
Qualified requesters may obtain copies of this publication from DDC. Foreign announcement and dissemination of this publication by DDC is not authorized. Release or announcement to the public is not authorized.		
11. SUPPLEMENTARY NOTES		12. SPONSORING MILITARY ACTIVITY
		Department of the Army Fort Detrick, Frederick, Maryland, 21701
13. ABSTRACT		
An easily portable unit, consisting of an aluminum tubular frame covered with transparent polyvinyl sheeting, has been developed to contain infected plants and exclude airborne fungal contaminants. A 100-cfm squirrel-cage blower supplies air through a filter to the interior of the chamber, maintaining an internal positive pressure that prevents the entrance of contaminants when the unit is opened. Air is exhausted through a filter at a rate that provides sufficient flow through the chamber to hold the interior air temperature at approximately that of the outside ambient air. This air flow causes no visible agitation of the plants.		
14. Key Words		
Isolation chamber Infected plants Cross contamination Portable equipment Transparent Multipurpose		

Unclassified
Security Classification