

Unclassified

Evolution of Combustion Byproducts from Gaseous Fire Suppression Agents

Contract FA8075-14-D-0014

DS TAT 2T10

TAT # 16-1258

Report:

11 October 2018

(Cover dates 2010-11 October 2018)



Operated by:

Alion Science & Technology Corporation

GCSS

12601 Fair Lakes Cir

Fairfax, VA 22033

DISTRIBUTION STATEMENT A: Approved for public release; distribution unlimited.

Unclassified

REPORT DOCUMENTATION PAGE

Form Approved

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Washington Headquarters Service, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188) Washington, DC 20503.

PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.

1. REPORT DATE (DD-MM-YYYY) 11/10/2018	2. REPORT TYPE Presentation	3. DATES COVERED (From - To) 2010 - 11/10/2018
--	---------------------------------------	--

4. TITLE AND SUBTITLE Evolution of Combustion Byproducts from Gaseous Fire Suppression Agents	5a. CONTRACT NUMBER FA8075-14-D-0014 DO# 2T10
	5b. GRANT NUMBER N/A
	5c. PROGRAM ELEMENT NUMBER N/A

6. AUTHOR(S) Dr. Steven Hodges, TARDEC Fire Protection Team, Alion Science and Technology Mike Chapman, Warfighter Directorate, US Army Aberdeen Test Center	5d. PROJECT NUMBER N/A
	5e. TASK NUMBER Delivery Order #2T10
	5f. WORK UNIT NUMBER N/A

7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Defense Systems Alion Science & Technology Corporation 12601 Fair Lakes Cir Fairfax, VA 22033	8. PERFORMING ORGANIZATION REPORT NUMBER N/A
---	--

9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) U.S. Army TARDEC LEATHERS.EDWIN 6501 E. 11 Mile Road .W.JR.1094292057 Warren, MI 48397	10. SPONSOR/MONITOR'S ACRONYM(S) TARDEC
	11. SPONSORING/MONITORING AGENCY REPORT NUMBER N/A

Digitally signed by LEATHERS.EDWIN.W.JR.1094292057
Date: 2018.10.18 13:23:33 -04'00'

12. DISTRIBUTION AVAILABILITY STATEMENT

DISTRIBUTION STATEMENT A: Approved for public release; distribution unlimited.

13. SUPPLEMENTARY NOTES

14. ABSTRACT
Task 3.3.2 Provide subject matter expertise in the area of fire prevention, detection, and suppression and for other damage prevention and damage reduction systems. (Deliverable 4.8: Ground Vehicle Survivability Technologies and Demonstrators Reports).

The US Army plans to modernize legacy vehicle platforms, including Automatic Fire Extinguishing Systems (AFES), and is considering replacing legacy agents with more environmentally friendly suppression agents. TARDEC's exploratory tests are intended to compare various suppression agents, including new, more environmentally friendly ones, with those currently deployed.

15. SUBJECT TERMS

16. SECURITY CLASSIFICATION OF: U			17. LIMITATION OF ABSTRACT SAR	18. NUMBER OF PAGES 18	19a. NAME OF RESPONSIBLE PERSON Mr. Joel King
a. REPORT U	b. ABSTRACT U	c. THIS PAGE U			19b. TELEPHONE NUMBER (Include area code) (586) 282-6032



U.S. ARMY RESEARCH, DEVELOPMENT AND ENGINEERING COMMAND

EVOLUTION OF COMBUSTION BYPRODUCTS FROM GASEOUS FIRE SUPPRESSION AGENTS

Steve Hodges

Mike Chapman

Fire Protection Team

Field Sampling and Analysis

TARDEC

ATC

11 OCT 2018

DISTRIBUTION STATEMENT A. Approved for public release; distribution unlimited.



INTRODUCTION

- An interesting observation made during a study of potential fire suppression agents with lower GWP than those currently used, was that the byproducts from FK-5-1-12 evolved quite differently than those from Halon 1301 or HFC227-BC.^[1]

“Note that although the peak acid levels for ‘HFC-227BC’ and ‘FK-5-1-12+’ ... are similar, the integrated levels used in casualty assessments were very different: none of the FK-5-1-12-based tests ‘passed,’ The difference is related to the relative evolution in time of COF₂ and HF. Halon and HFC-227BC tests with good fire suppression show COF₂ quickly peaking and then slowly decaying as the HF level slowly rises; in FK-5-1-12 tests both COF₂ and HF peak quickly and then slowly decay. The result is that the total integrated acid level used in casualty assessments ... is higher in FK-5-1-12-based tests.”

1. Hodges, S. E. and McCormick, S. J., “Fire Extinguishing Agents for Protection of Occupied Spaces in Military Ground Vehicles,” Suppression & Detection Symposium (SUPDET), National Fire Protection Association (NFPA), 2010.
<http://www.dtic.mil/dtic/tr/fulltext/u2/a517470.pdf>



BACKGROUND – 2008

The US Army plans to modernize legacy vehicle platforms, including Automatic Fire Extinguishing Systems (AFES).

Legacy vehicles use Halon 1301 or HFC-227BC to protect the crew. 1301 has high Ozone Depletion Potential (ODP) and Global Warming Potential (GWP). HFC-227 has high GWP.

The Army is considering replacing legacy agents with more environmentally friendly suppression agents.

TARDEC was tasked to test alternate agents, including FK-5-1-12.

- FK-5-1-12 suppression agent has zero ODP and low GWP. The manufacturer has claimed that it is essentially a drop-in replacement for 1301 or HFC-227ea.

Excerpt from www.dtic.mil/docs/citations/ADA517470



EXPLORATORY TESTS 2008-2009

Purpose

TARDEC's Exploratory tests are intended to compare various suppression agents, including new, more environmentally friendly ones, with those currently deployed.

Approach

Three extinguisher suppliers supported the tests (12/08-9/09) – they were asked to provide suppression systems that would yield marginal suppression 'passes' and 'failures' based on current vehicle performance criteria.

The tests were conducted in a 260 ft³ (7.36 m³) box with relatively little clutter, no stowage, and no active air flow.



Excerpt from www.dtic.mil/docs/citations/ADA517470



EXPLORATORY TESTS (CONTINUED)

Seven test series conducted between Dec08 and Sep09

157 live-fire tests

9 suppression agents

- Halon 1301 - 'halon' (*used in legacy vehicles*)
- Halon 1301 with Dry Chemicals (DC) – 'halon+' & 'halonK'
- HFC-227ea with DC – 'HFC227BC' (*used in vehicles since 2001*)
- FK-5-1-12
- FK-5-1-12 with DC – 'FK-5-1-12+'
- Water with Potassium Acetate – 'water+'
- Two Dry Chemicals – Sodium (+) and Potassium (K) Bicarbonates

4 Extinguisher configurations from 3 suppliers

- N₂ charged with solenoid valve
(Abrams, BFV, FAASV, STRYKER, UAH, & some MRAP)
- N₂ charged with linear actuated valve (NLOS-C Crew & Mission)
- N₂ charged with SQUIB actuated valve (some MRAP)
- Hybrid Fire Extinguisher actuated by Gas Generator (experimental)



Excerpt from www.dtic.mil/docs/citations/ADA517470



U.S. ARMY
RDECOM

EXPLORATORY TESTS UNSUPPRESSED FIRE (BL1)



DISTRIBUTION STATEMENT A. Approved for public release; distribution unlimited.



U.S. ARMY
RDECOM

EXPLORATORY TESTS SUPPRESSED FIRE (KHBC1)



DISTRIBUTION STATEMENT A. Approved for public release; distribution unlimited.



OVERVIEW OF 2009 RESULTS

**Best Performance							
Agent	Total	*Pass	**Least Agent Weight (lb)	Lowest Acid Dose (ppm-min)	Lowest Pressure Peak (psi)	Fastest Fire Out Time (ms)	Note
Halon	21	12	~5	~500	<1	<200	Legacy fielded product
Halon+	19	16	~2.5	<20	<1	<200	New mix compatible with fielded extinguishers
HalonK	7	4	~2.5	<20	<1	<200	New mix compatible with fielded extinguishers
HFC227BC	36	17	~5	<20	<1	<200	Fielded product
FK-5-1-12	21	0	>25	~2,000	1.2	<200	Available
FK-5-1-12+	15	0	>15	~1,300	1.6	<200	Invention required
Water+	23	12	~4	0	1.5	~400	Development required; operational issues?
NaBC	13	7	~3	0	<1	<200	Available; safety & operational issues?
KBC	2	2	~2	0	<1	<200	Available; safety & operational issues?
Total	157	70					

* The goal was to 'pass' half the tests

** Best Performance and Least Agent Weight are not obtained simultaneously

Excerpt from www.dtic.mil/docs/citations/ADA517470



COMBUSTION BYPRODUCTS^[1]


- Continuous sampling gas phase Fourier Transform Infrared (FTIR) spectrometers were used to analyze the combustion byproducts from each trial in near real time. Using this technique allows for the accurate measurement of multiple analytes, including COF₂ and HF.
- Since the relative toxicity of these compounds are quite different, the ability to quantify each of these compounds is necessary for an adequate determination of injury or incapacitation due to inhalation of these toxic gases.

1. ATC Chemistry test report no. 2009-CC-359.




DEPLOYED AGENT - HALON 1301

Minimum Design Concentration: 5.0%



Halon 1301 @ 3.25%
5-min Dose 439 ppm-min



Halon 1301 @ 4.77%
5-min Dose <233 ppm-min



$$Dose = \int_0^{5 \text{ min}} (HF + HBr + 2COF_2) dt \leq 746 \text{ ppm-min}$$



U.S. ARMY
RDECOM

DEPLOYED AGENT – HFC227-BC

Minimum HFC-227ea Design Concentration: 8.7%



HFC-227ea @ 2.50%, 5%w/w BC
5-min Dose **1,070** ppm-min


HFC-227ea @ 4.88%, 5%w/w BC
5-min Dose <125 ppm-min

$$Dose = \int_0^{5 \text{ min}} (HF + 2COF_2) dt \leq 746 \text{ ppm-min}$$




TESTED LOW-GWP AGENT – FK-5-1-12

Minimum Design Concentration: 5.9%



FK-5-1-12 @ 5.90%
 5-min Dose **8,100** ppm-min




FK-5-1-12 @ 9.31%
 5-min Dose **4,959** ppm-min

$$Dose = \int_0^{5 \text{ min}} (HF + 2COF_2) dt \leq 746 \text{ ppm-min}$$



TESTED LOW-GWP AGENT – FK-5-1-12-BC

Minimum FK-5-1-12 Design Concentration: 5.9%



FK-5-1-12 @ 9.32%, 5% w/w BC*

5-min Dose **1,900** ppm-min

$$Dose = \int_0^{5 \text{ min}} (HF + 2COF_2) dt \leq 746 \text{ ppm-min}$$

*FK-5-1-12 and BC powder can not be stored together; they react chemically

DISTRIBUTION STATEMENT A. Approved for public release; distribution unlimited.



SUMMARY

- Halon 1301 and HFC227-BC generally produced significant levels of carbonyl fluoride (COF_2) initially which then decayed into hydrogen fluoride (HF), generally the levels of byproduct remained below acceptable limits
- FK-5-1-12 produced very high levels of HF and COF_2 simultaneously, and the levels of byproduct remained above acceptable limits
- Adding BC dry chemical to the FK-5-1-12 discharge nozzle improved performance, but did not change the temporal trend, and the levels of byproduct remained above acceptable limits
- Even when HFC227-BC was applied at less than 1/3 of the HFC-227ea class B minimum design concentration of 8.7%, the byproduct levels were much lower than the criteria dose limit



CONCLUSION

- Correlated with the distinct differences in the temporal evolution of byproducts, the dose of acid and carbonyl byproducts from FK-5-1-12, neat or with dry chemical, were consistently well above the US Army casualty criteria limit of 746 ppm-min (5-minute dose), while byproducts from HFC227-BC and Halon 1301, used with normal design concentrations, were well below the limit.
- Overall, this result suggests that chemicals, such as FK-5-1-12, that are designed to be more reactive, thus yielding shorter atmospheric lifetimes and therefore lower GWPs, generate much higher byproduct levels during the fire suppression process than more stable, and thus likely higher GWP, compounds.



DISCLAIMER

Reference herein to any specific commercial company, product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or the Department of the Army (DoA). The opinions of the authors expressed herein do not necessarily state or reflect those of the United States Government or the DoA, and shall not be used for advertising or product endorsement purposes.