

Foam Quality Effects on the Firefighting Capabilities of PFAS-Free Foams

WP19-5374

Gerard G. Back (Jerry)

JENSEN HUGHES

3610 Commerce Drive, Suite 817
Baltimore, MD 21227

Final Debrief

29 July 2022



This report was prepared under contract to the Department of Defense Environmental Security Technology Certification Program (ESTCP). The publication of this report does not indicate endorsement by the Department of Defense, nor should the contents be construed as reflecting the official policy or position of the Department of Defense. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the Department of Defense.

REPORT DOCUMENTATION PAGE

*Form Approved
OMB No. 0704-0188*

The public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing the burden, to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.
PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.

1. REPORT DATE (DD-MM-YYYY) 20/04/2021			2. REPORT TYPE ESTCP Project Outbrief		3. DATES COVERED (From - To) 9/4/2020 - 9/4/2022	
4. TITLE AND SUBTITLE Foam Quality Effects on the Firefighting Capabilities of PFAS-Free Foams					5a. CONTRACT NUMBER 20-C-0064	
					5b. GRANT NUMBER	
					5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S) Jerry Back Jensen Hughes, Inc. John Farley Naval Research Laboratory					5d. PROJECT NUMBER WP19-5374	
					5e. TASK NUMBER	
					5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Jensen Hughes, Inc., 3610 Commerce Dr. Suite 817 Baltimore, MD 21227					8. PERFORMING ORGANIZATION REPORT NUMBER WP19-5374	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) Environmental Security Technology Certification Program 4800 Mark Center Drive, Suite 16F16 Alexandria, VA 22350-3605					10. SPONSOR/MONITOR'S ACRONYM(S) ESTCP	
					11. SPONSOR/MONITOR'S REPORT NUMBER(S) WP19-5374	
12. DISTRIBUTION/AVAILABILITY STATEMENT DISTRIBUTION STATEMENT A. Approved for public release: distribution unlimited.						
13. SUPPLEMENTARY NOTES						
14. ABSTRACT <ul style="list-style-type: none"> ● The ultimate objective is to predict the firefighting capabilities of PFFs when discharged through typical Department of Defense (DoD) nozzles and systems <ul style="list-style-type: none"> ○ Demonstrate firefighting capabilities of PFFs as a function of foam quality (expansion ratio and drainage time) ○ Characterize the foam quality produced by typical DoD discharge devices and legacy protein foam hardware 						
15. SUBJECT TERMS Firefighting foam, AFFF, Fluorine-Free Foam, PFAS-Free Foam, PFF, Extinguishment, Burnback, Foam Quality, Expansion Ratio						
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT UNCLASS	18. NUMBER OF PAGES 25	19a. NAME OF RESPONSIBLE PERSON Gerard (Jerry) Back	
a. REPORT UNCLASS	b. ABSTRACT UNCLASS	c. THIS PAGE UNCLASS			19b. TELEPHONE NUMBER (Include area code) 443-313-9834	

Project Team

JENSEN HUGHES

Gerard Back (Jerry), Fire Protection Engineer **PI**
38 years of experience covering the spectrum of fire protection topics/issues



NRL

John Farley, Director of Fire Test Operations (Foam Expert / FF / DC)
40 years of USN firefighting experience and research

Stan Karwoski, Senior Firefighting Technician
20 years of practical firefighting experience and research



Technical Objectives

The ultimate objective is to predict the firefighting capabilities of PFFs when discharged through typical Department of Defense (DoD) nozzles and systems

- Demonstrate firefighting capabilities of PFFs as a function of foam quality (expansion ratio and drainage time)
- Characterize the foam quality produced by typical DoD discharge devices and legacy protein foam hardware

Two separate demonstrations conducted in parallel

Technical Approach

Firefighting Capabilities

Demonstrate firefighting capabilities of PFFs as a function of foam quality (expansion ratio and drainage time)

Four leading PFFs tested (and baseline C6 AFFF)

Tests conducted in MILSPEC 28 ft² pan (two fuels)

Foam qualities tested over a range of expansions 1 to 9

Two flow rates:

2 gpm (0.07 gpm/ft²)

3 gpm (0.11 gpm/ft²)

Test Design – Fire Performance


Foam Concentrates

Manufacturer	Foam Name	Type	Viscosity
Buckeye	Mil-Spec Type 3	AFFF	Newtonian
Bio-ex	ECOPOL A3+	PFF	Newtonian
Fomtec	Enviro USP	PFF	Non-Newtonian
National	Avio Green	PFF	Newtonian
Solberg	RE-HEALING RF3	PFF	Non-Newtonian

28 ft² Mil-Spec Fires and Procedures Jet A and Gasoline



Air-Aspirating Nozzle Openings Varied 2 & 3 gpm



10 second preburns, 90 second discharges

Firefighting Data Review



Focus on 0.07gpm/ft² application rate

Foam quality/aspiration produces similar trends and application rate – “L curves”

Extinguishment similar between products

Critical expansion for gas 5-6 expansion

Critical expansion for Jet A 3-4 expansion





AFFF pushes lines to left 2 exp points

Burnback Data Review

90 second foam discharge

Burnback varied between product types (i.e., Newtonian and Non-Newtonian)



Non-Newtonian provides an additional 3-5 minutes of protection







AFFF similar to Newtonian PFFs

Burnback Data Review – Newtonian

Land-based Mil-Spec (MIL-PRF-XX727) eliminates non-Newtonian products
 Gradual increase with increased expansion/aspiration (2–3-minute increase)
 Gas 3-4 minutes of protection over 5-9 expansion range (delta 1.5 minutes)
 Jet A 3-6 minutes of protection over 3-9 expansion range (delta 3 minutes)
 (Jet A is about 2 minutes longer than gas)



Increased Application Rate Data Review



Technical Approach

Foam Quality

Characterization of foam quality produced by typical DoD discharge devices (and legacy PF devices)

- Fixed system nozzles used throughout DoD (between 4-6);
- Manual firefighting nozzles used throughout DoD (between 2-4);
- Firefighting vehicle nozzles used throughout DoD (between 2-3);
- One PF nozzle of each type listed above.

Test Design

Types of Discharge Devices


Fixed Non-Air-Aspirated Nozzles	Fixed Air-Aspirated Nozzles	NAVFAC Hangar Nozzle
		
Hose Line Nozzles	Bumper/Roof Turret Nozzles	Foam Tubes
		

Test Design – Foam Quality

Foam Concentrates

Manufacturer	Foam Name	Type	Viscosity
Buckeye	Mil-Spec Type 3	AFFF	Newtonian
Bio-ex	ECOPOL A3+	PFF	Newtonian
Fomtec	Enviro USP	PFF	Non-Newtonian
National	Avio Green	PFF	Newtonian
Solberg	RE-HEALING RF3	PFF	Non-Newtonian

NFPA 412 Backboard



China Lake Hose Line Nozzle Tests



CBD Nozzle Tests



Data Review

General Observations

PFFs “foamier” than AFFF about 1-2 expansion points higher across all devices

Non-Newtonian PFFs “foamier” than Newtonian PFFs (by about 1 expansion point)

Non-Newtonian foam is more robust and drains slower than Newtonian PFFs and AFFF (AFFF and Newtonian PFFs have similar drainage times)
AFFF & Newtonian PFFs 3-5 minutes / Newtonian PFFs over 10 minutes

Foam quality (both expansion and drainage times) consistent for similar discharge devices (e.g., all non-air-aspirating hose line nozzles produced similar foam quality)

Data Review

DoD Discharge Devices Foam Quality Measurements

Man. / Model	Buckeye AFFF		National Avio		Solberg RF3	
	Exp. Ratio	Drainage (sec)	Exp. Ratio	Drainage (sec)	Exp. Ratio	Drainage (sec)
Tyco / B1	5.1	300	7.7	400	9.8	>2000
Bete / TF29-180-24	2.2	-	2.6	-	3.2	364
Globe / GL5601	3.5	-	4.7	-	5.4	630
Viking / GN 200/360	3.9	-	6.1	180	9.0	>2000
Elkhart / SFL-GN-95*	3.2	-	4.3	90	5.9	742
Akron Brass / 3023*	3.5	-	4.9	80	6.1	712
TFT / ME1VPGI-125*	3.1	-	4.6	-	6.7	723
Akron Brass / 3352*	3.3	-	4.9	-	6.6	765
Akron Brass / 3353*	3.2	-	4.6	-	6.5	732
Rosenbauer / RM25*	3.0	-	4.6	-	5.9	721

“-“ below measurable range “*” Spray Pattern Specific (values shown are ~10 degree spray patterns)

Protein Foam Discharge Device Foam Quality Measurements

Man. / Model	Buckeye AFFF		National Avio		Solberg RF3	
	Exp. Ratio	Drainage (sec)	Exp. Ratio	Drainage (sec)	Exp. Ratio	Drainage (sec)
Angus K40	6.1	170	7.4	400	8.2	1430
National Foam JS-10	6.2	211	8.3	633	9.5	1635
National Foam PC-31	6.2	236	7.6	549	9.5	1569
Task Force Tips FJ-LX-HM	7.1	354	9.5	703	11.9	>2000
Task Force Tips FJ-MX-HM	8.9	401	16.9	765	20.7	>2000

Data Review

General Summary

Fixed system nozzles (non-air-aspirating) used by DoD (between 2-5 exp.)

- 2-3 expansion for standard orifice nozzles and 4-5 for deflector plate nozzles

Fixed system nozzles (air-aspirating) used by DoD (between 8-10 exp)

Fixed system NAVFAC Hangar Grate Nozzle (between 6-9 exp)

Manual firefighting nozzles used by DoD (between 2-6 exp., pattern dependent)


- 2-4 expansion for straight stream and 4-6 for narrow angle patterns (5-15 degrees)

Firefighting vehicle nozzles used by DoD (between 2-6 exp., pattern dependent)

- 2-4 expansion for straight stream and 4-6 for narrow angle patterns (5-15 degrees)


Foam tubes and legacy protein foam hardware (8-20 flow rate dependent)

Data Interpretation – Jet A




Data Interpretation – Jet A

Critical Expansion Ratio ~ 4




Data Application – Jet A

Critical Expansion Ratio ~ 4



Data Interpretation – Gas

Critical Expansion Ratio ~ 5.5



Key Points

Firefighting Capabilities

Firefighting capabilities increase with increased aspiration (5 or above should be fine)

Extinguishment (“L” type curve for ext. time vs expansion)

Critical aspiration for PFFs ~4 exp. for Jet A and 5.5 exp. for gasoline (at 0.07 gpm/ft²)

Burnback (Gradual increase with increased expansion/aspiration)

Burnback varied between product types (Newtonian vs Non-Newtonian)

Non-Newtonian provides an additional 3-5 minutes of protection

PFFs provided protection Jet A 3-6 minutes for Jet A and 3-4 minutes for gasoline (at 0.11 gal/ft²)

Foam Quality

Typical DoD discharge devices produce foam in the 2-8 exp. range

Protein foam discharge devices produce foam in the 6-20 exp. Range

Manual firefighting nozzles (hose line and turret nozzles) are below critical at straight stream

All-in-All, there are only a few areas of concern when fielding the top performing PFFs in DoD applications

Next Steps / Path Forward

WP21-3461 & WP21-3465 Phase III

Manual firefighting nozzles (hose line and turret nozzles) require additional research


1. Development of novel nozzle designs specifically suited to discharge of PFFs (i.e., variable aspiration while maintaining pattern control).
2. Improvements to application techniques and firefighting tactics/doctrine to reduce the performance gap between AFFF and these PFFs

Technology Transfer

The final product is of this effort is the knowledge associated with the capabilities of PFFs as a function of foam quality.

This provides a tool to predict the firefighting capabilities of PFFs when discharged through typical Department of Defense (DoD) nozzles and systems (as well as others).

The information is available on the SERDP/ESTCP website and will be presented at a least two technical conferences held by the fire protection industry over the next year or so.



Questions?



JENSEN HUGHES



NRL



ESTCP