

AD/A-003 212

WATER POLLUTION SURVEY, MOODY AIR FORCE  
BASE, GEORGIA

Richard A. Virost

Environmental Health Laboratory  
Kelly Air Force Base, Texas

November 1974

DISTRIBUTED BY:

**NTIS**

National Technical Information Service  
U. S. DEPARTMENT OF COMMERCE

UNCLASSIFIED

Security Classification

AD/A-003212

DOCUMENT CONTROL DATA - R & D

(Security classification of title, body of abstract and indexing annotation must be entered when the overall report is classified)

|  |   |
|--|---|
| 1. ORIGINATING ACTIVITY (Corporate author)<br>USAF Environmental Health Laboratory<br>Kelly AFB, Texas 78241 | 2a. REPORT SECURITY CLASSIFICATION<br>UNCLASSIFIED<br>2b. GROUP |
|--|---|

3. REPORT TITLE  
WATER POLLUTION SURVEY - MOODY AFB, GEORGIA

4. DESCRIPTIVE NOTES (Type of report and inclusive dates)

5. AUTHOR(S) (First name, middle initial, last name)  
Richard A. Virost  
1Lt, USAF, BSC

|                                 |                               |                      |
|---------------------------------|-------------------------------|----------------------|
| 6. REPORT DATE<br>November 1974 | 7a. TOTAL NO. OF PAGES<br>121 | 7b. NO. OF REFS<br>3 |
|---------------------------------|-------------------------------|----------------------|

|   |  |
|---|--|
| 8a. CONTRACT OR GRANT NO.<br><br>b. PROJECT NO.<br><br>c.<br><br>d. | 9a. ORIGINATOR'S REPORT NUMBER(S)<br><br>EHL(K) 74-27<br><br>9b. OTHER REPORT NO(S) (Any other numbers that may be assigned this report) |
|---|--|

10. DISTRIBUTION STATEMENT  
Approved for public release and sale; distribution unlimited.

|                         |                                  |
|-------------------------|----------------------------------|
| 11. SUPPLEMENTARY NOTES | 12. SPONSORING MILITARY ACTIVITY |
|-------------------------|----------------------------------|

13. ABSTRACT

This report contains results of a wastewater survey of Moody AFB GA planned by a bioenvironmental engineer of the USAF Environmental Health Laboratory, Kelly AFB TX and conducted by personnel of Moody AFB. Analysis of the Moody sewage treatment plant operating logs for the period January-November 1973 is also included. The Moody AFB sewage treatment plant is a well-run low-rate trickling filter plant, designed for 0.75 MGD. The plant provides excellent secondary treatment to 0.393 MGD of medium strength sewage. The effluent is chlorinated before discharge to Beatty Creek. Some industrial wastewaters identified in the report are discharged directly to the storm sewer system. Connection of these waste streams to the sanitary system should be completed by the end of FY 75 or the beginning of FY 76. The base has received its final NPDES permit. The sewage treatment plant can comply with the interim discharge requirements of the permit, but it will require modifications to meet the final limits that will apply beginning on 1 July 1977. A stream dissolved oxygen survey is recommended to gather data to determine the effect of the base's discharge on the receiving waters. A sampling protocol is included with the report to supplement sewage treatment plant monitoring requirements with base-wide surveillance of all discharged storm waters.

Reproduced by  
NATIONAL TECHNICAL  
INFORMATION SERVICE  
US Department of Commerce  
Springfield, VA. 22151

| 14. KEY WORDS  | LINK A |    | LINK B |    | LINK C |    |
|--|--------|----|--------|----|--------|----|
|  | ROLE   | WT | ROLE   | WT | ROLE   | WT |
| Water Quality Standards<br>Sanitary Sewage<br>Industrial Wastewater<br>Trickling Filters<br>Water Monitoring Program |        |    |        |    |        |    |

ia

USAF ENVIRONMENTAL HEALTH LABORATORY (AFLC)

UNITED STATES AIR FORCE

KELLY AFB, TEXAS 78241

WATER POLLUTION SURVEY

Moody AFB GA  
EHL(K) 74-27  
November 1974

Prepared By:

*Richard A. Virost*

RICHARD A. VIROST, 1Lt, USAF, BSC  
Consulting Bioenvironmental Engineer

Reviewed By:

*Albert M. Elliott*

ALBERT M. ELLIOTT, Lt Col, USAF, BSC  
Chief, Special Projects Division

Approved By:

*Walter W. Melvin Jr.*

WALTER W. MELVIN, Jr, Col, USAF, MC  
Commander

APPROVED FOR PUBLIC RELEASE AND SALE; DISTRIBUTION UNLIMITED.

*if*

## NOTICE

This report has been prepared by the Air Force for the purpose of aiding study and research. It is not to be used for promotional or advertising of any product. The views expressed herein are those of the author/reviewers and do not necessarily reflect the official views of the publishing agency, the United States Air Force or the Department of Defense.

## TABLE OF CONTENTS

| Section  | Page |
|--|------|
| I. SUMMARY.....  | 1    |
| II. INTRODUCTION.....  | 2    |
| A. Purpose.....  | 2    |
| B. Historical Background.....  | 2    |
| III. DISCUSSION.....   | 3    |
| A. Base Description.....   | 3    |
| B. Sanitary Wastewater Sources and Treatment.....  | 4    |
| C. Industrial Wastewater Sources and Treatment....   | 12   |
| D. National Pollutant Discharge Elimination<br>System (NPDES) Permit.....                  | 18   |
| E. Monitoring Program.....   | 20   |
| IV. CONCLUSIONS.....   | 21   |
| V. RECOMMENDATIONS.....  | 22   |
| <br>Appendix   |      |
| A. Authorization For Survey.....   | 23   |
| B. Water Use Classifications and Water Quality<br>Criteria for the State of Georgia.....   | 28   |
| C. Equivalent Base Population.....   | 53   |
| D. Industrial Waste Source Survey and Inventory.....                                       | 55   |
| E. Trip Report.....  | 64   |
| F. Water Pollution Surveillance Sampling Program.....                                      | 73   |
| G. Field Survey Results.....   | 92   |
| H. National Pollutant Discharge Elimination System<br>Permit #GA0020001, Moody AFB GA..... | 101  |
| DD Form 1473.....  | 114  |
| Distribution List.....   | 116  |

| Tables   | Page |
|--|------|
| 1. Flowrate in MGD.....  | 6    |
| 2. Average Composition of Raw Wastewater.....                                      | 9    |
| 3. Composition of Raw Wastewater Entering Moody AFB<br>STP.....                    | 10   |
| 4. STP Average Performance.....  | 11   |
| 5. Composition of Final Effluent, Moody AFB STP.....                               | 13   |
| 6. Identified Industrial Wastewater Sources.....                                   | 15   |
| 7. Average Storm Sewer Discharge Composition.....                                  | 17   |
| 8. Comparison of Moody STP Discharge with NPDES<br>Permit Limits.....              | 19   |
| C-1 Equivalent Base Population.....  | 54   |
| D-1 Industrial Waste Source Survey and Inventory.....                              | 56   |
| F-1 Water Pollution Surveillance Sampling Stations...                              | 75   |
| F-2 Physical and Chemical Data From Sampling<br>Stations.....                      | 76   |
| F-3 Field Data Worksheet for Stations S-1 and S-2<br>Moody AFB, GA.....            | 78   |
| F-4 Field Data Worksheet for Stations R-1, R-2, R-3,<br>R-4, R-5 or R-6.....       | 79   |
| F-5 Field Data Worksheet for Stations R-7 and R-8....                              | 80   |
| F-6 BOD <sub>5</sub> Worksheet Stations S-1 and S-2.....                           | 82   |
| F-7 BOD <sub>5</sub> Worksheet Stations R-1 through R-8.....                       | 83   |
| F-8 Total Suspended Solids Worksheet.....  | 84   |
| F-9 Sample Analysis Request Form.....  | 88   |
| F-10 Coding of Water Sample Sources.....   | 89   |
| F-11 Summary of Analyses for Water Pollution<br>Surveillance Sampling Station..... | 91   |

| Tables |  | Page |
|--------|--|------|
| G-1    | Data Summary for Sampling Station S-1..... | 93   |
| G-2    | Data Summary for Sampling Station S-2..... | 94   |
| G-3    | Data Summary for Sampling Station R-1..... | 95   |
| G-4    | Data Summary for Sampling Station R-2..... | 96   |
| G-5    | Data Summary for Sampling Station R-3..... | 97   |
| G-6    | Data Summary for Sampling Station R-4..... | 98   |
| G-7    | Data Summary for Sampling Station R-5..... | 99   |
| G-8    | Data Summary for Sampling Station R-6..... | 100  |

#### Figures

|     |   |    |
|-----|---|----|
| 1.  | Simplified Plant Layout-Sanitary Sewage Treatment Plant, Moody AFB GA.....              | 5  |
| 2.  | Daily Wastewater Flowrate.....  | 7  |
| 3.  | Storm Drainage System.....  | 16 |
| F-1 | Relationship of Flow to Sample Size at Sewage Treatment Plant.....                      | 86 |
| F-2 | Relationship of Sampling Interval to Sample Size in Drainage Ditches/Lakes Outfall..... | 86 |

## I. SUMMARY

This report contains results of a wastewater survey of Moody AFB GA planned by a bioenvironmental engineer of the USAF Environmental Health Laboratory, Kelly AFB TX and conducted by personnel of Moody AFB. Analysis of the Moody sewage treatment plant operating logs for the period January-November 1973 is also included.

The Moody AFB sewage treatment plant is a well-run low-rate trickling filter plant, designed for 0.75 MGD. The plant provides excellent secondary treatment to 0.393 MGD of medium strength sewage. The effluent is chlorinated before discharge to Beatty Creek. Some industrial wastewaters identified in the report are discharged directly to the storm sewer system. Connection of these waste streams to the sanitary system should be completed by the end of FY 75 or the beginning of FY 76.

The base has received its final NPDES permit. The sewage treatment plant can comply with the interim discharge requirements of the permit, but it will require modifications to meet the final limits that will apply beginning on 1 July 1977. A stream dissolved oxygen survey is recommended to gather data to determine the effect of the base's discharge on the receiving waters. A sampling protocol is included with the report to supplement sewage treatment plant monitoring requirements with base-wide surveillance of all discharged storm waters.

## II. INTRODUCTION

### A. Purpose

The USAF Environmental Health Laboratory, Kelly AFB TX was requested in October 1971 to conduct an on-site survey of the sewage treatment plant system, storm drainage system, and plant operators' laboratory procedures. This technical report presents the results of a water sampling program conducted at Moody AFB during September-October 1972 plus statistical analysis of the Water Pollution Control Utility Log (AF Forms 1462, 1463) of the Moody sewage treatment plant for the period January-November 1973. Objectives of this report are as follows:

1. Determine the composition and quantity of domestic and industrial wastewaters generated by base activities.
2. Determine the effectiveness of existing treatment facilities.

### B. Historical Background

1. In October 1971, the Commander, Moody Air Force Base requested an on-site survey of the base sewage treatment plant system, storm drainage system and plant operator's laboratory procedures. In October 1971, HQ ATC requested HQ AFLC to authorize the USAF Environmental Health Laboratory, Kelly (EHL/K) to conduct the survey. This request was approved (see Appendix A).

2. In December 1971, two EHL/K representatives conducted a preliminary survey of water pollution abatement activities. A trip report written after this trip contained suggestions for improvement of the plant operator's laboratory procedures. This report is included as Appendix E.

3. In February 1972, an Operations Plan was written by Capt. Charles W. Bullock and published by EHL/K. In accordance with the plan, personnel of Moody AFB would use equipment loaned by EHL/K to conduct a comprehensive sampling program.

4. Between 27 September and 7 October 1972, personnel of Moody AFB conducted the sampling program outlined in the Operations Plan. Those samples were submitted to EHL/K for chemical analysis and engineering interpretation.

5. In March 1974, a statistical analysis was performed on the Moody STP's Water Pollution Control Utility Logs (AF Forms 1462, 1463) for the period January-November 1973.

### III. DISCUSSION

#### A. Base Description

1. Moody AFB is located in South-Central Georgia, approximately 9 miles northeast of Valdosta on Georgia Highway 125.

#### 2. Weather

Moody is surrounded by low flat coastal plains and its proximity to the Atlantic Ocean and Gulf of Mexico produces a humid, relatively mild climate. The average summer maximum temperature is 93 degrees. Minimum readings average 72 degrees in the summer and 46 degrees in the winter. Rainfall averages 48-50 inches annually.

#### 3. Hydrology

The southern part of the base drains to Mission Lake. From this area water flows eastward into Grand Bay Swamp, along with water from the eastern and northern areas of the base. Grand Bay swamp drains to Grand Bay Creek and finally to the Alapaha River. The northwestern part of the base drains westward to Beatty Creek and from there through Cat Creek to the Withlacoochee River.

#### 4. Water Supply

Base water comes from eight deep wells, three of which are for drinking. Water from these three wells is chlorinated and fluoride is added. Of the remaining five wells, one is for air-conditioning cooling water, another is for golf course irrigation, a third for jet engine test stand cooling, the fourth is for domestic purposes at the Mission Lake recreation area on base, and the last is not in use at present.

#### 5. Base Mission

Moody AFB is the home of the 38th Flying Training Wing, with a mission of undergraduate pilot training. Both the T-37 and the T-38 aircraft are used for the training. The base supports these planes with routine field maintenance.

#### 6. Base Population

There are approximately 2500 military assigned to Moody AFB, plus approximately 550 civilian employees. Dormitory facilities are available for 651 unaccompanied personnel. On base family housing consists of 306 units, plus 49 trailer units. The equivalent base population is 2688 (see Appendix C).

## 7. Sanitary Sewage Treatment

Approximately 0.393 MGD of sanitary sewage is treated by a secondary sewage treatment plant having a design capacity of 0.750 MGD. This corresponds to 146 gallons of wastewater/population equivalent. The treated effluent is discharged directly to Beatty Creek.

### B. Sanitary Wastewater Sources and Treatment

#### 1. Source of Wastewater

Domestic wastewaters from almost all on-base duty areas and all on-base housing areas are collected and treated at the base secondary sewage treatment plant. This plant also treats wastewater from the corrosion control facility, Bldg 717.

#### 2. Description of Sewage Treatment Plant (STP)

The sewage treatment plant consists of primary and secondary clarifiers, two standard rate trickling filters, an unheated but internally circulated anaerobic digester, two sludge drying beds, chlorinator and chlorine contact tank, and Parshall flume flow measuring device on the discharge line from the plant. A simplified diagram of the plant is presented in Figure 1.

#### 3. Receiving Waters

The plant outfall flows into Beatty Creek which reportedly originates from springs under the base's runway 18L and 18R. Beatty Creek flows for three miles into Cat Creek and thence into the Withlacoochee River. The river and all of its tributaries are classified by the State of Georgia for fishing and propagation of fish. The minimum flow in Beatty Creek over a ten period is zero (seven day ten year minimum).

#### 4. Flow Rate and Collection System Integrity

The average flow rate of wastewater during the period January-November 1973 is given in Table 1. This value was determined from the STP's operating logs for that period. The flow rate was measured by the Parshall flume located on the effluent line leaving the STP. The data showed much variability, as depicted in Figure 2. Part of this fluctuation may be attributed to operating problems encountered with the flowmeter. The STP superintendent indicated that on several occasions the meter dial numbers stuck and required lubrication. At other times orifices on the meter plugged up and caused errors in the reading. These errors were assumed to be randomly distributed. The average flows in Table 1 are presented for three different conditions of rainfall: no rain, more than 0.2 inch of rain, and more than 1 inch of rain. These data indicate that rainfall produces greater wastewater flows, but that the higher flows do not normally exceed the design capacity of the plant.




FIGURE 1 SIMPLIFIED PLANT LAYOUT - SANITARY SEWAGE TREATMENT PLANT  
MOODY AFB GA

TABLE 1


FLOWRATE IN MGD  
 JAN - NOV 1973  
 Moody AFB, GA

|                         | PERCENTILE RANGE (10-90) | MEAN (MGD) | 95% CONFIDENCE LIMITS OF MEAN | NUMBER OF DAYS |
|-------------------------|--------------------------|------------|-------------------------------|----------------|
| All Days                | 0.160-0.640              | 0.393      | 0.384-0.411                   | 335            |
| All Dry Days*           | 0.160-0.580              | 0.375      | 0.351-0.399                   | 211            |
| All Wet Days**          | 0.160-0.720              | 0.441      | 0.394-0.488                   | 57             |
| All Extreme Wet Days*** | 0.400-0.720              | 0.555      | 0.505-0.605                   | 31             |

\*Days on which there was no significant rainfall either on that day or the previous day.

\*\*Days on which the rainfall was significant; i.e., rainfall greater than 0.2 inch plus the following day.

\*\*\*Days on which the rainfall exceeded 1 inch, plus the following day.



## 5. Composition of Raw Wastewater

The composition of the raw wastewater is presented in Tables 2 and 3. Table 2 contains a summary of the data taken during the sampling program conducted by Moody AFB personnel between 27 September and 7 October 1972. Table 3 is based on the analysis of the AF Forms 1462 and 1463 from the Moody AFB STP for the period January-November 1973. The composition values are typical of an average strength domestic wastewater.

## 6. Primary Treatment

The primary clarifiers are designed for an overflow rate of 600 gal/sq ft/day, and are operated at an average overflow rate of 315 gal/sq ft/day based on the average flow from January to November 1973. The reduction of BOD<sub>5</sub>, suspended solids and settleable solids in the primary clarifier is presented in Table 4. These data support a conclusion that the primary clarifier is removing normal amounts of BOD<sub>5</sub> and settleable solids, but only 41% of the suspended solids instead of an anticipated 60%.

## 7. Secondary Treatment

### a. Operation of the Trickling Filters

The two trickling filters together would receive 3.25 mgad at the design flow rate of 0.750 MGD. At the average flowrate of January-November 1973, the hydraulic loading was 1.71 mgad. The average BOD<sub>5</sub> applied loading on the filters for the same time period was 7.0 lb BOD<sub>5</sub> applied/1000 ft<sup>3</sup> bed volume/day. These values are within the operating range suggested by Fair, Geyer, and Okun<sup>1</sup> for a low-rate trickling filter. Table 4 presents data on the reduction of BOD<sub>5</sub> and suspended solids by the trickling filter. On the average, 48% of the BOD<sub>5</sub> and 45% of the suspended solids entering the Moody STP is removed by the trickling filters. This corresponds to a 78% removal of BOD and a 76% removal of suspended solids across the trickling filters. There is no recycle of trickling filter effluent practiced at the plant.

### b. Operation of the Final Clarifier

The final clarifiers are designed for an overflow rate of 937 gal/sq ft/day and a weir rate of 6098 gal/ft/day. This is within the design range suggested by the Ten State Standards<sup>2</sup> for a low rate trickling filter plant. At the average flow, January-November 1973, the overflow rate is 491 gal/sq ft/day and the weir rate is 3195 gal/ft/day. Table 4 shows that the clarifiers removed 30% of the BOD<sub>5</sub> and 35% of the suspended solids that were in the effluent of the trickling filter, or 4% and 5% respectively of the plant influent BOD<sub>5</sub> and suspended solids.

<sup>1</sup>Fair, Geyer and Okun; Water Purification and Wastewater Treatment and Disposal, 1968.

<sup>2</sup>As quoted in MOP #8 Sewage Treatment Plant Design, Water Pollution Control Federation, Washington DC 1967.

TABLE 2  
 AVERAGE COMPOSITION OF RAW WASTEWATER  
 MOODY AFB CA STP\*

| Chemical/Physical<br>Data (mg/l unless noted) |   | Average | Average<br>Loading<br>(lbs/day) |
|---|---|---------|---------------------------------|
| GENERAL                                       | Dissolved O <sub>2</sub>                    | <0.0    |                                 |
|   | Temperature °C                              | 27.     |                                 |
|   | pH (units)                                  | 7.2     |                                 |
|   | BOD <sub>5</sub>                            | 121.    | 369.                            |
|   | COD   | 209.    | 637.                            |
|   | Total Organic Carbon                        | 54.     | 164.                            |
|   | Oils/Greases (by IR)                        | 20.9    | 64.                             |
|   | Surfactants, MBAS (as LAS)                  | 14.1    | 43.                             |
|   | Total Kjeldahl Nitrogen (as N)              | 22.8    | 71.                             |
| RADICALS                                      | Ammonia, NH <sub>3</sub> (as N)             | 19.2    | 60.                             |
|   | Cyanide, CN                                 | <0.01   | <0.031                          |
|   | Nitrate, NO <sub>3</sub> (as N)             | 0.3     | <0.82                           |
|   | Nitrite, NO <sub>2</sub> (as N)             | <0.005  | <0.017                          |
|   | Phenolics, C <sub>6</sub> H <sub>5</sub> OH | 0.011   | 0.035                           |
|   | Phosphate, Total-PO <sub>4</sub> (as P)     | 8.0     | 25.2                            |
| METALS/IONS                                   | Aluminum                                    | 0.20    | 0.61                            |
|   | Cadmium                                     | <0.01   | <0.03                           |
|   | Chloride                                    | 27.4    | 87.                             |
|   | Chromium, Hexavalent                        | <0.05   | <0.15                           |
|   | Chromium, Total                             | <0.05   | <0.15                           |
|   | Copper                                      | 0.05    | 0.14                            |
|   | Iron  | 0.22    | 0.69                            |
|   | Lead  | <0.05   | <0.15                           |
|   | Manganese                                   | <0.05   | <0.15                           |
|   | Mercury                                     | <0.005  | <0.014                          |
|   | Nickel                                      | <0.05   | <0.15                           |
|   | Silver                                      | <0.01   | 0.031                           |
|   | Zinc  | 0.09    | 0.27                            |

\*Data based on results of Sampling Program, 27 September -  
 7 October 1972. For more detailed results, see Appendix G.

TABLE 3  
 COMPOSITION OF RAW WASTEWATER ENTERING MOODY AFB STP  
 FROM AF FMS 1463  
 Jan-Nov 1973

|                         | 10-90<br>PERCENTILE<br>RANGE | MEAN | 95% CONFIDENCE<br>LIMITS OF MEAN | NUMBER OF DAYS<br>CONSIDERED |
|-------------------------|------------------------------|------|----------------------------------|------------------------------|
| BOD <sub>5</sub> , mg/l | 198-294                      | 244  | 238-250                          | 98                           |
| Suspended Solids, mg/l  | 192-304                      | 252  | 243-261                          | 98                           |
| Settleable Solids, ml/l | 5.0-10.3                     | 7.9  | 7.7-8.1                          | 335                          |
| pH, Units               | 6.8-7.2                      |      | -                                | 335                          |

TABLE 4  
 STP AVERAGE PERFORMANCE  
 FROM AF FMS 1463  
 JAN-NOV 1973  
 MOODY AFB GA

|                   | INFLUENT | EFFLUENT | % REDUCTION IN TREATMENT UNIT 10-90 PERCENTILE | % REDUCTION IN TREATMENT UNIT MEAN | % REDUCTION IN TREATMENT UNIT 95% CONFIDENCE LIMIT OF MEAN | MEAN % REMOVAL OF RAW INFLUENT |
|-------------------|----------|----------|--|------------------------------------|--|--------------------------------|
| PRIMARY CLARIFIER |          |          |  |                                    |  |                                |
| BOD <sub>5</sub>  | 244      | 151      | 26-46  | 38                                 | 36-39  | 38                             |
| Suspended Solids  | 252      | 148      | 34-48  | 41                                 | 40-42  | 41                             |
| Settleable Solids | 7.9      | 0.2      | 96-100   | 98                                 | 97-98  | 98                             |
| TRICKLING FILTER  |          |          |  |                                    |  |                                |
| BOD <sub>5</sub>  | 151      | 33       | 72-84  | 78                                 | 77-79  | 48                             |
| Suspended Solids  | 148      | 35       | 68-82  | 76                                 | 75-77  | 45                             |
| FINAL CLARIFIER   |          |          |  |                                    |  |                                |
| BOD <sub>5</sub>  | 33       | 23       | 16-42  | 30                                 | 28-32  | 4                              |
| Suspended Solids  | 35       | 22       | 16-58  | 35                                 | 33-38  | 5                              |

BOD<sub>5</sub> and suspended solids are in mg/l. Settleable solids are in ml/l.

### c. Overall Secondary Treatment Performance

The trickling filters and final clarifier combined remove 85% of both the BOD<sub>5</sub> and the suspended solids treated by the two units. This unit removal corresponds to 52% removal of the total influent BOD<sub>5</sub> and 50% removal of the total influent suspended solids.

#### 8. Final Effluent

The average composition of the final effluent is displayed in Table 5. The STP achieves better than 90% reduction of both BOD<sub>5</sub> and suspended solids. This performance exceeds the current EPA standards for secondary treatment (85% removal of BOD<sub>5</sub> and suspended solids).

#### 9. Chlorination

Chlorination is currently being performed in a baffled chlorination tank with a residence time of 26 minutes at the design flowrate and 49 minutes at the average flowrate January-November 1973. This is an adequate time for chlorine contact, and exceeds the minimum time of 15 minutes recommended in the WPCF MOP #8. Treatment plant operating logs for October and November 1973 indicate that the chlorine residual in the effluent was between 0.8 and 1.0 mg/l by the ortho tolidine test. Current chlorination practice recommends the use of the amperometric technique for determining chlorine residual<sup>3</sup>. The equipment required is expensive (\$400) but the results are more accurate, and consistently higher (by 2-5 mg/l) than the orthotolidine test. Good control of the chlorination process is essential both for disinfection of the effluent stream and protection of biological life in Beatty Creek, since excessive chlorination can harm the native aquatic life.

#### 10. Sludge Disposal

Waste sludge is pumped to a 28,600 cu. ft. unheated anaerobic digester. This capacity corresponds to 10.6 cu. ft./capita based on the equivalent base population of 2,688 (Nov 1973). The Ten-State Standard for a low rate trickling filter plant is 6-8 cu ft/capita for a northern climate. Less capacity would be required in the warmer southern climate, so the digester is adequately sized. Digested sludge flows by gravity to two sand drying beds. The dried sludge is collected and spread on the grassy areas near the runways to condition and improve the soil.

### C. Industrial Wastewater Sources and Treatment

#### 1. Industrial Wastewater Sources

An industrial waste source survey of Moody AFB was conducted by Moody Environmental Health personnel during February 1974. The results

<sup>3</sup>White, G.C.; Handbook of Chlorination, Van Nostrand Reinhold Company, New York, 1972.

TABLE 5  
 COMPOSITION OF FINAL EFFLUENT, MOODY AFB STP  
 January-November 1973

|                            | NUMBER OF DAYS<br>CONSIDERED | 10-90<br>PERCENTILE<br>RANGE | MEAN  | 95% CONFIDENCE<br>LIMITS ON MEAN | % REDUCTION |
|----------------------------|------------------------------|------------------------------|-------|----------------------------------|-------------|
| BOD <sub>5</sub>           | 98                           | 18-30                        | 23.4  | 23-24                            | 90.4%       |
| Suspended Solids           | 98                           | 16-32                        | 22.4  | 21-24                            | 91.4%       |
| Settleable Solids          | 335                          | -                            | Trace | -                                | ~100%       |
| Total PO <sub>4</sub> As P | 10                           | -                            | 6.7*  | -                                | 16.3%*      |
| NH <sub>4</sub> As N       | 10                           | -                            | 1.09* | -                                | 94%*        |

Concentrations are in mg/l, except for settleable solids which are in ml/L

\*Based on data from sampling during 27 September - 7 October 1972.

are included as Appendix D of this report. The survey indicated that many industrial wastewaters flowed untreated into open or covered storm sewers which drained into the branches and mill races around the base. Identified pollution sources are listed in Table 6. Notable exceptions to the untreated discharge of waste were found in:

- a. Corrosion control facility (Bldg 717) which discharged to the sanitary system.
- b. Film processing agencies which sent process "fixer" solution to redistribution/marketing (R/M) for silver recovery.
- c. Jet engine test stand (Bldg 1700) and vehicular maintenance activities, both of which sent collected oils and hydraulic fluids to R/M.
- d. Motor pool and field maintenance battery shops, which neutralized battery acids before discharging them to storm drains.

## 2. Industrial Waste Discharge

Figure 3 depicts nineteen separate storm sewer outfalls from the base, excluding the housing area. During the preliminary survey in December 1971, four outfalls appeared to carry most of the industrial waste loads. These are noted in Figure 3 as sites R-2, R-3, R-5 and R-6. In the survey conducted by Moody personnel (27 Sep - 7 Oct 1972) two additional drainage locations were sampled, R-1, on the line draining the car wash area, and R-4, the overflow from Mission Lake. Average results of the survey are presented in Table 7. Station R-1 had elevated surfactants and BOD<sub>5</sub>, probably from the car wash area. Station R-2 had high concentrations of pollutants typical of shop discharges. Station R-3 had high surfactants. Station R-4 at the discharge end of Mission Lake revealed that some treatment for the surfactant discharges is provided by the lake. Station R-5 is typical of clean storm water. Analysis of samples from Station R-6, the headwaters of Beatty Creek, indicates that dissolved iron enters the stream from its underground sources.

## 3. Correction of Industrial Wastewater Discharge

Since the industrial waste source survey of February 1974, plans have been prepared to eliminate the discharge of pollutants to the storm sewer system. Specific alterations are included in Table 6. The net effect of these changes will be to connect the industrial waste discharges to the sanitary system for treatment before discharge. The biological processes of the STP should be able to remove most of the organic components of the industrial waste without any ill effect on the trickling filters. Some of the metal ions will be used in biological growth while the remainder will be adequately diluted by the much larger sanitary sewage flow, 0.015 MGD Vs. 0.393 MGD, or an average dilution of 1 to 26. The projects to eliminate dis-

TABLE 6  
IDENTIFIED INDUSTRIAL WASTEWATER SOURCES  
Moody AFB GA

| Source of Discharge   | Plan for Elimination   |
|---|--|
| 1. Aircraft Washrack, Bldg 754<br>2. Aircraft Parts Maintenance, Bldg 758<br>3. Aircraft Paint Hanger, Bldg 717<br>4. Auto Hobby Shop, Bldg 841<br>5. Auto Washrack, Bldg 973<br>6. Fire Truck Wash Area, Bldg 621<br>7. POL Storage Area, Bldg 722 | Connect each discharge to the sanitary sewer system through its own oil/water/solids separator. The oil and solids will be removed on a routine basis. |
| 8. Base Exchange Service Station, Bldg 943  | Contain discharge in a storage tank, which will be pumped out by a disposal contractor.  |
| 9. Boiler Blowdown, Bldg 900  | Connect discharge from existing separator to the sanitary sewer system.  |




FIGURE 3 STORM DRAINAGE SYSTEM, MOODY AFB GA

Table 7  
Average Storm Sewer Discharge Composition  
27 Sep-7 Oct 1972  
Moody AFB GA

| Chemical/Physical Data (mg/l unless noted)  | Sampling Station |        |        |         |         |        |
|---|------------------|--------|--------|---------|---------|--------|
|   | R1               | R2     | R3     | R4      | R5      | R6     |
| Dissolved O <sub>2</sub>                    | 4.4              | <0.0   | 5.8    | 3.3     | 5.3     | 5.3    |
| Temperature °C                              | 26.              | 26.    | 26.    | 27.     | 25.     | 25.    |
| pH (units)                                  | 7.4              | 6.1    | 6.0    | 6.7     | 6.4     | 6.5    |
| Flow (GD)                                   | 5133.            | 8326.  | 2244.  | No Flow | No Flow | 3843.  |
| BOD <sub>5</sub>                            | 42.              | 275.   | <12.   | <12.    | <12.    | <12.   |
| COD   | 170.             | 706.   | 20.    | 46.     | 21.     | 11.    |
| Total Organic Carbon                        | 34.              | 180.   | 5.     | 12.     | 6.      | 2.     |
| Oils/Greases (by IR)                        | 3.9              | 8.1    | 0.8    | 1.3     | 0.6     | 0.8    |
| Surfactants, MBAS (as LAS)                  | 13.7             | 4.0    | 4.3    | 0.3     | 0.5     | 0.3    |
| Total Kjeldahl Nitrogen (as N)              | 1.10             | 8.56   | 0.65   | 1.18    | 0.39    | 1.05   |
| Ammonia, NH <sub>3</sub> (as N)             | 0.40             | 4.90   | 0.12   | 0.27    | 0.09    | 0.81   |
| Cyanide, CN                                 |                  | <0.01  | <0.01  | <0.01   | <0.01   | <0.01  |
| Nitrate, NO <sub>3</sub> (as N)             | <0.2             | 0.3    | <0.2   | <0.2    | 0.64    | 0.42   |
| Nitrite, NO <sub>2</sub> (as N)             | <0.005           | <0.005 | <0.005 | <0.005  | <0.005  | 0.014  |
| Phenolics, C <sub>6</sub> H <sub>5</sub> OH |                  | 0.109  | <0.006 | <0.005  | 0.006   | 0.004  |
| Phosphate, Total-PO <sub>4</sub> (as P)     | 2.5              | 6.1    | 0.3    | 0.1     | <0.1    | 0.1    |
| Aluminum                                    | 0.41             | 0.74   | 0.13   | 0.14    | 0.15    | 0.1    |
| Cadmium                                     | <0.01            | <0.01  | <0.01  | <0.01   | <0.01   | <0.01  |
| Chloride                                    |                  |        |        | 21.     | 14.     | 20.    |
| Chromium, Hexavalent                        | <0.05            | <0.05  | <0.05  | <0.05   | <0.05   | <0.05  |
| Chromium, Total                             | <0.05            | <0.05  | <0.05  | <0.05   | <0.05   | <0.05  |
| Copper                                      | <0.02            | <0.02  | <0.02  | <0.02   | <0.02   | <0.02  |
| Iron  | 0.49             | 3.86   | 0.17   | 0.58    | 0.10    | 2.45   |
| Lead  | <0.05            | <0.05  | <0.05  | <0.05   | <0.05   | <0.05  |
| Manganese                                   | <0.05            | 0.13   | <0.05  | 0.09    | <0.05   | <0.05  |
| Mercury                                     | <0.005           | <0.005 | <0.005 | <0.005  | <0.005  | <0.005 |
| Nickel                                      | <0.05            | <0.05  | <0.05  | <0.05   | <0.05   | <0.05  |
| Silver                                      | <0.01            | <0.01  | <0.01  | <0.01   | <0.01   | <0.01  |
| Zinc  | 3.66             | <0.05  | <0.05  | <0.05   | <0.05   | <0.05  |

charge of untreated industrial waste to the storm drainage system should be completed as soon as possible. In addition to connection of certain drains to the sanitary collection system, procedures should be instituted to prevent the introduction of solid industrial materials into water solution and/or suspension.

#### D. National Pollutant Discharge Elimination System (NPDES) Permit

##### 1. Permit Development

Moody AFB has been granted an NPDES permit, #GA0020001, to discharge water from the STP to Beatty Creek and thence to the Withlacoochee River. A copy of this permit is included as Appendix H of this report. Table 8 indicates the current average STP effluent composition and the limitations required by the NPDES permit for both an interim period, until 30 June 1977, and a final period beginning on 1 July 1977 and lasting to the expiration date of the permit, 30 June 1979. The interim limits are based on secondary sewage treatment standards. The final effluent limitations placed on the discharge by the permit are based on the classification of the river and all of its tributaries for fishing and propagation of warm water fish. The main objective of the permit discharge limitations is to avoid the lowering of the dissolved oxygen at any point in the stream below a minimum of 4.0 mg/l. The Moody STP discharge contains three components which affect the dissolved oxygen of the receiving stream, namely BOD<sub>5</sub>, ammonia nitrogen, and dissolved oxygen. The Region IV of the U.S. EPA at Atlanta, Georgia used a computer program based on the "Manhattan Model" of the Streeter-Phelps dissolved oxygen sag equation to determine effluent limitations for these three components. The program indicated that the accepted normal EPA effluent values of 30 mg/l BOD<sub>5</sub>, 13-18 mg/l ammonia nitrogen, and no minimum effluent dissolved oxygen would not be adequate to avoid a downstream dissolved oxygen deficiency during the most stringent case of a seven day 10 year minimum flow of zero in the receiving stream and a discharge from the Moody STP at the plant's design capacity of 0.750 MGD. These stringent conditions are equivalent to requiring that the plant effluent itself support the propagation of fish. Several other combinations of effluent limitations were tried in the computer program before the values listed in Table 8 for BOD<sub>5</sub>, ammonia nitrogen, and effluent dissolved oxygen (Final Limits) were found to maintain the required dissolved oxygen at all points of Beatty Creek. This combination of effluent restrictions is not the only one that would satisfy the stream dissolved oxygen requirement. For example the effluent ammonia nitrogen level could be raised but this would require either a corresponding decrease in the effluent BOD<sub>5</sub> concentration or an increase in the effluent dissolved oxygen concentration or a combination of the two to preserve the minimum stream dissolved oxygen standard.

##### 2. Permit Compliance

Comparison of the values indicates that the Moody STP is presently meeting all the interim limits on both a concentration and a weight

TABLE 8  
COMPARISON OF MOODY STP DISCHARGE  
WITH NPDES PERMIT LIMITS

|                                  | PRESENT<br>PLANT<br>EFFLUENT* | INTERIM<br>LIMITS**<br>UNTIL<br>30 JUN 77 | FINAL<br>LIMITS**<br>1 JUL ,7<br>30 JUN 79 |
|----------------------------------|-------------------------------|---|--|
| Flow, MGD                        | 0.393                         | 0.750                                     | 0.750                                      |
| Concentration                    |                               |   |  |
| BOD <sub>5</sub> , mg/l          | 23.4                          | 30.                                       | 15.  |
| Ammonia Nitrogen, mg N/l         | 1.09†                         | -   | 2.0  |
| Dissolved Oxygen, mg/l           | -                             | -   | 6.0  |
| Suspended Solids, mg/l           | 22.4                          | 30.                                       | 30.  |
| pH Range: Minimum                | 6.8                           | 6.0                                       | 6.0  |
| Maximum                          | 7.2                           | 9.0                                       | 9.0  |
| Fecal Coliform, counts/100 ml †† | -                             | 200                                       | 200  |
| Mass Loading                     |                               |   |  |
| BOD <sub>5</sub> , lb/day        | 76.8                          | 188                                       | 93   |
| Ammonia Nitrogen, lb N/day       | 3.58                          | -   | 12.5                                       |
| Suspended Solids, lb/day         | 73.5                          | 188                                       | 188  |

\*Average Based on AF Fms 1462 and 1463, January-November 1973

\*\*Monthly Average

†Average Based on Survey Data, 27 September - 7 October 1972

††Monthly Geometric Mean

of pollutant basis. The plant does not presently meet the final concentration limits for BOD<sub>5</sub>, and may not meet the concentration limits for ammonia nitrogen and dissolved oxygen, since there is no treatment unit at the plant specifically designed for control of these latter two parameters. The final weight of pollutant limits for both BOD<sub>5</sub> and ammonia nitrogen are readily met by the plant discharge. This achievement can be attributed to the fact the the average plant flowrate is only 0.393 MGD, or 52% of the design flowrate of 0.750 MGD.

### 3. Suggested Modifications to Assure Compliance

The Moody STP is a well-run secondary treatment plant that already achieves over 90% reduction of both BOD<sub>5</sub> and suspended solids. Further removals of BOD<sub>5</sub> and ammonia, and addition of dissolved oxygen to meet the 1 July 1977 final limits of the permit will not be possible with the present facility. The plant will require upgrading by chemical addition to the existing clarifiers and/or an additional treatment unit (tertiary treatment) to further treat the effluent from the final clarifier. There are many possible processes that could be used to remove BOD<sub>5</sub> and ammonia, and add dissolved oxygen, e.g., aeration, foam flotation, ultrafiltration, etc. Pilot plant studies with the Moody effluent will be required to determine the most suitable processes. The goal should be to choose a single process, either one that will enable the plant to meet all of the 1977 limits, or one that will achieve an excellent level of one of the parameters in the effluent, i.e. very low BOD<sub>5</sub>, very low ammonia or very high dissolved oxygen. Then the final limits of the permit could be made less stringent for the other two parameters in light of the interrelated effect of the three parameters on the dissolved oxygen in the receiving stream.

### 4. Documentation of Stream Conditions

The final effluent limits contained in the Moody NPDES permit are based on a computer projection of the effect of discharge of the full design flowrate of the STP, 0.750 MGD, on the receiving waters. Since the plant is normally operated at an average flowrate of 0.393 MGD, the projection may not be entirely valid. A stream dissolved oxygen survey would document the effects of the STP discharge on the receiving waters, and should be accomplished before any plant modifications are planned or started.

### E. Monitoring Program

A recommended monitoring program for the storm and treated sanitary discharges of Moody AFB is included with this report as Appendix F. Quarterly sampling for the first two years followed by semi-annual (Spring and Fall) sampling should be adequate to both detect any unusual discharges from the base and to build up a history of good performance. This sampling program is in addition to the monitoring program required by the base's NPDES permit.

#### IV. CONCLUSIONS

1. The Moody AFB STP is a well run low-rate trickling filter plant, achieving over 90% reduction of BOD<sub>5</sub> and 91% reduction of suspended solids.

2. The plant should meet the interim provisions of the NPDES permit which are based on secondary treatment requirements. In addition, the plant should have little problem meeting the 1 July 77 final limits in term of total lbs/day since the plant is being operated at 52 percent of design flow while the discharge limitations are based on the full design flow of 0.750 MGD. Additional facilities for BOD<sub>5</sub> removal, ammonia-nitrogen removal and dissolved oxygen augmentation will be required to meet the final concentration limits specified in the NPDES permit.

3. Several sources of industrial waste discharge to the storm sewer system have been identified. Current planning is to install oil/water/solids separators and pipes to connect these streams to the sanitary system.

## V. RECOMMENDATIONS

1. An effort should be made to reduce or eliminate the amount of solid industrial material that can get into water and become a water pollution problem.

2. Those industrial wastes which by their very nature are liquid and for which there is no market for recovery, recycle or separate disposal should be transported to the sanitary sewage treatment plant for treatment before discharge, if such treatment is compatible with good operation of the treatment plant.

3. The identified industrial waste streams that are currently discharging to storm sewers should be connected to the sanitary sewer system as rapidly as possible.

4. A stream dissolved oxygen survey of Beatty Creek should be conducted to determine the effect of the Moody STP effluent on the stream and verify the EPA permit requirements for 1977. This survey should be scheduled to follow completion of the project to connect the identified industrial waste streams to the sanitary treatment system.

5. An amperometric titration unit should be procured and used to determine the chlorine residual in the effluent from the STP.

6. The monitoring program of Appendix F should be conducted quarterly for two years, and then semi-annually thereafter.

APPENDIX A  
Authorization For Survey

*Banowsky*  
DEPARTMENT OF THE AIR FORCE  
HQ. 3550th PILOT TRAINING WING (ATC)  
MOODY AIR FORCE BASE, GEORGIA 31601



REPLY TO: DEMC/Lt Stauffer/3722  
ATTN OF:

7 October 1971

SUBJECT: Survey of Sewage Treatment Plant and Storm Drainage System

TO: ATC/DEMU/Mr. Banowsky

1. Request that a Environmental Health Lab Team be provided to survey the sewage treatment plant system, storm drainage system and plant operators lab procedures at Moody AFB. Survey results would be used to determine whether or not the sewage treatment plant is adequate to handle an additional load, and the chemicals contained therein, from the aircraft washracks and the vehicle washracks.
2. The present sewage treatment plant is designed for handling .750 MGD.
3. Two hundred additional MFH units are being constructed. The anticipated date for full occupancy is 1 September 1972.
4. Copies of the analysis performed on the grab samples taken from the storm drainage system and a map of the system showing the locations where the samples were taken are attached for your review and comments.

FOR THE COMMANDER

*William D. Thompson*  
WILLIAM D. THOMPSON, Major, USAF  
Base Civil Engineer

- 2 Atch  
1. Analysis  
2. Map

DEPARTMENT OF THE AIR FORCE  
HEADQUARTERS AIR TRAINING COMMAND  
RANDOLPH AIR FORCE BASE, TEXAS 78148



18 OCT 1971

REPLY TO  
ATTN OF DEMU

SUBJECT Environmental Survey

TO SG

1. Moody AFB has requested that their sewage treatment and storm drainage systems be surveyed in the attached letter to DEMU, dated 7 Oct 71.
2. This request is in accordance with AFR 161-22.

1 Atch  
Moody/DEMC Ltr, 7 Oct 71

A handwritten signature in cursive script, appearing to read "Gerald J. Newlin".

GERALD J. NEWLIN, Lt Col, USAF  
Chief, Utilization Division  
Dir, Ops & Maint, DCS/CE

DEPARTMENT OF THE AIR FORCE  
HEADQUARTERS AIR TRAINING COMMAND  
RANDOLPH AIR FORCE BASE, TEXAS 78148



19 OCT 1971

REPLY TO  
ATTN OF:

SGPAAP

SUBJECT:

Environmental Pollution Survey

TO:

AFLC/SGPE  
Wright-Patterson AFB, OH 45433

Request personnel from the USAF Environmental Health Laboratory at Kelly AFB, Texas, accomplish an environmental pollution survey at Moody AFB, Georgia (see attachments 1 & 2).

FOR THE COMMANDER

A handwritten signature in cursive script, appearing to read "Doyce B. Dees, Jr.", is written over the typed name.

DOYCE B. DEES, JR., Colonel, USAF, MC  
Assistant Surgeon

2 Atch  
1. ATC/DEMU Ltr,  
18 Oct 1971  
2. Moody/DEMC Ltr,  
7 Oct 1971 w/ atch

Info Cy: ATC/DEMU  
w/o atch

DEPARTMENT OF THE AIR FORCE  
HEADQUARTERS AIR FORCE LOGISTICS COMMAND  
WRIGHT-PATTERSON AIR FORCE BASE, OHIO 45433



REPLY TO  
ATTN OF SGP

21 Oct 1971

SUBJECT Environmental Pollution Survey

TO USAFERHL, Kelly/CC

The attached request is forwarded for your action.

FOR THE COMMANDER


A handwritten signature in dark ink, appearing to read "Harold W. Dietz", is written over the typed name.

HAROLD W. DIETZ, Colonel, USAF, MC  
Deputy Surgeon

1 Atch  
ATC/SGPAAP ltr, 19 Oct 71,  
w/2 atch

Cy to:  
ATC/SGPAAP/DEMU

APPENDIX B  
WATER USE CLASSIFICATIONS  
AND  
WATER QUALITY CRITERIA  
FOR THE  
STATE OF GEORGIA



Department of Natural Resources  
Environmental Protection Division



Region IV, May, 1974

Atlanta, Georgia

## TABLE OF CONTENTS

|                                      | <u>Pages</u> |
|--------------------------------------|--------------|
| <u>Water Quality Criteria</u> .....  | 1-8          |
| <u>Stream Classifications</u> .....  | 9            |
| General Classifications.....         | 10           |
| Savannah River Basin.....            | 11           |
| Ogeechee River Basin.....            | 11, 12       |
| Oconee River Basin.....              | 12, 13       |
| Upper Ocmulgee River Basin.....      | 13, 14       |
| Lower Ocmulgee River Basin.....      | 14           |
| Altamaha River Basin.....            | 15           |
| Satilla River Basin.....             | 15, 16       |
| St. Marys River Basin.....           | 16           |
| Suwannee River Basin.....            | 16           |
| Ochlocknee River Basin.....          | 16, 17       |
| Flint River Basin.....               | 17           |
| Chattahoochee River Basin.....       | 18, 19       |
| Tallapoosa River Basin.....          | 19           |
| Coosa River Basin.....               | 19, 20, 21   |
| Tennessee River Basin.....           | 21, 22       |
| <u>River Basins of Georgia</u> ..... | 23           |

AUGUST 1972

RULES  
OF  
STATE WATER QUALITY CONTROL BOARD

CHAPTER 730-3  
WATER USE CLASSIFICATIONS AND  
WATER QUALITY STANDARDS \*

TABLE OF CONTENTS

|  |                                  |
|--|----------------------------------|
| 730-3-.01 Purpose                                      | 730-3-.07 Natural Water Quality  |
| 730-3-.02 Water Quality Enhancement                    | 730-3-.08 Treatment Requirements |
| 730-3-.03 Definitions                                  | 730-3-.09 Streamflows            |
| 730-3-.04 Water Use Classifications                    | 730-3-.10 Mixing Zone            |
| 730-3-.05 General Criteria for All Waters              | 730-3-.11 Effective Date         |
| 730-3-.06 Specific Criteria for Classified Water Usage |                                  |

730-3-.01 PURPOSE - *The establishment of water quality standards.*

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.02 WATER QUALITY ENHANCEMENT - *The purposes and intent of the Board in establishing Water Quality Standards are to provide enhancement of water quality and prevention of pollution; to protect the public health or welfare in accordance with the public interest for drinking water supplies, conservation of fish, game and other beneficial aquatic life, and agricultural, industrial, recreational, and other beneficial uses.*

*Those waters in the State whose existing quality is better than the minimum levels established in standards on the date standards become effective will be maintained at high quality; with the Board having the power to authorize new developments, when it has been affirmatively demonstrated to the Board that a change is justifiable to provide necessary social or economic development; and provided further that the level of treatment required is the highest and best practicable under existing technology to protect existing beneficial water uses.*

*In applying these policies and requirements, the State of Georgia will recognize and protect the interest of the Federal Govern-*

ment in interstate (including coastal and estuarine) waters. Toward this end the Board will consult and cooperate with the Environmental Protection Agency on all matters affecting the Federal interest.

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.03 DEFINITIONS - All terms used in this rule shall be interpreted in accordance with definitions as set forth in the Act and as otherwise herein defined.

(1) "Reasonable and necessary uses" means drinking water supplies, conservation of fish, game and other aquatic life, agricultural, industrial, recreational, and other legitimate uses.

(2) "Shellfish" refers to clams, oysters, scallops, mussels, and other mollusks.

(3) "Intake temperature" is the natural or background temperature of a particular waterbody unaffected by any man-made discharge or thermal input.

(4) "Coastal waters" are those littoral recreational waters on the ocean side of the Georgia coast.

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.04 WATER USE CLASSIFICATIONS - Water use classifications for which the criteria of this rule are applicable are as follows:

- (1) Drinking Water Supplies
- (2) Recreation
- (3) Fishing, propagation of Fish, Shellfish, Game and Other Aquatic Life
- (4) Agricultural
- (5) Industrial
- (6) Navigation
- (7) Wild River
- (8) Scenic River
- (9) Urban Stream

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.05 GENERAL CRITERIA FOR ALL WATERS - The following criteria are deemed to be necessary and applicable to all waters of the State:

(1) All waters shall be free from materials associated with municipal or domestic sewage, industrial waste or any other waste which will settle to form sludge deposits that become putrescent, unsightly or otherwise objectionable.

(2) All waters shall be free from oil, scum and floating debris associated with municipal or domestic sewage, industrial waste or other discharges in amounts sufficient to be unsightly or to interfere with legitimate water uses.

(3) All waters shall be free from material related to municipal,

industrial or other discharges which produce turbidity, color, odor or other objectionable conditions which interfere with legitimate water uses.

(4) All waters shall be free from toxic, corrosive, acidic and caustic substances discharged from municipalities, industries or other sources in amounts, concentrations or combinations which are harmful to humans, animals or aquatic life.

(5) *Applicable State and Federal requirements and regulations for the discharge of radioactive substances shall be met at all times.*

(6) *No man-made physical or other alteration of stream beds that may violate established water quality standards, or reduce the waste assimilative capacity of the streams, will be permitted without the express approval of this Board.*

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.06 SPECIFIC CRITERIA FOR CLASSIFIED WATER USAGE - The following criteria are deemed necessary and shall be required for the specific water usage as shown:

(1) Drinking Water Supplies -

(a) Those waters approved by the Georgia Department of Public Health and requiring only approved disinfection and meeting the requirements of the latest edition of "Public Health Service Drinking Water Standards"; or waters approved by the Georgia Department of Public Health for human consumption and food-processing or for any other use requiring water of a lower quality.

1. *Bacteria: Fecal coliform not to exceed a geometric mean of 50 per 100 ml based on at least four samples taken over a 30-day period and not to exceed 200 per 100 ml in more than five percent of the samples in any 90-day period.*

2. *Floating solids, settleable solids, sludge deposits or any taste, odor or color producing substances: None associated with any waste discharge.*

3. *Sewage, industrial or other wastes: None.*

(b) Those raw water supplies requiring approved treatment to meet the requirements of the Georgia Department of Public Health and the latest edition of "Public Health Service Drinking Water Standards" or which are approved by the Georgia Department of Public Health for human consumption and food-processing; or for any other use requiring water of a lower quality.

1. **Bacteria:** Fecal coliform not to exceed a geometric mean of 1,000 per 100 ml based on at least four samples taken over a 30-day period and not exceed a maximum of 4,000 per 100 ml.
2. **Dissolved Oxygen:** A daily average of 6.0 mg/l and no less than 5.0 mg/l at all times for waters designated as trout streams by the State Game and Fish Commission. A daily average of 5.0 mg/l and no less than 4.0 mg/l at all times for waters supporting warm water species of fish.
3. **pH:** Within the range of 6.0 - 8.5.
4. **No material or substance in such concentration that, after treatment, would exceed the requirements of the Georgia Department of Public Health and the latest edition of "Public Health Service Drinking Water Standards."**
5. **Temperature:** Not to exceed 90°F. At no time is the temperature of the receiving waters to be increased more than 5°F above intake temperature except that in estuarine waters the increase will not be more than 1.5°F. In streams designated as trout or smallmouth bass waters by the State Game and Fish Commission, there shall be no elevation or depression of natural stream temperatures.

(2) Recreation -

General recreational activities such as water skiing, boating, and swimming, or for any other use requiring water of a lower quality. These criteria are not to be interpreted as condoning water contact sports in proximity to sewage or industrial waste discharges regardless of treatment requirements.

(a) **Bacteria:** Fecal Coliform not to exceed a geometric mean of:

- (1) Coastal Waters - 100 per 100 ml
- (2) All other recreational waters - 200 per 100 ml
- (3) Should water quality and sanitary studies show natural fecal coliform levels exceed 200/100 ml (geometric mean) occasionally in high quality recreational waters, then the allowable geometric mean fecal coliform level shall not exceed 300 per 100 ml in lakes and reservoirs and 500 per 100 ml in free flowing fresh water streams.

The geometric mean will be used as the method of criteria expression. This technique will be applied to no less than four samples collected from a given sampling site over a 30-day period at intervals not less than 24 hours.

- (b) **Dissolved Oxygen:** A daily average of 6.0 mg/l and no less than 5.0 mg/l at all times for waters designated as trout streams by the State Game and Fish Commission. A daily average of 5.0 mg/l and no less than 4.0 mg/l at all times for waters supporting warm water species of fish.

- (c) pH: Within the range of 6.0 - 8.5.
  - (d) Toxic Wastes, Other Deleterious Materials: None in concentrations that would harm man, fish and game or other beneficial aquatic life.
  - (e) *Temperature: Not to exceed 90°F. At no time is the temperature of the receiving waters to be increased more than 5°F above intake temperature except that in estuarine waters the increase will not be more than 1.5°F. In streams designated as trout or smallmouth bass waters by the State Game and Fish Commission, there shall be no elevation or depression of natural stream temperatures.*
- (3) Fishing, Propagation of Fish, Shellfish, Game and Other Aquatic Life; or for any other use requiring water of a lower quality.
- (a) *Dissolved Oxygen: A daily average of 6.0 mg/l and no less than 5.0 mg/l at all times for waters designated as trout streams by the State Game and Fish Commission. A daily average of 5.0 mg/l and no less than 4.0 mg/l at all times for waters supporting warm water species of fish.*
  - (b) pH: Within the range of 6.0 - 8.5.
  - (c) *Bacteria: Fecal Coliform not to exceed a geometric mean of 1,000 per 100 ml based on at least four samples taken over a 30-day period and not exceed a maximum of 4,000 per 100 ml.*
  - (d) *Bacteria: (Applicable only to waters designated as approved shellfish harvesting waters by the appropriate State agencies) The requirements will be consistent with those established by the State and Federal agencies responsible for the National Shellfish Sanitation Program.*
  - (e) *Temperature: Not to exceed 90°F. At no time is the temperature of the receiving waters to be increased more than 5°F above intake temperature except that in estuarine waters the increase will not be more than 1.5°F. In streams designated as trout or smallmouth bass waters by the State Game and Fish Commission, there shall be no elevation or depression of natural stream temperatures.*
  - (f) Toxic Wastes, Other Deleterious Materials: None in concentrations that would harm man, fish and game or other beneficial aquatic life.
- (4) Agricultural -

For general agricultural uses such as stock watering and irrigating; or for any other use requiring water of a lower quality.

- (a) *Bacteria: Fecal coliform not to exceed a geometric mean of 5,000 per 100 ml based on at least four samples taken over a 30-day period.*
- (b) *Dissolved Oxygen: No less than 3.0 mg/l at any time.*
- (c) *pH: Within the range of 6.0 - 8.5.*
- (d) *Temperature: Not to exceed 90°F. At no time is the temperature of the receiving waters to be increased more than 5°F above intake temperature except that in estuarine waters the increase will not be more than 1.5°F. In streams designated as trout or smallmouth bass waters by the State Game and Fish Commission, there shall be no elevation or depression of natural stream temperatures.*
- (e) *Toxic Substances, Other Deleterious Materials: None in concentrations that would interfere with or adversely affect uses for general agricultural purposes or would prevent fish survival.*

(5) Industrial -

For processing and cooling water with or without special treatment; or for any other use requiring water of a lower quality.

- (a) *Dissolved Oxygen: No less than 3.0 mg/l at any time*
- (b) *pH: Within the range of 6.0 - 8.5.*
- (c) *Toxic Substances, Other Deleterious Materials: None in concentrations that would prevent fish survival or interfere with legitimate and beneficial industrial uses.*
- (d) *Temperature: Not to exceed 90°F. At no time is the temperature of the receiving waters to be increased more than 5°F above intake temperature except that in estuarine waters the increase will not be more than 1.5°F. In streams designated as trout or smallmouth bass waters by the State Game and Fish Commission, there shall be no elevation or depression of natural stream temperatures.*

(6) Navigation -

To provide for commercial ship traffic and protection of seamen or crews.

- (a) *Bacteria: Fecal coliform not to exceed a geometric mean of 5,000 per 100 ml based on at least four samples taken over a 30-day period.*
- (b) *Dissolved Oxygen: No less than 3.0 mg/l at any time.*

(c) pH: Within the range of 6.0 - 8.5.

(d) Toxic Substances, Other Deleterious Materials: None in concentrations that would damage vessels, prevent fish survival or otherwise interfere with commercial navigation.

(e) Temperature: Not to exceed 90°F. At no time in the temperature of the receiving waters to be increased more than 5°F above intake temperature except that in estuarine waters the increase will not be more than 1.5°F. In streams designated as trout or smallmouth bass waters by the State Game and Fish Commission, there shall be no elevation or depression of natural stream temperatures.

(7) Wild River -

This classification will be applicable to any waters of the State when so designated by an authorized State or Federal Agency and will be effective simultaneously with that Agency's proper designation.

For all waters designated as "Wild River", there shall be no alteration of natural water quality from any source.

(8) Scenic River -

This classification will be applicable to any waters of the State when so designated by an authorized State or Federal Agency and will be effective simultaneously with that Agency's proper designation.

For all waters designated as "Scenic River", there shall be no alteration of natural water quality from any source.

(9) Urban Stream -

This classification is applicable to streams in highly developed urban areas.

(a) All conditions specified under "GENERAL CRITERIA FOR ALL WATERS" (730-3-.05) will apply, and in addition, the waters so classified are to be aesthetically compatible to adjacent areas.

(b) Bacteria: Fecal coliform not to exceed a geometric mean of 2,000 per 100 ml based on at least four samples taken over a 30-day period and not to exceed a maximum of 5,000 per 100 ml.

(c) pH: Within the range of 6.0 - 8.5.

(1) *Dissolved Oxygen: No less than 3.0 mg/l at any time.*

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.07 *NATURAL WATER QUALITY - It is recognized that certain natural waters of the State may have a quality that will not be within the general or specific requirements contained herein.*

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.08 *TREATMENT REQUIREMENTS - Notwithstanding the above criteria, the requirements of the Board relating to secondary or equivalent treatment for all waste shall prevail. The adoption of these criteria shall in no way preempt the treatment requirements.*

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.09 *STREAMFLOWS - Specific criteria or standards set for the various parameters apply to all flows on regulated streams. On unregulated streams, they shall apply to all streamflows equal to or exceeding the 7-day, 10-year minimum flow.*

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.10 *MIXING ZONE - Effluents released to streams or impounded waters shall be fully and homogeneously dispersed and mixed insofar as practical with the main flow or water body by appropriate methods at the discharge point. Use of a reasonable and limited mixing zone may be permitted on receipt of satisfactory evidence that such a zone is necessary and that it will not create an objectionable or damaging pollution condition.*

Authority: Ga. Laws 1964, p. 416, as amended.

730-3-.11 *EFFECTIVE DATE - This Chapter shall become effective on*

\_\_\_\_\_  
Authority: Ga. Laws 1964, p. 416, as amended.

CLASSIFICATIONS FOR WATERS

IN THE STATE OF GEORGIA



JOE D. TANNER  
Commissioner

# Department of Natural Resources

ENVIRONMENTAL PROTECTION DIVISION  
47 TRINITY AVENUE, S.W.  
ATLANTA, GEORGIA 30334

R. S. HOWARD, JR.  
Division Director

January 8, 1974

## PROPOSED ADDITIONAL CLASSIFICATIONS FOR THE WATERS OF THE STATE OF GEORGIA

### Stream Categories

Streams and stream reaches not listed below for specific classifications, either existing or proposed, will fit into the following categorical classifications:

- A. Streams and stream reaches which are not shown on the Georgia Department of Transportation's official county maps are not classified unless they receive a wastewater discharge. In that case, they are classified as fishing.
- B. Streams and stream reaches which are shown as naturally intermittent, ephemeral or a combination thereof on the Georgia Department of Transportation's official county maps or which can be documented as being intermittent by records of the United States Geological Survey are not classified unless they receive a wastewater discharge. In that case, they are classified as fishing.
- C. Stream channels, drainage ditches and canals which are naturally intermittent, ephemeral or a combination thereof are not classified.
- D. Streams and stream reaches not specifically classified below (existing or proposed) and not categorically classified above (A, B, or C) are classified as fishing.

CLASSIFICATIONS FOR THE WATERS  
OF THE STATE OF GEORGIA

May, 1974

| <u>SAVANNAH RIVER BASIN</u>                 |   | <u>CLASSIFICATION</u> |
|---|---|-----------------------|
| Savannah River                              | Georgia-North Carolina State Line to Clark Hill Dam (Mile 238)            | Recreation            |
| Savannah River                              | Clark Hill Dam (Mile 238) to Augusta, 13th Street Bridge                  | Drinking Water        |
| Savannah River                              | Augusta, 13th Street Bridge to U.S. Hwy. 301 Bridge (Mile 129)            | Fishing               |
| Butler Creek<br>(and its tributaries)       | Headwaters in Augusta to confluence with Savannah River                   | Urban                 |
| Cason's Dead River<br>(and its tributaries) | Headwaters in Augusta to confluence with Savannah River                   | Urban                 |
| Savannah River                              | U.S. Hwy. 301 Bridge (Mile 129) to U.S. Hwy. 17 Bridge (Mile 22)          | Drinking Water        |
| Savannah River                              | U.S. Hwy. 17 Bridge (Mile 22) to Field's Cut (Mile 5)                     | Industrial Navigation |
| Savannah River                              | Field's Cut (Mile 5) to Fort Pulaski (Mile 0)                             | Fishing               |
| Savannah River                              | Fort Pulaski (Mile 0) to Open Sea and all littoral waters of Tybee Island | Recreation            |

| <u>OGEECHEE RIVER BASIN</u> |  | <u>CLASSIFICATION</u> |
|-----------------------------|--|-----------------------|
| Ogeechee River              | Headwaters to U.S. Hwy. 80 Bridge          | Fishing               |
| Ogeechee River              | U.S. Hwy. 80 Bridge to U.S. Hwy. 17 Bridge | Fishing               |

|                       |  |            |
|-----------------------|--|------------|
| Ogeechee River        | U.S. Hwy. 17 Bridge to Open Sea and littoral waters of Skidaway, Ossabaw, Sapelo and St. Catherines Islands            | Recreation |
| Little Ogeechee River | Headwaters to U.S. Hwy. 80 Bridge  | Fishing    |
| Little Ogeechee River | U.S. Hwy. 80 Bridge to South End of White Bluff Road near Carmelite Monastery  | Fishing    |
| Little Ogeechee River | South End of White Bluff Road near Carmelite Monastery to Open Sea and littoral waters of Skidaway and Ossabaw Islands | Recreation |

OCONEE RIVER BASIN

CLASSIFICATION

|                     |   |                |
|---------------------|---|----------------|
| Middle Oconee River | Headwaters to Georgia Hwy. 82   | Fishing        |
| Middle Oconee River | Georgia Hwy. 82 to U.S. Hwy. 78   | Drinking Water |
| Middle Oconee River | U.S. Hwy. 78 to confluence with North Oconee River                      | Fishing        |
| North Oconee River  | Headwaters to State Route 2434  | Fishing        |
| North Oconee River  | State Route 2434 to Athens Water Intake                                 | Drinking Water |
| North Oconee River  | Athens Water Intake to confluence with Middle Oconee River              | Fishing        |
| Trail Creek         | Headwaters in Athens to confluence with N.Oconee River                  | Urban          |
| Oconee River        | From confluence of North and Middle Oconee Rivers to Georgia Highway 16 | Fishing        |
| Oconee River        | Georgia Highway 16 to Sinclair Dam                                      | Recreation     |

|              |   |                |
|--------------|---|----------------|
| Oconee River | Sinclair Dam to Georgia Hwy.22                | Drinking Water |
| Oconee River | Georgia Hwy. 22 to Georgia Highway 57         | Fishing        |
| Oconee River | Georgia Hwy. 57 to U.S Hwy.80                 | Drinking Water |
| Oconee River | U.S. Hwy.80 to confluence with Ocmulgee River | Fishing        |

UPPER OCMULGEE RIVER BASIN

CLASSIFICATION

|                    |   |                |
|--------------------|---|----------------|
| South River        | Headwaters to Georgia Hwy. 81                                     | Urban          |
| Intrenchment Creek | Headwaters in Atlanta to confluence with South River              | Urban          |
| Shoal Creek        | Headwaters in DeKalb County to confluence with South River        | Urban          |
| Conley Creek       | Headwaters near Atlanta Army Depot to confluence with South River | Urban          |
| Doolittle Creek    | Headwaters to DeKalb County to confluence with South River        | Urban          |
| Snapfinger Creek   | Headwaters in Dekalb County to confluence with South River        | Urban          |
| South River        | Georgia Highway 81 to Georgia Highway 36                          | Fishing        |
| Yellow River       | Headwaters to Georgia Hwy. 124                                    | Fishing        |
| Yellow River       | Georgia Hwy. 124 to Porterdale Water Intake                       | Drinking Water |
| Yellow River       | Porterdale Water Intake to Georgia Highway 36                     | Fishing        |

|              |  |                |
|--------------|--|----------------|
| Alcovy River | Headwaters to Georgia Hwy. 138   | Fishing        |
| Alcovy River | Georgia Hwy. 138 to Covington Water Intake   | Drinking Water |
| Alcovy River | Covington Water Intake to Newton Factory Road Bridge   | Fishing        |
| Jackson Lake | From South River at Highway 36<br>From Yellow River at Highway 36<br>From Alcovy River at Newton Factory Road Bridge to Lloyd Shoals Dam | Recreation     |

LOWER OCMULGEE RIVER BASIN

CLASSIFICATION

|                  |   |                |
|------------------|---|----------------|
| Ocmulgee River   | Lloyd Shoals Dam to Georgia Highway 18              | Fishing        |
| Towaliga River   | Headwaters to Georgia Hwy. 36                       | Drinking Water |
| Towaliga River   | Georgia Highway 36 to High Falls Dam                | Recreation     |
| Ocmulgee River   | Georgia Highway 18 to Macon Water Intake            | Drinking Water |
| Ocmulgee River   | Macon Water Intake to Georgia Highway 96            | Industrial     |
| Walnut Creek     | Macon City limits to confluence with Ocmulgee River | Urban          |
| Cabin Creek      | Headwaters in Griffin to Parham Road                | Urban          |
| Tobesofkee Creek | Lake Tobesofkee                                     | Recreation     |
| Tobesofkee Creek | Tobesofkee Dam to confluence with Ocmulgee River    | Urban          |
| Ocmulgee River   | Georgia Hwy. 96 to confluence with Oconee River     | Fishing        |

ALTAMAHA RIVER BASINCLASSIFICATION

|                |  |            |
|----------------|--|------------|
| Altamaha River | Confluence of Oconee and Ocmulgee Rivers to U.S. Hwy. 301                      | Fishing    |
| Altamaha River | U.S. Hwy. 301 to Altamaha Sound  | Fishing    |
|                | All littoral waters on the ocean side of St. Simons, Sea, and Sapelo Islands   | Recreation |
| Ochoopee River | Headwaters to confluence with Altamaha River                                   | Fishing    |
| Mackay River   | Confluence with Altamaha River to St. Simons Sound                             | Fishing    |
| Roanoke River  | Northern confluence with Mackay River to Southern confluence with Mackay River | Fishing    |
| Wendover River | Northern confluence with Mackay River to Southern confluence with Mackay River | Fishing    |

SATILLA RIVER BASINCLASSIFICATION

|               |   |         |
|---------------|---|---------|
| Satilla River | Headwaters to Seaboard Coast Line Railroad              | Fishing |
| Satilla River | Seaboard Coast Line Railroad to St. Andrews Sound       | Fishing |
| Kettle Creek  | Headwaters at Waycross to confluence with Satilla River | Urban   |
| City Creek    | Headwaters at Waycross to confluence with Satilla River | Urban   |

|                             |  |            |
|-----------------------------|--|------------|
| Twenty-Mile Creek           | Georgia Highway 353 near Douglas to confluence with Seventeen-Mile Creek | Urban      |
| Little Satilla River        | Seaboard Coast Line Railroad to St. Andrews Sound                        | Fishing    |
| East River                  | South End to West End  | Navigation |
| Turtle and Brunswick Rivers | Headwaters to St. Simons Sound   | Fishing    |
|                             | All littoral waters on ocean side of Cumberland and Jekyll Islands       | Recreation |

ST. MARYS RIVER BASIN

CLASSIFICATION

|                 |  |            |
|-----------------|--|------------|
| St. Marys River | Headwaters to Cumberland Sound                         | Fishing    |
| North River     | Headwaters to confluence with St. Marys River          | Industrial |
|                 | All littoral waters on ocean side of Cumberland Island | Recreation |

SUWANNEE RIVER BASIN

CLASSIFICATION

|   |  |         |
|---|--|---------|
| Suwannee River                            | Headwaters to Georgia-Florida State Line | Fishing |
| Alapaha River                             | Headwaters to Georgia-Florida State Line | Fishing |
| Withlacoochee River (Withlacoochee Creek) | Headwaters to Georgia-Florida State Line | Fishing |

OCHLOCKNEE RIVER BASIN

CLASSIFICATION

|                                    |   |         |
|------------------------------------|---|---------|
| Ochlocknee River                   | Headwaters to Georgia-Florida State Line                      | Fishing |
| Oguina Creek (and its tributaries) | Headwaters in Thomasville to confluence with Ochlocknee River | Urban   |

|  |  |         |
|--|--|---------|
| Parkers Mill Creek                         | Headwaters in Cairo to confluence with Tired Creek | Urban   |
| Aucilla River<br>(including Aucilla Creek) | Headwaters to Georgia-Florida State Line           | Fishing |

FLINT RIVER BASIN

CLASSIFICATION

|                |  |                |
|----------------|--|----------------|
| Flint River    | Headwaters to Georgia Hwy. 54  | Industrial     |
| Sullivan Creek | Headwaters in College Park to confluence with Flint River                          | Urban          |
| Mud Creek      | Headwaters in Hapeville to confluence with Flint River                             | Urban          |
| Flint River    | Georgia Hwy. 54 to S1061, Woolsey Road   | Fishing        |
| Flint River    | S1061, Woolsey Road to Georgia Highway 16  | Drinking Water |
| Flint River    | Georgia Highway 16 to Georgia Highway 27   | Fishing        |
| Flint River    | Georgia Highway 27 to Albany to Georgia Power Company Dam at Lake Worth, Albany    | Recreation     |
| Flint River    | Georgia Power Company Dam at Lake Worth, Albany to Bainbridge, U.S. Hwy. 84 Bridge | Fishing        |
| Flint River    | Bainbridge, U.S. Hwy. 84 Bridge to Jim Woodruff Dam, Lake Seminole                 | Recreation     |

CHATTAHOOCHEE RIVER BASINCLASSIFICATION

|                                       |   |                             |
|---------------------------------------|---|-----------------------------|
| Chattahoochee River                   | Headwaters to Buford Dam                                    | Recreation                  |
| Flat Creek                            | Headwaters in Gainesville to Chattahoochee River            | Urban                       |
| Chattahoochee River                   | Buford Dam to Atlanta (Peachtree Creek)                     | Drinking Water & Recreation |
| Chattahoochee River                   | Atlanta (Peachtree Creek) to Cedar Creek                    | Industrial                  |
| Sope Creek                            | Headwaters in Marietta to Chattahoochee River               | Urban                       |
| Rottenwood Creek                      | Headwaters in Marietta to Chattahoochee River               | Urban                       |
| Nickajack Creek                       | Headwaters in Marietta to Chattahoochee River               | Urban                       |
| Peachtree Creek (and its tributaries) | Headwaters to Chattahoochee River                           | Urban                       |
| Proctor Creek                         | Headwaters in Atlanta to Chattahoochee River                | Urban                       |
| Sandy Creek                           | Headwaters in Atlanta to Chattahoochee River                | Urban                       |
| Utoy Creek                            | Headwaters in East Point to Chattahoochee River             | Urban                       |
| Olley Creek                           | Headwaters in Marietta to Sweetwater Creek                  | Urban                       |
| Chattahoochee River                   | Cedar Creek to Franklin, Georgia (U.S. Hwy. 27)             | Fishing                     |
| Chattahoochee River                   | U.S. Hwy. 27 Bridge at Franklin, Georgia, to West Point Dam | Recreation                  |
| Chattahoochee River                   | West Point Dam to West Point Mfg. Company Water Intake      | Drinking Water              |

|                     |  |                             |
|---------------------|--|-----------------------------|
| Chattahoochee River | West Point Mfg. Company Water Intake to Osanippa Creek   | Fishing                     |
| Chattahoochee River | Osanippa Creek to Columbus, Georgia (14th Street Bridge)                                       | Recreation & Drinking Water |
| Chattahoochee River | Columbus, Georgia (14th Street Bridge) to Cowikee Creek  | Fishing                     |
| Chattahoochee River | Cowikee Creek to Great Southern Division of Great Northern Paper Company                       | Recreation                  |
| Chattahoochee River | Great Southern Division of Great Northern Paper Company to Georgia Highway 91 (Neal's Landing) | Fishing                     |
| Chattahoochee River | Georgia Highway 91 (Neal's Landing) to Jim Woodruff Dam  | Recreation                  |

TALLAPOOSA RIVER BASIN

CLASSIFICATION

|                         |  |                |
|-------------------------|--|----------------|
| Tallapoosa River        | Headwaters to Georgia Highway 100  | Drinking Water |
| Tallapoosa River        | Georgia Highway 100 to Georgia-Alabama State Line                          | Fishing        |
| Little Tallapoosa River | Headwaters to SCS Dam No. 36 (Carrollton Raw Water Intake)                 | Drinking Water |
| Little Tallapoosa River | SCS Dam No. 36 (Carrollton Raw Water Intake) to Georgia-Alabama State Line | Fishing        |

COOSA RIVER BASIN

CLASSIFICATION

|                 |  |                |
|-----------------|--|----------------|
| Conasauga River | Georgia Highway 2 to Dalton Water Intake                 | Drinking Water |
| Conasauga River | Dalton Water Intake to confluence with Coosawattee River | Fishing        |

|                     |  |                |
|---------------------|--|----------------|
| Mill Creek          | Headwaters to Dalton Water Supply  | Drinking Water |
| Mill Creek          | Dalton Water Supply to confluence with Coahulla Creek                                | Urban          |
| Drowning Bear Creek | From confluence with Tar Creek in Dalton to Conasauga River                          | Urban          |
| Ellijay River       | Headwaters to Ellijay Water Intake   | Drinking Water |
| Ellijay River       | Ellijay Water Intake to confluence with Cartecay River                               | Fishing        |
| Cartecay River      | Headwaters to Ellijay Water Intake   | Drinking Water |
| Cartecay River      | Ellijay Water Intake to confluence with Ellijay River                                | Fishing        |
| Coosawattee River   | From confluence of Ellijay and Cartecay Rivers to confluence with Mountaintown Creek | Fishing        |
| Coosawattee River   | Confluence of Mountaintown Creek to Carters Dam                                      | Recreation     |
| Coosawattee River   | Carters Dam to confluence with Conasauga River                                       | Fishing        |
| Oostanaula River    | Confluence of Conasauga and Coosawattee Rivers to Calhoun Water Intake               | Drinking Water |
| Oostanaula River    | Calhoun Water Intake to confluence with Armuchee Creek                               | Fishing        |
| Oostanaula River    | Confluence with Armuchee Creek to Rome Water Intake                                  | Drinking Water |
| Oostanaula River    | Rome Water Intake to confluence with Etowah River                                    | Fishing        |

|                 |   |                                |
|-----------------|---|--------------------------------|
| Etowah River    | Headwaters to State Route 2551  | Fishing                        |
| Etowah River    | State Route 2551 to Canton<br>Water Intake  | Drinking Water                 |
| Etowah River    | Canton Water Intake to Georgia<br>Highway 20  | Fishing                        |
| Etowah River    | Georgia Highway 20 to Allatoona<br>Dam  | Recreation &<br>Drinking Water |
| Etowah River    | Allatoona Dam to Cartersville<br>Water Intake                                       | Drinking Water                 |
| Etowah River    | Cartersville Water Intake to<br>confluence with Oostanaula River                    | Fishing                        |
| Silver Creek    | Headwaters to confluence with<br>Etowah River near Rome                             | Urban                          |
| Coosa River     | Rome-confluence of Oostanaula and<br>Etowah Rivers to Georgia-Alabama<br>State Line | Fishing                        |
| Coosa River     | Alabama State Line  | Recreation                     |
| Chattooga River | Headwaters to Georgia-Alabama<br>State Line   | Fishing                        |
| City Creek      | Headwaters to confluence with<br>Chattooga Creek at LaFayette                       | Urban                          |


TENNESSEE RIVER BASIN

CLASSIFICATION

|   |  |            |
|---|--|------------|
| Little Tennessee<br>River                     | Headwaters to Georgia-North<br>Carolina State Line | Fishing    |
| Hiawasse River<br>(including Lake<br>Chatuge) | Headwaters to Georgia-North<br>Carolina State Line | Recreation |

|  |  |            |
|--|--|------------|
| Nottely River                                  | Headwaters to Georgia-North<br>Carolina State Line | Recreation |
| Toccoa River<br>(including Blue<br>Ridge Lake) | Headwaters to Georgia-Tennessee<br>State Line      | Recreation |
| South Chickamauga<br>Creek                     | Headwaters to Georgia-Tennessee<br>State Line      | Fishing    |
| West Chickamauga<br>Creek                      | Headwaters to Georgia-Tennessee<br>State Line      | Fishing    |
| Spring Creek                                   | Headwaters to Georgia-Tennessee<br>State Line      | Fishing    |
| Dry Creek                                      | Headwaters to Georgia-Tennessee<br>State Line      | Fishing    |
| Chattanooga Creek                              | Headwaters to Georgia-Tennessee<br>State Line      | Fishing    |
| Lookout Creek                                  | Headwaters to Georgia-Tennessee<br>State Line      | Fishing    |

RIVER BASINS AND MAJOR STREAMS IN GEORGIA



**COOSA BASIN**  
COOSA RIVER

**CHATTAHOOCHEE BASIN**  
CHATTAHOOCHEE RIVER

**FLINT BASIN**  
FLINT RIVER

**OCHMULGEE BASIN**  
OCHMULGEE RIVER (HEADWATERS)

**SIMMONS BASIN**  
SIMMONS RIVER (HEADWATERS)

**ST. MARYS-NASSAU BASIN**  
ST. MARYS RIVER

**OCHMULGEE BASIN**  
OCHMULGEE RIVER

**ST. MARYS BASIN**  
ST. MARYS RIVER

**OCONEE BASIN**  
OCONEE RIVER

**ALTAMAHA BASIN**  
ALTAMAHA RIVER

**SAVANNAH BASIN**  
SAVANNAH RIVER

**OGEECHEE BASIN**  
OGEECHEE RIVER

RIVER BASINS OF  
GEORGIA

APPENDIX C  
EQUIVALENT BASE POPULATION

The equivalent base population is an attempt to relate the number of people either assigned, working or living at a base to the equivalent population a city of full-time residents would have. The equivalency is based on two assumptions.

1. A military workday of 8 hours = 1/3 day/capita.
2. An average base housing population of 4 (1 military + 3 dependents).

Table C-1 contains the development of the equivalent base population.

TABLE C-1  
EQUIVALENT BASE POPULATION  
Moody AFB, GA

|                             | NUMBER<br>30 Nov 1973 | EQUIV.<br>FACTOR | EQUIVALENT<br>POPULATION |
|-----------------------------|-----------------------|------------------|--------------------------|
| Military Personnel Assigned | 2503                  | 1/3              | 834                      |
| Foreign Military Personnel  | 20                    | 1/3              | 7                        |
| Civilian Employees          | 555                   | 1/3              | 185                      |
| BOQ Occupancy               | 176                   | 2/3              | 117                      |
| Enlisted Quarters Occupancy | 313                   | 2/3              | 209                      |
| Housing Units               | 306                   | 2/3 + 3          | 1122                     |
| Trailer Units               | 49                    | 2/3 + 3          | 180                      |
| VOQ/TAQ                     | 11*                   | 1                | 11                       |
| Guest Housing Occupancy     | 23*                   | 1                | 23                       |
| Equivalent Base Population  |                       |                  | 2688                     |

\*Average Occupancy 1 - 30 November 1973.

## Appendix D

### INDUSTRIAL WASTE SOURCE SURVEY AND INVENTORY

The Military Public Health Section, USAF Hospital, Moody AFB GA, conducted a base-wide industrial waste source survey on 7 Feb 1974 and compiled an inventory of industrial chemical usage by building number, using activity, and disposal method. These data are presented numerically by building number in Table D-1.

TABLE D-1 INDUSTRIAL WASTE SOURCE SURVEY AND INVENTORY

| Bldg No. | Squadron Section OIC/ACOIC Phone No.                                  | Description of Operation(s) | INDUSTRIAL CHEMICALS  |  | Disposal Methods (Incl. discharge point & estimated dilution waters.)  | Disposed To:              |
|----------|---|-----------------------------|---|--|--|---------------------------|
|          |   |                             | Nomenclature FS#  | Est. Use Rate (gal/No.)<br>Used Collected                              |  |                           |
| 133      | TRCO<br>Photo Lab<br>Capt Baker<br>3345<br>Dewain<br>Fletcher<br>3589 | Photo Film Processing       | GAF - Hyphinol<br>GAF - Vividol<br>GAF - Surfifix<br>Acetic Acid<br>Ansochrome<br>Color Processing<br>Chemicals                           | 4.1<br>None<br>25<br>None<br>25<br>None<br>16.6<br>None<br>1.6<br>None | Discharge down sanitary sewer  | S-1                       |
| 558      | C/S<br>T-37B<br>Post Dock<br>Capt Haran<br>MSGT<br>Charles<br>3304    | Wash and Clean T-37B A/C    | A/C Cleaning Compound<br>6850-935-0995  | 55<br>None   | Used on ramp and drained to storm sewer (no separators)  | R5                        |
| 702      | F/S<br>NDI<br>Capt<br>Miller<br>MSGT Ray<br>3281                      | Non-Destructive Inspection  | Trichloroethylene<br>6810-551-1487<br><br>Developer<br>6750-165-7133<br><br>Developer<br>6850-782-2718<br><br>Emulsifier<br>6850-782-2737 | 110<br>None<br><br>41.6<br>8.3<br>4.1                                  | Sprayed on A/C and allowed to evaporate<br><br>Dumped into storm drain<br><br>Collected in drums and sent to R/M | Unk<br><br>R-3<br><br>R/M |

TABLE D-1 (cont'd)

| Bldg No.                | Squadron Section OIC/NCOIC Phone No.                                    | Description of Operation(s)     | INDUSTRIAL CHEMICALS                        |                                       | Disposal Methods (Incl'd. discharge point & estimated dilution waters.) | Disposed To:  |     |                                    |     |
|-------------------------|---|---------------------------------|---|---------------------------------------|---|---|-----|------------------------------------|-----|
|                         |   |                                 | Nomenclature FSN                            | Est. Use Rate (gal/Mo.) Used Collect. |   |   |     |                                    |     |
| 702<br>(cont'd)         |   |                                 | Fixer Solution<br>6750-L-000038-3001        | 41.6                                  | None  | Dumped into storm drain   | R-3 |                                    |     |
|                         |   |                                 | Penetrant<br>6850-782-2736                  | 4.1                                   | 4.1   |   |     | Collected in drums and sent to R/M | R/M |
|                         |   |                                 | Methyl Iso Butyl<br>Ketone<br>6810-286-3785 | 5                                     | 5   |   |     |                                    |     |
|                         |   |                                 | PD-680<br>9140-261-7453                     | 4.1                                   | None  |   |     |                                    |     |
| 717                     | FMS<br>Corrosion<br>Control<br>Capt<br>Miller<br>Mr.<br>Roberts<br>3770 | Strip, Repaint<br>and treat A/C | Methyl ethyl ketone<br>6810-223-9069        | 440                                   | None  | Sent through strainer and settling tank, and pumped into sanitary sewer | S-1 |                                    |     |
|                         |   |                                 | Toluene<br>6810-290-0048                    | 20                                    | None  |   |     |                                    |     |
|                         |   |                                 | Remover<br>8010-926-1489                    | 330                                   | None  |   |     |                                    |     |
|                         |   |                                 | Remover<br>8010-943-2137                    | 110                                   | None  |   |     |                                    |     |
|                         |   |                                 | Thinner<br>8010-527-2896                    | 110                                   | 110   |   |     | Collected in drums and sent to R/M | R/M |
| Naptha<br>6810-223-9069 | 5   | 5                               |   |                                       |   |   |     |                                    |     |

TABLE D-1 (cont'd)

| Bldg No.                  | Squadron Section OIC/NGOIC Phone No.    | Description of Operation(s)       | INDUSTRIAL CHEMICALS   |   | Disposal Methods (Incl. discharge point & estimated dilution waters.) | Disposed To: |
|---------------------------|---|-----------------------------------|--|---|---|--------------|
|                           |   |                                   | Nomenclature FSN   | Est. Use Rate (gal/No.)<br>Used Collected |   |              |
| T-37 Wash Rack Behind 754 | OMS Washrack Capt Miller SSgt Pope 3775 | Wash and Corrosion Treat T-37 A/C | Alkaline Soap  | 110                                       | None  | R-3          |
|                           |   |                                   | Passagell 6850-L0000833001   | 2   | None  |              |
|                           |   |                                   | Cleaning Compound Mil Spec C-38334 6850-527-2426                                 | 80  | None  |              |
| T-38 Wash Rack Behind 754 | OMS Capt Ledbetter SSgt Garriet 3336    | Wash T-38 A/C                     | Soap Solvent Mil Spec C-25769 1 part soap to 3 part water 3-4 A/C washed per day | 55  | None  | R-3          |
| 755                       | AGE Maint. Capt Miller TSgt Lott 3273   | Cleaning of AGE Equipment         | Cleaning Solution POL 6850-637-6135  | 55  | None  | R-3          |

TABLE D-1 (cont'd)

| Squadron Section OIC/NCOIC Phone No.                               | Description of Operation(s) | INDUSTRIAL CHEMICALS   |                                 | Disposal Methods (Incl. discharge point & estimated dilution waters.) | Disposed To:   |           |
|--|-----------------------------|--|---------------------------------|---|--|-----------|
|  |                             | Nomenclature FSN   | Est. Use Rate (gal/Mo.)<br>Used |   |  | Collected |
| 753<br>FMS<br>Cleaning Plant<br>Capt Miller<br>MSGT Mullen<br>3284 | Cleaning A/C Metal Parts    | Alkaline Cleaner Compound (corrosion remover)<br>6850-550-5565 | 800                             | None  | Contained in tank. Rinse tank overflow drained through storm sewer to Mission Lake                 | R-3       |
|  |                             | Carbon remover<br>PC 111<br>6850-281-3042                      | 110                             | 110   | Collected in drums and sent to R/M Rinse tank overflow drained through storm sewer to Mission Lake | R/M       |
|  |                             | Dry Cleaning Solvent<br>PD 680<br>6850-285-8011                | 55                              | None  | Drained through storm sewer to Mission Lake after the solvent becomes contaminated                 | R-3       |
|  |                             | Paint Stripper<br>Mil Spec T 5555                              | 55                              | None  | Lost in parts rinse tank which is drained through storm sewer to Mission Lake                      | R-3       |
|  |                             | Potassium Permanganate   | None                            | None  | In tank, not discharged  | No        |
|  |                             | Sodium Carbonate<br>6810-237-2906                              | None                            | None  |  |           |
|  |                             | Sodium Hydroxide<br>6810-174-6581                              | None                            | None  |  |           |
|  |                             | Trichloroethylene<br>6810-270-9982                             | 220                             | None  | Lost only by evaporation   | Unk       |

TABLE D-1 (cont'd)

| Bldg No. | Squadron Section OIC/NCOIC Phone No.                | Description of Operation(s)                        | INDUSTRIAL CHEMICALS                |   | Disposal Methods (Incl'd. discharge point & estimated dilution waters.) | Disposed To:  |     |
|----------|---|--|-------------------------------------|---|---|---|-----|
|          |   |  | Nomenclature FSN                    | Est. Use Rate (gal/Mo.)<br>Used Collected |   |   |     |
| 758      | FMS Access. Repair Lt Watson MSgt Cannington 3640   | Repair Accessory A/C Parts                         | Calibration Fluid 6850-264-2771     | 20  | None  | All wastes go through storm drain to Mission Lake   | R-3 |
|          |   |  | Carbon Remover PC 111 6850-281-3042 | 20  |   |   |     |
|          |   |  | Trichloroethylene 6810-184-4800     | 20  |   |   |     |
|          |   |  | PD 680 6550-637-6135                | 20  | 20  |   |     |
| 769      | Refueling Maint. Capt Blair Jimmy Sammers 3260 3528 | Perform Periodic Maintenance on refueling vehicles | Oil and JP4                         | 30  | None  | Used fuel and oil are collected in a holding tank any water is separated out by an oil/water separator and drained to Mission Lake. The fuel and oil are removed periodically by tank truck | R-3 |
| 785      | FMS Battery Shop Capt Baker TSgt Cairns             | Rebuilding A/C and AGE Batteries                   | Potassium Hydroxide 6810-281-2029   |   |   | Old battery cells are occasionally drained. The liquid is neutralized and sent through the storm sewer to Mission Lake.   | R-3 |

TABLE D-1 (cont'd)

| Bldg No. | Squadron Section<br>OIG/NGOIC<br>Phone No.                            | Description of<br>Operation(s)   | INDUSTRIAL CHEMICALS                                |   | Disposal Methods<br>(Incl. discharge point &<br>estimated dilution waters.) | Dis-<br>posed<br>To: |
|----------|---|--|---|---|---|----------------------|
|          |   |  | Nomenclature<br>FSN                                 | Est. Use Rate<br>(gal/Mo.)<br>Used Collected. |   |                      |
| 785      | FMS<br>Electric<br>Shop<br>Capt<br>Miller<br>TSgt<br>Tucker<br>3745   | Repair A/C<br>Electrical<br>Equipment  | Potassium Hydroxide                                 | 2.5<br>None                                   | Drained to gravel seepage pit   | Pit                  |
| 785      | FMS<br>Hydraulic<br>Shop<br>Capt<br>Miller<br>MSGT<br>Pittman<br>3355 | Maintenance<br>and repair of<br>T-37 and T-38<br>Pneumatic and<br>Hydraulic<br>Systems | Hydraulic Fluid<br>Mil Spec H-5606<br>9150-252-6383 | All   | Collected in drums and sent to R/M  | R/M                  |
|          |   |  | PD680<br>6850-637-6135                              | 55  |   |                      |
| 900      | Med Gp<br>X-Ray<br>Dr.<br>Brown<br>TSgt<br>McLaughlin<br>3295         | Black/White<br>Film Pro-<br>cessing  | Fixer Solution                                      | 70  | Sent to R/M for silver recovery   | R/M                  |
|          |   |  | Other processing<br>Chemicals                       | 70  | Discharged to sanitary sewer  | S-1                  |
| 903      | Battery<br>Shop<br>MSGT<br>Strickland                                 | Vehicle<br>Battery<br>Repair   | Battery Acids and<br>Washings                       | 15<br>None                                    | Acid is neutralized and discharged<br>to storm sewer                        | R-1                  |

TABLE D-1 (cont'd)

| Bldg No.                             | Squadron Section OIC/NCOIC Phone No.                   | Description of Operation(s)   | INDUSTRIAL CHEMICALS   |                              | Disposal Methods (Incl'd. discharge point & estimated dilution waters.) | Disposed To:   |
|--------------------------------------|--|---|--|------------------------------|---|--|
|                                      |  |   | Nomenclature FSN   | Est. Use Rate (gal/Mo.) Used |   |  |
| 925<br>976<br>977                    | ABGp Vehicle Main. Lt Col Dellord MSgt Strickland 3582 | Base Vehicle Maintenance and repair   | Oil<br>Hydraulic Fluid   | 55<br>15                     | 5<br>15   | R/M  |
| CE Wash rack South of 926 behind 973 | CE O&M Maj Will Mr Spells 3849                         | Wash CE and other vehicles  | General purpose Cleaner Continental Chem Corp 7930-515-2477<br>2-5 oz/Gal of water | 357 gal in 9000 gal of water | None  | R-2  |
| 943                                  | AAFES BX Service Station Mr. Peterson 3451             | Routine maintenance for motorized vehicles and gasoline supply for on base vehicles | Gasoline (Amoco) and oils along with grease, lubricants, hydraulic fluids          | 500                          | 500   | None<br>All waste petroleum products are collected in a 1000 gal tank. The tank is pumped out by a private refinery. |

TABLE D-1 (cont'd)

| Squadron<br>Section<br>CIC/MOCIC<br>Phone No. | Description<br>of<br>Operation(s)                    | INDUSTRIAL CHEMICALS   |  | Disposal Methods<br>(Incl'd. discharge point &<br>estimated dilution waters.) | Dis-<br>posed<br>To:  |
|---|--|--|--|---|---|
|   |  | Nomenclature<br>FSN  | Est. Use Rate<br>(gal/No.)<br>Used Collected |   |   |
| 973   | ABGp<br>Operations<br>Mr Pike<br>Mr Smith<br>3461    | General purpose<br>Detergent<br>7930-515-2477<br>2-5 oz/Gal of water | 1500<br>in<br>45,000<br>gal of<br>water      | None  | R-1   |
| 1700<br>1701<br>1703                          | TMS<br>Jet Engine<br>Test Stand<br>Mr Cartee<br>3620 | Spilled JP4<br>and Class 3100<br>chemical cleaners                   | 55   | 55  | R/M<br>Collected in drums and sent to R/M<br>Washdown runoff flows into swamp |

APPENDIX E  
Trip Report



REPLY TO  
ATTN OF: CC

12 January 1972

SUBJECT: Trip Report - Special Project 71-51, Moody AFB GA

Commander, USAF Env Health Lab/CC, Kelly AFB TX 78241  
to: AFLC/SGPE, Wright-Patterson AFB OH 45433  
IN TURN

1. Place visited: Moody AFB GA.
2. Inclusive dates: 5-10 December 1971.
3. Persons making trip: Capt Charles W. Bullock and Capt Edward E. LeFebvre.
4. Primary mode of transportation: Commercial air.
5. Purpose of trip:
  - a. To conduct a preliminary survey of water pollution abatement activities at Moody AFB GA.
  - b. To determine the need for and method of accomplishing a comprehensive evaluation of the base's watewaters and their treatment.

6. Persons contacted:

Maj William D. Thompson, Base Civil Engineer  
\*Maj Kenneth Will, Chief of Operations and Maintenance, Civil Engineering  
Maj Alfred Watson, Hospital Commander  
\*Lt Don Stauffer, Civil Engineering Environmental Protection Coordinator  
SMSgt Don R. Thomas, NCOIC, Vehicle Maintenance  
MSgt Don Hancock, NCOIC FMS Accessory Repair Section  
\*TSgt Thomas Knowlton, NCOIC Military Public Health  
TSgt David Zimmerman, NCOIC Corrosion Control  
TSgt G. N. Draper, NCOIC NDI Lab  
SSgt William Garren, NCOIC FMS Cleaning Shop  
\*Mr Ilbert Brayshaw, GS-13, Associate Base Civil Engineer  
\*Mr. Fred Fleteau, GS-12, Chief Engineer  
\*Mr. Edgar Hull, GS-8, TRCO, Water and Sewage  
Mr. Garland Stone, Foreman for Water and Sewage Treatment Contractors  
Mr. C. E. Stalvey, Redistribution and Marketing

\*Attended briefing of preliminary survey findings, 9 December 1971.

## 7. Findings and Observations:

### a. Domestic wastewater sources and treatment:

(1) Domestic wastewaters from almost all on-base duty areas and all on-base housing areas are collected and treated at the base secondary sewage treatment plant.

(2) The treatment plant consists of primary and secondary clarifiers, two standard rate trickling filters, an unheated but internally circulated anaerobic digester, two sludge drying beds, chlorinator and chlorine contact tank, and parshall flume flow measurement device.

(3) The plant outfall flows into Beatty Branch which reportedly originates from springs under the base's runway 18L and 18R. Beatty Branch flows into Cat Creek and thence into the Withlatchoochee River.

(4) A survey of the plant and a cursory review of its past year's operating logs indicated that the plant is providing exceptionally good secondary treatment. The plant's hydraulic design capacity of 0.75 million gallons per day (MGD) is only loaded between 0.3 and 0.4 MGD. Five-day biochemical oxygen demand (BOD<sub>5</sub>) removal efficiencies through the plant usually exceed 90%. Aquatic life in Beatty Branch appeared normal and no obvious pollution was observed in the branch near the plant outfall.

(5) Considerable evidence of recent "in-house" efforts existed to show a progressive rehabilitative program for the entire treatment plant system (see Attach 1). These actions were exemplary, sorely needed, and should continue to receive full support. The most important of these projects to be completed are the:

(a) Repair of the primary and secondary clarifier appertenances before the new housing units' waste begins to arrive at the plant.

(b) Repair of the plant's post chlorination unit which allegedly has not operated since 1961.

(c) Installation of a new flow measurement recorder on the plant's parshall flume. Plant flow measurements have not been made for an extended period and have been estimated to average 70% of the base's daily potable water consumption.

(6) The laboratory equipment is inadequate for doing all the tests

needed to properly evaluate the plant's operation. The most immediate needs for laboratory equipment are listed in Paragraph 8 below. Excellent efforts have been made to do many analyses with the laboratory equipment currently available.

(7) Three of the plant operators are currently licensed sewage plant operators in Georgia. However, it is highly desirable that one operator receive more intensive, short course training in sewage chemistry and laboratory techniques and equipment. Recommendations for training and references are given in Paragraph 8 below.

(8) During the survey, data were collected to evaluate the sewage plant's:

(a) Past operational efficiency.

(b) Capability to effectively treat incremental increases in loadings which would come from projected base housing projects.

b. Industrial wastewater sources and treatment:

(1) Many industrial wastewaters flow untreated into open or covered storm sewers which drain into branches/mill races around the base. Notable exceptions to these untreated discharges were: corrosion control facility (Bldg 717) discharges to sanitary sewer, film processing agencies send processor "fixer" solutions to redistribution/marketing (R/M) for silver recovery, jet engine test stand (Bldg 1700) and vehicular maintenance activities send collected oils and hydraulic fluids to R/M, and the base motor pool and field maintenance battery shops neutralize their battery acids before discharging them to storm drains.

(2) Tab G-3, Base Master Plan, depicted nineteen separate storm sewer outfalls from the base, excluding the housing area. As observed during the survey, four outfalls appeared to carry most of the industrial waste loads. Past records estimated these industrial waste discharges at 0.05 to 0.07 MGD. However, the wastes through these outfalls have never been qualitatively or quantitatively evaluated except for grabbing samples to indicate the:

(a) Sources of elevated lead concentrations in some fish taken from Mission Lake (1970).

(b) Chemical pollutants possibly present in the base's storm sewer outfalls and run-off drainage areas (1971).

(3) Many of the industrial shops were visited and data were taken on their chemical inventory, usage rates, process uses of the chemicals, and discharge points of these chemicals. A format for tabulating this information was outlined. The usefulness of such a format in monitoring pollution sources was discussed with Military Public Health personnel.

(4) Of the four storm sewers having industrial waste loads, two flow south into a branch which has been dammed downstream to form on-base Mission Lake. The lake's discharge flows off-base and ultimately reaches Grand Bay Creek and the Alapaha River. Although aquatic life in the lake appeared normal, surfactant suds were observed on the shoreline and some oil deposits were in the lake's discharge channel. Effectively, Mission Lake should be considered as an oxidation treatment pond for whatever industrial wastes enter it. The lake's effectiveness for such treatment is unknown as is the quality and quantity of its influent and effluent waters.

#### 8. Recommendations and Conclusions:

a. An excellent "in-house" rehabilitation of the sewage treatment system is in progress. Accomplishment of those items in the order listed in Paragraph 7a(5) is most important. Until the flow detector/recorder is installed, the plant's flow during the day should be estimated by measuring the water level through the parshall flume. The procedure for doing this was discussed during the survey.

b. The base sewage treatment laboratory equipment listed in Atch B should be procured as quickly as possible. Although some items are cited from commercial catalogues, they or their equivalents should be obtained through medical or non-medical FSN supply channels if available.

c. Information of recommended short course sewage chemistry training could be obtained from:

(1) Environmental Protection Agency, 4676 Columbia Parkway, Cincinnati, OH 45226.

(2) Environmental Engineering Sciences, University of Florida, Gainesville, FL 32601.

d. The following useful references should be obtained and utilized in sewage testing and treatment plant operation:

(1) Standard Methods for The Examination of Water and Wastewater, 14th Edition (1971), American Public Health Association, 1740 Broadway, New York, NY 10019. Cost: \$22.50.


(2) Operation of Wastewater Treatment Plants, Manual of Practice No. 11, Water Pollution Control Federation, 3900 Wisconsin Ave, Washington, DC 20016. Cost: \$3.00.

(3) Anaerobic Sludge Digestion, Manual of Practice No. 16, same publisher as (2) above. Cost: \$2.50.

e. The industrial waste source inventory data available should be expanded and tabulated into the format discussed during the survey. This should be accomplished prior to complete sampling of the storm sewers carrying industrial wastes.

f. Chemical pollutants and flows of industrial wastes in four storm sewers, the car wash area near the base motor pool, and Mission Lake's effluent should be determined. A forthcoming "operations plan" will be published by this office to outline equipment supplied by this Laboratory and procedures to be used by Moody AFB personnel to collect needed field data and samples. An on-site Environmental Health Laboratory team to evaluate these industrial wastes is not considered necessary.

g. After all these data have been evaluated, a comprehensive technical report will evaluate Moody AFB's water pollution abatement activities and any additional wastewater treatment needs necessary to meet pollution control criteria.



CHARLES W. BULLOCK, CAPT, USAF, BSC  
Bioenvironmental Engineer

2 Atch  
a/s

Cy to: Base Civ Engr, &  
Base Med Svcs Officer,  
Moody AFB GA 31602  
USAF Env Health Lab/CC  
McClellan AFB CA 95652

**"IN-HOUSE" TREATMENT PLANT SYSTEM REHABILITATION/ALTERATION**

| <u>Action/Item</u>  | <u>Status</u>  |
|---|--|
| 1. Overhaul golf course lift stations 2 pumps, increase impellar diameters from 11 to 12 inches.  | Recently completed.  |
| 2. Clean out plant outfall and fill-in/compact area around the outfall line to Beatty Branch.   | " "  |
| 3. Replace and grade sand in sludge drying beds.  | " "  |
| 4. Removal of trees whose leaves were falling into and interfering with plant operations.   | " "  |
| 5. Repair all external lighting on plant grounds.   | " "  |
| 6. Install gate to plant entrance   | " "  |
| 7. Thoroughly clean main lift station and wet well on base.   | " "  |
| 8. Overhaul the three 3650 gpm pumps in the main lift station.  | " "  |
| 9. Clean out and install two 50 gph acid pumps in corrosion control's waste collection tank.  | " "  |
| 10. Replace mercury amalgam seals on trickling filter rotary arms with rosin seals.   | Materials on hand, to be completed in January 1972.          |
| 11. Repair comminutor at main lift station on base.   | In progress.   |
| 12. Repair/replace pumping controls at main lift station on base.   | To be completed early in 1972.                               |
| 13. Repair primary clarifier's influent and by-pass gates, skimmer chains and flats, skimmer motor drive and reduction gears, effluent valving. Completely clean primary clarifiers and seal them as necessary. | Materials due in December 1971 and completed by summer 1972. |

ATCH 1

| <u>Action/Item</u>   | <u>Status</u>   |
|--|---|
| 14. Modify primary clarifier's oil/grease skimmer collection boxes.  | To be completed by summer 1972.                                   |
| 15. Install chlorinator and flow recorder with controls in Control House.  | Equipment due in February 1972 and work completed by August 1972. |
| 16. Replace recirculating pumps to increase capacity to 100% recirculation from secondary clarifier.                                 | To be done during 1972.   |
| 17. Overhaul the single lift pump in the trailer park lift station and provide back up by installing another pump of equal capacity. | To be done during 1972.   |
| 18. Prepare to replace golf course lift station pumps if increasing impellar diameter does not handle new housing load.              | Contingency planning.   |
| 19. Install comminutors at trailer park and golf course lift stations.   | In planning.  |
| 20. Refurbish Control/Laboratory Building: lower ceiling, improve lighting system, install lockers, and repair showers.              | In planning.  |
| 21. Fence entire treatment plant grounds to keep out children from the nearby base trailer park.                                     | In planning.  |

RECOMMENDED SEWAGE TREATMENT LABORATORY EQUIPMENT/SUPPLIES

| <u>Item/Description</u>   | <u>Estimated Cost</u> |
|---|-----------------------|
| 1. Ainsworth Type 23N Balance, Scientific Products Catalogue #M1497-2. Availability of equal FSN item unknown. Need one.  | \$530.00              |
| 2. Muffle Furnace, Stepless control, Type 1300, Thermo-lyne, Scientific Products Catalogue #F8510-1. Availability of equal FSN item unknown. Need one.  | \$98.00               |
| 3. Pipets, automatic, with selector collors, 2ml capacity, Curtin Products Catalogue #192-294. Need case of 6. Availability of equal FSN item unknown.  | \$37.20 (box of 6)    |
| 4. Holder, m. porous bacterial filtering disk, uses 47mm diameter filtering paper, FSN 6640-299-8691. Also obtain 47mm diameter filter paper, Whatman 41 type, low ash content; see Millipore Filter Corporation's Catalogue. | Unknown               |
| 5. Dish, moisture determination, 60mm diameter, with lift tab, flat bottom, aluminum. FSN 6640-938-5615.  | Unknown               |
| 6. Filler, pipet, 3 ball valve type. FSN 6640-889-1712. Need 6.   | Unknown               |
| 7. Expendable needs for Beckman Model "G" ph meter:   |                       |
| a. One each: caromel electrode FSN 6630-431-4760 and glass electrode FSN 6630-431-4770.   | \$30.00 each          |
| b. Batteries see meter parts listed under meter FSN 6630-431-4750.  | Unknown               |
| c. Operation's instruction manual. Request from manufacturer.   | Probably Free         |
| d. Buffer pH7 for calibrating meter. Order from chemical supply firm (need several pints)   | \$7.00/pint           |
| e. Electrolyte for glass electrolyte:   | Unknown               |
| saturated potassium chloride (KCl) solution. Order from manufacturer or chemical supply firm (need one bottle)  |                       |

## APPENDIX F

### Water Pollution Surveillance Sampling Program

#### I. PURPOSE AND OBJECTIVES OF PROGRAM

A. Purpose: The purpose of this program is to provide minimal, routine sampling of sewage plant operations, the base's major storm drainage ditches, Mission Lake's outfall, the golf course reservoir, and Grassy Pond.

B. Objectives: Sampling data and analyses will chemically and physically characterize these waters in order to attain the following objectives:

1. Determine sewage plant compliance with current performance specifications.
2. Evaluate any future needs to modify sewage plant operations and/or performance specifications.
3. Evaluate storm drainage ditch water quality, identify any industrial wastes in the storm drainage ditches and Mission Lake, and evaluate any effects of industrial waste loadings.
4. Advise of any industrial waste treatment needs.
5. Monitor the water quality in the golf course reservoir and Grassy Pond.
6. Provide baseline data for continued water pollution control and abatement programs on Moody AFB GA.

#### II. SCOPE AND DESIGN OF PROGRAM

A. Scope: The scope of this program involves doing the following at ten sampling stations:

1. Measuring flow rates from the sewage treatment plant and estimating water flow levels in the storm drainage ditches and Mission Lake's outfall.
2. Testing the temperature, pH, dissolved oxygen (D.O.), five-day biochemical oxygen demand (BOD<sub>5</sub>), and total suspended solids on applicable grab and composited samples from all sampling stations. Testing for total chlorine residual on all grab samples collected from Station S-2.
3. Collecting, compositing, preserving, and sending composited

samples to EHL(K) for analysis.

4. Recording field data, compiling these data with EHL(K) analytical results, and maintaining these data in a historical record.

5. Resampling any station when:

- a. Routine sampling analyses are abnormal,
- b. Industrial waste discharges are evident, or
- c. Aquatic flora or fauna appear affected.

B. Design:

1. Ten minimal, routine sampling stations are defined and described in Table F-1.

2. Table F-2 lists the physical and chemical data to be obtained at each sampling station.

3. Minimal, routine sampling frequency should be once in the spring and fall and preferably during the same months each year.

a. For Stations S-1, S-2, and R-1 through R-6, the sampling day should be on a Friday when the following conditions are met:

(1) Rainfall during the preceding seven days has been negligible, and

(2) All sewage plant processes have been operating normally during the previous month.

b. For Stations R-7 and R-8, the sampling day could be any weekday when rainfall during the preceding seven days has been negligible.

III. SAMPLING PROGRAM PROCEDURES

A. Measurement or Estimate of Flows:

1. Station S-1: Flows cannot be measured at this station but will be assumed equal to those measured at Station S-2.

2. Station S-2: Flow measurements will be recorded on the sewage plant Parshall flume's instantaneous and accumulative recorder.

3. Stations R-1 through R-6: Flows will be estimated based on the ditches' and lake outfall's flow conditions of: high, normal, low, or no flow.

Table F-1: Water Pollution Surveillance Sampling Stations - Moody

| Station Number* | Grid Coordinates | Code Type of Sample** | Description of Station Location  |
|-----------------|------------------|-----------------------|--|
| S-1             | 4G(1)            | BJ                    | Basin at head of primary clarifiers in sewage treatment plant.   |
| S-2             | 3A(1)            | BT                    | End of sewage plant's discharge culvert or at beginning of outfall ditch.  |
| R-1             | 4F(2)            | BT                    | Manhole between Bldg 907 and 908 (Line contains runoff and industrial wastes from motor pool area and open car wash facility.)   |
| R-2             | 6F(2)            | BT + BQ               | Culvert southwest side of Burma Road (Line contains runoff and industrial wastes from maintenance and POL activities along Robbins Road.)  |
| R-3             | 6E(2)            | BT + BQ               | Buried 42" storm sewer line; use manhole just north of Burma Road. (Line contains runoff and industrial wastes from FMS activities and aircraft washings.)                                   |
| R-4             | 8D(2)            | AS                    | Discharge outlet at Mission Lake's retaining wall.   |
| R-5             | 5A(2)            | BQ                    | 30 or 42" storm sewer line <sup>†</sup> ; use manhole just west of Burma Road. (Line contains runoff and industrial wastes from flight line activities and aircraft washrack near Bldg 658.) |
| R-6             | 3D(2)            | BQ                    | Culvert east of Clark St. (Line contains headwaters of Reatty Branch and possibly some industrial runoff.)   |
| R-7             | 4G(2)            | AJ,AK,AE              | Golf Course Reservoir. Sample from around the perimeter. (Reservoir contains raw well water, golf course and base housing area runoff.)  |
| R-8             | none (3)         | AJ + AK               | Off-base base recreational area, Grassy Pond. Sample from around the pond's perimeter. (Pond contains runoff from recreational area and natural woodland drainage as well as ground waters.) |

\* The alphabetical part of the station number denotes the type of station. S-Sewage domestic, R-Runoff storm and industrial. The numerical part of the station number denotes how many station types are to be sampled and are numbered counter-clockwise from the base's main gate. Except for stations R-7 and R-8 which have been added to this program, station numbers and location are the same as used in "Wastewater Pollution Survey Operations Plan, Moody AFB," published by USAF EHL(K), Kelly AFB TX (February 1972).

\*\* EHL(K) code to be used to identify sample source and use of the water. Also see Table F-11, this appendix. (1) As indicated on "Piping Layout Sewage Treatment Plant," dated 20 Jan 1966.

(2) Refer to page 1 of 1, Tab G-3. "Base Master Plan" dated 1 Apr 1970 and last revised Nov 1971.

(3) Refer to Base Civil Engineer Drawing, "Grassy Pond Annex," dated 14 Sep 1967. + Tab G-3 Master Plan shows a 42" line flowing into a 30" line. This appears to be an error in the drawing and thus the line size must be verified by base personnel.



4. Stations R-7 and R-8: Normally these water bodies have no outfall flows which can be measured or estimated.

B. Collection and Analyses of Samples:

1. All grab and manually composited samples except those for oils/greases and any pesticides should be taken from:

a. Station S-1: The distribution box just upstream of the primary clarifiers.

b. Station S-2: The end of the sewage plant's discharge culvert where the flow discharges into the outfall ditch.

c. Stations R-1 through R-6: Where the water's depth permits collection several inches below the water's surface without disturbing the sediments.

d. Stations R-7 and R-8: Collect each of the day's four samples from points equally spaced around the perimeter of the water body. Take sample from boat or shoreline several inches below the water's surface without disturbing any sediments.

2. All grab samples to be manually composited samples for oils/grease and any pesticides analyses should be taken from the water's surface.

3. Field data measurements of temperature, pH, dissolved oxygen (D.O.), and total chlorine residual listed in Table F-2 will be determined on manually collected grab samples. Each of these grab measurements will be taken at the times given in the field data worksheets (Tables F-3, F-4, and F-5). These measurements will be recorded onto these worksheets.

a. Temperature will be measured with a standard mercury immersion thermometer in either °F or °C.

b. The pH should be measured on-site as quickly as possible after collecting the sample. Measure pH's with a pH meter which is continuously maintained in calibration against a pH buffer of 7.0.

c. D.O. samples must be collected by slowly submerging a BOD bottle into the water and filling it without any air entrapment. Using the azide modification method for D.O., add the 2 ml each of manganese sulfate solution and alkali-iodide-azide reagent to the sample, re-stopper and vigorously shake contents. Keep the sample out of sunlight until returning it to a laboratory for analysis. (See analysis procedure in either 12th or 13th edition of Standard Methods for the Examination of Water and Wastewater.)

Table F-3 Field Data Worksheet for Station S-1 and S-2 - Moody AFB GA  
 (Circle the station used on this sheet)

Day of Week \_\_\_\_\_ Date \_\_\_\_\_ Precipitation During Previous Week \_\_\_\_\_ inches

| Time of Day (Hr ± 30 min)                                       | Grab Samples for Measurement of |                         | Flow Volumes at   |                | Volume of Flow Proportioned Grab Sample to be Analyzed for |                                   |
|---|---------------------------------|-------------------------|---|----------------|--|-----------------------------------|
|   | Temp (°)                        | D.O. (ml of Titrant)    | Temp (hrs)  | Meter Readings | All But Oil/Grease and/or Pesticides                       | Oil/Grease and/or Pesticides Only |
| 07 --   |                                 |                         | 0000  |                |  |                                   |
| 07 --   |                                 |                         | 07 --   |                |  |                                   |
| 10 --   |                                 |                         | 10 --   |                |  |                                   |
| 13 --   |                                 |                         | 13 --   |                |  |                                   |
| 15 --   |                                 |                         | 15 --   |                |  |                                   |
| 18 --   |                                 |                         | 18 --   |                |  |                                   |
| 21 --   |                                 |                         | 21 --   |                |  |                                   |
| 24 --   |                                 |                         | 24 --   |                |  |                                   |
| Ave Values  |                                 |                         | Total Daily Flow (MG)   |                | Approximate Total Composite Volume (ml)                    |                                   |
| Day's Compositated Sample Split for EHLA Analyses Groupings of: |                                 | Moody AFB Sample Number | Remarks:  |                |  |                                   |
| A   |                                 |                         | 1. Describe plant operating conditions during previous month: |                |  |                                   |
| B   |                                 |                         | 2. Other:   |                |  |                                   |
| C   |                                 |                         |   |                |  |                                   |
| D   |                                 |                         |   |                |  |                                   |
| E   |                                 |                         |   |                |  |                                   |
| F   |                                 |                         |   |                |  |                                   |
| G   |                                 |                         |   |                |  |                                   |
| H   |                                 |                         |   |                |  |                                   |

Average post chlorination feed rate during sampling day: \_\_\_\_\_ lbs/million gallons of sewage flow

Table F-4: Field Data Worksheet for Stations R-1, R-2, R-3, R-4, R-5 or R-6 - Moody AFB GA  
 (Circle the Station used on this sheet)

Day of Week \_\_\_\_\_ Date \_\_\_\_\_ Precipitation During Previous Week \_\_\_\_\_ inches

| Time of Day (Hr ± 30 min)                     | Grab samples for measurement of: |                    | Estimate of Station's Flow Conditions* | Time Since Previous Sample (Hr) | Time Difference (hrs) | Volume of Grab Sample to be Analysed for |                                   |
|---|----------------------------------|--------------------|--|---------------------------------|-----------------------|--|-----------------------------------|
|   | Temp (°)                         | pH (ml of Titrant) |  |                                 |                       | All But Oil/Grease & Pesticides (ml)     | Oil/Grease & Pesticides only (ml) |
| 08 --   |                                  |                    |  | 0000                            |                       |  |                                   |
| 11 --   |                                  |                    |  | 08                              |                       |  |                                   |
| 14 --   |                                  |                    |  | 08                              |                       |  |                                   |
| 16 --   |                                  |                    |  | 11                              |                       |  |                                   |
|   |                                  |                    |  | 11                              |                       |  |                                   |
|   |                                  |                    |  | 14                              |                       |  |                                   |
|   |                                  |                    |  | 14                              |                       |  |                                   |
|   |                                  |                    |  | 16                              |                       |  |                                   |
| Ave Values                                    |                                  |                    |  |                                 |                       |  |                                   |
| Day's Composite Split for EHIK Analyses Group |                                  |                    |  | Moody AFB Sample Number         |                       |  |                                   |
| A   |                                  |                    |  |                                 |                       |  |                                   |
| B   |                                  |                    |  |                                 |                       |  |                                   |
| C   |                                  |                    |  |                                 |                       |  |                                   |
| D   |                                  |                    |  |                                 |                       |  |                                   |
| E   |                                  |                    |  |                                 |                       |  |                                   |
| F   |                                  |                    |  |                                 |                       |  |                                   |
| G   |                                  |                    |  |                                 |                       |  |                                   |
| H   |                                  |                    |  |                                 |                       |  |                                   |

Remarks:

- Describe conditions of flora/fauna in the stream/ditch/lake as well as other observations.
- Other:

\*Based on flow conditions of: high, normal, low, no flow

Table F-5: Field Data Worksheet for Stations R-7 and R-8 - Moody AFB GA  
 (Circle the station used on this sheet)

Day of Week \_\_\_\_\_ Date \_\_\_\_\_ Precipitation During Previous Week \_\_\_\_\_ inches

| Time of Day<br>(hr ± 30 min)   | Grab Samples for Measurement of: |                         |                      | Perimeter Location of Sample:<br>N, S, E, W* | Volume of Grab Sample Collected for Analysis of |                                     |
|--|----------------------------------|-------------------------|----------------------|--|---|-------------------------------------|
|  | Temp (°)                         | pH                      | D.O. (ml of Titrant) |  | All But Oil/Grease and Pesticides (ml)          | Oil/Grease and Pesticides only (ml) |
| 08 --  |                                  |                         |                      |  |   |                                     |
| 11 --  |                                  |                         |                      |  |   |                                     |
| 14 --  |                                  |                         |                      |  |   |                                     |
| 16 --  |                                  |                         |                      |  |   |                                     |
| Ave Values   |                                  |                         |                      |  |   |                                     |
| Day's Composite Split for EHIK Analyses Group  |                                  | Moody AFB Sample Number |                      |  |   |                                     |
| A  |                                  |                         |                      |  |   |                                     |
| B  |                                  |                         |                      |  |   |                                     |
| C  |                                  |                         |                      |  |   |                                     |
| D  |                                  |                         |                      |  |   |                                     |
| E  |                                  |                         |                      |  |   |                                     |
| F  |                                  |                         |                      |  |   |                                     |
| G  |                                  |                         |                      |  |   |                                     |
| H  |                                  |                         |                      |  |   |                                     |
| Remarks:   |                                  |                         |                      |  |   |                                     |
| 1. Describe conditions of flora/fauna in the water body as well as any other observations. |                                  |                         |                      |  |   |                                     |
| 2. Other:  |                                  |                         |                      |  |   |                                     |

\*Enter directional location of sample collection point around the water body's perimeter.

d. Total chlorine residuals at Station S-2 should be measured on-site as quickly as possible after collecting the grab sample. Testing procedures should be by the OTA, color comparator method given in 12th or 13th edition of Standard Methods.

4. Field data measurements of BOD<sub>5</sub>, total suspended solids, and fecal coliform (Station S-2 only) will be analyzed on the day's composited sample for a given station. Samples should be prepared from the well-mixed contents of the glass "compositing" jugs.

a. BOD<sub>5</sub>:

(1) BOD<sub>5</sub>'s are to be analyzed using unseeded dilution water per the procedures in Standard Methods, 12th or 13th edition.

(2) Dilutions of a composited sample into 300 ml BOD<sub>5</sub> bottles should be as follows:

(a) Station S-1: Two dilutions of 10 ml and two dilutions of 5 ml.

(b) Station S-2: Two dilutions of 50 ml.

(c) Stations R-1 through R-8: Single dilutions of 10 ml, 20 ml, and 100 ml.

(3) BOD<sub>5</sub> worksheets, Tables F-6 and F-7, should be used in setting up and recording each station's BOD<sub>5</sub> analyses.

b. Total Suspended Solids (TSS):

(1) These solids should be determined per the membrane glass fiber filter method described in Standard Methods, 13th edition, pp. 537-538.

(2) TSS worksheet, Table F-8, should be used to set up, record, and analyze each station's TSS.

c. Fecal Coliform:

(1) Bacterial analyses of fecal coliform from Station S-2 should be analyzed per the membrane filter procedure, 13th edition of Standard Methods.

(2) Worksheets for this analysis have not been prepared because calculations and sample sizes are highly variable and must be determined in the field. After the desired sample volume has been determined, triplicate analyses of that volume is recommended with the reported results being the triplicate's average number of fecal coliforms/100 ml of sample.

Table F-6: BOD<sub>5</sub> Worksheet Stations S-1 and S-2 - Moody AFB GA

Date Grabs Collected and Compositd \_\_\_\_\_  
 Date BOD<sub>5</sub>'s Prepared \_\_\_\_\_  
 Date BOD<sub>5</sub>'s Analyzed \_\_\_\_\_

NOTE: DILUTION WATER CONTAINS NO SEED

| Blanks                                   |            | Bottle No.    | ml of Titrant      | Average ml of Titrant                      | Net Change of Blanks |  |   |
|--|------------|---------------|--------------------|--|----------------------|--|---|
| 100% Aerated Dilution H <sub>2</sub> O @ | 15 min     |               |                    |  |                      |  |   |
|  | 15 min     |               |                    |  |                      |  |   |
|  | 5 day      |               |                    |  |                      |  |   |
|  | 5 day      |               |                    |  |                      |  |   |
| Samples @ 5 day                          | Bottle No. | ml of Titrant | Ave. ml of Titrant | Ave 5-day Blank Minus Samples Ave Titrant* | Multi Factor         | BOD <sub>5</sub> of each Dilution (mg/l) | Ave. BOD <sub>5</sub> of Dilutions (mg/l) |
| S-1 @ 5.0 ml                             |            |               |                    |  | 60                   |  |   |
| S-1 @ 5.0 ml                             |            |               |                    |  |                      |  |   |
| S-1 @ 10.0 ml                            |            |               |                    |  | 30                   |  |   |
| S-1 @ 10.0 ml                            |            |               |                    |  |                      |  |   |
| S-2 @ 50 ml                              |            |               |                    |  | 6                    |  |   |
| S-2 @ 50 ml                              |            |               |                    |  |                      |  |   |

\*Calculate only when samples average titrant is greater than 1 ml, and is 2 ml less than Average 15-minute Blank.

Table F-7. BOD<sub>5</sub> Worksheet Stations R-1 through R-8 - Moody AFB GA

Date Grabs Collected and Composited \_\_\_\_\_  
 Date BOD<sub>5</sub>'s Prepared \_\_\_\_\_ Analyzed \_\_\_\_\_

| Blanks                                   |                     | Bottle No. | ml of Titrant | Average ml of Titrant |   |              |                         |                              |
|--|---------------------|------------|---------------|-----------------------|---|--------------|-------------------------|------------------------------|
| 100% Aerated Dilution H <sub>2</sub> O @ |                     | 15 min     |               |                       |   |              |                         |                              |
|  |                     | 15 min     |               |                       |   |              |                         |                              |
|  |                     | 5 day      |               |                       |   |              |                         |                              |
|  |                     | 5 day      |               |                       |   |              |                         |                              |
| Net Change of Blanks →                   |                     |            |               |                       |   |              |                         |                              |
| Sta. No.                                 | Dilutions ml/300 ml | Bottle No. | ml of Titrant | Ave ml Titrant        | Ave 5-day Blank Minus Sample Ave Titrant* | Multi Factor | BOD <sub>5</sub> (mg/l) | Ave. BOD <sub>5</sub> (mg/l) |
|  | 10                  |            |               |                       |   | 30           |                         |                              |
|  | 10                  |            |               |                       |   | 15           |                         |                              |
|  | 20                  |            |               |                       |   | 3            |                         |                              |
|  | 20                  |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 10                  |            |               |                       |   | 30           |                         |                              |
|  | 10                  |            |               |                       |   | 15           |                         |                              |
|  | 20                  |            |               |                       |   | 3            |                         |                              |
|  | 20                  |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 10                  |            |               |                       |   | 30           |                         |                              |
|  | 10                  |            |               |                       |   | 15           |                         |                              |
|  | 20                  |            |               |                       |   | 3            |                         |                              |
|  | 20                  |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 10                  |            |               |                       |   | 30           |                         |                              |
|  | 10                  |            |               |                       |   | 15           |                         |                              |
|  | 20                  |            |               |                       |   | 3            |                         |                              |
|  | 20                  |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 10                  |            |               |                       |   | 30           |                         |                              |
|  | 10                  |            |               |                       |   | 15           |                         |                              |
|  | 20                  |            |               |                       |   | 3            |                         |                              |
|  | 20                  |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |
|  | 100                 |            |               |                       |   |              |                         |                              |

\*Calculate only when samples average titrant is greater than 1 ml, and is 2 ml less than average 15-minute blank.

Table F-8: Total Suspended Solids Worksheet -- All Stations

Date Grab Samples Collected and Composited \_\_\_\_\_  
 Date TSS Analyzed \_\_\_\_\_

| Station No. | Dried Weight (gms) of                                   | Multi Factor = $\frac{(1000) (1000)}{\text{Sample Volume (ml) Filtered}}$ |       | TSS (mg/l) |
|-------------|---|---|-------|------------|
|             |   |   |       |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |
|             | Paper + Solids _____<br>Paper _____<br>Difference _____ | (1000) (1000) = _____   | _____ |            |

5. Any grab samples which are to be composited should:

a. Be collected at the same time that flows are recorded/estimated and when other grab measurements are taken at the station. (See data worksheets, Tables F-3, F-4 and F-5).

b. Be of the following volumes:

(1) Stations S-1 and S-2. Determine the total flow (MG) from the plant's flow totalizer since the previous sampling and use Figure F-1 to determine each grab sample's volume. Note that:

(a) The day's first sample at 0800 hours must be proportioned to the day's flow since 0000 hours.

(b) These stations' composited samples will be for a 24-hour period.

(c) The composited samples' volume may be 1 gallon ( $\pm$  500 ml) depending on plant flow rates at time of sample collection.

(2) Stations R-1 through R-6: Record the station's flow condition and hours since previous sampling. Use Figure F-2 to determine each grab sample's volume. If the station is not flowing, grab 946 ml of sample during each of the four visits to the station. Note that:

(a) The day's first sample volume at 0800 hours should be for an 8-hour time period.

(b) These station's composited samples will be for a 16-hour period.

(c) Each station's composited sample volume should be approximately one gallon even though the stations flow rates may differ significantly.

(3) Stations R-7 and R-8: Since there is normally no flow at these stations, grab 946 ml of sample during each of the day's four visits to the station. Note that these stations' daily composite samples consist of four grab samples of equal volume and should total about one gallon in the plastic compositing container and one gallon in the glass compositing container.

c. Be dumped into the station's compositing containers. These containers should be kept in an unlighted 35°F refrigerator when not at the stations collecting the samples.

6. At the end of the sampling day or the following morning, the compositing containers should be well shaken and:




Figure F-1: Relationship of Flow to Sample Size at Sewage Treatment Plant -- Moody AFB, GA




Figure F-2: Relationship of Sampling Interval to Sample Size in Drainage Ditches/Lake Outfall -- Moody AFB, GA.

a. Used to prepare each station's BOD<sub>5</sub> and total suspended solids samples.

b. Used to prepare Station S-2's fecal coliform samples.

c. Split into the separate containers which will contain the appropriate preservatives.

(1) Properly label each of these containers with its "base sample number". Recommend these sample numbers be determined as in the example below:

S-1 - 73 - S - A  
[1] [2] [3] [4]

[1] Denotes the sampling station.

[2] Denotes the year of sampling.

[3] Denotes "S" for spring sampling or "F" for fall sampling.

[4] Denotes the EHL(K) analyses grouping and defines which analyses will be done on the sample as well as the sample's preservation.

(2) Record the base sample number on its station's data worksheet. (See Tables F-3, F-4 and F-5).

(3) Prepare a sample's analysis request form for each sample container to be sent to EHL(K). A recommended form is given as Table F-9.

(4) Pack and ship the prepared samples and paperwork to EHL(K) as quickly as possible.

#### IV. PROGRAM RESPONSIBILITIES AND COORDINATION

##### A. USAF Environmental Health Laboratory-Kelly AFB

1. Provide any telephonic consult needed in conducting this program.

2. Analyze the samples submitted and comment on any abnormal results.

B. Moody AFB. Suggested responsibilities for various base offices are:

1. Civil Engineering:



Table F-10. Coding of Water Sample Sources

| SOURCE OF SAMPLE   | CODE |
|--|------|
| Base Drinking Water Distribution System.....   | AA   |
| Boiler Water.....  | AB   |
| Deionized Water.....   | AC   |
| Distilled Water.....   | AD   |
| Irrigation Water.....  | AE   |
| Municipal Water Supply Furnished Base.....   | AF   |
| Industrial Process Water (Raw).....  | AG   |
| Industrial Process Water (Treated).....  | AH   |
| Other Treatment Process Water.....   | AI   |
| Raw Surface Water.....   | AJ   |
| Raw Ground Water.....  | AK   |
| Softened Water.....  | AL   |
| Steam Condensate.....  | AM   |
| Swimming Pool Water.....   | AN   |
| Treated Cooling Water.....   | AO   |
| Untreated Cooling Water.....   | AP   |
| Stream (Upstream of Base).....   | AQ   |
| Stream Not Receiving Waste Water (Downstream of Base).....                                 | AR   |
| Stream Receiving Waste Water (On Base).....  | AS   |
| Stream Receiving Waste Water (Downstream of Base).....                                     | AT   |
| Other Water Sample.....  | AU   |
| Aircraft & Ground Equipment Washrack Waste Water (Untreated).....                          | BA   |
| Aircraft & Ground Equipment Washrack Waste Water (After Oil Skimming).....                 | BB   |
| Aircraft & Ground Equipment Washrack Waste Water (After Oil Skimming & Sedimentation)..... | BC   |
| Activated Sludge or Extended Aeration Activated Sludge Treatment Plant Effluent.....       | BD   |
| Automotive Cleaning Waste Water.....   | BE   |
| Battery Shop Waste Water.....  | BF   |
| Chemical Waste Water Treatment Plant Effluent.....   | BG   |
| Chemical Waste Water Treatment Plant Influent.....   | BH   |
| Contact Aeration Treatment Plant Effluent.....   | BI   |
| Domestic Sewage Treatment Plant Influent.....  | BJ   |
| Domestic Sewage Lagoon, Final Effluent.....  | BK   |
| Domestic Sewage, Primary Treatment Effluent.....   | BL   |
| Electroplating Waste Water.....  | BM   |
| Filter Backwash Water.....   | BN   |
| Fuel Tank Cleaning Waste Water.....  | BO   |
| Floor Drain Waste Water.....   | BP   |
| General Storm Drainage Run-Off Waste Water.....  | BQ   |
| Ion Exchange Resin Bed Recharge Waste Water.....   | BR   |
| Missile Propellant Contaminated Waste Water.....   | BS   |
| Other Waste Water.....   | BT   |
| Parts Cleaning Wash Water (Multi-Stage Washers, etc.).....                                 | BU   |
| Paint Stripping Waste Water.....   | BV   |
| Photographic Waste Water.....  | BW   |
| POL Storage Waste Water.....   | BX   |
| Mixed Waste Water (Domestic & Industrial Waste).....                                       | BY   |

a. Collecting all prescribed data and samples from Stations C-1 and S-2.

b. Sharing sewage plant laboratory space and equipment with Military Public Health and assist them in analyzing BOD<sub>5</sub>, total suspended solids, and fecal coliform samples.

c. Coordinating with Military Public Health personnel in accomplishing this program.

d. Providing any additional manning Military Public Health may need in collecting all data and samples from Stations R-1 through R-8.

## 2. Military Public Health:

a. Having this program's worksheet forms locally reproduced.

b. Collecting all prescribed data and samples from stations R-1 through R-8.

c. Coordinating with Civil Engineering in analyzing all BOD<sub>5</sub>, total suspended solids, and fecal coliform samples.

d. Splitting the composited samples, labeling them, preparing analysis request forms, and shipping them to EHL(K) for analysis.

e. Tabulating field data and EHL(K) analyses into summary sheets for historical records and for submittal to the Base Environmental Protection Committee. Table F-11 lists all analyses recommended for each sampling station in this program. Recommend this table be locally reproduced for each station and used to summarize a given station's analyses.

f. Following-up abnormal results, resampling, and identifying pollutional sources.

## 3. Base Environmental Protection Committee:

a. Support this sampling program and review each station's semi-annual summary of analysis.

b. Coordinate with base agencies to control and/or adequately treat any pollutional discharges.

Table F-11: Summary of Analyses for Water Pollution Surveillance Sampling Station \_\_\_\_\_, Moody AFB, GA

| Data (mg/l unless noted)       | Sampling Day and Date                       |  |  |  |  |  |  |  |  |  |  |  |
|--------------------------------|---|--|--|--|--|--|--|--|--|--|--|--|
|                                |   |  |  |  |  |  |  |  |  |  |  |  |
| Dissolved O <sub>2</sub>       | Range                                       |  |  |  |  |  |  |  |  |  |  |  |
|                                | Average                                     |  |  |  |  |  |  |  |  |  |  |  |
| Temperature (°C)               | Range                                       |  |  |  |  |  |  |  |  |  |  |  |
|                                | Average                                     |  |  |  |  |  |  |  |  |  |  |  |
| pH                             | Range                                       |  |  |  |  |  |  |  |  |  |  |  |
|                                | Average                                     |  |  |  |  |  |  |  |  |  |  |  |
| Total Chlorine Residual        | Range                                       |  |  |  |  |  |  |  |  |  |  |  |
|                                | Average                                     |  |  |  |  |  |  |  |  |  |  |  |
| Flow ( )                       |   |  |  |  |  |  |  |  |  |  |  |  |
| BOD <sub>5</sub>               |   |  |  |  |  |  |  |  |  |  |  |  |
| COD                            |   |  |  |  |  |  |  |  |  |  |  |  |
| Total Organic Carbon           |   |  |  |  |  |  |  |  |  |  |  |  |
| Oils/Grease (by IR)            |   |  |  |  |  |  |  |  |  |  |  |  |
| Surfactants, MBAS (as LAS)     |   |  |  |  |  |  |  |  |  |  |  |  |
| Total Kjeldahl Nitrogen (as N) |   |  |  |  |  |  |  |  |  |  |  |  |
| Total Suspended Solids         |   |  |  |  |  |  |  |  |  |  |  |  |
| Turbidity (units)              |   |  |  |  |  |  |  |  |  |  |  |  |
| Color (units)                  |   |  |  |  |  |  |  |  |  |  |  |  |
| Fecal Coliform ( #/100ml)      |   |  |  |  |  |  |  |  |  |  |  |  |
| RADICALS                       | Ammonia, NH <sub>3</sub> (as N)             |  |  |  |  |  |  |  |  |  |  |  |
|                                | Cyanide, CN                                 |  |  |  |  |  |  |  |  |  |  |  |
|                                | Nitrate, NO <sub>3</sub> (as N)             |  |  |  |  |  |  |  |  |  |  |  |
|                                | Phenolics, C <sub>6</sub> H <sub>5</sub> OH |  |  |  |  |  |  |  |  |  |  |  |
|                                | Phosphate, Total-PO <sub>4</sub> (as P)     |  |  |  |  |  |  |  |  |  |  |  |
| METALS/IONS                    | Cadmium                                     |  |  |  |  |  |  |  |  |  |  |  |
|                                | Chloride                                    |  |  |  |  |  |  |  |  |  |  |  |
|                                | Chromium, Hexavalent                        |  |  |  |  |  |  |  |  |  |  |  |
|                                | Chromium, Total                             |  |  |  |  |  |  |  |  |  |  |  |
|                                | Copper                                      |  |  |  |  |  |  |  |  |  |  |  |
|                                | Iron  |  |  |  |  |  |  |  |  |  |  |  |
|                                | Lead  |  |  |  |  |  |  |  |  |  |  |  |
|                                | Manganese                                   |  |  |  |  |  |  |  |  |  |  |  |
|                                | Mercury                                     |  |  |  |  |  |  |  |  |  |  |  |
|                                | Nickel                                      |  |  |  |  |  |  |  |  |  |  |  |
|                                | Silver                                      |  |  |  |  |  |  |  |  |  |  |  |
|                                | Zinc  |  |  |  |  |  |  |  |  |  |  |  |
| Pesticides                     |   |  |  |  |  |  |  |  |  |  |  |  |
|                                |   |  |  |  |  |  |  |  |  |  |  |  |

APPENDIX G  
FIELD SURVEY RESULTS

The following tables present the results of a field survey conducted in accordance with the sampling program described in Appendix E. The results are for the period 27 Sep - 7 Oct 1972.

Table G-1: Data Summary for Sampling Station S-1, Moody AFB, GA\*

| Chemical/Physical Data** (mg/l unless noted) | Sampling Day and Date (1972)* |            |           |           |           |           |           |         |         |         | Values  |         |         |
|--|-------------------------------|------------|-----------|-----------|-----------|-----------|-----------|---------|---------|---------|---------|---------|---------|
|  | Wed 27 Sep                    | Fri 29 Sep | Sun 1 Oct | Mon 2 Oct | Wed 4 Oct | Fri 5 Oct | Sat 7 Oct | Maximum | Minimum | Average | Maximum | Minimum | Average |
| Range  | <0-2.0                        | <0-0.0     | <0-4.6    | <0-1.5    | <0-2.4    | <0-0.0    | <0-0.4    |         |         |         |         |         |         |
| Average                                      | <0.0                          | <0.0       | 1.0       | 0.2       | 0.6       | <0.0      | <0.0      | 4.6     | <0.0    | <0.0    | <0.0    | <0.0    | <0.0    |
| Range  | 28-29                         | 25-29      | 26-28     | 25-27     | 27-28     | 27-28     | 25-27     |         |         |         |         |         |         |
| Average                                      | 28                            | 28         | 27        | 26        | 27        | 28        | 26        | 29      | 25      | 27      | 25      | 27      | 27      |
| Range  | 6.7-7.3                       | 6.8-7.2    | 6.9-7.9   | 7.2-7.4   | 7.2-7.9   | 7.5-7.8   | 6.9-7.2   |         |         |         |         |         |         |
| Average                                      | 7.0                           | 7.1        | 7.2       | 7.3       | 7.4       | 7.2       | 7.0       | 7.9     | 6.7     | 7.2     | 6.7     | 7.2     | 7.2     |
| Flow (MGD)                                   | 0.382                         | 0.391      | 0.312     | 0.324     | 0.449     | 0.374     | 0.358     | 0.449   | 0.312   | 0.370   | 0.449   | 0.312   | 0.370   |
| ECOD   | (*)                           | (*)        | (*)       | (*)       | (*)       | 122       | 120       | 122     | 120     | 121     | 122     | 120     | 121     |
| CO <sub>2</sub>                              | 255                           | 223        | 120       | 353       | 148       | 142       | 220       | 353     | 120     | 209     | 353     | 120     | 209     |
| Total Organic Carbon                         | 63                            | 53         | 37        | 96        | 40        | 41        | 48        | 96      | 37      | 54      | 96      | 37      | 54      |
| Oils/Greases (by IR)                         | (*)                           | 30.0       | 23.0      | 17.5      | 18.0      | 13.0      | 23.8      | 30.0    | 13.0    | 20.9    | 30.0    | 13.0    | 20.9    |
| Surfactants, MBAS (as LAS)                   | 15.0                          | 20.0       | 7.0       | 25.0      | 7.7       | 2.2       | 22.0      | 25.0    | 2.2     | 14.1    | 25.0    | 2.2     | 14.1    |
| Total Kjeldahl Nitrogen (as N)               | 19.34                         | 19.75      | 15.31     | 15.09     | 28.39     | 21.79     | 40.01     | 40.01   | 15.09   | 22.8    | 40.01   | 15.09   | 22.8    |
| Ammonia, NH <sub>3</sub> (as N)              | 13.92                         | 18.0       | 13.20     | 12.40     | 23.4      | 16.8      | 36.6      | 36.6    | 12.4    | 19.2    | 36.6    | 12.4    | 19.2    |
| Cyanide, C <sub>2</sub>                      | <0.01                         | <0.01      | <0.01     | <0.01     | <0.01     | <0.01     | <0.01     | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |
| Nitrate, NO <sub>3</sub> (as N)              | <0.2                          | <0.2       | 0.3       | 0.6       | <0.2      | 0.23      | <0.2      | 0.6     | <0.2    | 0.3     | <0.2    | <0.2    | 0.3     |
| Nitrite, N <sub>2</sub> (as N)               | <0.005                        | <0.005     | 0.006     | 0.006     | <0.006    | <0.005    | <0.005    | 0.006   | <0.005  | <0.005  | <0.006  | <0.005  | <0.005  |
| Phenolics, C <sub>6</sub> H <sub>5</sub> OH  | 0.010                         | 0.010      | 0.025     | 0.005     | 0.010     | 0.010     | 0.010     | 0.025   | 0.005   | 0.011   | 0.025   | 0.005   | 0.011   |
| Phosphate, Total-PO <sub>4</sub> (as P)      | 11.2                          | 8.1        | 4.3       | 0.6       | 7.6       | 10.2      | 13.9      | 13.9    | 0.60    | 8.0     | 13.9    | 0.60    | 8.0     |
| Aluminum                                     | 0.20                          | 0.24       | 0.16      | 0.28      | 0.2       | <0.1      | 0.2       | 0.28    | <0.1    | 0.20    | 0.28    | <0.1    | 0.20    |
| Cadmium                                      | <0.01                         | <0.01      | <0.01     | <0.01     | <0.01     | <0.01     | <0.01     | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |
| Chloride                                     | 56                            | 20         | 16        | 20        | 40        | 16        | 24        | 56      | 16      | 27.4    | 56      | 16      | 27.4    |
| Chromium, Hexavalent                         | <0.05                         | <0.05      | <0.05     | <0.05     | <0.05     | <0.05     | <0.05     | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Chromium, Total                              | <0.05                         | <0.05      | <0.05     | <0.05     | <0.05     | <0.05     | <0.05     | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Copper                                       | 0.06                          | 0.06       | 0.06      | 0.04      | 0.04      | 0.03      | 0.04      | 0.06    | 0.03    | 0.05    | 0.06    | 0.03    | 0.05    |
| Iron   | 0.34                          | 0.31       | 0.12      | 0.16      | 0.25      | 0.10      | 0.25      | 0.34    | 0.10    | 0.22    | 0.34    | 0.10    | 0.22    |
| Lead   | <0.05                         | <0.05      | <0.05     | <0.05     | <0.05     | <0.05     | <0.05     | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Manganese                                    | <0.05                         | <0.05      | <0.05     | <0.05     | <0.05     | <0.05     | <0.05     | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Mercury                                      | <0.005                        | <0.005     | <0.005    | <0.005    | <0.005    | <0.005    | <0.005    | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  |
| Nickel                                       | <0.05                         | <0.05      | <0.05     | <0.05     | <0.05     | <0.05     | <0.05     | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Silver                                       | <0.01                         | <0.01      | <0.01     | <0.01     | <0.01     | <0.01     | <0.01     | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |
| Zinc   | 0.10                          | 0.09       | 0.09      | 0.07      | 0.06      | <0.05     | 0.16      | 0.16    | <0.05   | 0.09    | 0.16    | <0.05   | 0.09    |
| Chlorodane (µg/l)                            |                               |            |           |           |           |           |           |         |         |         |         |         |         |
| SS (ppm)                                     |                               |            |           |           |           |           |           |         |         |         |         |         |         |
| DO (ppm)                                     |                               |            |           |           |           |           |           |         |         |         |         |         |         |
| DO <sub>2</sub> (ppm)                        |                               |            |           |           |           |           |           |         |         |         |         |         |         |

NOTES: \* Sampling station is identified and survey techniques are discussed in "Water Pollution Survey Operations Plan, Moody AFB, GA," Special Project 71-51, USAF Environmental Health Lab, Kelly AFB, TX 78211, (February 1972).

\*\* The first four data were determined from grab samples during the survey day while the remaining data were analyzed on 24-hour composite samples collected proportional to flow throughout the day. All samples were properly preserved.

(\*) Sample container was broken before sample could be analyzed.

+ Units are nanograms per liter.

Blank entries in column denote that such data were not required in the "Survey Plan".

Table G-2: Data Summary for Sampling Station S-2, Moody AFB, GA\*

| Chemical/Physical Data** (=2/1 unless noted) | Sampling Day and Date (1972)* |         |         |         |         |         |         | Values  |         |         |
|--|-------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
|  | Wed                           | Fri     | Sun     | Mon     | Wed     | Fri     | Sat     | Maximum | Minimum | Average |
| Disolved O <sub>2</sub>                      | 4.7-6.0                       | 1.0-4.3 | 3.8-6.2 | 2.0-5.4 | 3.1-6.5 | 1.6-6.4 | 1.3-5.5 |         |         |         |
| Average                                      | 5.4                           | 2.6     | 5.2     | 4.6     | 4.1     | 4.3     | 3.7     | 6.5     | 1.0     | 4.3     |
| Temperature °C                               | 27-29                         | 25-28   | 25-26   | 25-26   | 24-27   | 25-28   | 25-25   |         |         |         |
| Average                                      | 28.                           | 27.     | 25.     | 25.     | 26.     | 26.     | 25.     | 29.     | 24.     | 26.     |
| pH (units)                                   | 7.0-7.3                       | 6.9-7.4 | 7.2-7.4 | 7.2-7.3 | 7.0-7.5 | 7.2-7.8 | 6.7-7.3 |         |         |         |
| Average                                      | 7.2                           | 7.3     | 7.3     | 7.3     | 7.4     | 7.4     | 7.1     | 7.8     | 6.7     | 7.3     |
| Flow (MGD)                                   | 0.382                         | 0.391   | 0.312   | 0.324   | 0.449   | 0.347   | 0.358   | 0.449   | 0.312   | 0.370   |
| BOD <sub>5</sub>                             | <12.                          | <12.    | 18.     | <12.    | 66.     | <12.    | <12.    | 66.     | <12.    | <20.    |
| CO <sub>2</sub>                              | 49.                           | 11.     | 22.     | 22.     | 33.     | 49.     | 71.     | 71.     | 11.     | 37.     |
| Total Organic Carbon                         | 11.                           | 4.      | 7.      | 7.      | 5.      | 11.     | 14.     | 14.     | 4.      | 8.      |
| Oils/Greases (by IR)                         | 1.6                           | 0.9     | 2.6     | 0.4     | 1.4     | 2.6     | 2.6     | 2.6     | 0.4     | 1.7     |
| Surfactants, MBAS (as LAS)                   | 0.9                           | 1.6     | 1.5     | 1.1     | 1.2     | 2.2     | 0.3     | 2.2     | 0.3     | 1.3     |
| Total Kjeldahl Nitrogen (as N)               | 1.68                          | 4.77    | 2.20    | 1.63    | 2.68    | 5.4     | 1.9     | 5.40    | 1.63    | 2.89    |
| Ammonia, NH <sub>3</sub> (as N)              | 0.096                         | 2.59    | 0.62    | 0.38    | 0.98    | 2.83    | 0.10    | 2.83    | 0.10    | 1.09    |
| Chloride, CN                                 | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |
| Nitrate, NO <sub>3</sub> (as N)              | 9.5                           | 0.7     | 4.0     | 7.0     | 5.42    | 0.27    | 0.68    | 9.50    | 0.27    | 1.94    |
| Nitrite, NO <sub>2</sub> (as N)              | 0.03                          | 0.199   | 0.038   | 0.018   | 0.042   | 0.182   | 0.608   | 0.608   | 0.182   | 0.160   |
| Phenolics, C <sub>6</sub> H <sub>5</sub> OH  | 0.010                         | 0.015   | <0.001  | <0.001  | 0.005   | 0.005   | 0.010   | 0.015   | <0.001  | 0.007   |
| Phosphate, Total-PO <sub>4</sub> (as P)      | 4.0                           | 4.7     | 5.6     | 6.8     | 6.3     | 7.3     | 11.9    | 11.9    | 4.0     | 6.7     |
| Aluminum                                     | <0.10                         | 0.14    | 0.10    | <0.10   | 0.2     | <0.1    | <0.1    | 0.2     | <0.10   | 0.1     |
| Cadmium                                      | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |
| Chloride                                     | 16.                           | 28.     | 32.     | 36.     | 28.     | 36.     | 36.     | 36.     | 16.     | 30.     |
| Chromium, Hexavalent                         | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Chromium, Total                              | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Copper                                       | 0.03                          | 0.03    | <0.02   | <0.02   | 0.04    | 0.03    | 0.03    | 0.04    | <0.02   | 0.03    |
| Iron   | <0.10                         | <0.10   | 0.16    | 0.14    | 0.25    | 0.25    | 0.59    | 0.59    | <0.10   | 0.23    |
| Lead   | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Manganese                                    | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | 0.10    | 0.10    | <0.05   | 0.05    |
| Mercury                                      | <0.005                        | <0.005  | <0.005  | <0.005  | <0.005  | 0.008   | 0.003   | 0.008   | <0.005  | <0.016  |
| Nickel                                       | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |
| Silver                                       | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |
| Zinc   | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | 0.06    | <0.05   | 0.06    | <0.05   | <0.05   |
| 1,1-Dichloroethane (ugm/l)                   |                               |         |         |         |         |         |         |         |         |         |
| BOD <sub>5</sub> (+)                         |                               |         |         |         |         |         |         |         |         |         |
| BOD <sub>5</sub> (-)                         |                               |         |         |         |         |         |         |         |         |         |
| BOD <sub>5</sub> (+)                         |                               |         |         |         |         |         |         |         |         |         |

NOTES: \* Sampling station is identified and survey techniques are discussed in "Water Pollution Survey Operations Plan, Moody AFB, GA," Special Project 71-51, USAF Environmental Health Lab, Kelly AFB, TX 78241, (February 1972).  
 \*\* The first four data were determined from grab samples during the survey day while the remaining data were analyzed on 24-hour composite samples collected proportional to flow throughout the day. All samples were properly preserved.  
 (\*) Sample container was broken before sample could be analyzed.  
 + Units are nanograms per liter.

Blank entries in column denote that such data were not required in the "Survey Plan".

Table G-3: Data Summary for Sampling Station R-1, Moody AFB, GA\*

| Chemical/Physical Data** (mg/l unless noted) | Sampling Day and Date (1972)* |               |               |              |              |         |         | Values  |  |  |
|--|-------------------------------|---------------|---------------|--------------|--------------|---------|---------|---------|--|--|
|  | Tue<br>26 Sep                 | Fri<br>29 Sep | Sat<br>30 Sep | Wed<br>4 Oct | Sat<br>7 Oct | Maximum | Minimum | Average |  |  |
| Dissolved O <sub>2</sub>                     | 2.8-5.4                       | 1.1-5.7       | 2.5-7.1       | 0.3-6.6      | 3.2-6.5      |         |         |         |  |  |
| Range  | 3.8                           | 4.2           | 5.8           | 3.5          | 4.9          |         |         |         |  |  |
| Average                                      |                               |               |               |              |              | 7.1     | 4.4     | 4.4     |  |  |
| Temperature °C                               | 26-30                         | 25-26         | 26-27         | 23-27        | 23-24        |         |         |         |  |  |
| Range  | 28                            | 26            | 27            | 25           | 24           |         |         |         |  |  |
| Average                                      |                               |               |               |              |              | 30      | 23      | 26      |  |  |
| pH (units)                                   | 7.3-7.6                       | 7.2-7.6       | 7.3-7.6       | 7.2-7.7      | 7.3-7.6      |         |         |         |  |  |
| Range  | 7.4                           | 7.4           | 7.5           | 7.5          | 7.4          |         |         |         |  |  |
| Average                                      |                               |               |               |              |              | 7.7     | 7.2     | 7.4     |  |  |
| Flow (GD)                                    | 4359                          | 3948          | 5576          | 7960         | 4071         | 7960    | 3948    | 5183    |  |  |
| BOD <sub>5</sub>                             | 22                            | 91            | 16            | 30           | 50           | 91      | 16      | 42      |  |  |
| COD  | 163                           | 511           | 22            | 109          | 44           | 511     | 22      | 170     |  |  |
| Total Organic Carbon                         | 33                            | 98            | 6             | 24           | 10           | 98      | 6       | 34      |  |  |
| Oils/Greases (by IR)                         | (*)                           | 1.8           | 3.5           | 5.2          | 4.9          | 5.2     | 1.8     | 3.9     |  |  |
| Surfactants, MBAS (as LAS)                   | 20                            | (*)           | 7.6           | 13.6         | 13.6         | 20.0    | 7.6     | 13.7    |  |  |
| Total Kjeldahl Nitrogen (as N)               | 0.03                          | 0.87          | 1.36          | 2.08         | 1.18         | 2.08    | 0.03    | 1.10    |  |  |
| Ammonia, NH <sub>3</sub> (as N)              | 0.03                          | 0.46          | 0.38          | 0.14         | 0.94         | 0.94    | 0.03    | 0.40    |  |  |
| Cyanide, CN                                  |                               |               |               |              |              |         |         |         |  |  |
| Nitrate, NO <sub>3</sub> (as N)              | <0.2                          | 0.3           | <0.2          | <0.2         | <0.2         | 0.3     | <0.2    | <0.2    |  |  |
| Nitrite, NO <sub>2</sub> (as N)              | 0.006                         | <0.005        | <0.005        | <0.005       | <0.005       | 0.006   | <0.005  | <0.005  |  |  |
| Phenolics, C <sub>6</sub> H <sub>5</sub> OH  |                               |               |               |              |              |         |         |         |  |  |
| Phosphate, Total-P0 <sub>4</sub> (as P)      | 1.5                           | 1.6           | 1.9           | <0.1         | 7.3          | 7.3     | <0.1    | 2.5     |  |  |
| Aluminum                                     | 0.29                          | 0.26          | 0.28          | 0.20         | 1.0          | 1.0     | 0.20    | 0.41    |  |  |
| Calcium                                      | <0.01                         | <0.01         | <0.01         | <0.01        | <0.01        | <0.01   | <0.01   | <0.01   |  |  |
| Chloride                                     |                               |               |               |              |              |         |         |         |  |  |
| Chromium, Hexavalent                         | <0.05                         | <0.05         | <0.05         | <0.05        | <0.05        | <0.05   | <0.05   | <0.05   |  |  |
| Chromium, Total                              | <0.05                         | <0.05         | <0.05         | <0.05        | <0.05        | <0.05   | <0.05   | <0.05   |  |  |
| Copper                                       | <0.02                         | <0.02         | <0.02         | <0.02        | <0.02        | <0.02   | <0.02   | <0.02   |  |  |
| Iron   | 0.10                          | 0.44          | 0.31          | 1.29         | 0.30         | 1.29    | 0.10    | 0.49    |  |  |
| Lead   | <0.05                         | <0.05         | <0.05         | <0.05        | <0.05        | <0.05   | <0.05   | <0.05   |  |  |
| Manganese                                    | <0.05                         | <0.05         | <0.05         | 0.06         | <0.05        | 0.06    | <0.05   | <0.05   |  |  |
| Mercury                                      | <0.005                        | <0.005        | <0.005        | <0.005       | 0.008        | 0.008   | <0.005  | <0.005  |  |  |
| Nickel                                       | <0.05                         | 0.07          | <0.05         | <0.05        | <0.05        | 0.07    | <0.05   | <0.05   |  |  |
| Silver                                       | <0.01                         | <0.01         | <0.01         | <0.01        | <0.01        | <0.01   | <0.01   | <0.01   |  |  |
| Zinc   | 0.09                          | <0.05         | 0.09          | <0.05        | <0.05        | 0.09    | <0.05   | 0.06    |  |  |
| Chlorodane (µg/l)                            |                               |               |               |              |              |         |         |         |  |  |
| DDE (+)                                      |                               |               |               |              |              |         |         |         |  |  |
| DDT (+)                                      |                               |               |               |              |              |         |         |         |  |  |
| PCP (+)                                      |                               |               |               |              |              |         |         |         |  |  |

NOTES: \* Sampling station is identified and survey techniques are discussed in "Water Pollution Survey Operations Plan, Moody AFB, GA," Special Project 71-51, USAF Environmental Health Lab, Kelly AFB, TX 78211, (February 1972).

\*\* The first four data were determined from grab samples during the survey day while the remaining data were analyzed on 24-hour composite samples collected proportional to flow throughout the day. All samples were properly preserved.

(\*) Sample container was broken before sample could be analyzed.

+ Units are nanograms per liter.

blank entries in column denote that such data were not required in the "Survey Plan".

Table G-4: Data Summary for Sampling Station R-2, Moody AFB, GA\*

| Chemical/Physical Data** (mg/l unless noted) | Sampling Day and Date (1972)* |               |               |               |               |              |         |         |         |        | Values                    |  |  |
|--|-------------------------------|---------------|---------------|---------------|---------------|--------------|---------|---------|---------|--------|---------------------------|--|--|
|  | Mon<br>25 Sep                 | Tue<br>26 Sep | Wed<br>27 Sep | Thu<br>28 Sep | Fri<br>29 Sep | Wed<br>4 Oct | Maximum | Minimum | Average |        |                           |  |  |
| Dissolved O2                                 | Range                         | <0.0          | <0.0          | <0.0          | <0.0          | <0.0         | <0.0    | <0.0    | <0.0    |        |                           |  |  |
|  | Average                       | <0.0          | <0.0          | <0.0          | <0.0          | <0.0         | <0.0    | <0.0    | <0.0    |        |                           |  |  |
| Temperature °C                               | Range                         | 24-27         | 26-28         | 25-28         | 24-27         | 23-27        | 28.     | 23.     | 26.     |        |                           |  |  |
|  | Average                       | 26.           | 27.           | 27.           | 26.           | 25.          | 28.     | 23.     | 26.     |        |                           |  |  |
| pH (units)                                   | Range                         | 6.2-8.0       | 5.7-6.0       | 5.5-5.6       | 6.3-6.7       | 5.8-6.1      | 5.7-6.0 | 8.0     | 5.5     | 6.1    | Average Loading (lbs/day) |  |  |
|  | Average                       | 7.1           | 5.9           | 5.6           | 6.5           | 6.0          | 5.8     | 8.0     | 5.5     | 6.1    |                           |  |  |
| Flow (GD)                                    | Range                         | 5438.         | 9407.         | 8722.         | 8443.         | 9217.        | 8715.   | 9407.   | 5438.   | 8226.  |                           |  |  |
|  | Average                       | 312           | 186.          | 300.          | 255.          | 320.         | 312.    | 320.    | 186.    | 275.   |                           |  |  |
| BOD5   | Range                         | 424.          | 508.          | (*)           | 429.          | 999.         | 1071.   | 1071.   | 424.    | 706.   |                           |  |  |
|  | Average                       | 87            | 118.          | (*)           | 159.          | 250.         | 285.    | 285.    | 87.     | 180.   |                           |  |  |
| Total Organic Carbon                         | Range                         | 0.4           | 4.6           | 10.0          | 14.4          | 0.7          | 7.1     | 14.4    | 0.7     | 8.1    |                           |  |  |
|  | Average                       | 0.4           | 4.6           | 10.0          | 14.4          | 0.7          | 7.1     | 14.4    | 0.7     | 8.1    |                           |  |  |
| Oils/Greases (by IR)                         | Range                         | 0.4           | 4.6           | 10.0          | 14.4          | 0.7          | 7.1     | 14.4    | 0.7     | 8.1    |                           |  |  |
|  | Average                       | 0.4           | 4.6           | 10.0          | 14.4          | 0.7          | 7.1     | 14.4    | 0.7     | 8.1    |                           |  |  |
| Surfactants, MBAS (as LAS)                   | Range                         | 6.52          | 4.46          | 4.37          | 14.52         | 2.50         | 18.96   | 18.96   | 2.50    | 8.56   |                           |  |  |
|  | Average                       | 6.16          | 0.81          | 3.84          | 6.48          | 1.30         | 10.80   | 10.80   | 0.81    | 4.90   |                           |  |  |
| Total Kjeldahl Nitrogen (as N)               | Range                         | <0.01         | <0.01         | <0.01         | <0.01         | <0.01        | <0.01   | <0.01   | <0.01   | <0.01  |                           |  |  |
|  | Average                       | <0.01         | <0.01         | <0.01         | <0.01         | <0.01        | <0.01   | <0.01   | <0.01   | <0.01  |                           |  |  |
| Ammonia, NH3 (as N)                          | Range                         | 0.5           | <0.2          | <0.2          | 0.3           | <0.2         | <0.2    | 0.5     | <0.2    | 0.3    |                           |  |  |
|  | Average                       | <0.005        | <0.005        | <0.005        | 0.006         | <0.005       | <0.005  | 0.006   | <0.005  | <0.005 |                           |  |  |
| Nitrate, NO3 (as N)                          | Range                         | 0.90          | 0.100         | 0.105         | 0.115         | 0.115        | 0.130   | 0.130   | 0.090   | 0.109  |                           |  |  |
|  | Average                       | 9.6           | 11.5          | 4.7           | <0.1          | 8.1          | 2.6     | 11.5    | <0.1    | 6.1    |                           |  |  |
| Nitrite, NO2 (as N)                          | Range                         | 1.00          | 0.68          | 0.70          | 0.60          | 0.48         | 1.00    | 1.00    | 0.48    | 0.74   |                           |  |  |
|  | Average                       | <0.01         | <0.01         | <0.01         | <0.01         | <0.01        | <0.01   | <0.01   | <0.01   | <0.01  |                           |  |  |
| Phenolics, C6H5OH                            | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Phosphate, Total-PO4 (as P)                  | Range                         | 4.07          | 2.92          | 4.72          | 2.67          | 3.89         | 4.90    | 4.90    | 2.67    | 3.86   |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Lead   | Range                         | 0.18          | 0.14          | 0.14          | 0.08          | 0.14         | 0.12    | 0.18    | 0.08    | 0.13   |                           |  |  |
|  | Average                       | <0.005        | <0.005        | <0.005        | <0.005        | <0.005       | <0.005  | <0.005  | <0.005  | <0.005 |                           |  |  |
| Manganese                                    | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Mercury                                      | Range                         | <0.01         | <0.01         | <0.01         | <0.01         | <0.01        | <0.01   | <0.01   | <0.01   | <0.01  |                           |  |  |
|  | Average                       | <0.01         | <0.01         | <0.01         | <0.01         | <0.01        | <0.01   | <0.01   | <0.01   | <0.01  |                           |  |  |
| Nickel                                       | Range                         | 0.06          | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | 0.06    | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.003        | <0.003        | <0.003        | <0.003        | <0.003       | <0.003  | <0.003  | <0.003  | <0.003 |                           |  |  |
| Silver                                       | Range                         | <0.001        | <0.001        | <0.001        | <0.001        | <0.001       | <0.001  | <0.001  | <0.001  | <0.001 |                           |  |  |
|  | Average                       | <0.001        | <0.001        | <0.001        | <0.001        | <0.001       | <0.001  | <0.001  | <0.001  | <0.001 |                           |  |  |
| Zinc   | Range                         | <0.01         | <0.01         | <0.01         | <0.01         | <0.01        | <0.01   | <0.01   | <0.01   | <0.01  |                           |  |  |
|  | Average                       | <0.001        | <0.001        | <0.001        | <0.001        | <0.001       | <0.001  | <0.001  | <0.001  | <0.001 |                           |  |  |
| Chlorodane (µgm/l)                           | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Cadmium                                      | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Chloride                                     | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Chromium, Hexavalent                         | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Cromium, Total                               | Range                         | 0.03          | <0.02         | 0.02          | <0.02         | <0.02        | 0.02    | 0.03    | <0.02   | <0.02  |                           |  |  |
|  | Average                       | 4.07          | 2.92          | 4.72          | 2.67          | 3.89         | 4.90    | 4.90    | 2.67    | 3.86   |                           |  |  |
| Copper                                       | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Iron   | Range                         | 0.18          | 0.14          | 0.14          | 0.08          | 0.14         | 0.12    | 0.18    | 0.08    | 0.13   |                           |  |  |
|  | Average                       | <0.005        | <0.005        | <0.005        | <0.005        | <0.005       | <0.005  | <0.005  | <0.005  | <0.005 |                           |  |  |
| Lead   | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| Mercury                                      | Range                         | <0.01         | <0.01         | <0.01         | <0.01         | <0.01        | <0.01   | <0.01   | <0.01   | <0.01  |                           |  |  |
|  | Average                       | <0.001        | <0.001        | <0.001        | <0.001        | <0.001       | <0.001  | <0.001  | <0.001  | <0.001 |                           |  |  |
| Nickel                                       | Range                         | 0.06          | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | 0.06    | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.003        | <0.003        | <0.003        | <0.003        | <0.003       | <0.003  | <0.003  | <0.003  | <0.003 |                           |  |  |
| Silver                                       | Range                         | <0.001        | <0.001        | <0.001        | <0.001        | <0.001       | <0.001  | <0.001  | <0.001  | <0.001 |                           |  |  |
|  | Average                       | <0.001        | <0.001        | <0.001        | <0.001        | <0.001       | <0.001  | <0.001  | <0.001  | <0.001 |                           |  |  |
| Zinc   | Range                         | <0.01         | <0.01         | <0.01         | <0.01         | <0.01        | <0.01   | <0.01   | <0.01   | <0.01  |                           |  |  |
|  | Average                       | <0.001        | <0.001        | <0.001        | <0.001        | <0.001       | <0.001  | <0.001  | <0.001  | <0.001 |                           |  |  |
| Chlorodane (µgm/l)                           | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| DDE (+)                                      | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| DDD (+)                                      | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
| DDT (+)                                      | Range                         | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |
|  | Average                       | <0.05         | <0.05         | <0.05         | <0.05         | <0.05        | <0.05   | <0.05   | <0.05   | <0.05  |                           |  |  |

NOTES: \* Sampling station is identified and survey techniques are discussed in "Water Pollution Survey Operations Plan, Moody AFB, GA," Special Project 71-31, USAF Environmental Health Lab, Kelly AFB, TX 78211, (February 1972).

\*\* The first four data were determined from grab samples during the survey day while the remaining data were analyzed on 24-hour composite samples collected proportional to flow throughout the day. All samples were properly preserved.

(\*) Sample container was broken before sample could be analyzed.

+ Units are nanograms per liter.

Blank entries in column denote that such data were not required in the "Survey Plan".

Table G-3: Data Summary for Sampling Station R-3, Moody AFB, GA\*

| Chemical/Physical Data** (mg/l unless noted) | Sampling Day and Date (1972)* |         |         |         |         |         |     |        |        |       | Values  |         |         |
|--|-------------------------------|---------|---------|---------|---------|---------|-----|--------|--------|-------|---------|---------|---------|
|  | Mon                           | Tue     | Wed     | Thu     | Fri     | Wed     | Thu | 28 Sep | 29 Sep | 4 Oct | Maximum | Minimum | Average |
| Dissolved O <sub>2</sub>                     | 25 Sep                        | 4.1-6.5 | 3.7-8.3 | 4.0-7.6 | 2.2-6.9 | 3.9-8.9 |     |        |        |       |         |         |         |
|  | Range                         | 5.7     | 5.4     | 6.1     | 6.0     | 4.9     | 6.8 |        |        |       | 8.9     | 2.2     | 5.8     |
| Temperature °C                               | 24-29                         | 24-27   | 26-28   | 24-26   | 24-26   | 23-26   |     |        |        |       |         |         |         |
|  | Range                         | 26      | 27      | 25      | 25      | 25      |     |        |        |       | 29      | 23      | 26      |
| pH (units)                                   | 6.0-6.9                       | 5.5-5.8 | 5.6-5.8 | 5.4-6.0 | 5.9-6.2 | 6.2-6.3 |     |        |        |       |         |         |         |
|  | Average                       | 6.4     | 5.6     | 5.7     | 5.8     | 6.1     | 6.3 |        |        |       | 6.9     | 5.4     | 6.0     |
| Flow (GD)                                    | 2565                          | 2144    | 1874    | 2243    | 1540    | 3100    |     |        |        |       |         |         |         |
|  | <12                           | <12     | <12     | 15      | <12     | <12     |     |        |        |       | 15      | <12     | <12     |
| COD <sub>5</sub>                             | 5                             | 22      | 27      | <5.0    | 43      | 16      |     |        |        |       |         |         |         |
|  | 2                             | 7       | 4       | 1.0     | 9       | 5       |     |        |        |       | 9       | 1       | 5       |
| Total Organic Carbon                         | (*)                           | (*)     | (*)     | <0.3    | 0.8     | 1.2     |     |        |        |       |         |         |         |
|  | 3.0                           | 1.3     | 0.7     | 0.4     | 20.0    | 0.48    |     |        |        |       | 1.2     | 0.3     | 0.8     |
| Surfactants, NPAS (as LAS)                   | 0.58                          | <0.01   | 0.54    | 0.51    | 1.15    | 1.1     |     |        |        |       |         |         |         |
|  | <0.01                         | <0.01   | 0.04    | 0.17    | 0.38    | 0.12    |     |        |        |       | 1.15    | 0.01    | 0.65    |
| Ammonia, NH <sub>3</sub> (as N)              | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |     |        |        |       |         |         |         |
|  | <0.2                          | <0.2    | <0.2    | <0.2    | <0.2    | <0.2    |     |        |        |       | <0.2    | <0.2    | <0.004  |
| Nitrate, NO <sub>3</sub> (as N)              | <0.005                        | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  |     |        |        |       |         |         |         |
|  | <0.005                        | <0.001  | 0.010   | 0.10    | 0.005   | 0.005   |     |        |        |       | <0.005  | <0.005  | <0.001  |
| Nitrite, NO <sub>2</sub> (as N)              | 0.005                         | 1.2     | <0.1    | <0.1    | 0.3     | <0.1    |     |        |        |       |         |         |         |
|  | <0.1                          | 0.18    | 0.12    | <0.10   | 0.15    | <0.1    |     |        |        |       | 1.2     | <0.1    | 0.3     |
| Phosphates, Total-P <sub>04</sub> (as P)     | 0.10                          | 0.01    | 0.01    | <0.01   | 0.21    | <0.01   |     |        |        |       |         |         |         |
|  | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |     |        |        |       | 0.18    | <0.10   | 0.13    |
| Aluminum                                     | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       |         |         |         |
|  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       | <0.05   | <0.05   | <0.001  |
| Chloride                                     | <0.02                         | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   |     |        |        |       |         |         |         |
|  | 0.10                          | 0.14    | 0.12    | <0.10   | 0.44    | 0.10    |     |        |        |       | <0.02   | <0.02   | <0.001  |
| Barium, Hexavalent                           | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       |         |         |         |
|  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       | <0.05   | <0.05   | <0.001  |
| Copper                                       | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       |         |         |         |
|  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       | 0.44    | <0.10   | <0.003  |
| Iron   | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       |         |         |         |
|  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       | <0.05   | <0.05   | <0.001  |
| Manganese                                    | <0.005                        | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  |     |        |        |       |         |         |         |
|  | <0.05                         | <0.05   | 0.07    | <0.05   | <0.05   | <0.05   |     |        |        |       | 0.007   | <0.005  | <0.001  |
| Mercury                                      | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |     |        |        |       |         |         |         |
|  | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |     |        |        |       | <0.01   | <0.01   | <0.001  |
| Nickel                                       | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       |         |         |         |
|  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       | <0.05   | <0.05   | <0.001  |
| Silver                                       | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       |         |         |         |
|  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       | <0.05   | <0.05   | <0.001  |
| Zinc   | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       |         |         |         |
|  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |     |        |        |       | <0.05   | <0.05   | <0.001  |
| Chloroform (µg/l)                            |                               |         |         |         |         |         |     |        |        |       |         |         |         |
|  |                               |         |         |         |         |         |     |        |        |       |         |         |         |
| DDE (+)                                      |                               |         |         |         |         |         |     |        |        |       |         |         |         |
|  |                               |         |         |         |         |         |     |        |        |       |         |         |         |
| DDE (-)                                      |                               |         |         |         |         |         |     |        |        |       |         |         |         |
|  |                               |         |         |         |         |         |     |        |        |       |         |         |         |
| DDE (+)                                      |                               |         |         |         |         |         |     |        |        |       |         |         |         |
|  |                               |         |         |         |         |         |     |        |        |       |         |         |         |
| DDE (-)                                      |                               |         |         |         |         |         |     |        |        |       |         |         |         |
|  |                               |         |         |         |         |         |     |        |        |       |         |         |         |

NOTES: \* Sampling station is identified and survey techniques are discussed in "Water Pollution Survey Operations Plan, Moody AFB, GA," Special Project 71-51, USAF Environmental Health Lab, Kelly AFB, TX 78241, (February 1972).  
 \*\* The first four data were determined from grab samples during the survey day while the remaining data were analyzed on 24-hour composite samples collected proportional to flow throughout the day. All samples were properly preserved.  
 (\*) Sample container was broken before sample could be analyzed.  
 + Units are nanograms per liter.  
 Blank entries in column denote that such data were not required in the "Survey Plan".

Table G-6: Data Summary for Sampling Station R-4, Moody AFB, GA\*

| Chemical/Physical<br>Data** (mg/l unless noted) | Sampling Day and Date (1972)* |         |         |         |         |         |         |         |         |         | Values                           |  |  |
|---|-------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|----------------------------------|--|--|
|   | Mon                           | Tue     | Wed     | Thu     | Fri     | Wed     | 4 Oct   | Maximum | Minimum | Average | Average<br>Loading†<br>(lbs/day) |  |  |
|   | 25 Sep                        | 26 Sep  | 27 Sep  | 28 Sep  | 29 Sep  | 29 Sep  | 4 Oct   |         |         |         |                                  |  |  |
| Dissolved O2                                    | 2.8-7.1                       | 1.6-5.5 | 1.2-5.3 | 1.0-6.7 | 1.2-4.3 | 1.3-3.7 | 2.5     | 7.1     | 1.0     | 3.3     |                                  |  |  |
| Temperature °C                                  | 4.4                           | 3.6     | 3.7     | 3.0     | 2.8     | 2.5     | 23-28   | 31.     | 23.     | 27.     |                                  |  |  |
| pH (units)                                      | 26-30                         | 26-31   | 25-31   | 26-31   | 25-30   | 23-28   | 25.     |         |         |         |                                  |  |  |
| DO (GD)   | 6.7-7.4                       | 6.3-6.8 | 6.2-6.7 | 6.4-6.9 | 6.6-6.9 | 6.6-7.2 | 6.9     | 7.4     | 6.7     | 6.7     |                                  |  |  |
| DO5   | 7.0                           | 6.5     | 6.4     | 6.6     | 6.8     | 6.9     | No Flow |         |         |         |                                  |  |  |
| DO  | <12.                          | (*)     | <12.    | 31.     | <12.    | <12.    | <12.    | 31.     | <12.    | <12.    |                                  |  |  |
| Total Organic Carbon                            | 43.                           | 49.     | 54.     | 38.     | 38.     | 55.     | 55.     | 55.     | 38.     | 46.     |                                  |  |  |
| Oils/Greases (by IR)                            | 10.                           | 16.     | 16.     | 8.      | 8.      | 12.     | 12.     | 16.     | 8.      | 12.     |                                  |  |  |
| Surfactants, NBAS (as LAS)                      | (*)                           | (*)     | (*)     | 0.6     | 0.6     | 2.6     | 2.6     | 2.6     | 0.6     | 1.3     |                                  |  |  |
| Total Kjeldahl Nitrogen (as N)                  | 0.2                           | 0.2     | 0.3     | 0.3     | 0.3     | 0.2     | 0.2     | 0.3     | 0.2     | 0.3     |                                  |  |  |
| Ammonia, NH3 (as N)                             | 1.32                          | 0.89    | 0.72    | 0.81    | 0.74    | 2.57    | 2.57    | 2.57    | 0.72    | 1.18    |                                  |  |  |
| Cyanide, CN                                     | 0.096                         | <0.01   | 0.038   | 0.43    | 0.48    | 0.55    | 0.55    | 0.55    | <0.01   | 0.27    |                                  |  |  |
| Nitrate, NO3 (as N)                             | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |                                  |  |  |
| Nitrite, NO2 (as N)                             | <0.2                          | <0.2    | <0.2    | <0.2    | <0.2    | <0.2    | <0.2    | <0.2    | <0.2    | <0.2    |                                  |  |  |
| Phenolics, C6H5OH                               | <0.005                        | <0.005  | <0.005  | 0.005   | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  |                                  |  |  |
| Phosphate, Total-PO4 (as P)                     | <0.001                        | <0.001  | 0.005   | 0.010   | 0.005   | 0.005   | 0.005   | 0.010   | <0.001  | <0.005  |                                  |  |  |
| Aluminum  | <0.1                          | <0.1    | 0.1     | <0.1    | <0.1    | 0.3     | 0.3     | 0.3     | <0.1    | 0.1     |                                  |  |  |
| Cadmium   | 0.16                          | 0.16    | 0.12    | 0.12    | 0.20    | <0.10   | <0.10   | 0.20    | <0.10   | 0.14    |                                  |  |  |
| Chloride  | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |                                  |  |  |
| Chromium, Hexavalent                            | 20.                           | 20.     | 20.     | 20.     | 28.     | 16.     | 16.     | 28.     | 16.     | 21.     |                                  |  |  |
| Chromium, Total                                 | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |                                  |  |  |
| Copper  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |                                  |  |  |
| Iron  | <0.02                         | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   |                                  |  |  |
| Lead  | 0.50                          | 0.38    | 0.50    | 0.85    | 0.63    | 0.64    | 0.64    | 0.85    | 0.38    | 0.58    |                                  |  |  |
| Manganese                                       | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |                                  |  |  |
| Mercury   | 0.22                          | 0.06    | 0.08    | 0.10    | 0.04    | <0.05   | <0.05   | 0.22    | 0.04    | 0.09    |                                  |  |  |
| Nickel  | <0.005                        | <0.005  | <0.005  | <0.005  | <0.005  | 0.007   | 0.007   | 0.007   | <0.005  | <0.005  |                                  |  |  |
| Silver  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | 0.07    | 0.07    | 0.07    | <0.05   | <0.05   |                                  |  |  |
| Zinc  | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |                                  |  |  |
| Chloroform (µgm/l)                              | 0.06                          | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | 0.06    | <0.05   | <0.05   |                                  |  |  |
| Chloroform (+)                                  | (*)                           | (*)     | (*)     | (*)     | 0.21    | 0.00    | 0.00    | 0.06    | <0.05   | <0.05   |                                  |  |  |
| Chloroform (+)                                  | (*)                           | (*)     | (*)     | (*)     | 7.31    |         |         | 0.06    | <0.05   | <0.05   |                                  |  |  |
| Chloroform (+)                                  | (*)                           | (*)     | (*)     | (*)     | 20.67   |         |         | 0.06    | <0.05   | <0.05   |                                  |  |  |
| Chloroform (+)                                  | (*)                           | (*)     | (*)     | (*)     | 68.47   |         |         | 0.06    | <0.05   | <0.05   |                                  |  |  |

NOTES: \* Sampling station is identified and survey techniques are discussed in "Water Pollution Survey Operations Plan, Moody AFB, GA," Special Project 71-51, USAF Environmental Health Lab, Kelly AFB, TX 78241, (February 1972).  
 \*\* The first four data were determined from grab samples during the survey day while the remaining data were analyzed on 24-hour composite samples collected proportional to flow throughout the day. All samples were properly preserved.  
 (\*) Sample container was broken before sample could be analyzed.  
 + Units are nanograms per liter.  
 Blank entries in column denote that such data were not required in the "Survey Plan".  
 † Average loading not determined since there was no flow at this station.

Table G-7: Data Summary for Sampling Station R-5, Moody AFB, GA\*

| Chemical/Physical Data** (mg/l unless noted) | Sampling Day and Date (1972)* |         |         |         |         |         |         |         |         |  | Values |  |  |
|--|-------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|--|--------|--|--|
|  | Tue                           | Mon     | Tue     | Wed     | Thu     | Fri     | Maximum | Minimum | Average |  |        |  |  |
|  | 26 Oct                        | 2 Oct   | 3 Oct   | 4 Oct   | 5 Oct   | 6 Oct   |         |         |         |  |        |  |  |
| Dissolved O <sub>2</sub>                     | 4.5-5.8                       | 4.8-6.0 | 5.4-6.7 | 5.1-7.1 | 4.2-5.9 | 5.2-4.8 |         |         |         |  |        |  |  |
| Range  | 5.0                           | 5.5     | 6.0     | 5.6     | 4.6     | 5.0     | 7.1     | 4.2     | 5.3     |  |        |  |  |
| Average                                      | 25-26                         | 25-25   | 20-25   | 23-25   | 23-26   | 24-26   |         |         |         |  |        |  |  |
| Temperature °C                               | 26                            | 25      | 23      | 24      | 25      | 25      |         |         | 25      |  |        |  |  |
| PH (units)                                   | 5.9-6.5                       | 6.0-6.3 | 6.2-6.4 | 6.4-6.6 | 6.3-6.6 | 6.4-6.7 |         |         |         |  |        |  |  |
| Range  | 5.2                           | 5.2     | 6.3     | 6.3     | 6.4     | 6.5     | 6.7     | 5.9     | 6.4     |  |        |  |  |
| Average                                      | No Flow                       |         |         |         |         | No Flow |         |         |         |  |        |  |  |
| Flow ( GPD )                                 | <12                           | <12     | <12     | <12     | (*)     | 12      | 12      | <12     | <12     |  |        |  |  |
| BOD <sub>5</sub>                             | 33                            | <5      | 55      | <5      | 11      | 5       | 65      | 5       | 21      |  |        |  |  |
| COD  | 9                             | 1       | 20      | 2       | 3       | <1      | 20      | <1      | 6       |  |        |  |  |
| Total Organic Carbon                         | (*)                           | <0.3    | 0.4     | 1.0     | 0.5     | 0.8     | 1.0     | 0.3     | 0.6     |  |        |  |  |
| Oils/Greases (by IR)                         | 2.4                           | 0.1     | 0.1     | 0.2     | 0.2     | 0.2     | 2.4     | 0.1     | 0.5     |  |        |  |  |
| Surfactants, MBAS (as LAS)                   | 0.29                          | 0.10    | 0.16    | 0.72    | 0.79    | 0.26    | 0.79    | 0.10    | 0.39    |  |        |  |  |
| Total Kjeldahl Nitrogen (as N)               | <0.01                         | 0.05    | 0.02    | 0.14    | 0.24    | 0.07    | 0.24    | <0.01   | 0.09    |  |        |  |  |
| Ammonia, NH <sub>3</sub> (as N)              | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |  |        |  |  |
| Cyanide, CN                                  | 0.7                           | 0.3     | 0.6     | 0.72    | 0.72    | 0.81    | 0.81    | 0.30    | 0.64    |  |        |  |  |
| Nitrate, NO <sub>3</sub> (as N)              | 0.005                         | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  | 0.005   | <0.005  | <0.005  |  |        |  |  |
| Nitrite, NO <sub>2</sub> (as N)              | 0.010                         | 0.005   | 0.005   | 0.008   | 0.003   | 0.005   | 0.010   | 0.003   | 0.006   |  |        |  |  |
| Phenolics, C <sub>6</sub> H <sub>5</sub> OH  | <0.1                          | <0.1    | <0.1    | <0.1    | <0.1    | <0.1    | <0.1    | <0.1    | <0.1    |  |        |  |  |
| Phosphate, Total-PO <sub>4</sub> (as P)      | 0.37                          | 0.10    | 0.10    | 0.1     | <0.1    | <0.1    | 0.37    | <0.1    | 0.15    |  |        |  |  |
| Aluminum                                     | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |  |        |  |  |
| Cadmium                                      | 20                            | 20      | 12      | 8       | 12      | 12      | 20      | 8       | 14      |  |        |  |  |
| Chloride                                     | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |  |        |  |  |
| Chromium, Hexavalent                         | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |  |        |  |  |
| Chromium, Total                              | <0.02                         | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   | <0.02   |  |        |  |  |
| Copper                                       | <0.10                         | 0.12    | <0.10   | 0.10    | 0.10    | <0.10   | 0.12    | <0.10   | 0.10    |  |        |  |  |
| Iron   | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |  |        |  |  |
| Lead   | <0.005                        | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  | <0.005  |  |        |  |  |
| Manganese                                    | <0.005                        | <0.005  | <0.005  | 0.005   | 0.005   | <0.005  | 0.005   | <0.005  | <0.005  |  |        |  |  |
| Mercury                                      | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |  |        |  |  |
| Nickel                                       | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   | <0.01   |  |        |  |  |
| Silver                                       | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   | <0.05   |  |        |  |  |
| Zinc   |                               |         |         |         |         |         |         |         |         |  |        |  |  |
| Chloroform (BSE/l)                           |                               |         |         |         |         |         |         |         |         |  |        |  |  |
| CODE (+)                                     |                               |         |         |         |         |         |         |         |         |  |        |  |  |
| BOD (+)                                      |                               |         |         |         |         |         |         |         |         |  |        |  |  |
| PH (+)                                       |                               |         |         |         |         |         |         |         |         |  |        |  |  |

NOTES: \* Sampling station is identified and survey techniques are discussed in "Water Pollution Survey Operations Plan, Moody AFB, GA," Special Project 71-51, USAF Environmental Health Lab, Kelly AFB, TX 78241, (February 1972).  
 \*\* The first four data were determined from grab samples during the survey day while the remaining data were analyzed on 24-hour composite samples collected proportional to flow throughout the day. All samples were properly preserved.  
 (\*) Sample container was broken before sample could be analyzed.  
 † Units are nanograms per liter.  
 Blank entries in column denote that such data were not required in the "Survey Plan".  
 ‡ Average loading not determined since there was no flow at this station.

Table G-8: Data Summary for Sampling Station R-6, Moody AFB, GA\*

| Chemical/Physical Data** (mg/l unless noted) | Sampling Day and Date (1972)* |         |         |         |         |     |         | Values  |         |
|--|-------------------------------|---------|---------|---------|---------|-----|---------|---------|---------|
|  | Tue                           | Mon     | Tue     | Wed     | Thu     | Fri | Maximum | Minimum | Average |
| 26 Sep                                       | 2 Oct                         | 3 Oct   | 4 Oct   | 5 Oct   | 6 Oct   |     |         |         |         |
| 4.1-6.0                                      | 5.6-6.1                       | 5.5-7.0 | 4.8-5.9 | 4.5-5.1 | 4.8-5.8 |     |         |         |         |
| 4.9  | 5.8                           | 6.0     | 5.3     | 4.9     | 5.1     |     |         |         | 5.3     |
| 25-29  | 25-26                         | 21-26   | 23-27   | 22-26   | 23-24   |     |         |         |         |
| 27   | 26                            | 24      | 25      | 25      | 24      |     |         |         | 25      |
| 6.1-6.3                                      | 6.3-6.7                       | 6.4-6.8 | 6.7-6.9 | 6.5-6.7 | 6.5-6.8 |     |         |         |         |
| 6.2  | 6.5                           | 6.6     | 6.8     | 6.6     | 6.6     |     |         |         |         |
| 4943   | 4048                          | 495     | 2300    | 3366    | 3484    |     |         |         | 3843    |
| <12  | <12                           | <12     | <12     | (*)     | (*)     |     |         |         | <12     |
| 5  | 5                             | 16      | 5       | 22      | 11      |     |         |         | 11      |
| 1  | 1                             | 4       | 2       | 4       | 2       |     |         |         | 2       |
| (*)  | 0.6                           | 0.6     | 0.8     | 0.9     | 0.9     |     |         |         | 0.8     |
| 0.2  | 0.1                           | 0.5     | 0.3     | 0.2     | 0.3     |     |         |         | 0.3     |
| 0.68   | 0.89                          | 0.93    | 1.6P    | 1.32    | 0.77    |     |         |         | 1.05    |
| 0.58   | 0.89                          | 0.86    | 0.64    | 0.98    | 0.58    |     |         |         | 0.81    |
| <0.01  | <0.01                         | <0.01   | <0.01   | <0.01   | <0.01   |     |         |         | <0.01   |
| 0.5  | 0.5                           | 0.4     | 0.50    | 0.27    | 0.36    |     |         |         | 0.42    |
| <0.005                                       | 0.006                         | 0.006   | 0.006   | 0.006   | 0.053   |     |         |         | 0.014   |
| 0.010  | 0.005                         | <0.001  | 0.003   | <0.001  | 0.005   |     |         |         | 0.004   |
| <0.1   | <0.1                          | <0.1    | 0.3     | <0.1    | <0.1    |     |         |         | 0.1     |
| <0.10  | <0.10                         | <0.10   | <0.1    | <0.1    | 0.3     |     |         |         | 0.1     |
| <0.01  | <0.01                         | <0.01   | <0.01   | <0.01   | 0.01    |     |         |         | <0.01   |
| 24   | 24                            | 20      | 16      | 16      | 20      |     |         |         | 20      |
| <0.05  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   |     |         |         | <0.05   |
| <0.05  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   |     |         |         | <0.05   |
| <0.02  | <0.02                         | <0.02   | <0.02   | 0.03    | <0.02   |     |         |         | <0.02   |
| 3.13   | 2.83                          | 1.75    | 2.00    | 2.61    | 2.37    |     |         |         | 2.45    |
| <0.05  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   |     |         |         | <0.05   |
| 0.06   | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   |     |         |         | <0.05   |
| <0.005                                       | <0.005                        | <0.005  | 0.007   | 0.007   | 0.005   |     |         |         | 0.005   |
| <0.05  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   |     |         |         | <0.05   |
| <0.01  | <0.01                         | <0.01   | <0.01   | <0.01   | 0.02    |     |         |         | <0.01   |
| <0.05  | <0.05                         | <0.05   | <0.05   | <0.05   | <0.05   |     |         |         | <0.05   |
| (*)  | 0.51                          | 0.30    | 0.00    | 0.00    | 0.00    |     |         |         | +       |
| (*)  | 17.50                         | 7.10    |         |         |         |     |         |         | +       |
| (*)  | 16.23                         | 9.42    |         |         |         |     |         |         | +       |
| (*)  | 32.97                         | 33.25   |         |         |         |     |         |         | +       |

NOTES: \* Sampling station is identified and survey techniques are discussed in "Water Pollution Survey Operations Plan, Moody AFB, GA," Special Project 71-51, USAF Environmental Health Lab, Kelly AFB, TX 78241, (February 1972).

\*\* The first four data were determined from grab samples during the survey day while the remaining data were analyzed on 24-hour composite samples collected proportional to flow throughout the day. All samples were properly preserved.

(\*) Sample container was broken before sample could be analyzed.

+ Units are nanograms per liter.

Blank entries in column denote that such data were not required in the "Survey Plan".

† Not calculated due to limited data.

APPENDIX H

National Pollutant Discharge  
Elimination System  
Permit #GA0020001  
Moody AFB GA

FINAL

Permit No. GA00.0001

AUTHORIZATION TO DISCHARGE UNDER THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Federal Water Pollution Control Act, as amended, (33 U.S.C. 1251 et. seq; the "Act"),

Air Training Command, USAF  
Moody Air Force Base

is authorized to discharge from a facility located at  
9 miles north of Valdosta, Georgia

to receiving waters named  
Beatty Creek

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II, and III hereof.

This permit shall become effective upon receipt.

This permit and the authorization to discharge shall expire at midnight,

June 30, 1979

Signed this 5<sup>th</sup> day of APR 1974

*Original Signed By:*

JACK E. RAVAN  
Regional Administrator

PART I

Page / of //

Permit No. *GA0020001*

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. The concentration of pollutants in the discharge will be limited as indicated by the table(s) labeled "Effluent Limitations." The effluent shall meet the requirements in the table or the conditions in paragraph (a) below, whichever yields the highest quality effluent.
  - (a) For BOD<sub>5</sub> and suspended solids, the arithmetic mean of the values of the effluent samples collected in a period of 30 consecutive days shall not exceed 15 percent of the arithmetic mean of values for influent samples collected at approximately the same times during the same period (85 percent removal).
  - (b) Fecal coliform bacteria will be reported as the geometric mean of the values for the samples collected.
  - (c) Chemical oxygen demand (COD) or total organic carbon (TOC) may be substituted for biochemical oxygen demand (BOD) when a long term BOD:COD or BOD:TOC correlation has been demonstrated.
  - (d) Where daily flow measurements are required, and instantaneous flow measuring equipment is not provided, a daily average flow may be reported. This daily average flow shall be determined as the total flow measured during a period of 30 consecutive days divided by the number of days the treatment facility was in operation during that period.

Permit No. GA0029001

Maximum Hydraulic Flow  
(24 hour average flow,  
averaged monthly)

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning upon receipt and lasting through 6/30/77  
the permittee is authorized to discharge from outfall(s) serial number(s) 001

Such discharges shall be limited and monitored by the permittee as specified below: 2,838.2cu. m/day (0.750 mgd)

| Parameter                         | Discharge Limitations |                |                       | Monitoring Requirements |                     |                     |
|-----------------------------------|-----------------------|----------------|-----------------------|-------------------------|---------------------|---------------------|
|                                   | Monthly Average       | Weekly Average | Monthly Concentration | Measurement Frequency   | Sample Type         | Sampling Point      |
| Biochemical Oxygen Demand (5 day) | 85(188)               | 128(282)       | 30                    | 45                      | once/week composite | Influent & Effluent |
| Suspended Solids                  | 85(188)               | 128(282)       | 30                    | 45                      | once/week composite | Influent & Effluent |
| Fecal Coliform Bacteria           | _____                 | _____          | _____                 | _____                   | once/week grab      | Effluent            |
| pH                                | _____                 | _____          | _____                 | _____                   | once/week grab      | Effluent            |
| Flow, mgd                         | _____                 | _____          | _____                 | _____                   | daily               | _____               |

The fecal coliform bacteria shall be limited to 200 and 400 counts/100 ml as a Monthly Geometric Mean and Weekly Geometric Mean respectively.

The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

The effluent shall not cause a visible sheen on the receiving water.

Permit No. GA0020001

**EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

During the period beginning July 1, 1977 and lasting through 6/30/79 and Maximum Hydraulic Flow (24 hour average flow, the permittee is authorized to discharge from outfall(s) serial number(s) 001 averaged monthly)

Such discharges shall be limited and monitored by the permittee as specified below: 2,838.8 cu. m/day ( 0.750 mgd)

| Parameter                         | Discharge Limitations     |                     | Monitoring Requirements |                               |
|-----------------------------------|---------------------------|---------------------|-------------------------|-------------------------------|
|                                   | Loading, kg/day (lbs/day) | Concentration, Mg/l | Measurement Frequency   | Sample Type & Sampling Point  |
| Biochemical Oxygen Demand (5 day) | 43(93)                    | 15                  | once/weekly             | composite Influent & Effluent |
| Suspended Solids                  | 85(188)                   | 30                  | once/weekly             | composite Influent & Effluent |
| Fecal Coliform Bacteria           | _____                     | _____               | once/weekly             | grab Effluent                 |
| pH                                | _____                     | _____               | once/weekly             | grab Effluent                 |
| Flow, mgd                         | _____                     | _____               | daily                   | _____                         |
| NH <sub>3</sub> -N                | 5.7(12.5)                 | 2.0                 | once/weekly             | composite Effluent            |
| D.O.                              | N/A                       | 6.0                 | once/daily              | grab Effluent                 |

The fecal coliform bacteria shall be limited to 200 and 400 counts/100 ml as a Monthly Geometric Mean and Weekly Geometric Mean respectively.

The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored

There shall be no discharge of floating solids or visible foam in other than trace amounts.

The effluent shall not cause a visible sheen on the receiving water.

PART I

Page 4 of 11

Permit No. GA0020001

B SCHEDULE OF COMPLIANCE

Not later than January 1, 1975 the permittee shall submit for approval a proposed schedule for achieving compliance with the final limitations by July 1, 1977. This schedule shall contain as a minimum the dates indicated in items a through e below and where time intervals between any two dates is greater than nine months interim progress reports shall be submitted. Upon approval by the Regional Administrator this compliance schedule shall become a part of this permit.

- (a) Completion of preliminary plans - \_\_\_\_\_.
- (b) Completion of final plans - \_\_\_\_\_.
- (c) Contract awarded - \_\_\_\_\_.
- (d) Commence construction - \_\_\_\_\_.
- (e) Completion of construction - \_\_\_\_\_.
- (f) Operational level attained - July 1977.

C. MONITORING AND REPORTING

1. Representative Sampling

Sampling and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge.

2. Reporting

Monitoring results obtained during the previous 3 months shall be summarized for each month and reported on a Discharge Monitoring Report Form (EPA No. 3320-1), postmarked no later than the 28th day of the month following the completed reporting period. The first report is due on September 28, 1974. Duplicate signed copies of these, and all other reports required herein, shall be submitted to the Regional Administrator and the State at the following addresses:

Water Enforcement Branch  
Environmental Protection Agency  
Region IV  
1421 Peachtree Street, N.E.  
Atlanta, Georgia 30309

Georgia Environmental  
Protection Division  
Department of Natural Resources  
47 Trinity Avenue, SW  
Atlanta, GA 30334

3. Definitions

- a. The monthly average, other than for fecal coliform bacteria, is the arithmetic mean of all the 24-hour composite samples collected in a one-month period. The monthly average for fecal coliform bacteria is the geometric mean of samples collected in a one-month period.
- b. The weekly average, other than for fecal coliform bacteria, is the arithmetic mean of all the 24-hour composite samples collected during a one-week period. The weekly average for fecal coliform bacteria is the geometric mean of samples collected in a one-week period.

4. Test Procedures

The analytical and sampling methods used shall conform to the latest edition of the reference methods listed below. (These are interim references to be replaced by Section 304(a) guidelines when available). However, different but equivalent methods are allowable if they receive the prior written approval of the state water pollution control agency and/or the EPA Regional Administrator.

- a. Standard Methods for the Examination of Water and Wastewater 18th Edition, 1965, American Public Health Association, New York, New York, 1960.
- b. A. S. C. Methods for the Examination of Water and Wastewater, 1960, American Public Health Association, Philadelphia, Pa. 19103.

PART I

Page 6 of 11

Permit No. GA0020001

- c. Methods for Chemical Analysis of Water and Wastes, April 1971,  
Environmental Protection Agency, Water Quality Office, Analytical  
Quality Control Laboratory, 1014 Broadway, Cincinnati, Ohio 45202.

A twenty-four hour composite sample consists of not less than 6  
effluent portions collected at regular intervals in a 24-hour period and  
composited according to flow. For fecal coliform bacteria, a sample consists  
of one effluent portion collected during a 24-hour period at peak flow  
conditions.

The permittee shall periodically calibrate and perform maintenance procedures  
on all monitoring and analytical instrumentation at intervals to insure  
accuracy of measurements.

5. Recording of Results

For each measurement of sample taken pursuant to the requirements of this  
permit, the permittee shall record the following information:

- a. The exact place, date, and time of sampling;
- b. The dates the analyses were performed;
- c. The person(s) who performed the analyses;
- d. The analytical techniques or methods used; and
- e. The results of all required analyses.

6. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein  
more frequently than required by this permit, using approved analytical  
methods as specified above, the results of such monitoring shall be included  
in the calculation and reporting of the values required in the Discharge  
Monitoring Report Form (EPA No. 3320-1). Such increased frequency shall  
also be indicated.

7. Records Retention

All records and information resulting from the monitoring activities  
required by this permit, including all records of analyses performed and  
calculated, and all information of instrument calibration and maintenance records,  
shall be retained and shall be available for a minimum of three  
(3) years after the date of the final discharge report of the  
State or Federal agency.

PART II

Page 7 of 11  
Permit No. GAO020001

A. MANAGEMENT REQUIREMENTS

1. Change in Discharge

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit more frequently than or at a level in excess of that authorized shall constitute a violation of the permit. Any anticipated facility expansions, production increases, or process modifications which will result in new, different, or increased discharges of pollutants must be reported by submission of a new NPDES application or, if such changes will not violate the effluent limitations specified in this permit, by notice to the permit issuing authority of such changes. Following such notice, the permit may be modified to specify and limit any pollutants not previously limited.

2. Noncompliance Notification

If, for any reason, the permittee does not comply with or will be unable to comply with any daily maximum effluent limitation specified in this permit, the permittee shall provide the Regional Administrator and the State with the following information, in writing, within five (5) days of becoming aware of such condition:

- a. A description of the discharge and cause of noncompliance; and
- b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate and prevent recurrence of the noncomplying discharge.

3. Facilities Operation

The permittee shall at all times maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee to achieve compliance with the terms and conditions of this permit.

4. Adverse Impact

The permittee shall take all reasonable steps to minimize any adverse impact to navigable waters resulting from noncompliance with any effluent limitations specified in this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

5. Bypassing

Any discharge from or bypass of facilities necessary to maintain compliance with the terms and conditions of this permit is prohibited, except (i) when unavoidable to prevent loss of life or severe property damage, or (ii) when

excessive storm drainage or runoff would damage any facilities necessary for compliance with the effluent limitations and prohibitions of this permit. The permittee shall notify the permit issuing authority in writing within 72 hours of each such diversion or bypass in accordance with the procedures specified above for reporting noncompliance. The permittee shall within 30 days after such incident submit to EPA for approval a plan to prevent recurrence of such incidents.

6. Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering navigable waters.

7. Power Failures

The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures either by means of alternate power sources, stand by generators or retention of inadequately treated effluent. Should the treatment works not include the above capabilities at time of permit issuance, the permittee must furnish within 120 days to the permitting authority, for approval, an implementation schedule for their installing.

8. Onshore or Offshore Construction

This permit does not authorize or approve the construction of any onshore or offshore physical structures or facilities or the undertaking of any work in any navigable waters.

B. RESPONSIBILITIES

1. Right of Entry

The permittee shall allow the Regional Administrator, and/or their authorized representatives, upon the presentations of credentials:

- a. To enter upon the permittee's premises where an effluent source is located or in which any records are required to be kept under the terms and conditions of this permit; and
- b. At reasonable times to have access to and copy any records required to comply with the terms and conditions of this permit; to inspect, sample, test, and monitor any equipment or monitoring method required in this permit; and to sample any discharge of pollutants.

PART II

Page 9 of 11

Permit No. , GA0020001

2. Transfer of Ownership or Control

In the event of any change in control or ownership or facilities from which the authorized discharges emanate, the permittee shall notify the succeeding owner or controller of the existence of this permit by letter, a copy of which shall be forwarded to the Regional Administrator and the State water pollution control agency.

3. Availability of Reports

Except for data determined to be confidential under Section 308 of the Act, all reports prepared in accordance with the terms shall be available for public inspection at the offices of the State water pollution control agency and the Regional Administrator. As required by the Act, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the Act.

4. Permit Modification

After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to, the following:

- a. Violation of any terms or conditions of this permit;
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.

5. Toxic Pollutants

Notwithstanding part II, B-4 above, if a toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is established under Section 307(a) of the Act for a toxic pollutant which is present in the discharge and such standard or prohibition is more stringent than any limitation for such pollutant in this permit, this permit shall be revised or modified in accordance with the toxic effluent standard or prohibition and the permittee so notified.

C. Civil and Criminal Liability

Except as provided in permit conditions in "penalties" (Part II, A-5) and "enforcement" (Part II, A-11), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.

PART II

Page 10 of 11

Permit No. GA0020001

7. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Act.

8. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Act.

9. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

10. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit shall not be affected thereby.

11. Expiration of Permit

Permittee shall not discharge after the expiration date. In order, to receive authorization to discharge beyond the expiration date, the permittee shall submit such information, forms, and fees as are required by the agency authorized to issue permits no later than 180 days prior to the expiration date.

12. Industrial Pretreatment Standards

Permittee shall require any industrial dischargers into the permitted system to meet Federal Pretreatment Standards (40 CFR, Part 122) promulgated in response to Section 301(b) of the Act. The permittee shall provide semi-annual reports to the permittee on any violations of the pretreatment standards which have been incurred on a regular basis by the industry and the results achieved therefrom. Other information may be necessary regarding new industrial dischargers, and this shall be reported to the permittee after the permittee has approved the discharge of the new industrial discharge.

PART II

Page 11 of 11

Permit No. GA0020001

A major contributing industry is one that: (a) has a flow of 50,000 gallons or more per average work day; (b) has a flow greater than five percent of the flow carried by the municipal system receiving the waste; (c) has in its waste a toxic pollutant in toxic amounts as defined in standards issued under Section 307(a) of the Act; (d) has significant impact either singly or in combination with other contributing industries, on the treatment works or the quality of its effluent.

Any change in the definition of a major contributing industry as a result of promulgations in response to Section 307 of the Act shall become a part of this permit.