

AD-A041 402

CORPS OF ENGINEERS CINCINNATI OHIO  
DEVELOPMENT OF WATER RESOURCES IN APPALACHIA. VOLUME 17. APPEND--ETC(U)  
JUN 68

F/G 8/6

UNCLASSIFIED

NL

1 OF 1  
ADA  
041402



END  
DATE  
FILMED  
7-77

AD A 041402

0155

Development  
of  
WATER RESOURCES  
in  
APPALACHIA

19

COPY AVAILABLE TO THE PUBLIC  
PERMIT FULLY LEGIBLE REPRODUCTION

APPENDIX B  
POWER SUPPLY  
AND  
REQUIREMENTS



ORIGINAL CONTAINS COLOR PLATES: ALL OTHER  
REPRODUCTIONS WILL BE IN BLACK AND WHITE

DISTRIBUTION STATEMENT A  
Approved for public release;  
Distribution Unlimited

D D C  
APR 11 1977  
LIBRARY

COPY

FEDERAL POWER COMMISSION





FEDERAL POWER COMMISSION  
REGIONAL OFFICE

730 Peachtree Building  
Atlanta, Georgia 30308


TO: THE READER

Appendix "B" entitled "Power Supply and Requirements" is one of nine appendices to the "Report for Development of Water Resources in Appalachia." It furnishes information on the electric power industry in and adjacent to the Appalachian region.

The electric power requirements of the Appalachian region were about 23 million kilowatts of load and 128 billion kilowatt-hours of energy in 1965 and they are estimated to be about 32 million kilowatts of load and 177 billion kilowatt-hours of energy in 1970. Requirements for 2000 are estimated to be about 164 billion kilowatts of load and 930 billion kilowatt-hours of energy which represent increases of more than 500 percent in both load and energy over the 1970 requirements.

About 11 percent of the electric supply available for use in 1970 will be from hydroelectric developments and 89 percent from fuel-electric plants. A large part of the peak portions of the load is from hydroelectric facilities, and it is expected that pumped-storage projects will constitute a major part of the future hydroelectric developments. Nearly all of the lower or base portions of the load are furnished by fuel-electric plants, and most of the tremendous amounts of new supply needed for future years will continue to be from fossil- and nuclear-fired generating plants. Both water and fuel are sufficiently abundant in the Appalachian region to support the much larger power supplies needed to meet future requirements.

Water resource developments for all uses are summarized in the main report which should be consulted for an over-all view of the Appalachian region. An index for the report components and appendices is shown on pages iv and iv-a of this appendix.

  
Robert C. Price  
Regional Engineer

APPROVED BY	
RTIC	W. G. BROWN <input checked="" type="checkbox"/>
DDO	OUT STATION <input type="checkbox"/>
UNAPPROVED	<input type="checkbox"/>
JUSTIFICATION	
BY	
DISTRIBUTION, AVAILABILITY CODE	
WAL	AVAIL AND W SPECIAL
A	

DEVELOPMENT  
OF  
WATER RESOURCES  
IN  
APPALACHIA

1

APPENDIX B  
POWER SUPPLY AND REQUIREMENTS

DDC  
RECEIVED  
JUL 11 1977  
RECEIVED  
A

ORIGINAL CONTAINS COLOR PLATES: ALL DDC  
REPRODUCTIONS WILL BE IN BLACK AND WHITE

FEDERAL POWER COMMISSION  
BUREAU OF POWER

June 1968

DISTRIBUTION STATEMENT A  
Approved for public release;  
Distribution Unlimited

6

11 Jun 68

DEVELOPMENT  
 OF  
 WATER RESOURCES  
 IN  
 APPALACHIA  
 Volume 17.  
 APPENDIX B  
 POWER SUPPLY AND REQUIREMENTS

12 79p.

TABLE OF CONTENTS

	<u>Page</u>
CHAPTER I - SUMMARY .....	B-1
CHAPTER II - INTRODUCTION .....	E-3
Purpose of Study .....	B-3
Scope of Study .....	B-3
CHAPTER III - MARKET FOR POWER .....	B-5
Description of Market Area .....	B-5
Past and Estimated Future Electric Power Requirements .....	B-6
CHAPTER IV - EXISTING ELECTRIC POWER SUPPLY .....	B-17
Utility Systems .....	B-17
Generating Facilities .....	B-20
Transmission Facilities .....	B-21
CHAPTER V - FUTURE POWER SUPPLY ADDITIONS .....	B-35
CHAPTER VI - HYDROELECTRIC POWER RESOURCES .....	B-39
CHAPTER VII - WATER REQUIREMENTS FOR HYDROELECTRIC AND THERMAL-ELECTRIC POWER GENERATION .....	B-53
Hydroelectric Power Generation .....	B-53
Thermal-Electric Power Generation .....	B-53
CHAPTER VIII - CONCLUSIONS .....	B-57
GLOSSARY .....	B-59
BIBLIOGRAPHY .....	B-65

410 111

W.B.

TABLES

<u>Table No.</u>		<u>Page</u>
1	PAST ANNUAL ELECTRIC POWER REQUIREMENTS - 15 Power Supply Areas .....	B-7
2	ESTIMATED PAST ANNUAL ELECTRIC POWER REQUIREMENTS - Appalachian Region .....	B-7
3	ANNUAL ELECTRIC POWER REQUIREMENTS OF ALL UTILITIES - By Power Supply Areas .....	B-8
4	ESTIMATED FUTURE ELECTRIC POWER REQUIREMENTS - 15 Power Supply Areas .....	B-13
5	ESTIMATED FUTURE ELECTRIC POWER REQUIREMENTS - Appalachian Region Under Normally Expected Growth Conditions .....	B-13
6	ESTIMATED FUTURE ELECTRIC POWER REQUIREMENTS - Appalachian Region Under "Developmental Benchmarks" Growth Conditions .....	B-14
7	MONTHLY DISTRIBUTION OF LOADS FOR 1967 - 15 Power Supply Areas .....	B-16
8	MAJOR ELECTRIC POWER SUPPLIERS - 15 Power Supply Areas .....	B-17
9	POWER POOL GROUPS - 15 Power Supply Areas .....	B-20
10	INSTALLED CAPACITY AVAILABLE FOR 1970 - 15 Power Supply Areas .....	B-21
11	AVAILABLE POWER SUPPLY GENERATING PLANTS - 15 Power Supply Areas .....	B-22
12	OWNERSHIP OF MAJOR ELECTRIC FACILITIES - 15 Power Supply Areas .....	B-27
13	ADDITIONAL POWER REQUIREMENTS - 15 Power Supply Areas ...	B-38
14	HYDROELECTRIC POWER RESOURCES - 15 Power Supply Areas ...	B-40
15	ESTIMATED AT-MARKET POWER VALUES - 15 Power Supply Areas .....	B-48


TABLES (Cont'd)

<u>Table No.</u>		<u>Page</u>
16	WATER WHEEL REQUIREMENTS - HYDROELECTRIC GENERATING PLANTS .....	B-53
17	ENERGY CONVERSION AND COOLING WATER REQUIREMENTS - MODERN, LARGE STEAM-ELECTRIC GENERATING PLANTS .....	B-54

ILLUSTRATIONS

<u>Figure</u>		
1	APPALACHIAN REGION AND ELECTRIC POWER SUPPLY AREAS .....	B-4
2	TRENDS OF PAST AND ESTIMATED FUTURE POWER REQUIREMENTS - Appalachian Region and 15 Power Supply Areas .....	B-15
3	ELECTRIC FACILITIES - 15 Power Supply Areas .....	B-29
4	ESTIMATED DEMAND-TIME DIAGRAM - Summer Month 1980 .....	B-36
5	HYDROELECTRIC PLANTS - 15 Power Supply Areas .....	B-49

REPORT  
For  
DEVELOPMENT OF WATER  
RESOURCES IN APPALACHIA



VOLUME INDEX

MAIN REPORT

Volume Number	Part Number	Chapter Number	Contents		
1	I	-	Summary Report		
2	I	-	Key Map Folio (By States)		
3	II	1	Water Sub-Region A Today		
		2	Shaping the Plan for Sub-Region A		
		3	Water Sub-Region B Today		
		4	Shaping the Plan for Sub-Region B		
		5	Water Sub-Region C Today		
		6	Shaping the Plan for Sub-Region C		
		4	II	7	Water Sub-Region D Today
				8	Shaping the Plan for Sub Region D
				9	Water Sub-Region E Today
				10	Shaping the Plan for Sub-Region E
				11	Water Sub-Region F Today
				12	Shaping the Plan for Sub-Region F
5	II	13	Water Sub-Region G Today		
		14	Shaping the Plan for Sub-Region G		
		15	Water Sub-Region H Today		
		16	Shaping the Plan for Sub-Region H		
		17	Water Sub-Region I Today		
		18	Shaping the Plan for Sub-Region I		
		19	Water Sub-Region J Today		
		20	Shaping the Plan for Sub-Region J		
		6	III	1	Introduction to Project Analyses
				2	Tamaqua Local Protection Project
3	Royal Glen Reservoir				
4	Hipes Reservoir				
7	III	5	Clinchfield Reservoir		
		6	Roaring River Reservoir		
		7	Curry Creek Reservoir		
8	III	8	Dalton Reservoir		
		9	Coosa River Navigation		
		10	Stannard Reservoir		
9	III	11	St. Petersburg Reservoir		
		12	Greenbrier Reservoirs		
		13	Lower Knox Reservoir		

REPORT  
For  
DEVELOPMENT FOR WATER  
RESOURCES IN APPALACHIA

VOLUME INDEX

MAIN REPORT (cont'd)

Volume Number	Part Number	Chapter Number	Contents
10	III	14	Whiteoak Reservoir
		15	Logan Reservoir
		16	Midland Local Protection Project
11	III	17	Upper French Broad System (TVA)
		18	Yellow Creek Port (TVA)
		19	Otocsin (Pa.)
		20	Naturealm (Pa.)
12	IV	-	Concepts & Methods
13	V	-	State Water Supplements: Ala., Ga., Ky., Md., Miss., N.Y., N.Car.
14	V	-	State Water Supplements: O., Pa., S.Car., Tenn., Va., W.Va.
15	VI	-	History, Coordination & Cooperation

APPENDICES

Volume Number	Appendix Designation	Title
16	A	Agriculture, Forestry and Conservation
17	B	Power Supply and Requirements
18	C	Prevention of Water Pollution by Drainage from Mines
19	D	Water Supply and Water Pollution Control
20	E	Economic Base Study
21	F	Recreation and Aesthetics
22	G	Fish and Wildlife Resources
23	H	Ground Water
24	I	Mineral Industry Resources and Water Requirements



25 Loose Leaf Volume-Errata and Addenda

## PREFACE

This Appendix B on Power Supply and Requirements is a supplement to the Report on Development of Water Resources in Appalachia. It was prepared by the staff of the Atlanta Regional Office with assistance and contributions of information and material furnished by other Bureau of Power offices of the Federal Power Commission having territorial jurisdiction in the Appalachian area.

*This document*  
The Appendix furnishes general information on the electric power industry in and adjacent to the Appalachian Region, and it presents estimates of future power requirements and other data which may be used for guidance in selecting resource projects for further study and future development. Some of the projects may be chiefly electric power oriented, and others may only have electric power associated with their other purposes. Some would be hydroelectric developments with either conventional or pumped-storage installations, or a combination of both. Others may be needed for condensing water requirements for large thermal-electric installations. The data in the *tl* Appendix should aid in reaching a proper judgment concerning electric power matters and in selecting the proper resource projects for development. *←*

APPALACHIAN REGION  
POWER SUPPLY AREAS



## CHAPTER I - SUMMARY

Electric power requirements for the Appalachian region were estimated by proportioning to the region, on a population and area basis, electric power requirements for a larger area consisting of 15 power supply areas within which the Appalachian region is located. The locations of the Appalachian region and the 15 power supply areas are shown on the facing page.

The electric power requirements for the 15 power supply areas were about 86 million kilowatts and 489 billion kilowatt-hours in 1965. Estimated requirements for the Appalachian region for the same year were about 23 million kilowatts of demand and 128 billion kilowatt-hours of energy. For the larger area the requirements in 1967 were about 91 million kilowatts of demand and 549 billion kilowatt-hours of energy.

Future requirements to about 1980, under normally expected growth conditions, are expected to double about every 11 to 12 years. From 1980 to about year 2000 the requirements will double about every 14 to 16 years. After year 2000 they are expected to double about every 17 years. Under the goals of the Appalachian "developmental benchmarks," the requirements after 1980 may be expected to double about every 13 to 14 years. Under either the normal or "developmental benchmarks" growth rate, future electric power requirements are enormous and impose a formidable demand for large increases in electric power supply. The estimated total requirements in 1980 for the 15 power supply areas are about 234 million kilowatts of demand and 1,310 billion kilowatt-hours of energy. For the Appalachian region in 1980 they are estimated to be about 60 million kilowatts and 338 billion kilowatt-hours under normal growth conditions and about 61 million kilowatts and 340 billion kilowatt-hours under "developmental benchmarks" conditions.

The supply for electric power in the 15 power supply areas for 1970 is estimated to be about 145 million kilowatts. It is composed of about 16 million kilowatts of hydroelectric power and about 129 million kilowatts of fossil and nuclear fuel-fired electric power.

Supply for reserve is needed in addition to that required for load. When nominal reserves of 15 percent are considered, the 1980 additional supply for load above that available from the 1970 supply will amount to about 124 million kilowatts of new capacity. About 99 million kilowatts of this may be classed as a high load factor supply normally of the type furnished by fossil- or nuclear-fired plants and the remaining 25 million kilowatts as a low load factor supply normally of the type which may be furnished by hydroelectric plants.

The Appalachian region has a good and extensive transmission network. During recent years numerous high-voltage transmission lines capable of carrying large blocks of power have been constructed. Only a few small areas are not within a short distance of an adequate source of supply.

A factor which could tend to increase further the future power supply in the Appalachian region would be the location of large supply sources within the region from which power would be transported to and used in other areas. These supply sources may include both fuel-fired electric and hydroelectric facilities. With sufficient water available for condensing and other needed uses, the fuel-fired facilities could be large and near their source of fuel. Hydroelectric facilities could be obtained from conventional, pumped-storage, or a combination of conventional-pumped storage developments at numerous favorable sites in the Appalachian region. Water and fuel both are sufficiently abundant in the Appalachian region to support much larger electric power supplies.

## CHAPTER II - INTRODUCTION

### Purpose of Study

This Appendix provides information on the electric power requirements and supply for the Appalachian region, which was prepared for use in resource planning and development analyses. A study was made to analyze and evaluate both the present and future electric power situations.


### Scope of Study

Electric power is not confined to established political or geographic boundaries. The electric power supply in the eastern United States cuts across both state and regional boundaries. Accordingly, a larger area than the Appalachian region was included in the study. The larger area consists of 15 power supply areas within which the Appalachian region is located.

Future electric power requirements are enormous and impose a formidable demand for large increases in supply. Electric power is a desirable, convenient, and clean means of meeting a large part of the future total power requirements. Water and fuel, primary ingredients in the production of electric power, are sufficiently abundant in the Appalachian region and the contiguous area to meet the electric power supply requirements to beyond year 2020, the end of the study period.

The study involved determinations of the present and future electric power requirements and the accompanying electric power supply needed for a 562,000-square mile area within the selected 15 power supply areas. These data were then related to the 195,000-square mile area in the Appalachian region. Determinations for the larger area were based on normally expected growth conditions. Power requirements for the Appalachian region were made for both the normally expected growth conditions and for the stimulated "developmental benchmark" growth conditions.

Results of the electric power supply study for the Appalachian region and other pertinent data are presented in this Appendix.



**BOUNDARIES**

Appalachian Region	—————
Power Supply Area	—————
Power Supply Area No.	10
Economic Sub-Region (OBE)	—————
Economic Sub-Region No.	10
Water Areas (CE)	—————
Water Area No.	G-5
State	—————
County	—————

**APPALACHIAN REGION  
AND  
ELECTRIC POWER SUPPLY AREAS**

ALSO  
ECONOMIC SUB-REGIONS (OBE)  
WATER AREAS (CE)

SCALE IN MILES  
0 100 200 300

Figure 1

## CHAPTER III - MARKET FOR POWER

### Description of Market Area

Power Supply Areas were established by the Federal Power Commission in 1934 when it divided the Continental United States into 48 areas. The division was made to comply with the requirements of the Federal Power Act to divide the country into areas which can be served most economically, to conserve natural resources, and to encourage the voluntary interconnection and coordination of facilities for the generation, transmission, and sale of electric power. Each of the power supply areas is more or less self-contained as to its electric requirements and supply, and the geographic bounds have remained substantially as they were originally established.

Outlines of the Appalachian region and the 15 selected power supply areas located in the eastern part of the United States are shown on Figure 1. Also shown, for comparative purposes, are 27 economic subregions and 10 water areas selected for study of the Appalachian region by the Office of Business Economics and the Corps of Engineers, respectively. Twelve of the 15 selected power supply areas are partially within the Appalachian region. They are Areas 3, 5, 7, 9, 10, 12, 18, 19, 20, 21, 22, and 23. Areas 7 and 10 are nearly all within the Appalachian region, while only a small part of Area 12 is in the region. The other areas in the group of 12 range between these two extremes as to the part within the Appalachian region. The remaining three areas which must be considered in any power supply and requirements study of Appalachia are contiguous to the Appalachian region. They are Areas 4, 6, and 8. These 15 areas represent the composite area within which the electrical requirements of the Appalachian region may be supplied. The supply might come from interconnected and coordinated systems within or outside the Appalachian region or from a combination of facilities located within and outside the region.

The Appalachian region is within 12 of the 15 power supply areas mentioned, except for two very small segments in Mississippi. Small portions of two of 20 counties, that were added to the Appalachian region by Act of Congress late in 1967, extend partially into Power Supply Area 25. No data have been prepared for this area for use in the Appalachian study because there are no significant power loads in these small county segments. It is considered that the data prepared for the Appalachian study, included in this Appendix, are sufficient for any power requirements and supply studies which may be needed.

Estimates of population and available data on economic activities were the principal data used to establish potential normal growth electric markets and electric power requirements. Using these data and following usual procedures of estimating power requirements provide results which normally might be expected to occur in the future.

In order to establish a relationship between the electric power requirements of the 15 power supply areas and the Appalachian region, population estimates for past and subsequent years for the 15 power supply areas and area determination were used and compared with past and subsequent population estimates for corresponding years and the area within the Appalachian region. Population estimates for the Appalachian region were prepared by the Office of Business Economics. The resulting related estimates of electric power requirements are considered to represent normal growth conditions. These normal growth estimates for the Appalachian region have been accelerated by the use of factors and multipliers furnished by the Office of Appalachian Studies to obtain results comparable to the "developmental benchmarks" used in other activities.

Much of the mountainous area of the eastern United States is within the Appalachian region. The source of many of the streams that empty waters into both the Atlantic Ocean and the Gulf of Mexico is in the Appalachian region. The mountainous terrain and available water provide a tremendous potential for pumped storage and some remaining potential for conventional or combined conventional-pumped storage hydroelectric developments. Many of the potential hydroelectric sites, undoubtedly, will be developed as rapidly as their power can be used to satisfy a part of the total supply spectrum, provided they can be constructed and operated as economically as other comparable sources of supply.

Fossil fuels of the type burned mostly in steam-electric generating plants are found throughout most of the Appalachian region. These fuels, which are predominantly coal, are most often shipped to surrounding areas for use in producing electric power. It is possible that in lieu of shipping the fuel to other areas, large fossil fuel burning generating plants might be located in the Appalachian region and the power produced by these plants delivered by high-voltage electric transmission circuits to outlying areas. Such "mine-mouth" generation, however, faces competition from nuclear fueled generating plants located closer to load centers.

#### Past and Estimated Future Electric Power Requirements

During the 15 years from 1950 to 1965 the total electric energy requirements for load nearly tripled in quantity in both the 15 power supply areas shown on Figure 1 and the Appalachian region, and the demand increased about 2.75 times in size. The annual peak during this period occurred in December. The past annual electric power requirements of utilities in the 15 power supply areas and load factors are summarized by five-year intervals from 1950 through 1965 in Table 1.

TABLE 1

PAST ANNUAL ELECTRIC POWER REQUIREMENTS  
(15 Power Supply Areas)

<u>Year</u>	<u>Energy for Load (gwh)</u>	<u>Peak Demand (mw)</u>	<u>Load Factor (%)</u>
1950	164,263	31,343	59.8
1955	276,754	49,952	63.2
1960	367,358	63,083	66.3
1965	488,525	86,062	64.6

Past annual power requirements for the Appalachian region were obtained by apportioning total requirements of the 15 power supply areas to the Appalachian region on a population and area basis. A ratio of two parts population and one part area was used in the apportionment. The resulting estimated past annual power requirements for the Appalachian region are shown in Table 2.

TABLE 2

ESTIMATED PAST ANNUAL ELECTRIC POWER  
REQUIREMENTS IN APPALACHIAN REGION

<u>Year</u>	<u>Energy for Load (gwh)</u>	<u>Peak Demand (mw)</u>	<u>Load Factor (%)</u>
1950	45,336	8,651	59.8
1955	74,724	13,487	63.2
1960	96,982	16,264	66.3
1965	128,482	22,634	64.6

Data on power requirements for each of the selected 15 power supply areas, shown on Figure 1, are given in Table 3. Future electric power requirements are estimated at five-year intervals from 1970 through 1990, and thereafter for years 2000 and 2020. The estimates through 1990 represent results obtained through close coordination with estimates and projections of important elements such as population, housing, income, appliance, saturation, commercial activities, and manufacturing, which influence substantially or relate closely to the use of electric power. They are also in substantial agreement with estimates made by major utilities to the Federal Power Commission in connection with updating the National Power Survey. Beyond 1990 the results are obtained from projections of curves. The future power requirements shown in Table 3 are based upon normally expected growth conditions.

TABLE 3

## ANNUAL ELECTRIC POWER REQUIREMENTS OF ALL UTILITIES

Power Supply Area	Year		Energy for Load (gwh)	Peak Demand (mw)	Load Factor (%)	Month of Peak
	Past	Esti- mated				
3	1950		17,291	2,793	70.7	Dec.
	1955		23,085	3,987	66.1	Dec.
	1960		27,304	4,581	67.9	Dec.
	1965		36,080	6,043	68.2	Dec.
		1970	46,100	7,730	68.1	Winter
		1975	58,700	9,850	68.0	Winter
		1980	74,900	12,600	67.9	Winter
		1985	95,700	16,150	67.6	Winter
		1990	122,200	20,650	67.6	Winter
		2000	199,000	33,600	67.6	Winter
		2020	527,000	89,000	67.6	Winter
4	1950		15,491	3,531	50.1	Dec.
	1955		20,827	4,549	52.3	Dec.
	1960		27,411	5,540	56.5	Aug.
	1965		36,830	7,538	55.8	June
		1970	48,700	9,930	56.0	Summer
		1975	64,400	12,900	57.0	Summer
		1980	85,100	16,700	58.2	Summer
		1985	111,700	21,800	58.5	Summer
		1990	147,200	28,600	58.8	Summer
		2000	251,000	48,600	59.0	Summer
		2020	715,000	137,000	59.6	Summer
5	1950		31,743	6,173	58.7	Dec.
	1955		44,057	8,719	57.7	Dec.
	1960		57,937	10,808	61.0	Aug.
	1965		81,041	14,615	63.3	Aug.
		1970	116,640	21,070	63.2	Summer
		1975	163,030	29,370	63.4	Summer
		1980	218,770	39,270	63.6	Summer
		1985	292,920	52,410	63.8	Summer
		1990	388,380	69,280	64.0	Summer
		2000	680,000	121,100	64.1	Summer
		2020	2,040,000	362,200	64.3	Summer

TABLE 3 (Cont'd)

## ANNUAL ELECTRIC POWER REQUIREMENTS OF ALL UTILITIES

Power Supply Area	Year		Energy for Load (gwh)	Peak Demand (mw)	Load Factor (%)	Month of Peak	
	Past	Esti- mated					
6	1950		2,365	488	55.3	July	
	1955		3,484	768	51.8	Aug.	
	1960		5,079	1,196	48.5	Aug.	
	1965		8,002	1,874	48.7	Aug.	
		1970		12,740	3,050	47.7	Summer
		1975		18,280	4,340	48.1	Summer
		1980		25,490	6,000	48.5	Summer
		1985		34,780	8,120	48.9	Summer
		1990		47,120	10,910	49.3	Summer
		2000		84,500	19,400	49.7	Summer
		2020		261,000	58,800	50.7	Summer
7	1950		10,678	1,938	62.9	Dec.	
	1955		14,507	2,558	64.7	Dec.	
	1960		17,544	2,994	66.7	Jan.	
	1965		23,885	3,948	69.1	Dec.	
		1970		31,100	5,140	69.1	Winter
		1975		40,400	6,660	69.2	Winter
		1980		52,600	8,640	69.3	Winter
		1985		68,400	11,250	69.4	Winter
		1990		88,900	14,600	69.5	Winter
		2000		150,000	24,600	69.6	Winter
		2020		420,000	69,800	69.7	Winter
8	1950		4,778	929	58.6	Dec.	
	1955		6,978	1,333	59.8	Dec.	
	1960		8,574	1,590	61.6	Sept.	
	1965		11,574	2,002	66.0	Sept.	
		1970		15,400	2,590	68.0	Summer
		1975		20,530	3,450	68.0	Summer
		1980		27,350	4,590	68.0	Summer
		1985		36,400	6,110	68.0	Summer
		1990		48,500	8,140	68.0	Summer
		2000		85,500	14,350	68.0	Summer
		2020		260,000	43,600	68.1	Summer

TABLE 3 (Cont'd)

## ANNUAL ELECTRIC POWER REQUIREMENTS OF ALL UTILITIES

Power Supply Area	Year		Energy for Load (gwh)	Peak Demand (mw)	Load Factor (%)	Month of Peak	
	Past	Esti- mated					
9	1950		13,944	2,543	62.6	Dec.	
	1955		31,873	5,715	63.7	Nov.	
	1960		46,949	6,839	78.2	Jan.	
	1965		51,753	7,828	75.4	Dec.	
		1970		63,600	10,250	70.8	Winter
		1975		96,480	15,110	72.9	Winter
		1980		131,110	20,570	72.8	Winter
		1985		172,610	27,330	72.1	Winter
		1990		230,010	36,660	71.6	Winter
		2000		414,210	66,600	71.0	Winter
		2020		1,390,210	225,800	70.3	Winter
10	1950		5,302	931	64.9	Dec.	
	1955		8,376	1,341	71.3	Aug.	
	1960		9,916	1,643	68.7	Dec.	
	1965		13,770	2,273	69.1	Dec.	
		1970		18,300	3,020	69.2	Winter
		1975		24,400	4,010	69.5	Winter
		1980		32,500	5,310	69.9	Winter
		1985		43,300	7,080	69.8	Winter
		1990		57,700	9,410	70.0	Winter
		2000		101,000	16,450	70.1	Winter
		2020		302,000	49,200	70.1	Winter
12	1950		16,246	3,233	57.4	Dec.	
	1955		24,705	4,653	60.6	Dec.	
	1960		32,613	5,878	63.3	Dec.	
	1965		45,640	8,149	64.0	Aug.	
		1970		63,120	11,500	62.6	Summer
		1975		88,900	16,000	63.5	Summer
		1980		123,000	22,000	63.9	Summer
		1985		169,000	30,000	64.3	Summer
		1990		233,200	41,400	64.4	Summer
		2000		373,100	66,000	64.5	Summer
		2020		730,400	128,700	64.8	Summer

TABLE 3 (Cont'd)

## ANNUAL ELECTRIC POWER REQUIREMENTS OF ALL UTILITIES

Power Supply Area	Year		Energy for Load (gwh)	Peak Demand (mw)	Load Factor (%)	Month of Peak
	Past	Esti- mated				
18	1950		3,639	751	55.3	Dec.
	1955		5,938	1,171	57.9	Dec.
	1960		9,380	1,815	59.0	Aug.
	1965		14,994	2,923	58.6	Sept.
		1970	23,790	4,770	56.9	Summer
		1975	37,730	7,460	57.8	Summer
		1980	57,420	11,170	58.6	Summer
		1985	82,830	15,960	59.3	Summer
		1990	114,240	21,760	60.0	Summer
		2000	171,400	30,550	64.0	Summer
		2020	335,400	55,500	69.0	Summer
19	1950		1,426	318	51.2	Dec.
	1955		2,311	471	56.0	Dec.
	1960		3,362	672	57.0	Dec.
	1965		4,897	964	57.8	Aug.
		1970	8,770	1,770	56.6	Summer
		1975	13,080	2,470	60.5	Summer
		1980	18,080	3,470	59.5	Summer
		1985	27,080	5,280	58.5	Summer
		1990	38,080	7,490	58.0	Summer
		2000	57,000	10,950	59.4	Summer
		2020	111,400	20,800	61.2	Summer
20	1950		17,622	3,033	66.3	Dec.
	1955		53,207	8,314	73.1	Nov.
	1960		66,520	10,732	70.6	Dec.
	1965		77,378	12,804	69.0	Feb.
		1970	96,720	18,050	61.0	Winter
		1975	135,900	25,260	61.4	Winter
		1980	185,550	33,610	63.0	Winter
		1985	218,760	40,210	62.0	Winter
		1990	253,160	47,010	61.4	Winter
		2000	320,000	60,000	60.8	Winter
		2020	460,000	88,000	59.6	Winter

TABLE 3 (Cont'd)

## ANNUAL ELECTRIC POWER REQUIREMENTS OF ALL UTILITIES

Power Supply Area	Year		Energy for Load (gwh)	Peak Demand (mw)	Load Factor (%)	Month of Peak	
	Past	Esti- mated					
21	1950		12,282	2,430	57.7	Dec.	
	1955		19,560	3,597	62.1	Dec.	
	1960		27,488	4,992	62.9	Dec.	
	1965		41,374	7,322	64.3	Aug.	
		1970	66,500	11,460	66.2	Summer	
		1975	99,230	17,000	66.6	Summer	
		1980	143,650	24,560	66.7	Summer	
		1985	209,320	35,650	67.0	Summer	
		1990	313,880	53,300	67.1	Summer	
		2000	470,800	79,500	67.5	Summer	
		2020	921,600	153,800	68.4	Summer	
	22	1950		5,663	1,081	59.8	Dec.
		1955		8,778	1,640	61.1	Aug.
1960			13,458	2,548	60.3	July	
1965			20,391	3,896	59.6	Aug.	
		1970	32,180	6,080	60.3	Summer	
		1975	47,560	9,090	59.8	Summer	
		1980	67,930	12,940	59.8	Summer	
		1985	96,850	18,350	60.2	Summer	
		1990	126,890	23,970	60.4	Summer	
		2000	190,300	33,700	64.5	Summer	
		2020	372,600	61,800	68.7	Summer	
23		1950		5,790	1,186	55.7	Dec.
		1955		9,068	1,757	58.9	Aug.
	1960		13,822	2,638	59.8	Aug.	
	1965		20,916	3,882	61.5	Aug.	
		1970	33,890	6,320	61.2	Summer	
		1975	44,880	8,300	61.6	Summer	
		1980	66,150	12,190	62.0	Summer	
		1985	96,120	17,670	62.0	Summer	
		1990	137,790	25,260	62.3	Summer	
		2000	206,700	36,850	64.0	Summer	
		2020	404,600	70,000	66.0	Summer	

The estimated projected power requirements for the 15 power supply areas shown in Table 3 are summarized in Table 4.

TABLE 4

ESTIMATED FUTURE ELECTRIC POWER  
REQUIREMENTS OF UTILITIES IN 15  
POWER SUPPLY AREAS  
(Normally Expected Growth Conditions)

<u>Year</u>	<u>Energy for Load (gwh)</u>	<u>Peak Demand (mw)</u>	<u>Load Factor (%)</u>
1970	677,550	122,730	63.0
1975	953,550	171,270	63.5
1980	1,309,600	233,620	63.9
1985	1,755,770	315,370	63.6
1990	2,347,250	418,440	64.3
2000	3,754,510	662,250	64.6
2020	9,251,210	1,614,000	65.4

Estimates of the future electric power requirements for the Appalachian region under normal growth conditions were obtained by apportioning the data for the 15 power supply areas to the Appalachian region on a population and area basis. The apportioned values for the Appalachian region are shown in Table 5.

TABLE 5

ESTIMATED FUTURE ELECTRIC  
POWER REQUIREMENTS IN APPALACHIAN REGION  
(Normally Expected Growth Conditions)

<u>Year</u>	<u>Energy for Load (gwh)</u>	<u>Peak Demand (mw)</u>	<u>Load Factor (%)</u>
1970	177,000	32,000	63.0
1975	248,000	44,500	63.5
1980	337,500	60,200	63.9
1985	449,000	80,600	63.6
1990	597,000	106,100	64.3
2000	930,000	164,100	64.6
2020	2,220,000	338,000	65.4

The estimated electric power requirements for the Appalachian region under "developmental benchmarks" conditions are greater than the requirements under normally expected growth conditions. Following the pattern of an accelerated rate of increase in population under the "developmental benchmarks", the future power requirements become significantly greater after 1980. Estimates and projections under these accelerated growth conditions are shown in Table 6.

TABLE 6

ESTIMATED FUTURE ELECTRIC  
POWER REQUIREMENTS IN APPALACHIAN REGION  
(Under "Developmental Benchmarks" Growth Conditions)

<u>Year</u>	<u>Energy for Load (gwh)</u>	<u>Peak Demand (mw)</u>	<u>Load Factor (%)</u>
1970	177,000	32,000	63.0
1975	248,500	44,700	63.5
1980	340,000	60,700	63.9
1985	459,000	82,400	63.6
1990	615,000	109,600	64.0
2000	984,000	173,800	64.6
2020	2,460,000	430,000	65.4

No adjustments are made to the power requirement estimates presented in this report for the collective and the individual 15 power supply areas to compensate for the Appalachian region estimates and projections under "developmental benchmarks" growth conditions. Some adjustments may need to be made if part or all of the increased population and economic activities expected under "developmental benchmarks" are drawn from outside the 15 power supply areas. It is probable that part would come from outside and part from within the 15 power supply areas. Any adjustments in the totals for the 15 power supply areas, however, would be relatively small and would have very little effect on the results of this study. No adjustments will be needed in the totals if increased activities all come from within the 15 power supply areas, but there could be cases where adjustments would be needed among and between individual areas.

Past and estimated future power requirements for the 15 power supply areas under normally expected growth conditions, and for the Appalachian region under both normal and "developmental benchmarks" growth conditions are shown on Figure 2.

Monthly distributions in 1967 of peak loads, energy requirements, and load factors of the major suppliers in the 15 power supply areas are shown in Table 7.

# ELECTRICAL POWER REQUIREMENTS

## APPALACHIAN REGION and 15 POWER SUPPLY AREAS




TABLE 7

MONTHLY DISTRIBUTION OF LOADS - 1967  
(15 Power Supply Areas)

Time	Peak Load		Energy		Load
	(gw)	(%)	(1000 gwh)	(%)	(%)
Jan.	85.9	94.7	47.4	8.6	74.2
Feb.	86.0	94.8	43.8	8.0	75.8
Mar.	82.0	90.4	45.6	8.3	74.8
Apr.	78.8	86.9	42.1	7.7	74.2
May	79.7	87.9	43.9	8.0	74.0
June	90.5	99.8	46.1	8.4	70.7
July	89.5	98.7	46.3	8.4	69.5
Aug.	89.4	98.6	48.2	8.8	72.5
Sept.	84.0	92.6	43.7	8.0	72.2
Oct.	82.7	91.2	45.8	8.3	74.5
Nov.	89.3	98.4	47.1	8.5	73.2
Dec.	90.7	100.0	49.3	9.0	73.0
Year	90.7	100.0	549.3	100.0	69.1

Peak loads in the Appalachian region and most of the 15 power supply areas have occurred, until recent years, during winter months. During the past 10 to 15 years annual peaks have occurred in some of the areas during summer months, and the frequency of occurrence of summer peaks continues to increase. Summer loads are increasing faster over previous summer loads than the corresponding increase of winter loads. The higher rate of increase of summer peaks is due chiefly to large increases in air-conditioning loads. The load factors of summer loads are also increasing faster than those of winter loads. This will eventually result in the summer loads requiring more energy per given load. This condition, together with the leveling of summer and winter peaks, results in higher annual load factors. However, if subsequent summer loads continue to increase at a faster rate than winter loads the result will be a gradually decreasing annual load factor. This condition of unbalanced summer and winter loads does not adapt to the best economical use of supply facilities and it increases operating problems. To prevent the summer loads from becoming unproportionally large, utility companies will probably promote heating and other winter loads to keep the winter peaks in line with the summer peaks. Load shapes and load factors of the summer loads, however, are expected to remain "fatter" and higher than the winter loads. Annual load factors shown in Table 4 reflect this condition.

CHAPTER IV - EXISTING ELECTRIC POWER SUPPLY

Utility Systems

There were 78 major electric suppliers in the 15 power supply areas in 1967. They furnished about 91 million kilowatts of demand and 549 billion kilowatt-hours of energy at an annual load factor of about 68.9 percent. These supplies accounted for most of the electric power needs of the region. The major suppliers, located by power supply areas, are shown in Table 8. Installed capacities available for supply are given as of December 31, 1967, and the capacities scheduled at that time to be available for service through 1970 are also shown. About 99 percent of the total electric power supply in 1970 will be furnished by these major suppliers.

TABLE 8

MAJOR ELECTRIC POWER SUPPLIERS  
(15 Power Supply Areas)

Power Supply Area Supplier	Installed Capacity (mw)	
	Dec. 1967	1970 <sup>1/</sup>
Power Supply Areas 3 & 4 N. Y. Interconnected System <sup>2/</sup>	18,016	21,702
Power Supply Areas 5 & 6 P.J.M. Interconnection <sup>3/</sup>	21,963	29,119
Vineland Municipal System	52	52
Safe Harbor Water Power Corp.	228	228
	<u>22,243</u>	<u>29,399</u>
Power Supply Area 7 Allegheny Power System, Inc. <sup>4/</sup>	2,646	4,222
Duquesne Light Co.	<u>1,538</u>	<u>2,063</u>
	4,184	6,285
Power Supply Area 8 The Cleveland Elec. Illuminating Co.	2,146	2,771
Cleveland Division of Light & Power	138	223
	<u>2,284</u>	<u>2,994</u>

TABLE 8 (Cont'd)

Power Supply Area Supplier	Installed Capacity (mw)	
	Dec. 1967	1970 <sup>1/</sup>
<b>Power Supply Areas 9, 10, &amp; 12</b>		
Columbus Municipal Plant	58	58
Columbus & Sou. Ohio Electric Co.	1,045	1,103
Ohio Edison Co. & Penn. Pwr. Co.	3,089	3,712
The Toledo Edison Co.	835	1,072
Ohio Valley Electric Corp.	2,390	2,390
American Electric Power System <sup>5/</sup>	9,351	11,566
Danville Water, Gas and Elec. Dept.	39	39
Anderson Municipal Plant	19	19
Cincinnati Gas & Electric Co.	1,619	2,674
The Dayton Power & Light Co.	872	929
Fort Wayne Municipal Works	48	48
Hamilton Municipal Plant	97	97
Indianapolis Power & Light Co.	1,101	1,522
Louisville Gas & Electric Co.	1,258	1,603
Northern Indiana Public Service Co.	871	1,467
Pub. Serv. Co. of Indiana, Inc.	1,713	2,634
Richmond Power & Light	60	60
So. Indiana Gas & Electric Co.	289	589
	<u>24,754</u>	<u>31,582</u>
<b>Power Supply Area 18</b>		
Southeastern Power Administration	218	218
Virginia Electric and Power Co.	<u>4,272</u>	<u>5,171</u>
	4,490	5,389
<b>Power Supply Area 19</b>		
Big River Electric Cooperative	96	416
East Kentucky Rural Elec. Coop. Corp.	300	500
Kentucky Utilities Co.	762	762
Owensboro Municipal System	203	203
	<u>1,361</u>	<u>1,881</u>
<b>Power Supply Area 20</b>		
Tennessee Valley Authority <sup>6/</sup>	18,095	20,539
<b>Power Supply Area 21</b>		
Carolina Power & Light Co.	2,258	2,972
Duke Power Co.	4,723	6,153
Lockhart Power Co.	17	17
South Carolina Electric & Gas Co.	1,413	1,865
South Carolina Public Service Auth.	420	766
Yadkin, Inc.	201	201
Southeastern Power Administration	280	280
	<u>9,312</u>	<u>12,254</u>

TABLE 8 (Cont'd)

Power Supply Area Supplier	Installed Capacity (mw)	
	Dec. 1967	1970 <sup>1/</sup>
Power Supply Areas 22 & 23		
Alabama Electric Cooperative, Inc.	58	124
The Southern Co. <sup>7/</sup>	9,247	12,072
Savannah Electric and Power Co.	319	319
Southeastern Power Administration	552	627
	<u>10,176</u>	<u>13,142</u>

<sup>1/</sup> Includes installed capacity as of December 31, 1967, plus capacity scheduled at that time for service through 1970.

<sup>2/</sup> Jamestown Municipal System; Long Sault, Inc.; New York State Electric & Gas Corp.; Niagara-Mohawk Power Corp.; New York Power Authority; Rochester Gas & Electric Corp.; Central Hudson Gas & Electric Corp.; Consolidated Edison Co. of New York, Inc.; Long Island Lighting Co.; and Orange and Rockland Utilities, Inc.

<sup>3/</sup> Atlantic City Electric Co.; Baltimore Gas & Electric Co.; Bethlehem Steel Co.; Delmarva Power & Light Co.; General Electric Co.; Hershey Chocolate Corp.; Jersey Central Power & Light Co.; United Gas Improvement Co.; Metropolitan Edison Co.; New Jersey Power & Light Co.; Pennsylvania Electric Co.; Pennsylvania Power & Light Co.; Philadelphia Electric Co.; Potomac Electric Power Co.; and Public Service Electric and Gas Co.

<sup>4/</sup> Monongahela Power Co.; The Potomac Edison Co.; and West Pennsylvania Power Co.

<sup>5/</sup> Appalachian Power Co.; Indiana & Michigan Electric Co.; Kentucky Power Co.; Kingsport Power Co.; Ohio Power Co.; Wheeling Electric Co.; and Kanawha Valley Power Co.

<sup>6/</sup> Includes capacity of Tapoco, Inc., and Southeastern Power Administration.

<sup>7/</sup> Alabama Power Co.; Georgia Power Co.; Gulf Power Co.; Mississippi Power Co.; and Southern Electric Generating Co.

All the major electric power suppliers are interconnected to the network of transmission lines which extend through the 15 power supply areas. Most of the largest privately-owned utilities within the area are grouped into power pools through agreements. Installed capacities of the power pools for 1970 are shown in Table 9. The Tennessee Valley Authority, an agency of the Federal Government is not a member, as such, of any pool group but is included in Table 9 because of its size.

TABLE 9

POWER POOL GROUPS  
(15 Power Supply Areas)

<u>Supplier Group</u> <sup>1/</sup>	<u>Power Supply Area</u>	<u>Installed Capacity (1970) (mw)</u>
New York Interconnected System <sup>2/</sup>	3 & 4	21,463
Pennsylvania-New Jersey-Maryland Systems (PJM) <sup>3/</sup>	5 & 6	29,119
Alleghany Power System, Inc. <sup>4/</sup>	7	4,222
Combined Systems - Ohio Edison Co. and Pennsylvania Power Co.	9	3,712
American Electric Power System <sup>5/</sup>	9, 10, & 12	11,566
Carolina-Virginia Power Pool (CARVA) - Va. Elec. & Pwr. Co., Carolina Pwr. & Light Co., Duke Power Company, and S. C. Elec. & Gas Co.	18 & 21	16,161 <sup>8/</sup>
Tennessee Valley Authority <sup>6/</sup>	20	20,567
The Southern Co. <sup>7/</sup>	22 & 23	12,072 <sup>9/</sup>

<sup>1/</sup> Footnote references <sup>2/</sup> through <sup>7/</sup> refer to the corresponding footnotes in Table 8.

<sup>8/</sup> CARVA as of December 31, 1967, also dispatched 336 megawatts of power available under contract from Southeastern Power Administration.

<sup>9/</sup> The Southern Company as of December 31, 1967, also dispatched 497 megawatts of power available under contract from Southeastern Power Administration.

Generating Facilities

About 99 percent of the total electric power supply available for service by 1970 in the 15 power supply areas will be from plants with 10,000 kilowatts or more of installed capacity. The total supply scheduled for 1970 by power supply areas and division between fuel-electric and hydroelectric power are given in Table 10.

TABLE 10  
 INSTALLED CAPACITY AVAILABLE FOR 1970  
 (15 Power Supply Areas)

Power Supply Area	Installed Capacity (Millions of Kilowatts)		Total
	Fuel-Electric	Hydroelectric	
3 & 4	18	4	22
5 & 6	27	2	29
7	6	-	6
8	3	0	3
9, 10, & 12	31	1	32
18	5	1	6
19	2	-	2
20	16	4	20
21	10	2	12
22 & 23	<u>11</u>	<u>2</u>	<u>13</u>
Total	129	16	145

Information on generating supply available by 1970 by individual plants, and according to ownership and types of supply, is given in Table 11. The owner codes are explained in Table 12. Plant locations and plant numbers listed in Table 11 are keyed to the electric facilities map, Figure 3.

The types of supply shown in Table 11 include hydroelectric, conventional fuel-electric, nuclear and pumped-storage installations. The latter two are both recent additions to the sources of supply. Current trends, however, indicate that they will become important contributors and their proportions to the total supply are expected to increase substantially and rapidly.

#### Transmission Facilities

All major transmission circuits of 100,000 volts and above and all generating plants of 10,000 kilowatts and larger in the 15 power supply areas are shown on Figure 3. As indicated on the map, nearly all places in the entire area are within a few miles of a major source of supply. Those few small places, in most instances, are served by lower voltage circuits, not shown on the map, which are adequate for their current requirements.

Until recently most of the transmission circuits were operated at 115, 138, and 169 thousand volts with a few 230 and 345 thousand volt overlying lines. During recent years a large number of 230 and 500 thousand volt lines have been and are being added, and some lines of 765 thousand volts are being constructed. The higher voltage lines, capable of handling many times the loads of the lower voltage lines, will soon completely overlay the older 115, 138, and 169 thousand volt lines. These high-voltage trunk lines will interconnect between and among the major supply sources and load centers. Also, they will provide strong interconnection sources between the power supply areas and regions, and will aid in the degree of reliability of service.

TABLE II  
 AVAILABLE POWER SUPPLY  
 GENERATING PLANTS - EXISTING AND UNDER CONSTRUCTION  
 (15 Power Supply Areas)

PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER CODE	PLANT LOCATION	PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER CODE	PLANT LOCATION
<b>ALABAMA</b>					<b>GEORGIA</b>				
1	Berry	574.3 St	ALAP	L-5	1	Allatoona	72.0 Hy	USAR	J-3
2	Bennett Mills	404.8 St*	ALAP	L-5	2	Applight	131.3 St	GEPC	K-3
3	Baldwin	15.0 St	HEMI	J-7	3	Ashlan	252.0 St	GEPC	K-3
4	Central	20.0 St	REGO	J-7	7	Bartlett Ferry	55.0 Hy	GEPC	K-3
5	Childersburg	17.8 St	WOLC	J-7, K-3	8	Bias Ridge	21.0 Hy	TVA	K-3
6	Colbert	14.0 St 25c	WOLC	J-7, K-3	10	Bisford	26.0 Hy	USAR	J-3
7	Conley	139.0 St	ALAP	L-5, L-2	20	Goat Rock	26.0 Hy	GEPC	K-3
8	Fairfield	14.0 St	COBN	J-7	22	Hammond	374.0 St	GEPC	J-7
9	Gadsden No. 1 & 2	1,394.5 St	TVA	K-3	23	Hartwell	240.0 St*	USAR	K-3
10	Gorgas No. 1	14.0 St 25c	UNSS	J-7, K-3	27	Lloyd Shofko	14.0 Hy	GEPC	J-3
11	Gorgas No. 2	138.0 St	UNSS	J-7, K-3	29	McNams	143.8 St	GEPC	L-10
12	Gorgas No. 3	379.0 St	ALAP	J-7	30	Morgan Falls	16.4 Hy	GEPC	L-3
13	Huntsville	377.9 St	ALAP	J-7	32	Orlap	14.0 St	CRCP	L-3
14	Jordan Dam	97.0 Hy	TVA	K-7	33	North Highlands	29.0 Hy	GEPC	K-3
15	Joy Dam	104.0 Hy	ALAP	K-7	34	Notelby	15.0 Hy	TVA	K-3
16	Martin Dam	34.4 Hy	ALAP	K-7	35	Oilver	60.0 Hy	GEPC	K-3
17	McWilliams	177.0 Hy*	ALAP	K-7	37	Port Westworth	207.9 St	SASP	K-10
18	Mitchell Dam	154.0 Hy	ALAP	K-7	38	Riverside	116.0 St*	SASP	K-10
19	Mobile	41.0 St	ALSC	L-7	39	Stclair Dam	45.0 Hy	GEPC	J-3
20	Mobilis	22.0 St	ALMA	M-1, L-3	41	Stevens Creek	18.9 Hy	SOOG	J-10
21	Mobilis Mill	44.0 St	GEPC	M-1, L-2	42	Tallah Falls	72.0 Hy	GEPC	K-3
22	Nav Plant	71.8 St	INRC	L-2, L-3, K-3	44	Terrara	35.0 Hy	GEPC	K-3
23	North	12.0 St	USPT	L-2, K-3	46	Tigalo	45.0 Hy	GEPC	K-3
24	Palmer Dam	157.5 Hy	ALAP	J-7	47	Warwick	14.0 Hy	CRCP	L-3
25	Parlow Dam	58.0 Hy	ALAP	K-7	49	Mitchell, Wm.	213.3 St	GEPC	L-3
26	Russelton	19.3 St	UNSP	J-7	50	Yates	680.0 St	GEPC	J-3
27	Wheeler Dam	396.4 Hy	TVA	K-3	51	Yonah	22.5 Hy	GEPC	K-3
28	Widow Creek	1,978.0 St	TVA	K-7	52	Melbrough	598.4 St	GEPC	J-3
29	Wilson Dam	620.0 Hy	TVA	K-3	53	Carters	250.0 Hy*	USAR	K-3
30	Wills	87.8 Hy	ALAP	J-7	54	Branch, Barlow	698.2 St	GEPC	J-3
31	Gaston, Ernest H.	1,066.7 St	SURE	J-7	55	George, W. F.	544.0 St*	GEPC	J-3
32	Yates	30.0 Hy	ALAP	K-7	A	West Point	130.0 Hy	USAR	L-3
33	Buckhead Lock 17	44.0 Hy	ALAP	L-2	B	Wet Point	78.4 Hy*	USAR	K-3
34	Martin, Logan	127.8 Hy	ALAP	J-7	8	Batch	800.0 St*	GEPC	L-10
35	Greene County	598.8 St	ALAP	K-3					
36	H. Healy Berry	74.9 Hy	ALAP	J-7					
37	Millers Ferry	78.0 Hy*	USAR	K-3					
38	Soulin Dam	258.0 Hy	ALAP	K-7					
39	James Bluff	64.0 Hy*	USAR	K-3					
40	Jackson	64.0 St	ALSC	L-3					
41	Brown Ferry	1,450.0 Hy*	TVA	K-3					
42	Holt Dam	40.0 Hy*	ALAP	J-3					
	1/ 5.0 Mw owned by Mt. Vernon Woodbury Mills, Inc.								
	2/ Jointly owned by ALAP (60%) and MTR (40%).								
<b>DELAWARE</b>					<b>INDIANA</b>				
2	Delaware City	129.4 St	DEPL	D-9	1	Anderson	19.0 St	INER	C-1
3	Edgemoor	71.3 GT	DEPL	D-9	4	Broad	450.0 St	INER	D-1
4	Indian River	363.0 St	DEPL	D-10	5	Bluffington	25.5 St 25c	UNSS	K-3, K-15
5	Madison St.	15.0 GT	DEPL	D-10	6	Charleston No. 1 and No. 2	50.0 St	OIMA	K-3
6	Marshallton	163.2 St	DEPL	D-10	7	Clisty Creek	1,150.0 St	INER	K-3
7	McKean Run	150.0 St*	DEPL	D-10	8	Crawfordsville	41.0 St	CRAW	C-3
8	Overmant	21.0 GT	DEPL	D-10	9	Mitchell, Dean R.	11.5 St*	CRAW	C-3
9	Seaford	21.0 GT	DEPL	D-10	10	Presser	411.3 St	NOIP	K-3, K-15
10		11.0 GT	DEPL	D-9	12	Silverdport	210.0 St	FSIN	K-3
11		17.0 GT	DEPL	D-9	13	Wardspart	121.3 St	FSIN	K-3
12		44.1 St	DOBE	D-10	15	Calley, F. R.	40.8 St	SOIG	K-3
13		37.5 GT	DEPL	D-10	16	Frankfort	99.0 St*	FSIN	K-3
		22.5 St	SJAF	D-10	17	Gary (5 Plants)	30.0 St	FRAP	C-3
					19	Stout, S. W.	70.0 St 25c	UNSS	K-3, K-16
					21	Indiana Harbor	710.10 25c	UNSS	K-3, K-16
					22	Jasper	370.1 St	INPL	D-3, K-3
					23	Johnson St.	95.0 St	YOST	D-3, K-15
					24	Linton	4.5 St	JASI	K-3
					25	Lawton Park	20.0 St*	JASI	K-3
					26	Lafayette	40.0 St	RICI	L-1
					27	Ligonport	47.5 St	POKA	C-3
					28	Michigan City	55.5 St	DESP	C-3
					29	Nappanee	211.0 St	DESP	K-3, K-16
					30	Shelbyville	12.3 St	WAFB	C-3
					31	Gallagher, R. A.	600.0 St	FSIN	K-3, K-5
					32	Nobelville	100.0 St	FSIN	L-1
					33	Oskdale	11.0 Hy	NOIP	C-3
					34	Ohio River	112.5 St	SOIG	K-3
					35	Perry - See "A"	47.5 St	INPL	D-3, C-3
					36	Perry - See "A"	10.0 St	INPL	L-1, C-3
					37	Portland	44.0 St	PERI	C-3
					38	Rensselaer	10.0 St	INME	C-3
					39	State Line	100.10	INER	C-3
					40	Tenners Creek	112.0 St	INME	K-3, K-15
					41	Van Branch	39.0 St	INME	L-1
					42	Wabash River	97.5 St	FSIN	D-3
					43	Washington	13.0 St	WALP	K-3
					44	Fritchard, R. T.	393.0 St	INPL	L-3

General Notes: \*Under construction; 25c - Indicative frequencies other than 60 cycles; St - Steam; Nu - Nuclear; IC - Internal Combustion; Hy - Hydro; GT - Gas Turbine.

COPY AVAILABLE TO DOE DOES NOT PERMIT FULLY LEGIBLE PRODUCTION

TABLE II (Cont'd)

PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER	PLANT LOCATION	PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER	PLANT LOCATION
INDIANA (Cont'd)					MISSISSIPPI				
53	White Water Valley	5.0 DC	ECOL	W-1	7	Atton	77.0 DC	MEPS	W-1
60	Chicago (4 Plants)	15.0 DC 250	INDI	W-1, W-15	8	Jack Antwan	50.0 DC	MEPS	W-1
61	Holly	15.0 DC	INDI	W-1, W-15	12	Laurel	50.0 DC	MEPS	W-1
62	Warrior	15.0 DC	ADCO	W-1	13	Swain	50.0 DC	MEPS	W-1
63	East Chicago	15.0 DC*	ADCO	W-1	NEW JERSEY				
65	Northwest	15.0 DC	INDI	W-1, W-15	1	Argon	600.0 DC	PG&E	W-1, W-2
66	Petersburg	15.0 DC*	INDI	W-1	2	Burlington	400.0 DC	PG&E	W-1, W-2
67	Meridian	15.0 DC	INDI	W-1	3	Deerpark	100.0 DC	PG&E	W-1, W-2
A	Kashoek Peaking Station	6.0 DC	INDI	W-1	4	Werner, S. R.	110.0 DC	PG&E	W-1, W-2
B	Coryus	6.0 DC*	INDI	W-1	5	Roanoke	100.0 DC	PG&E	W-1, W-2
C	Petersburg	6.0 DC*	INDI	W-1	6	Gilbert	100.0 DC	PG&E	W-1, W-2
✓ Includes 1,000 kw in industrial plants which receive steam from this plant.					7	Greenwich	11.0 DC	AT&T	W-1, W-2
KENTUCKY					8	Keowee	170.0 DC	PG&E	W-1, W-2
2	Canal	50.0 DC	LOUIS	S-1, S-2	9	Linden	170.0 DC	PG&E	W-1, W-2
3	Cane Run	50.0 DC	LOUIS	S-1, S-2	11	Marion	170.0 DC	PG&E	W-1, W-2
4	Dix Run	50.0 DC	KEPCO	S-1, S-2	12	Marion	170.0 DC	PG&E	W-1, W-2
5	Wagon, R. W.	200.0 DC	KEPCO	S-1, S-2	14	Millville	6.0 DC	MEMO	W-1, W-2
6	Green River	200.0 DC	KEPCO	S-1, S-2	15	Missouri Avenue	17.0 DC	AT&T	W-1, W-2
10	Henderson	40.0 DC	KEPCO	S-1, S-2	19	Deerfield	50.0 DC*	AT&T	W-1, W-2
11	Kentucky Dam	100.0 DC	WEA	S-1, S-2	20	Deerfield	50.0 DC	PG&E	W-1, W-2
15	Ohio Falls	50.0 DC	LOUIS	S-1, S-2	22	Vinland	115.0 DC	PG&E	W-1, W-2
16	Owensboro	50.0 DC	WEA	S-1, S-2	23	Watauga	50.0 DC	PG&E	W-1, W-2
17	Polkys Dam	50.0 DC	LOUIS	S-1, S-2	25	England, S. L.	200.0 DC	AT&T	W-1, W-2
19	Flintville	5.0 DC	KEPCO	S-1, S-2	26	Oyster Creek	1,500.0 DC*	GE	W-1, W-2
20	Shawnee	1,700.0 DC	WEA	S-1, S-2	27	Jordan Creek	100.0 DC	GE	W-1, W-2
21	Troy	100.0 DC	KEPCO	S-1, S-2	29	Hudson	400.0 DC	PG&E	W-1, W-2
22	Waterloo	50.0 DC	WEA	S-1, S-2	30	Whippany	100.0 DC	WEPA	W-1, W-2
23	Watauga, W. S.	100.0 DC	WEA	S-1, S-2	A	Longwood Valley	100.0 DC*	GE	W-1, W-2
24	Wolf Creek	200.0 DC	WEA	S-1, S-2	B	John	2,000.0 DC*	PG&E	W-1, W-2
25	Worley	1,000.0 DC	WEA	S-1, S-2	NEW YORK				
26	Paradise	1,000.0 DC	WEA	S-1, S-2	2	Albany	400.0 DC	NYEP	W-1, W-2
27	Hig Sandy	1,100.0 DC*	WEA	S-1, S-2	3	Arthur Kill	170.0 DC	NYEP	W-1, W-2
28	Cooper, John Sherman	200.0 DC*	KEPCO	S-1, S-2	6	Astoria	1,500.0 DC	NYEP	W-1, W-2
29	Smith, Elmer	200.0 DC*	KEPCO	S-1, S-2	8	Mason, Robert-Nagars	110.0 DC	NYEP	W-1, W-2
30	Bald	50.0 DC*	NYEP	S-1, S-2	9	Scarsdale Falls	20.0 DC	NYEP	W-1, W-2
A	Coleman	200.0 DC*	NYEP	S-1, S-2	13	Benetto Bridge	10.0 DC 250	NYEP	W-1, W-2
✓ KEPCO and NYEP are part of American Electric Power Service Corp.					15	Blair	10.0 DC	NYEP	W-1, W-2
MARYLAND					17	Brown Falls	10.0 DC	NYEP	W-1, W-2
3	Calverton	10.0 DC	PG&E	S-1, S-2	18	Buffalo	10.0 DC 250	NYEP	W-1, W-2
5	Conowingo	47.5 DC	PG&E	S-1, S-2	21	Greenidge, S. A.	100.0 DC	NYEP	W-1, W-2
6	Cummins	10.0 DC	PG&E	S-1, S-2	22	Hartley, Charles F.	100.0 DC	NYEP	W-1, W-2
7	Deep Creek	10.0 DC	PG&E	S-1, S-2	29	Callan	10.0 DC	NYEP	W-1, W-2
8	Dickerson	50.0 DC	PG&E	S-1, S-2	30	Carrollwood	10.0 DC	NYEP	W-1, W-2
9	Durbin	10.0 DC	PG&E	S-1, S-2	31	Deerfield	10.0 DC	NYEP	W-1, W-2
11	Gold Street	17.5 DC	PG&E	S-1, S-2	36	Dunkirk	10.0 DC	NYEP	W-1, W-2
12	Superston	10.0 DC	PG&E	S-1, S-2	40	East River	10.0 DC	NYEP	W-1, W-2
13	Wagner, Herbert A.	50.0 DC	PG&E	S-1, S-2	42	Burrill, S. F.	100.0 DC	NYEP	W-1, W-2
14	Pennwood	100.0 DC	PG&E	S-1, S-2	44	Wick, S. J.	10.0 DC	NYEP	W-1, W-2
15	Pratt Street	20.0 DC 250	PG&E	S-1, S-2	47	For Highway	10.0 DC	NYEP	W-1, W-2
16	Riverdale	20.0 DC	PG&E	S-1, S-2	50	Five Falls	10.0 DC	NYEP	W-1, W-2
17	Smith, R. Paul	100.0 DC	PG&E	S-1, S-2	51	Freeman	10.0 DC	NYEP	W-1, W-2
20	Sparrow Point	100.0 DC 250	PG&E	S-1, S-2	60	Glennco - Loading 2 & 3	10.0 DC	NYEP	W-1, W-2
22	Vienna	10.0 DC	PG&E	S-1, S-2	61	Long	10.0 DC	NYEP	W-1, W-2
23	Westport	10.0 DC	PG&E	S-1, S-2	63	Long	10.0 DC	NYEP	W-1, W-2
25	Crane, Charles F.	100.0 DC	PG&E	S-1, S-2	65	Orangetown	10.0 DC	NYEP	W-1, W-2
26	Shak Point	10.0 DC	PG&E	S-1, S-2	69	Wall Cove	10.0 DC 250	NYEP	W-1, W-2
27	Lake	10.0 DC	PG&E	S-1, S-2	74	Winking	10.0 DC	NYEP	W-1, W-2
A	Morgantown	1,100.0 DC*	PG&E	S-1, S-2	78	High Falls	10.0 DC	NYEP	W-1, W-2
B	Salvert Cliffs	1,000.0 DC*	PG&E	S-1, S-2	82	Waters Branch	10.0 DC	NYEP	W-1, W-2
C	Griffith	10.0 DC	PG&E	S-1, S-2					
D	(Not available)	10.0 DC*	PG&E	S-1, S-2					
✓ Site not selected.									
MICHIGAN									
A	Cook	2,200.0 DC*	INDI	S-1					

General Notes: \*Under construction; 250, 500 - Indicate frequencies other than 60 cycles  
 S - Steam; DC - Nuclear; DC - Internal Combustion; DC - Gas Turbine

TABLE II (Cont'd)

PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER CODE	PLANT LOCATION	PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER CODE	PLANT LOCATION
<b>NEW YORK (Cont'd)</b>					<b>NORTH CAROLINA (Cont'd)</b>				
84	Indian Point	2,135.0 Nu*	COEN	B-10	20	San River	200.0 St	DPSC	G-11
		16.0 GT	COEN	B-10	25	Saks	25.0 St	AMEC	G-9
86	Jennison	60.0 St	NYEK	G-9	28	Farmers	200.0 St	TYA	G-10
91	Kodak Park	88.1 St	BAAC	A-9, P-13	30	Allen, W. G.	1,100.0 St	DPSC	G-10
		50.0 St*	BAAC	A-9	31	Warton	177.0 St	VIEP	G-12
		0.0 Hy	BAAC	A-9, P-13	32	Lee, H. F.	200.0 St	CAPO	B-10
97	Lovett	294.5 St	ORNU	B-10	33	Greenville	10.0 St	GREV	G-13
		195.0 St*	ORNU	B-10	34	High Brook	30.0 Hy	YANI	G-11
105	Milliken	270.0 St	NYTE	A-9	36	Blawie	117.1 Hy	TYA	G-10
111	Neversink	25.0 Hy	ORNU	B-10	38	Kennapolis	10.0 St	CMMS	G-10
114	Northport	774.0 St	LAJL	C-11	39	Kinston	30.0 St	KIPU	G-13
		16.0 GT	LAJL	C-11	41	Sutton, L. V.	225.0 St	CAPO	B-10
		4.0 IC	LAJL	C-11	45	Lookout Shoals	10.0 Hy	DPSC	G-10
121	Gawego	370.0 St	NIMP	B-10	48	Anderswood	100.0 St	CAPO	B-10
129	Port Jefferson	407.0 St	LAJL	C-11	50	M. Island	60.0 Hy	DPSC	G-10
		10.0 GT	LAJL	C-11	51	Northboro	40.0 Hy	DPSC	G-10
131	Poughkeepsie	10.0 St	ORNU	B-10	52	Playoff Forest	10.0 St	DPSC	G-10
132	Prospect	17.0 Hy	NIMP	A-13	53	Rhodize	25.0 Hy	DPSC	G-10
135	Rainbow	20.0 Hy	NIMP	A-13	54	Riverbend	60.0 St	VIEP	G-12
137	Rio	10.0 Hy	ORNU	B-10	55	Romanco Rapids	100.0 Hy	DPSC	G-10
139	Rockville Centre	18.7 IC	ROCK	C-11, G-9	57	Rosy Mount	30.0 St	DPSC	G-10
		8.0 IC*	RIMP	A-11	58	Sandwich	40.0 Hy	DPSC	G-10
140	Schaghticoke	15.1 Hy	ORNU	B-10	59	Shawnee Creek	10.0 Hy	DPSC	G-10
141	Schoenady	27.5 St 40c	ORNU	B-10	60	Shawnee	10.0 Hy	DPSC	G-10
143	School Street	19.0 Hy	NIMP	A-10	61	Shawnee	10.0 Hy	DPSC	G-10
147	Sherman Creek	210.5 St	COEN	C-11, B-9	64	Shawnee	10.0 Hy	DPSC	G-10
149	Sherman Island	10.0 Hy	NIMP	A-11	66	Shawnee	10.0 Hy	DPSC	G-10
150	Soft Marble	15.0 Hy	NIMP	A-13	67	Shawnee	10.0 Hy	DPSC	G-10
151	South Colton	10.0 Hy	NIMP	A-13	68	Shawnee	10.0 Hy	DPSC	G-10
154	Spier Falls	40.0 Hy	NIMP	A-14	69	Shawnee	10.0 Hy	DPSC	G-10
156	Stark	20.0 Hy	NIMP	B-13	70	Shawnee	10.0 Hy	DPSC	G-10
157	Station No. 3	200.2 St	ROHS	A-9, P-13	71	Shawnee	10.0 Hy	DPSC	G-10
158	Station No. 5	34.1 Hy	ROHS	A-9, P-13	72	Shawnee	10.0 Hy	DPSC	G-10
159	Station No. 7 (Russell)	250.0 St*	JAME	B-7	73	Shawnee	10.0 Hy	DPSC	G-10
161	S. A. Carlson	25.0 St*	JAME	B-7	74	Shawnee	10.0 Hy	DPSC	G-10
		30.0 Hy	NIMP	B-14	75	Shawnee	10.0 Hy	DPSC	G-10
162	Stewarts Bridge	14.0 Hy	ORNU	B-10	76	Shawnee	10.0 Hy	DPSC	G-10
163	Sturgeon Pool	21.0 Hy	NIMP	B-13	77	Shawnee	10.0 Hy	DPSC	G-10
170	Trenton Falls	162.0 St 25c	COEN	C-10, G-9	78	Shawnee	10.0 Hy	DPSC	G-10
180	Waterside No. 1 & 2	572.0 St	COEN	C-10, G-9	79	Shawnee	10.0 Hy	DPSC	G-10
		14.0 GT	COEN	C-10	80	Shawnee	10.0 Hy	DPSC	G-10
		107.5 St 25c	COEN	C-10, G-9	81	Shawnee	10.0 Hy	DPSC	G-10
184	Kent Avenue	20.0 GT	COEN	C-10	82	Shawnee	10.0 Hy	DPSC	G-10
185	9th Street	149.5 St 25c	COEN	C-10, G-9	83	Shawnee	10.0 Hy	DPSC	G-10
		15.0 St	COEN	C-10, G-9	84	Shawnee	10.0 Hy	DPSC	G-10
		84.0 GT	COEN	C-10, G-9	85	Shawnee	10.0 Hy	DPSC	G-10
186	74th Street	120.0 St 25c	COEN	C-10, G-9	86	Shawnee	10.0 Hy	DPSC	G-10
		10.0 St	COEN	C-10	87	Shawnee	10.0 Hy	DPSC	G-10
		37.0 GT	COEN	C-10	88	Shawnee	10.0 Hy	DPSC	G-10
187	Moses, Robt-St Lawrence	1,954.0 Hy	POAS	A-7, B-8	89	Shawnee	10.0 Hy	DPSC	G-10
188	Leviston Pump	200.0 Hy	POAS	A-7, B-8	90	Shawnee	10.0 Hy	DPSC	G-10
189	Favenswood	1,800.0 St	COEN	C-10, G-9	91	Shawnee	10.0 Hy	DPSC	G-10
191	Skell	10.0 IC*	LAJL	C-11	92	Shawnee	10.0 Hy	DPSC	G-10
		0.0 IC*	LAJL	C-11	93	Shawnee	10.0 Hy	DPSC	G-10
193	Southampton	11.0 GT	LAJL	C-11	94	Shawnee	10.0 Hy	DPSC	G-10
195	Brooklyn	20.0 St	ORNU	C-10, G-9	95	Shawnee	10.0 Hy	DPSC	G-10
197	Deferiet	11.0 St	ORNU	A-13	96	Shawnee	10.0 Hy	DPSC	G-10
198	Lackawanna (2 Pits)	47.0 St 25c	ORNU	A-7, B-8	97	Shawnee	10.0 Hy	DPSC	G-10
199	Nine Mile Point	620.0 Nu*	NIMP	B-12	98	Shawnee	10.0 Hy	DPSC	G-10
		0.0 IC	NIMP	B-12	99	Shawnee	10.0 Hy	DPSC	G-10
200	Syracuse	54.0 St	ALCO	A-9	100	Shawnee	10.0 Hy	DPSC	G-10
201	Southold	14.0 GT	LAJL	C-11	101	Shawnee	10.0 Hy	DPSC	G-10
202	West Babylon	58.0 GT	LAJL	C-11	102	Shawnee	10.0 Hy	DPSC	G-10
A	R. E. Glens	517.0 Nu*	ROSE	A-8, G-11	103	Shawnee	10.0 Hy	DPSC	G-10
B	Easton	790.0 Nu*	NIMP	A-10	104	Shawnee	10.0 Hy	DPSC	G-10
C	Hill Station	851.0 Nu*	NYTE	A-9	105	Shawnee	10.0 Hy	DPSC	G-10
D	Shoreham	565.0 Nu*	LAJL	C-11	106	Shawnee	10.0 Hy	DPSC	G-10
		48.0 St*	LAJL	C-11	107	Shawnee	10.0 Hy	DPSC	G-10
		0.0 IC*	LAJL	C-11	108	Shawnee	10.0 Hy	DPSC	G-10
E	Cornwall	1,300.0 Hy*	COEN	B-10	109	Shawnee	10.0 Hy	DPSC	G-10
F	(Not available)	1,124.0 Nu*	COEN	B-10	110	Shawnee	10.0 Hy	DPSC	G-10
✓	Site not selected.				111	Shawnee	10.0 Hy	DPSC	G-10
					112	Shawnee	10.0 Hy	DPSC	G-10
					113	Shawnee	10.0 Hy	DPSC	G-10
					114	Shawnee	10.0 Hy	DPSC	G-10
					115	Shawnee	10.0 Hy	DPSC	G-10
					116	Shawnee	10.0 Hy	DPSC	G-10
					117	Shawnee	10.0 Hy	DPSC	G-10
					118	Shawnee	10.0 Hy	DPSC	G-10
					119	Shawnee	10.0 Hy	DPSC	G-10
					120	Shawnee	10.0 Hy	DPSC	G-10
					121	Shawnee	10.0 Hy	DPSC	G-10
					122	Shawnee	10.0 Hy	DPSC	G-10
					123	Shawnee	10.0 Hy	DPSC	G-10
					124	Shawnee	10.0 Hy	DPSC	G-10
					125	Shawnee	10.0 Hy	DPSC	G-10
					126	Shawnee	10.0 Hy	DPSC	G-10
					127	Shawnee	10.0 Hy	DPSC	G-10
					128	Shawnee	10.0 Hy	DPSC	G-10
					129	Shawnee	10.0 Hy	DPSC	G-10
					130	Shawnee	10.0 Hy	DPSC	G-10
					131	Shawnee	10.0 Hy	DPSC	G-10
					132	Shawnee	10.0 Hy	DPSC	G-10
					133	Shawnee	10.0 Hy	DPSC	G-10
					134	Shawnee	10.0 Hy	DPSC	G-10
					135	Shawnee	10.0 Hy	DPSC	G-10
					136	Shawnee	10.0 Hy	DPSC	G-10
					137	Shawnee	10.0 Hy	DPSC	G-10
					138	Shawnee	10.0 Hy	DPSC	G-10
					139	Shawnee	10.0 Hy	DPSC	G-10
					140	Shawnee	10.0 Hy	DPSC	G-10
					141	Shawnee	10.0 Hy	DPSC	G-10
					142	Shawnee	10.0 Hy	DPSC	G-10
					143	Shawnee	10.0 Hy	DPSC	G-10
					144	Shawnee	10.0 Hy	DPSC	G-10
					145	Shawnee	10.0 Hy	DPSC	G-10
					146	Shawnee	10.0 Hy	DPSC	G-10
					147	Shawnee	10.0 Hy	DPSC	G-10
					148	Shawnee	10.0 Hy	DPSC	G-10
					149	Shawnee	10.0 Hy	DPSC	G-10
					150	Shawnee	10.0 Hy	DPSC	G-10
					151	Shawnee	10.0 Hy	DPSC	G-10
					152	Shawnee	10.0 Hy	DPSC	G-10
					153	Shawnee	10.0 Hy	DPSC	G-10
					154	Shawnee	10.0 Hy	DPSC	G-10
					155	Shawnee	10.0 Hy	DPSC	G-10
					156	Shawnee	10.0 Hy	DPSC	G-10
					157	Shawnee	10.0 Hy	DPSC	G-10
					158	Shawnee	10.0 Hy	DPSC	G-10
					159	Shawnee	10.0 Hy	DPSC	G-10
					160	Shawnee	10.0 Hy	DPSC	G-10
					161	Shawnee	10.0 Hy	DPSC	G-10
					162	Shawnee	10.0 Hy	DPSC	G-10
					163	Shawnee	10.0 Hy	DPSC	G-10
					164	Shawnee	10.0 Hy	DPSC	G-10
					165	Shawnee	10.0 Hy	DPSC	G-10
					166	Shawnee	10.0 Hy	DPSC	G-10
					167	Shawnee	10.0 Hy	DPSC	G-10
					168	Shawnee	10.0 Hy	DPSC	G-10
					169	Shawnee	10.0 Hy	DPSC	G-10
					170	Shawnee	10.0 Hy	DPSC	G-10
					171	Shawnee	10.0 Hy	DPSC	G-10
					172	Shawnee	10.0 Hy	DPSC	G-10
					173	Shawnee	10.0 Hy	DPSC	G-10
					174	Shawnee	10.0 Hy	DPSC	G-10
					175	Shawnee	10.0 Hy	DPSC	G-10
					176	Shawnee	10.0 Hy	DPSC	G-10
					177	Shawnee	10.0 Hy	DPSC	G-10</

TABLE II (Cont'd)

PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER CODE	PLANT LOCATION	PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER CODE	PLANT LOCATION
<b>OHIO (Cont'd)</b>					<b>PENNSYLVANIA (Cont'd)</b>				
47	Mad River	75.0 St	OSDC	1-1	17	Bellevue	41.7 St	PRSC	0-10, 8-11
49	Masoningale	87.0 St	OSDC	0-1, 8-1			11.0 St	PRSC	0-10, 8-11
54	Miami Fort	519.0 St	CISE	1-1, 8-7	19	Emporium	70.0 St	PRSC	0-10
56	Montpellier	3.0 St	MWSP	1-1			11.0 St	PRSC	0-10
		7.0 St*	MWSP	1-1			11.0 St	PRSC	0-10
57	Muskingum River	79.0 St	OSPC	1-1	21	Elrama	48.0 St	OSDC	0-10, 8-11
		419.0 St*	OSPC	1-1	24	Lyler	19.0 St	MSAC	0-10
51	Napoleon	11.0 St	SAPO	1-1	26	Phillips, Frank R.	114.7 St	PRSC	0-10, 8-11
		11.0 St*	SAPO	1-1	27	Front Street	11.0 St 25c	PRSC	0-10
60	Niles	25.0 St	OSDC	1-1, 8-1	32	Waco	11.0 St	PRSC	0-10
61	Norwalk	11.0 St	OSDC	0-1	34	Harshay	11.0 St	PRSC	0-10
		11.0 IC	OSDC	0-1	35	Holtwood	107.0 St	PRSC	0-10
62	Oberlin	11.0 IC	OSDC	0-1	36	Holtwood	107.0 St	PRSC	0-10
		11.0 IC*	OSDC	0-1	37	Holtwood	107.0 St	PRSC	0-10
63	Hubbards, O. H.	41.0 St	DAPO	1-1	38	Holtwood	107.0 St	PRSC	0-10
64	Ohio State Univ.	11.0 St	OSPC	0-1	41	Holtwood	107.0 St	PRSC	0-10
65	Orrville	31.0 St	OSPC	0-1	42	Holtwood	107.0 St	PRSC	0-10
		31.0 St*	OSPC	0-1	43	Holtwood	107.0 St	PRSC	0-10
66	Painesville	11.0 St	PAIS	1-1			11.0 St	PRSC	0-10, 8-11
		11.0 St*	PAIS	1-1			11.0 St	PRSC	0-10, 8-11
67	Painesville	11.0 St	MIRC	1-1	44	Martins Creek	11.0 St	PRSC	0-10
69	Philo	60.0 St	OSPC	0-1	45	Millburg	11.0 St	WSPF	0-10
70	Piqua	21.0 St	OSDC	0-1	46	Millburg	11.0 St	WSPF	0-10
71	Piqua	21.0 St	OSDC	0-1	47	Millburg	11.0 St	WSPF	0-10
73	Porton	23.0 St	OSDC	0-1	48	Millburg	11.0 St	WSPF	0-10
		11.0 IC	OSDC	0-1	49	Millburg	11.0 St	WSPF	0-10
74	Reading	11.0 St	OSDC	0-1, 8-1	51	New Castle	11.0 St	PRSC	0-10
		11.0 IC	OSDC	0-1, 8-1	52	New Castle	11.0 St	PRSC	0-10
75	Burger, R. E.	421.0 St	OSPC	0-1, 8-1	53	Piqua	11.0 St	PRSC	0-10
76	Rittman	11.0 St	PAIS	0-1, 8-1	54	Pittsburgh Works	71.0 St 25c	MSAC	0-10
77	Rockaway	11.0 St	OSDC	0-1, 8-1	55	Portland	11.0 St	MSAC	0-10
78	Rossford	11.0 St	OSDC	0-1, 8-1	56	Portland	11.0 St	MSAC	0-10
81	St. Mary's	11.0 St*	SAMA	0-1, 8-1	57	Portland	11.0 St	MSAC	0-10
		11.0 St*	SAMA	0-1, 8-1	58	Portland	11.0 St	MSAC	0-10
82	Scioto	11.0 St	OSDC	0-1, 8-1	59	Portland	11.0 St	MSAC	0-10
83	Shelby	11.0 St	OSDC	0-1, 8-1	60	Portland	11.0 St	MSAC	0-10
		11.0 IC	OSDC	0-1, 8-1	61	Portland	11.0 St	MSAC	0-10
		11.0 St*	OSDC	0-1, 8-1	62	Portland	11.0 St	MSAC	0-10
84	Summit, W. H.	1,097.0 St	OSDC	0-1, 8-1	63	Portland	11.0 St	MSAC	0-10
		1,097.0 St*	OSDC	0-1, 8-1	64	Portland	11.0 St	MSAC	0-10
87	Tidd	222.0 St	OSDC	0-1, 8-1	65	Portland	11.0 St	MSAC	0-10
89	Toledo Furnace	21.0 St	OSDC	0-1, 8-1	66	Portland	11.0 St	MSAC	0-10
90	Toronto	11.0 St	OSDC	0-1, 8-1	67	Portland	11.0 St	MSAC	0-10
91	Troy	11.0 St	OSDC	0-1, 8-1	68	Portland	11.0 St	MSAC	0-10
93	Walnut	11.0 St	OSDC	0-1, 8-1	69	Portland	11.0 St	MSAC	0-10
		11.0 St*	OSDC	0-1, 8-1	70	Portland	11.0 St	MSAC	0-10
95	Water Street	11.0 St	OSDC	0-1, 8-1	71	Portland	11.0 St	MSAC	0-10
98	West End	11.0 St	OSDC	0-1, 8-1	72	Portland	11.0 St	MSAC	0-10
100	Woodcock	11.0 St	OSDC	0-1, 8-1	73	Portland	11.0 St	MSAC	0-10
102	Youngstown	11.0 St	OSDC	0-1, 8-1	74	Portland	11.0 St	MSAC	0-10
109	Marlette	11.0 St	OSDC	0-1, 8-1	75	Portland	11.0 St	MSAC	0-10
110	Portsmouth	11.0 St	OSDC	0-1, 8-1	76	Portland	11.0 St	MSAC	0-10
111	South Point	11.0 St	OSDC	0-1, 8-1	77	Portland	11.0 St	MSAC	0-10
112	Chillicothe	11.0 St	OSDC	0-1, 8-1	78	Portland	11.0 St	MSAC	0-10
113	Cardinal	1,230.0 St	OSDC	0-1, 8-1	79	Portland	11.0 St	MSAC	0-10
		1,230.0 St*	OSDC	0-1, 8-1	80	Portland	11.0 St	MSAC	0-10
114	Dick's Creek	11.0 St	OSDC	0-1, 8-1	81	Portland	11.0 St	MSAC	0-10
		11.0 St*	OSDC	0-1, 8-1	82	Portland	11.0 St	MSAC	0-10
115	Defiance-Richland	70.0 St	OSDC	0-1, 8-1	83	Portland	11.0 St	MSAC	0-10
116	J. M. Stuart	1,830.0 St*	OSDC	0-1, 8-1	84	Portland	11.0 St	MSAC	0-10
		11.0 IC	OSDC	0-1, 8-1	85	Portland	11.0 St	MSAC	0-10
A	Pedro	11.0 IC	OSDC	0-1, 8-1	86	Portland	11.0 St	MSAC	0-10
B	Abiloon	11.0 IC	OSDC	0-1, 8-1	87	Portland	11.0 St	MSAC	0-10
C	Jones and Loflin	11.0 St	OSDC	0-1, 8-1	88	Portland	11.0 St	MSAC	0-10
D	Republic Steel	11.0 St	OSDC	0-1, 8-1	89	Portland	11.0 St	MSAC	0-10
E	Toledo	11.0 St*	OSDC	0-1, 8-1	90	Portland	11.0 St	MSAC	0-10
		11.0 St*	OSDC	0-1, 8-1	91	Portland	11.0 St	MSAC	0-10
1	Armstrong	126.4 St	WSPF	0-7	92	Portland	11.0 St	MSAC	0-10
4	Baraboo	130.0 St	PRSC	0-10, 8-11	93	Portland	11.0 St	MSAC	0-10
		1.8 IC	PRSC	0-10, 8-11	94	Portland	11.0 St	MSAC	0-10
		45.0 IC	PRSC	0-10, 8-11	95	Portland	11.0 St	MSAC	0-10
5	Bethlehem	12.5 St	PRSC	0-10	96	Portland	11.0 St	MSAC	0-10
		12.5 St 25c	PRSC	0-10	97	Portland	11.0 St	MSAC	0-10
		17.5 IC 25c	PRSC	0-10	98	Portland	11.0 St	MSAC	0-10
10	Chambersburg	15.0 St	OSDC	0-10	99	Portland	11.0 St	MSAC	0-10
		5.0 IC	OSDC	0-10	100	Portland	11.0 St	MSAC	0-10
11	Chester	256.0 St	PRSC	0-10, 8-11	101	Portland	11.0 St	MSAC	0-10
		74.4 St*	PRSC	0-10, 8-11	102	Portland	11.0 St	MSAC	0-10
		2.8 IC	PRSC	0-10, 8-11	103	Portland	11.0 St	MSAC	0-10
12	Coffey	262.5 St	OSDC	0-7, 8-11	104	Portland	11.0 St	MSAC	0-10
14	Crawford	116.8 St	OSDC	0-7, 8-11	105	Portland	11.0 St	MSAC	0-10
15	Crusby	417.8 St	PRSC	0-7, 8-11	106	Portland	11.0 St	MSAC	0-10
		2.8 IC	PRSC	0-7, 8-11	107	Portland	11.0 St	MSAC	0-10
16	Crusby	24.0 St 25c	OSDC	0-6	108	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	109	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	110	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	111	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	112	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	113	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	114	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	115	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	116	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	117	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	118	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	119	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	120	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	121	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	122	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	123	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	124	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	125	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	126	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	127	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	128	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	129	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	130	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	131	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	132	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	133	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	134	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	135	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	136	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	137	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	138	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	139	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	140	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	141	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	142	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	143	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	144	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	145	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	146	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	147	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	148	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	149	Portland	11.0 St	MSAC	0-10
		24.0 St 25c	OSDC	0-6	150	Portland</			

TABLE II (Cont'd)

PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER	PLANT CODE	LOCATION	PLANT NUMBER	NAME OF PLANT	MW CAPACITY AND TYPE	OWNER	PLANT CODE	LOCATION
<b>PENNSYLVANIA (Cont'd)</b>						<b>TENNESSEE (Cont'd)</b>					
N	Montour	774.7 St*	PEPL	C-9		31	Pikeville Landing	21.0 Hy	TVA		3-5
O	Falls	55.8 St*	PEPC	C-9		32	South Holston	15.0 Hy	TVA		3-10
P	Moser	51.8 St*	PEPC	C-9		33	Watts Bar	15.0 Hy	TVA		3-1
Q	West Chester	55.8 St*	PEPC	C-9		36	Watts Bar	15.0 Hy	TVA		3-1
1/	One-third owned by Penna. Power & Light Company.					37	Wilbur	22.0 St	TVA		3-1
2/	Financed by GPU Subsidiaries under the name of Sexton Experimental Corporation.					39	Wauhatchie	55.0 Hy	TVA		3-10
3/	Jointly owned by PEPL, PEPC, NABE, WEPC, PEPC, ATOC, & BEPL.					40	Watts Bar	15.0 Hy	TVA		3-1
4/	Jointly owned by PEPC & NETA.					41	Ball Bluff	95.0 St	TVA		3-1
5/	Owned by P.M. Companies.					42	Block Jack	95.0 St	TVA		3-7
6/	Jointly owned by Peninsula and N. Y. State Elec. and Gas.					43	Corrigan Hill	100.0 Hy*	USAR		3-7
7/	Jointly owned by PEPL, PEPC, NABE, WEPC, PEPC, BEPL, ATOC, and UNGI.					44	J. Percy Priest	25.0 Hy*	USAR		3-7
8/	Jointly owned by WEPC, WEPC, and MIPC.					A	Time Ford	45.0 Hy*	TVA		3-7
9/	Jointly owned by GEL and PEPC.					B	Clarksville	1,000.0 St*	TVA		3-6
						C	East Tennessee	1,000.0 St*	TVA		2/
						1/	Site not selected.				
<b>SOUTH CAROLINA</b>						<b>VIRGINIA-45</b>					
3	Burrards Roost	15.0 Hy	GRCC	C-10		8	Brantly	25.0 St	DAVI		3-7
4	Burrards Roost	15.0 St	DUPC	C-10		9	Brown Bluff	25.0 St	VIEP		3-8
6	Kyle	60.0 Hy	DUPC	C-10		12	Hyland	25.0 Hy	APPC		3-6
7	Cedar Creek	45.0 Hy	DUPC	C-10		13	Chesterfield	75.0 St	VIEP		3-1
8	Charleston	45.0 St	WEPC	C-11		16	Clyator	60.0 St*	VIEP		3-1
11	Charleston	20.0 St	USR	C-11		17	Clinch River	600.0 St	APPC		3-1
12	Clark Hill	20.0 Hy	USAR	C-10		21	Den River Mills	4.0 Hy	DARM		3-7
14	Columbia	10.0 Hy	SOCA	C-10				11.0 St 25c	DARM		3-7
15	Dearborn	45.0 Hy	DUPC	C-10				1.0 Hy 25c	DARM		3-7
16	Fishing Creek	36.7 Hy	DUPC	C-10				4.0 St	DARM		3-7
19	Great Falls	24.0 Hy	DUPC	C-10		25	Glen Lynn	401.0 St	APPC		3-6
20	Harrod	94.0 St	SOCA	C-11		32	Gerr, John St.	20.0 Hy	USAR		3-1
21	Hartsville	20.0 St	SOCA	C-11		43	Phillip	12.0 Hy	USAR		3-7
23	Lee	20.0 St*	DUPC	C-9		44	Pinebluffs	10.0 Hy	DAVI		3-6
24	Lockhart	12.0 Hy	USPC	C-10		45	Portsmouth	60.0 St	USR		3-8
26	Mathews No. 1	20.0 St	USMC	C-10		47	Portsmouth	60.0 St	VIEP		3-1
27	Mathews No. 2	20.0 St	USMC	C-10		48	Power Point	40.0 St	VIEP		3-1
31	99 Islands	15.0 Hy	DUPC	C-10				95.0 St*	VIEP		3-1
32	Parr	12.0 Hy	SOCA	C-10		50	Rudford Arsenal	20.0 St	USAR		3-1
33	Parr	12.0 St	SOCA	C-10		51	Sevens Avenue	100.0 St	VIEP		3-1
36	Jeffries	100.0 St	SOCA	C-11		52	Sevens	12.0 Hy	APPC		3-7
39	Rocky Creek	345.0 St*	SOCA	C-11		54	Silverton	11.0 St	WVFC		3-1
41	McMekin, S. C.	291.0 St	SOCA	C-10		55	Tomoka River	51.0 St	WVFC		3-1, 3-7
42	Saluda	150.0 Hy	SOCA	C-10		56	Smith Mtn. River	400.0 Hy	APPC		3-1
44	Jeffries	110.0 Hy	SOCA	C-11		57	Spruce	51.0 St	USR		3-1
43	Tiger	30.0 St	DUPC	C-10		58	Torktown	30.0 St	VIEP		3-1
49	Urbhart	200.0 St	SOCA	C-10		59	12th Street	4.0 Hy	VIEP		3-1
51	Waterloo	30.0 Hy	DUPC	C-11		60	Smith Mtn. Lower (Greenville)	40.0 Hy	APPC		3-7
53	Robinson, H. B.	206.0 St	CAPO	C-11		61	Spryview	10.0 St	EAIS		3-9
						8	South Anna	1,000.0 St*	VIEP		3-1
54	Conway (Greiner)	10.0 St*	CAPO	C-11		9	New River	90.0 Hy	APPC		3-6
55	Parr Nuclear	17.0 St	SOCA	C-10		1/	Power marketing under Southeastern Power Administration.				
56	Canadys	470.0 St	SOCA	C-11		2/	Operated since 7-1-51 by Appalachian Electric Power Co. for U. S. Government.				
57	Barton	34.0 St	SOCA	C-11		<b>WEST VIRGINIA</b>					
58	Charleston	11.0 St	SOCA	C-11		1	Allright	200.0 St	MOPC & FOMC 1/		3-7
59	Myrtle Beach	45.0 St	SOCA	C-10		3	Cabin Creek	271.0 St	APPC		3-6
A	Onoee	2,000.0 St*	DUPC	C-9		5	Charleston	4.0 St	FOMA		3-6
B	Keowee	1,000.0 St*	DUPC	C-9		6	Dr. Charleston	25.0 St	USCA		3-6
C	Jonassee	610.0 St*	DUPC	C-9		10	Kanawha	670.0 St	DUPC		3-6, 3-1
D	Waterloo	150.0 St*	SOCA	C-11		11	Kanawha River	450.0 St	APPC		3-6
<b>TENNESSEE</b>						15	Lake Lynn	51.2 Hy	WEPC		3-7
1	Appalachia	75.0 Hy	TVA	C-1		16	Marion	12.4 Hy	KATP		3-6
2	Boone Dam	75.0 Hy	TVA	C-1		18	Stacy	12.4 Hy	KATP		3-6
3	Calderwood	121.0 Hy	TAFI	C-1		19	Stacy	12.4 Hy	FOMA		3-6
4	Calhoun	45.0 St	USPC	C-1		21	Parsonsburg	25.0 St	FOMA		3-6
5	Cheatham	70.0 Hy	USAR	C-1		22	Spore, Philip	1.0 St 120c	FOMA		3-6
6	Center Hill	170.0 Hy	USAR	C-1		23	Riversville	170.0 St	MOPC		3-5
7	Cherokee	120.0 Hy	TVA	C-1		25	William Island	215.0 St	MOPC		3-7
8	Chickamauga	100.0 Hy	TVA	C-1		26	Wichow	300.0 St	USPC & WEPC		3-6, 3-2
9	Chilhowee	90.0 Hy	TAFI	C-1		27	Winfield	11.8 Hy	KATP		3-1
10	Dale Hollow	50.0 Hy	USAR	C-1		28	Mr. Stone	1,121.0 St*	VIEP		3-1
12	Douglas	110.0 Hy	TVA	C-1		29	Fl. Martin	50.0 St	MOPC		3-7
14	Fort Loudon	120.0 Hy	TVA	C-1		1/	Site not selected.				
15	Fort P. Henry	90.0 Hy	TVA	C-1		1/	Site not selected.				
17	Gallatin	1,250.0 St	TVA	C-1		1/	Site not selected.				
18	Great Falls	31.9 Hy	TVA	C-1		1/	Site not selected.				
21	Sevier, John	829.0 St	TVA	C-1		1/	Site not selected.				
22	Johnsonville	1,450.0 St	TVA	C-1		1/	Site not selected.				
23	Kingston	1,700.0 St	TVA	C-1		1/	Site not selected.				
24	Allen, Thomas H.	990.0 St	USAR	C-1, C-11		1/	Site not selected.				
26	Nolichucky	10.0 Hy	TVA	C-1		1/	Site not selected.				
27	Harris Dam	100.0 Hy	TVA	C-1		1/	Site not selected.				
28	Onoee No. 1	10.0 Hy	TVA	C-1		1/	Site not selected.				
29	Onoee No. 2	25.0 Hy	TVA	C-1		1/	Site not selected.				
30	Onoee No. 3	25.0 Hy	TVA	C-1		1/	Site not selected.				
31	Old Hickory	10.0 Hy	USAR	C-1		1/	Site not selected.				

General Notes: \*Under construction; 25c, 120c, and 150c - indicate frequencies other than 60 cycle; St - Steam; N - Nuclear; IC - Internal Combustion; Hy - Hydro; GT - Gas Turbine


TABLE 12  
 OWNERSHIP OF MAJOR ELECTRIC FACILITIES  
 (15 Power Supply Areas)


UTILITY ABBREVIATIONS	TYPE OF OWNER	UTILITIES	UTILITY ABBREVIATIONS	TYPE OF OWNER	UTILITIES	
<b>ALABAMA</b>						
ALAP	PRI	Alabama Power Company	OWNE	PRI	<b>KENTUCKY (Cont'd)</b> Ohio Valley Electric Corp. Owensboro Tennessee Valley Authority U. S. Army	
ALCA	IND	Aluminum Company of America	OWNE	MIN		
ALCO	COOP	Alabama Electric Cooperative	TVA	FED		
BEAM	IND	Beaumont Mills, Inc.	USAR	FED		
COEN	IND	Cocosa River Newsprint Company				
ESPC	PRI	Georgia Power Co.				
GNRP	PRI	Gulf States Paper Co.				
INPC	IND	International Paper Co.				
RESC	IND	Republic Steel Corporation				
SCPC	IND	Scott Paper Co.				
SOBG	PRI	Southern Electric Generating Company				
TVA	FED	Tennessee Valley Authority				
USAR	FED	U. S. Army				
USPF	IND	United States Pipe and Foundry Company				
UNSS	IND	United States Steel Corp.				
WOIC	IND	Woodward Iron Company				
<b>DELAWARE</b>						
DEPL	PRI	Delmarva Power & Light Co. of Delaware			<b>MARYLAND</b> Baltimore Gas & Electric Company Bethlehem Steel Co. Delaware Power & Light Co. of Delaware Easton Hagerstown Pennsylvania Electric Co. Pennsylvania Railroad Co., The Potomac Edison Co., The Potomac Electric Power Co. Potomac Transmission Co. Shenandoah Electric Co., The U. S. Army West Virginia Pulp & Paper Co.	
DOEE	MIN	Dover				
DUNE	IND	DuPont de Nemours, E.I., & Co.				
SEAF	MIN	Seaford				
<b>DISTRICT OF COLUMBIA</b>						
PERC	IND	Pennsylvania Railroad Company, The				
POSP	PRI	Potomac Electric Power Co.				
<b>FLORIDA</b>						
ALCO	COOP	Alabama Electric Coop.				<b>MICHIGAN</b> Dellaware and Michigan Electric Co.  <b>MISSISSIPPI</b> Mascotte Corp. Mississippi Power Co. Pearl River Valley AFA Tennessee Valley Authority
CHSC	COOP	Choctawhatchee Electric Coop., Inc.				
GUFC	PRI	Gulf Power Co.				
INPC	IND	International Paper Company				
USAR	FED	U. S. Army				
USN	FED	U. S. Navy				
<b>GEORGIA</b>						
CRCP	MIN	Crisp County Power Commission				
GEPC	PRI	Georgia Power Co.				
SEAP	PRI	Savannah Electric & Power Co.				
SOEG	PRI	South Carolina Electric & Gas Co.				
TVA	FED	Tennessee Valley Authority				
USAR	FED	U. S. Army				
<b>INDIANA</b>						
ALCO	IND	Alcoa Generating Corp.			<b>NEW JERSEY</b> Atlantic City Electric Company Jersey Central Power & Light Co. Millville Manufacturing Co. New Jersey Power & Light Co. Public Service Electric & Gas Co. Rahland Whippany Paper Board Co.	
AMNE	MIN	Anderson				
COEN	PRI	Commonwealth Edison Co. of Indiana, Inc.				
CRAN	MIN	Crawfordsville				
FOKA	MIN	Fort Wayne				
FRAP	MIN	Frankfort				
HELI	COOP	Hoosier Energy Division, P.W.C., Inc.				
INKE	PRI	Indiana-Kentucky Electric Corp.				
INME	PRI	Indiana & Michigan Electric Co.				
INPL	PRI	Indianapolis Power & Light Co.				
INST	IND	Inland Steel Co.				
JASJ	MIN	Jasper				
LOGP	MIN	Logansport				
MIPC	PRI	Miami Power Corporation				
NAPS	MIN	Nappanee				
NOIP	PRI	Northern Indiana Public Service Co.				
OHVI	PRI	Ohio Valley Transmission Corp.				
OLMA	IND	Olin-Mathieson Chemical Corp.				
PERI	PRI	Perrin				
PEIN	PRI	Public Service Co. of Indiana				
RENS	MIN	Reynolds				
RICI	MIN	Richmond				
SOIG	PRI	Southern Indiana Gas & Electric Co.				
UNGA	IND	Union Carbide Corp.				
UNSS	IND	U. S. Steel Corp.				
WALP	MIN	Washington				
YOST	IND	Youngstown Sheet & Tube Co.				
<b>KENTUCKY</b>						
APPC	PRI	Appalachian Power Co.			<b>NEW YORK</b> Allied Chemical Corp. Bethlehem Steel Co. Central Edison Gas & Electric Corp. Consolidated Edison Company of New York Eastman Kodak Co. Freeport General Electric Co. Jamestown Long Island Lighting Co. Long Suit, Inc. New York State Electric & Gas Corp. New York State, Dept. Public Works Niagara Mohawk Power Corporation Orange and Rockland Utilities, Inc. Power Authority of the State of New York Republic Steel Corp. Rockville Centre Rochester Gas & Electric Corp. St. Regis Paper Co. U. S. Navy	
BEIR	COOP	Big Rivers Rural Electric Coop. Corp.				
ELER	PRI	Electric Energy, Inc.				
HEMS	MIN	Hemlock				
KEPC	PRI	Kentucky Power Co., The				
KEUC	PRI	Kentucky Utilities Co.				
LOUE	PRI	Louisville Gas & Electric Co.				
<b>NORTH CAROLINA</b>						
AMEC	IND	American Enka Corporation				
BLRI	COOP	Blue Ridge Electric Membership Corp.				
CAMN	IND	Cannon Mills				
CAPO	PRI	Carolina Power and Light Co.				
CHFP	IND	Champion Paper & Fiber Company				
DUPC	PRI	Duke Power Co.				
GRVN	MIN	Greenville				
KEPJ	MIN	Kinston				
NAPL	PRI	Norfolk Power and Light Co.				
OLMC	IND	Olin-Mathieson Chemical Corp.				
ROMP	MIN	Rocky Mount				
TAPI	PRI	Tarboro, Inc.				
TVA	FED	Tennessee Valley Authority				
UNCO	STATE	University of North Carolina				
USN	FED	U. S. Army				
VILP	PRI	Virginia Electric and Power Co.				
WLOT	MIN	Wilson				
YADI	IND	Yadkin, Inc.				





2





INSERT "A"

COPY AVAILABLE TO EDO DOES NOT PERMIT FULLY LEGIBLE REPRODUCTION

A NOTE: For city area inserts see sheet 3 of 3

### LEGEND

**GENERATING STATIONS**


OVER 200,000 KW	200,000 TO 199,000 KW	10,000 TO 99,000 KW	FUEL (Numbers in symbols refer to plant list. T above symbol indicates plant is tied into transmission system by low voltage lines.)
			HYDRO
			PUBLICLY OWNED PLANTS
			UNDER CONSTRUCTION
			SUBSTATIONS

**TRANSMISSION LINES**

	100 TO 200 KILOVOLTS (Voltages shown on lines greater than 138 KV)
	201 TO 765 KILOVOLTS (Voltages shown on lines greater than 245 KV)
	Underground and submarine cable
	Connection between companies (Abbrev. refer to company list)
	Connecting lines Crossover

**BOUNDARIES**

	Appalachian Region
	Power Supply Area
	Power Supply Area Number





FEDERAL POWER COMMISSION  
BUREAU OF POWER

**ELECTRIC FACILITIES  
APPALACHIAN REGION  
AND SURROUNDING AREA**

SHOWING  
TRANSMISSION LINES OF 100,000 VOLTS\*  
AND ABOVE, AND GENERATING STATIONS OF  
100,000 KILOWATTS AND OVER.

\*69,000 VOLTS ON INSERTS


1968



MEMPHIS AREA  
Scale 10 Miles





BIRMINGHAM AREA  
Scale 10 Miles



MOBILE AREA  
Scale 10 Miles

21





### LEGEND

#### GENERATING STATIONS

OVER 100,000 KW    200,000 TO 199,000 KW    10,000 TO 99,000 KW




FUEL (Numbers in symbols refer to plant list. T above symbol indicates plant is tied into transmission system by low voltage lines)  
 HYDRO  
 PUBLICLY OWNED PLANTS  
 UNDER CONSTRUCTION  
 SUBSTATIONS

#### TRANSMISSION LINES



100 TO 200 KILOVOLTS  
 (Voltages shown on lines greater than 138 KV)  
 201 TO 765 KILOVOLTS  
 (Voltages shown on lines greater than 245 KV)  
 Underground and submarine cable  
 Connection between companies (Abbrev refer to company list)  
 Connecting lines    Crossover

#### BOUNDARIES



Appalachian Region  
 Power Supply Area  
 Power Supply Area Number


FEDERAL POWER COMMISSION  
 BUREAU OF POWER

### ELECTRIC FACILITIES APPALACHIAN REGION AND SURROUNDING AREA

SHOWING  
 TRANSMISSION LINES OF 100,000 VOLTS\*  
 AND ABOVE, AND GENERATING STATIONS OF  
 100,000 KILOWATTS AND OVER.

\*69,000 VOLTS ON INSERTS


1968



21

1

6 7 8 9 10 11 12



DIST. OF COLUMBIA AREA





INDIANAPOLIS AREA




BALTIMORE AREA



AREA



CINCINNATI AREA




BUFFALO AREA



PHILADELPHIA AREA

6 7 8 9 10 11 12



LEGEND

GENERATING STATIONS

- OVER 1,000,000 KW    200,000 TO 599,000 KW    10,000 TO 199,000 KW
- (10)    (12)    (8)    FUEL (Numbers in symbols refer to plant list; T above symbol indicates plant is tied into transmission system by low voltage lines)
- (6)    (31)    (15)    HYDRO
- FEDERAL    NON-FEDERAL    PUBLICLY OWNED PLANTS
- (square with X)    UNDER CONSTRUCTION
- (triangle)    SUBSTATIONS

TRANSMISSION LINES

- 100 TO 200 KILOVOLTS (Voltages shown on lines greater than 138 KV)
- - - - - 201 TO 765 KILOVOLTS (Voltages shown on lines greater than 245 KV)
- Underground and submarine cable
- Connection between companies (Abbrev. refer to company list)
- Connecting lines    Crossover

FEDERAL POWER COMMISSION  
BUREAU OF POWER

ELECTRIC FACILITIES  
APPALACHIAN REGION  
AND SURROUNDING AREA

SHOWING  
TRANSMISSION LINES OF 100,000 VOLTS\*  
AND ABOVE, AND GENERATING STATIONS OF  
100,000 KILOWATTS AND OVER.

\*69,000 VOLTS ON INSERTS  
1968

## CHAPTER V - FUTURE POWER SUPPLY ADDITIONS

A hypothetical duration (demand-time) diagram for a summer month in 1980 for the 15 selected power supply areas is shown on Figure 4. This type of diagram is often used in load analyses. It is a "fat" curve which represents a summer peak month with a high load factor requirement. The summer peak by that time is expected to be a little greater than the winter peak. The ordinate of the diagram is drawn to represent a load of about 234 million kilowatts and the abscissa to represent the 744 hours in the month. The area under the curve represents energy required for load, including losses, of about 125,000 gigawatt-hours.<sup>1/</sup> The monthly load factor is about 72 percent.

Reserve capacity must be provided for unexpected growth, unpredicted load changes, and any loss of capacity occasioned by an emergency outage of equipment or planned outages for inspection, maintenance, and repairs. The reserve capacity is in addition to the capacity required for load. It may range from a low to a high percentage of the load requirement. Fifteen percent of the 234 million kilowatts, or 35 million kilowatts, has been used for this analysis and, as shown on the diagram, has been added above the load requirement. This brings the estimated total capacity supply needed for the 1980 summer load to about 269 million kilowatts.

There will be about 145 million kilowatts available for supply in 1970 from plants located within the 15 power supply areas that have capacities of 10,000 kilowatts or larger. This total includes installed capacities from existing plants, those currently under construction, and plants scheduled for service by 1970. A major part of the retirements that will occur by 1980 can be accounted for by the capacity not included in the 145 million kilowatts from existing plants under 10,000 kilowatts in size.

The 145 million kilowatts of capacity available for supply in 1970 consist of about 16 million kilowatts of hydroelectric and 129 million kilowatts of fuel-electric capacity. About 35 million kilowatts of the fuel-electric capacity are at older and less efficient plants and are assigned to reserve use. This leaves 94 million kilowatts available for load. The 16 million kilowatts of hydroelectric power are first assigned to supply duty at their best operating position in the load. Since they would furnish supply at a relatively low load factor during an adverse period, they would operate best near the top or peak of the load. For the example shown, the 16 million kilowatts are divided about equally into two parts. Eight million kilowatts are placed in the top of the load and the remainder is placed lower down where it will operate at about 20 percent plant factor. During an adverse water period the average plant factor for the total hydroelectric supply of 16 million kilowatts is about 12 percent. During other periods the hydroelectric supply may operate at a higher plant factor.

A remaining unfilled part of the top or peak portion of the load may be supplied by capacity from future hydroelectric developments, either of the

---

<sup>1/</sup> A gigawatt-hour is 1,000,000 kilowatt-hours.




Figure 4

conventional, pumped-storage, or a combination of both types of installations. The conventional hydroelectric supply will, undoubtedly, be designed to operate at a rather low plant factor as most of the better sites for plants with higher plant factor operating capacities have been developed and are supplying load. There are many good pumped-storage sites, however, and plants at these sites can be designed to operate at plant factors up to nearly 40 percent, provided off-peak energy for pumping is available. There may be instances, however, where projects can be designed to operate at higher plant factors than 40 percent when a greater pumping capacity is provided in the plant than the generating capacity.

For this study a maximum of 40 percent plant factor from pumped-storage hydroelectric plants was determined on the basis that three kilowatt-hours of off-peak pumping are required for each two that are regenerated for load. This requires a three to two ratio of energy for pumping to energy for load if equal pumping versus generating capacity is maintained. The areas shown as blocks (A) and (C) of Figure 4 outside and above the load requirements under the duration curve represent the theoretical additional energy from existing supply that is not needed for current load requirements. This energy can be made available for use if it is needed. Only part, however, can be used for off-peak pumping without installing additional pumping capacity. As the pumping capacity is increased its use factor would decrease and would soon become uneconomical to provide. Only the energy shown in block (A) in the diagram could be used for off-peak pumping, assuming equal pumping and generating capacity. On the basis of three kilowatt-hours of off-peak pumping to two for on-peak generation, the area in block (A) would be 1.5 times as great as the area in block (B).

The demand-time diagram shows a five percent spinning reserve reduction of the fuel-electric supply during valley hours, or 12 million kilowatts, between the top of the fuel-electric supply in the load and when off-peak pumping can commence. This, together with the slope of the curve, usually limits the energy for load from the pump-back regeneration to less than 40 percent plant factor operation. The older fuel-electric supply of 94 million kilowatts is then placed in the load so that the energy area under (A) of the diagram will be 1.5 of the regenerated energy under (B). This establishes the lowest point that the top of the older fuel-electric supply may be operated. For the diagram shown it is at about 190 million kilowatts on the ordinate.

The unfilled spaces on the diagram may be filled with new supply. About 28 million kilowatts are available for new hydroelectric supply plus 96 million for new fuel-electric supply, or any combination of these where the hydroelectric portion is decreased and the fuel-electric portion increased.

Additional capacity to supply load at about 65 percent annual load factor will be needed for load growth beyond 1980. This supply can be divided into two components like the supply above, a high load factor base supply and a low load factor peak load supply. The high load factor part can be supplied from new fuel-electric supply and the low load factor part from new hydroelectric sources. The division of the new supply, depending upon

economics, and the availability of sites for hydroelectric development, will divide about 80 and 20 percent between the high and low load factor portions. Estimates of the additional power supply needed are shown in Table 13.

TABLE 13

ADDITIONAL POWER REQUIREMENTS  
(15 Power Supply Areas)

Item	Millions of Kilowatts				
	1970	1980	1990	2000	2020
Supply for load <sup>1/</sup>	123	234	410	662	1,614
For reserves <sup>2/</sup>	18	35	53	99	242
For retirements <sup>3/</sup>	-	0	11	19	77
Total needed	141	269	492	700	1,933
Supply available <sup>4/</sup>	145	145	269	492	719
Additional needed <sup>5/</sup>	-	124	223	208	1,113
High load factor portion (80%)	-	99	170	136	622
Low load factor portion (20%)	-	25	53	72	491

<sup>1/</sup> Load requirements from Table 4.

<sup>2/</sup> Fifteen percent of load adopted.

<sup>3/</sup> Four percent per decade of previous load and reserve. None assumed for 1980, and adjusted for 2020 to account for two decades.

<sup>4/</sup> Amount after 1970 is that available for last decade.

<sup>5/</sup> Amount needed to be added over previous amount.

The last item on Table 13 is the amount of supply needed for future low factor load which is of the type that may be supplied from new hydroelectric sources. The total amounts to about 359 million kilowatts by year 2020. It is unlikely that all of the requirements can or will be supplied from hydroelectric sources, chiefly pumped storage, but a large proportion can be supplied if resource planning and development are started in time.

Transmission lines existing and being built are extensive throughout the 15 power supply areas. Additional lines will be constructed, as the load grows, to connect between and among the loads and new supply sources that are added. It is unlikely that more than relatively short lines will be needed to connect most of the new hydroelectric developments to the supply.

## CHAPTER VI - HYDROELECTRIC POWER RESOURCES

Most of the better sites for development of conventional hydroelectric power in the 15 power supply areas are being utilized. There are, however, some good sites remaining which may be developed with conventional hydroelectric installations, and many good sites available where pumped-storage installations can be placed. Information on hydroelectric resources is presented in Table 14. It includes information both for existing developments and those potential sites which may appear feasible of development.

The location of the hydroelectric power sites given in Table 14 are shown on Figure 5.

It may be observed from the map that most of the undeveloped or potential sites are physically located in the Appalachian region. This is chiefly because of the favorable topography of the region for development of hydroelectric power, and especially for development of pumped-storage facilities.

The potential undeveloped hydroelectric sites listed in Table 14 may not all be feasible of development at one time. The projects need to be tested first for their general economic feasibility and then selections made from a few of the more favorable sites for a more detailed study to determine their final justification. Estimates of the value of power are needed in both cases, but they may be general for the first selection and specific for each individual project in the more detailed studies.

General estimates of at-market values of power are presented in Table 15. The estimates may or may not include adequate transmission and other adjustments for specific projects, but they are adequate for use in testing and selecting apparently feasible projects for more detailed and specific study.

The estimated power values are based upon the cost of power from an alternative steam-electric plant in each area. The alternative plant contains modern and efficient fuel-burning units of the size generally being installed in the area. The estimated values are divided into two components. One is based upon fixed costs which relate more nearly to the capacity component of the plant and is shown as "capacity value." The other relates more nearly to the quantity of energy generated and is shown as "energy value."

Two sets of capacity values are given. One is based upon Federal financing and the other on private financing. There are, however, no Federally financed alternatives in any of the 15 power supply areas. Private financing predominates in 14 of the areas and TVA financing predominates in Power Supply Area 20. "Federal Financing" values are included because the constructing agency, if Federal, as a matter of policy shows a comparison of the cost of project power with the cost of power from the cheapest alternative source using Federal financing. Other than for this purpose, the capacity values under "Private Financing" represent the capacity component of the value of power for each of the 15 power supply areas and are the estimates which should be used in determining the economic feasibility of the allocated electrical portion of any hydroelectric project.

TABLE 14  
HYDROELECTRIC POWER RESOURCES  
(15 Power Supply Areas)

MAJOR GEOGRAPHIC DRAINAGE MAJOR RIVER BASIN HYDROELECTRIC PROJECT DEVELOPMENT	MAP SYMBOL	RIVER	STATE	IN APPALACHIAN REGION	INSTALLED CAPACITY MW	AVERAGE ANNUAL GENERATION 10 <sup>3</sup> MWH	USABLE POWER STORAGE 1,000 A.F.	GROSS POWER HEAD FT.	TYPE
UNDEVELOPED									CONVENTIONAL, PUMPED STOR., COMBINED
GREAT LAKES-ST. LAWRENCE DRAINAGE									
LAKE ERIE BASIN									
CUYAHOGA FALLS	1-0.2	CUYAHOGA	OHIO	NO	0.2	0.4	N.A.	11	CONVENTIONAL
CATTARAUGUS	3-0.5	CATTARAUGUS CR.	N.Y.	NO	0.5	2	N.A.	N.A.	CONVENTIONAL
GENESSEE RIVER BASIN									
MILLS NO. 172	1-0.2	WISDOY CR.	N.Y.	YES	0.2	0.9	N.A.	68	CONVENTIONAL
WISDOY NO. 170	2-1.1	WISDOY CR.	N.Y.	YES	1.1	4.9	N.A.	104	CONVENTIONAL
POSTAGE	1-0.2	GENESSEE	N.Y.	NO	0.2	0.9	N.A.	41	CONVENTIONAL
MT. MORRIS NO. 160	3-0.3	GENESSEE	N.Y.	NO	0.3	2.9	N.A.	20	CONVENTIONAL
ROCHESTER NO. 26	7-1.0	GENESSEE	N.Y.	NO	1	3	N.A.	94	CONVENTIONAL
ROCHESTER NO. 2	8-0.5	GENESSEE	N.Y.	NO	0.5	16	N.A.	25	CONVENTIONAL
ROCHESTER UPPER FALLS 2	9-1.0	GENESSEE	N.Y.	NO	1	3	N.A.	91	CONVENTIONAL
ROCHESTER NO. 5	9-3.8	GENESSEE	N.Y.	NO	3.8	14.4	0	137	CONVENTIONAL
OSWEGO RIVER BASIN									
KUKA	1-2.0	KUKA LAKE	N.Y.	YES	2	6.4	6	380	CONVENTIONAL
WATERLOO	2-1.9	SENeca CANAL	N.Y.	NO	1.9	3.6	107	17	CONVENTIONAL
SENeca FALLS	3-0.7	SENeca	N.Y.	NO	0.7	11.5	0	60	CONVENTIONAL
NUMBER 1	4-0.7	FALL CR.	N.Y.	YES	0.7	5.3	N.A.	147	CONVENTIONAL
SHANK PLANT	5-0.3	OSWEGO	N.Y.	NO	0.3	0.8	N.A.	21	CONVENTIONAL
AUBURN	6-0.5	OSWEGO	N.Y.	NO	0.5	0.6	N.A.	16	CONVENTIONAL
AUBURN	7-0.7	OSWEGO	N.Y.	NO	0.7	2.3	N.A.	21	CONVENTIONAL
WOODEN MILL	8-0.3	OSWEGO	N.Y.	NO	0.3	2.6	N.A.	21	CONVENTIONAL
BALDWINVILLE	9-0.6	SENeca	N.Y.	NO	0.6	3.7	N.A.	8	CONVENTIONAL
OSWEGO FALLS	10-9.2	OSWEGO	N.Y.	NO	9.2	39	N.A.	18	CONVENTIONAL
FULTON	11-1.3	OSWEGO	N.Y.	NO	1.3	7.2	0	17	CONVENTIONAL
RYANVILLE	12-0.8	OSWEGO	N.Y.	NO	0.8	5.3	0	23	CONVENTIONAL
GRAND	13-1.7	OSWEGO	N.Y.	NO	1.7	21	0	24	CONVENTIONAL
MENARD	14-3.0	OSWEGO	N.Y.	NO	3	40.6	0	17	CONVENTIONAL
HIGH DAM NO. 6	15-7.0	OSWEGO	N.Y.	NO	7.0	50	0	22	CONVENTIONAL
HIGH DAM NO. 4	16-3.8	OSWEGO	N.Y.	NO	3.8	14.2	0	20	CONVENTIONAL
VARICK	16-8.8	OSWEGO	N.Y.	NO	8.8	44.2	0	20	CONVENTIONAL
NORTH ATLANTIC DRAINAGE									
DELAWARE RIVER BASIN									
BAWY MOUNTAIN	1-0.2	D. R. DELAWARE	N.Y.	YES	0.2	9.4	0.9	14.7	CONVENTIONAL
GENESSEE	2-0.7	D. R. DELAWARE	N.Y.	YES	0.7	30	20	65	CONVENTIONAL
WALLENPAUPACK	4-0.4	LAUREL CREEK	PA.	YES	0.4	11.4	16	122	CONVENTIONAL
SWINGING BRIDGE NO. 2	5-0.4	MONGAUP	N.Y.	NO	0.4	5	10	122	CONVENTIONAL
SWINGING BRIDGE NO. 1	6-5.0	MONGAUP	N.Y.	NO	5	20	0	115	CONVENTIONAL
MONGAUP FALLS	7-4.0	MONGAUP	N.Y.	NO	4	30.7	13	185	CONVENTIONAL
RIO	8-10	MONGAUP	N.Y.	NO	10	30.7	13	185	CONVENTIONAL
TOKEA ISLAND	9-1.00	DELAWARE	N.Y.	YES	1.00	3.1	N.A.	1.100	CONVENTIONAL
TOKEA ISLAND	10-0.5	DELAWARE	N.Y.	YES	0.5	2.1	N.A.	1.100	CONVENTIONAL
YARDS CREEK	11-33.8	YARDS CREEK	N.Y.	NO	33.8	N.A.	0	700	PUMPED STOR.
BRANTZVILLE	12-1.00	DELAWARE	N.Y.	NO	1.00	3.1	N.A.	1.100	CONVENTIONAL
WARREN MILL	14-0.7	MISCONINGOONG	N.Y.	NO	0.7	4	N.A.	50	CONVENTIONAL
HUNTSVILLE	15-0.4	MISCONINGOONG	N.Y.	NO	0.4	1.9	N.A.	27	CONVENTIONAL
RIVERVIEWVILLE	16-0.3	MISCONINGOONG	N.Y.	NO	0.3	1.1	N.A.	21	CONVENTIONAL
BRIDGEVILLE	17-0.1	DELAWARE	N.Y.	NO	0.1	0.3	N.A.	30	CONVENTIONAL
BRIDGEVILLE	18-0.0	DELAWARE	N.Y.	NO	0.0	0.0	N.A.	30	CONVENTIONAL
TREBLEY	19-0.0	DELAWARE	N.Y.	NO	0.0	0.0	N.A.	30	CONVENTIONAL
MILFVILLE	20-0.5	MAURICE	N.Y.	NO	0.5	2.6	N.A.	114	CONVENTIONAL
SUSQUEHANNA RIVER BASIN									
ONONDAGA									
WATERLOO	2-0.5	SUSQUEHANNA	N.Y.	YES	0.5	0.9	N.A.	N.A.	CONVENTIONAL
FALLS	3-0.7	SUSQUEHANNA	PA.	YES	0.7	1.0	0	30	CONVENTIONAL
SAATING	4-0.9	SUSQUEHANNA	PA.	YES	0.9	1.0	1,000	150	CONVENTIONAL
FIRST FURK	5-0.8	W. BR. SUSQUEHANNA	PA.	YES	0.8	1.0	1,000	150	CONVENTIONAL
KITTLE CREEK	6-1.6	KITTLE CR.	PA.	YES	1.6	1.0	0	115	CONVENTIONAL
LOVE HAVEN	7-0.1	W. BR. SUSQUEHANNA	PA.	YES	0.1	0.2	0	30	CONVENTIONAL
LOVE HAVEN	8-0.1	PINE CR.	PA.	YES	0.1	0.2	0	30	CONVENTIONAL
HILLGROVE	11-0.1	LOYALOCK	PA.	YES	0.1	0.4	N.A.	N.A.	CONVENTIONAL
MOORE	12-0.0	W. BR. SUSQUEHANNA	PA.	YES	0.0	0.0	N.A.	30	CONVENTIONAL
DEEP FALLS	13-1.0	SUSQUEHANNA	PA.	YES	1.0	1.0	0	70	CONVENTIONAL
WARRIOR RIDGE	15-2.0	JUNIATA	PA.	YES	2	8.9	0	160	CONVENTIONAL
RAYSDOWN	16-2.1	RAYSDOWN BR.	PA.	YES	2.1	12	0	27	CONVENTIONAL
YONKERS	17-0.4	JUNIATA	PA.	YES	0.4	1.0	0	32	CONVENTIONAL
WATERLOO	18-0.1	SUSQUEHANNA	PA.	YES	0.1	0.2	0	30	CONVENTIONAL
YORK HAVEN	19-2.5	SUSQUEHANNA	PA.	NO	2.5	16	N.A.	21	CONVENTIONAL
YORK HAVEN	20-2.0	SUSQUEHANNA	PA.	NO	2.0	12.5	0	22	CONVENTIONAL
SAFE HARBOR	21-2.1	SUSQUEHANNA	PA.	NO	2.1	9.0	63	54	CONVENTIONAL
HOLTHOOD	22-1.0	SUSQUEHANNA	PA.	NO	1.0	1.0	0	30	CONVENTIONAL
HOLTHOOD	23-1.0	SUSQUEHANNA	PA.	NO	1.0	1.0	0	30	CONVENTIONAL
MIDDY RUN	24-8.0	MIDDY RUN-CROOK	PA.	NO	8.0	N.A.	18.5	411	PUMPED STOR.
CONWINGO	25-0.7	SUSQUEHANNA	MD.	NO	0.7	1,719	71	89	CONVENTIONAL

TABLE 14 (Cont'd)

MAJOR GEOGRAPHIC DRAINAGE MAJOR RIVER BASIN HYDROELECTRIC PROJECT DEVELOPED	MAP SYMBOL	RIVER	STATE	IN APPALACHIAN REGION	INSTALLED CAPACITY MW	AVERAGE ANNUAL GENERATION 10 <sup>3</sup> MWH	USABLE POWER STORAGE 1,000 A.F.	GROSS POWER HEAD FT.	TYPE CONVENTIONAL, PUMPED STOR., COMBINED
PATAPSCO RIVER BASIN OSLMA	1-0.6	PATAPSCO	MD.	NO	0.4	3.4	N.A.	43	CONVENTIONAL
POTOMAC RIVER BASIN									
CLAYTON	1-0.8	POTOMAC	W.VA.	YES	1.0	1.0	0	10	CONVENTIONAL
CLAYTON	1-0.8	S. FK. POTOMAC	MD.-W.VA.	YES	1.0	1.0	0	10	CONVENTIONAL
CLAYTON	1-0.8	S. FK. POTOMAC	MD.-W.VA.	YES	1.0	1.0	0	10	CONVENTIONAL
CLAYTON	1-0.8	S. FK. POTOMAC	W.VA.	YES	1.0	1.0	0	10	CONVENTIONAL
CLAYTON	1-0.8	S. FK. POTOMAC	W.VA.	YES	1.0	1.0	0	10	CONVENTIONAL
CLAYTON	1-0.8	POTOMAC	MD.-W.VA.	YES	1.0	1.0	0	10	CONVENTIONAL
CLAYTON	1-0.8	POTOMAC	W.VA.	YES	1.0	1.0	0	10	CONVENTIONAL
DAM NO. 5	11-1.1	POTOMAC	W.VA.	YES	1.1	7.6	0	17	CONVENTIONAL
DAM NO. 4	12-1.0	POTOMAC	W.VA.	YES	1	7.5	0	19	CONVENTIONAL
SHENANDOAH NEWPORT	13-1.9	S. FK. SHENANDOAH	VA.	NO	0.9	4.7	0	12	CONVENTIONAL
LURAY	14-1.4	S. FK. SHENANDOAH	VA.	NO	1.4	9	0	21	CONVENTIONAL
WARREN	15-1.6	S. FK. SHENANDOAH	VA.	NO	1.6	9	0	18	CONVENTIONAL
MILLVILLE	16-1.3	SHENANDOAH	VA.	NO	1.3	4.7	0	12	CONVENTIONAL
MILLVILLE	16-1.3	SHENANDOAH	W.VA.	YES	1.3	11.7	0	27	CONVENTIONAL
HARPER'S FERRY	19-0.8	POTOMAC	W.VA.	NO	0.8	6.1	0	26	CONVENTIONAL
HARPER'S FERRY DAM NO. 102		POTOMAC	W.VA.	NO	0.8	6.1	0	26	CONVENTIONAL
WATERGATE	19-0.8	POTOMAC	MD.-W.VA.	NO	0.8	6.1	0	26	CONVENTIONAL
WATERGATE	19-0.8	POTOMAC	MD.-W.VA.	NO	0.8	6.1	0	26	CONVENTIONAL
WATERGATE	19-0.8	POTOMAC	MD.-W.VA.	NO	0.8	6.1	0	26	CONVENTIONAL
WATERGATE	19-0.8	POTOMAC	MD.-W.VA.	NO	0.8	6.1	0	26	CONVENTIONAL
DALECARLIA	20-3.0	POTOMAC CANAL	D.C.	NO	3	8	0	110	CONVENTIONAL
	20-3.0	POTOMAC	VA.	NO	3	8	0	110	CONVENTIONAL
SOUTH ATLANTIC DRAINAGE									
JAMES RIVER BASIN									
CHICK LAMP	1-0.8	W. FORK RIVER CR.	VA.	YES	0.8	0.8	0	800	CONVENTIONAL
CHICK LAMP	1-0.8	W. FORK RIVER CR.	VA.	YES	0.8	0.8	0	800	CONVENTIONAL
FALLING SPRINGS	2-0.4	FALLING SPRING CR.	VA.	YES	0.4	1.8	N.A.	515	CONVENTIONAL
MEADOW CREEK	3-0.3	MEADOW CR.	VA.	YES	0.3	1.7	N.A.	609	CONVENTIONAL
MEADOW CREEK	3-0.3	MEADOW CR.	VA.	YES	0.3	1.7	N.A.	609	CONVENTIONAL
MEADOW CREEK	3-0.3	MEADOW CR.	VA.	YES	0.3	1.7	N.A.	609	CONVENTIONAL
MEADOW CREEK	3-0.3	MEADOW CR.	VA.	YES	0.3	1.7	N.A.	609	CONVENTIONAL
MARSH VALLEY	4-0.3	MARSH VALLEY CR.	VA.	YES	0.3	1.4	N.A.	500	CONVENTIONAL
MARSH VALLEY	4-0.3	MARSH VALLEY CR.	VA.	YES	0.3	1.4	N.A.	500	CONVENTIONAL
MARSH VALLEY	4-0.3	MARSH VALLEY CR.	VA.	YES	0.3	1.4	N.A.	500	CONVENTIONAL
MARSH VALLEY	4-0.3	MARSH VALLEY CR.	VA.	YES	0.3	1.4	N.A.	500	CONVENTIONAL
BALCONY FALLS 2/	11-0.6	JAMES	VA.	NO	0.6	10	N.A.	15	CONVENTIONAL
BALCONY FALLS 2/	11-0.6	JAMES	VA.	NO	0.6	10	N.A.	15	CONVENTIONAL
ONSHAW	12-0.5	JAMES	VA.	NO	0.5	28	N.A.	27	CONVENTIONAL
SNOWDEN	13-1	JAMES	VA.	NO	1	7	N.A.	18	CONVENTIONAL
RIG ISLAND	14-0.5	JAMES	VA.	NO	0.5	2.4	N.A.	12	CONVENTIONAL
HOLCOMB ROCK	15-1.9	JAMES	VA.	NO	1.9	9	N.A.	17	CONVENTIONAL
REUSENS	17-1.2	JAMES	VA.	NO	1.2	49	N.A.	35	CONVENTIONAL
REUSENS	17-1.2	JAMES	VA.	NO	1.2	49	N.A.	35	CONVENTIONAL
REUSENS	17-1.2	JAMES	VA.	NO	1.2	49	N.A.	35	CONVENTIONAL
SCHUYLER NO. 2	20-0.5	ROCKFISH CR.	VA.	NO	0.5	1.7	N.A.	32	CONVENTIONAL
SCHUYLER NO. 1	21-0.4	ROCKFISH CR.	VA.	NO	0.4	1.4	N.A.	17	CONVENTIONAL
SCHUYLER NO. 1	21-0.4	ROCKFISH CR.	VA.	NO	0.4	1.4	N.A.	17	CONVENTIONAL
SCHUYLER NO. 1	21-0.4	ROCKFISH CR.	VA.	NO	0.4	1.4	N.A.	17	CONVENTIONAL
HYDRO PARK 2/	25-1.1	JAMES	VA.	NO	1.1	7.6	N.A.	20	CONVENTIONAL
HYDRO PARK 2/	25-1.1	JAMES	VA.	NO	1.1	7.6	N.A.	20	CONVENTIONAL
HOLLYWOOD 2/	28-0.0	JAMES	VA.	NO	0	21	N.A.	19	CONVENTIONAL
HOLLYWOOD	29-0.3	JAMES	VA.	NO	0.3	3.1	N.A.	42	CONVENTIONAL
PARK	30-0.1	JAMES	VA.	NO	0.1	12	N.A.	47	CONVENTIONAL
PARK	30-0.1	JAMES	VA.	NO	0.1	12	N.A.	47	CONVENTIONAL
PARK	30-0.1	JAMES	VA.	NO	0.1	12	N.A.	47	CONVENTIONAL
ROANOKE RIVER BASIN									
NIAGARA	1-0.1	ROANOKE	VA.	NO	0.1	13	0.2	60	CONVENTIONAL
SMITH MOUNTAIN	2-0.3	ROANOKE	VA.	NO	0.3	516	160	172	COMBINED
SMITH MOUNTAIN	2-0.3	ROANOKE	VA.	NO	0.3	516	160	172	COMBINED
LESLIEVILLE	3-0.0	ROANOKE	VA.	NO	0	60	0	73	CONVENTIONAL
LESLIEVILLE	3-0.0	ROANOKE	VA.	NO	0	60	0	73	CONVENTIONAL
LESLIEVILLE	3-0.0	ROANOKE	VA.	NO	0	60	0	73	CONVENTIONAL
PINNACLES	7-0.0	DAN	VA.	NO	0	30	N.A.	701	CONVENTIONAL
ALABAMA DOVE	8-0.5	DAN	N.C.	YES	0.5	3.2	N.A.	18	CONVENTIONAL
MAYO	9-0.7	MAYO	N.C.	NO	0.7	2.6	N.A.	35	CONVENTIONAL
AFALON	10-0.6	MAYO	N.C.	NO	0.6	3	N.A.	36	CONVENTIONAL
BELOTT	11-1.1	SMITH	VA.	NO	1.1	25	111	162	CONVENTIONAL
MARTINSVILLE	12-1.1	SMITH	VA.	NO	1.1	5	N.A.	32	CONVENTIONAL

TABLE 14 (Cont'd)

MAJOR GEOGRAPHIC DRAINAGE MAJOR RIVER BASIN HYDROELECTRIC PROJECT DEVELOPED UNDEVELOPED	MAP SYMBOL	RIVER	STATE	IN APPALACHIAN REGION	INSTALLED CAPACITY MW	AVERAGE ANNUAL GENERATION 10 <sup>3</sup> MWH	USABLE POWER STORAGE 1,000 A.F.	GROSS POWER HEAD FT.	TYPE CONVENTIONAL, PUMPED STOR., COMBINED
ROANOKE RIVER BASIN (CONTINUED)									
SPEAY	14-1.0	SMITH	N.C.	NO	1	2.6	N.A.	32	CONVENTIONAL
SCHOOLFIELD	17-5.1	DAN	VA.	NO	5.3	17	N.A.	28	CONVENTIONAL
RIVERSIDE	16-1.2	DAN	VA.	NO	1.2	3.9	N.A.	20	CONVENTIONAL
KERR	17-20.6	ROANOKE	VA.	NO	20.6	220	1,046	42	CONVENTIONAL
GASTON	14-17.8	ROANOKE	N.C.	NO	17.8	334	N.A.	43	CONVENTIONAL
ROANOKE RAPIDS	19-100	ROANOKE	N.C.	NO	100	34.3	33	47	CONVENTIONAL
YADKIN-PEE DEE RIVER BASIN									
WYTHE CREEK	1-36	WYTHE CR.	N.C.	YES	36	260	1.6	800	COMBINED
ROCK CREEK	4-37	ROCK CR.	N.C.	YES	37	151	2.1	735	COMBINED
ROCK DAM	1-37	ROCK CR.	N.C.	YES	37	323	3.1	600	COMBINED
WALKER	4-37	WALKER CR.	N.C.	YES	37	44	102	77	CONVENTIONAL
PILOT MOUNTAIN	3-0.5	ARABAT	N.C.	YES	0.5	1.6	N.A.	13	CONVENTIONAL
TRUCK	10-34	TRUCK CR.	N.C.	YES	34	31	139	131	CONVENTIONAL
DOCK	11-1.4	YADKIN	N.C.	YES	1.4	5.9	N.A.	10	CONVENTIONAL
SOLOMON	11-15	SOLOMON CR.	N.C.	YES	15	20	4.0	56	CONVENTIONAL
HIGH ROCK	11-33	YADKIN	N.C.	NO	33	113	235	49	CONVENTIONAL
TUCKERDOWN	15-42	YADKIN	N.C.	NO	42	150	6.7	54	CONVENTIONAL
NARROWS	16-97	YADKIN	N.C.	NO	97	405	129	177	CONVENTIONAL
FALLS	13-30	YADKIN	N.C.	NO	30	116	1.3	55	CONVENTIONAL
WOMAN'S CREEK	15-37	WOMAN'S CR.	N.C.	NO	37	131	1.1	102	CONVENTIONAL
TRUCK MOUNTAIN	20-37	TRUCK CR.	N.C.	NO	37	28	1.1	37	CONVENTIONAL
UPPER WOOD RUN	21-35	UPPER WOOD CR.	N.C.	NO	35	26	1.2	34	CONVENTIONAL
TELLERY	22-34	PEE DEE	N.C.	NO	34	190	33	71	CONVENTIONAL
LOWER FORD	24-37	ROCKY	N.C.	NO	37	142	1.1	108	CONVENTIONAL
MARSH FORD	24-37	ROCKY	N.C.	NO	37	19	1.7	38	CONVENTIONAL
SEMOG FORD	26-39	ROCKY	N.C.	NO	39	90	3.0	135	CONVENTIONAL
WOMAN'S CREEK	26-39	PEE DEE	N.C.	NO	39	260	9.7	141	CONVENTIONAL
WAGNER CREEK	26-39	PEE DEE	N.C.	NO	39	362	4.3	275	COMBINED
HOWETT FALLS 2/	28-25	PEE DEE	N.C.	NO	25	136	32	51	CONVENTIONAL
HOWETT FALLS 1/	28-25	PEE DEE	N.C.	NO	25	107	190	30	CONVENTIONAL
MORVEN	29-27	PEE DEE	N.C.	NO	27	105	N.A.	31	CONVENTIONAL
HARNSVILLE	30-0.3	BLACK CR.	S.C.	NO	0.3	0.3	N.A.	10	CONVENTIONAL
SANTOE RIVER BASIN									
LAKE TAHOA	1-0.2	BUCK CR.	N.C.	YES	0.2	1.1	N.A.	60	CONVENTIONAL
LAKE ANN VILLAGE	1-0.2	LEWISVILLE CR.	N.C.	YES	0.2	1.1	N.A.	60	CONVENTIONAL
LAKE ANN	1-0.2	LEWISVILLE CR.	N.C.	YES	0.2	1.1	N.A.	60	CONVENTIONAL
SHIMMY MOUNTAIN	1-0.2	LEWISVILLE CR.	N.C.	YES	0.2	1.1	N.A.	60	CONVENTIONAL
BRIDGewater	5-20	CATAWBA	N.C.	YES	20	49	172	141	CONVENTIONAL
LAKE ASH	5-20	CATAWBA	N.C.	YES	20	49	172	141	CONVENTIONAL
PHILLIPS BRANCH	7-30	RAILROAD CR.	N.C.	YES	30	22	1.3	90	CONVENTIONAL
BROWN MOUNTAIN	4-30	UPPER CR.	N.C.	YES	30	24	1.3	790	COMBINED
MILLINGTON	7-31	CATAWBA	N.C.	YES	31	79	1.0	70	CONVENTIONAL
WATER	10-30	CATAWBA	N.C.	YES	30	179	2.1	103	COMBINED
COLAND CREEK	11-30	CATAWBA	N.C.	YES	30	152	4.0	135	COMBINED
RHOBISS	12-26	CATAWBA	N.C.	YES	26	57	99	60	CONVENTIONAL
GUNPOWDER NO. 1	13-0.4	GUNPOWDER CR.	N.C.	YES	0.4	1	N.A.	75	CONVENTIONAL
LITTLE RIVER	14-0.5	UPPER LITTLE	N.C.	YES	0.5	0.5	N.A.	31	CONVENTIONAL
OXFORD	16-36	CATAWBA	N.C.	YES	36	94	52	92	CONVENTIONAL
MILLERSVILLE	17-0.3	LOWER LITTLE	N.C.	YES	0.3	0.2	N.A.	35	CONVENTIONAL
LAKE CHARLES	19-100	CATAWBA	N.C.	NO	100	331	9	161	CONVENTIONAL
LOOKOUT SHOALS	20-19	CATAWBA	N.C.	NO	19	33	4.3	73	CONVENTIONAL
DOWNS FORD	21-30	CATAWBA	N.C.	NO	30	140	618	113	CONVENTIONAL
MOUNTAIN ISLAND	20-60	CATAWBA	N.C.	NO	60	184	19	73	CONVENTIONAL
HENRY RIVER	23-0.1	HENRY PK.	N.C.	YES	0.1	0.5	N.A.	35	CONVENTIONAL
LAKE CHARLES	24-100	HENRY PK.	N.C.	YES	100	331	9	161	CONVENTIONAL
CAROLINIAN	26-1.7	SO. PK. CATAWBA	N.C.	NO	1.7	5.4	N.A.	30	CONVENTIONAL
DALLAS	27-0.2	SO. PK. CATAWBA	N.C.	NO	0.2	0.7	N.A.	20	CONVENTIONAL
SPENCER MOUNTAIN	23-0.6	SO. PK. CATAWBA	N.C.	NO	0.6	3.9	N.A.	25	CONVENTIONAL
MADISONVILLE	23-0.4	SO. PK. CATAWBA	N.C.	NO	0.4	3.2	N.A.	20	CONVENTIONAL
WELLS	31-60	CATAWBA	S.C.	NO	60	137	150	75	CONVENTIONAL
LAKE CHARLES	32-100	CATAWBA	S.C.	NO	100	331	9	161	CONVENTIONAL
WHEATY ISLAND	33-37	CATAWBA	S.C.	NO	37	112	54	36	CONVENTIONAL
LAKE CHARLES	33-37	CATAWBA	S.C.	NO	37	112	54	36	CONVENTIONAL
FIGHTING CREEK	34-37	CATAWBA	S.C.	NO	37	139	37	61	CONVENTIONAL
DEARBORN	35-45	CATAWBA	S.C.	NO	45	133	1.6	71 1/2	CONVENTIONAL
GREAT FALLS	36-25	CATAWBA	S.C.	NO	25	30	N.A.	71 1/2	CONVENTIONAL
BEAR CREEK	37-45	CATAWBA	S.C.	NO	45	132	N.A.	59 1/2	CONVENTIONAL
ROCKY CREEK	38-28	CATAWBA	S.C.	NO	28	11	1.5	59 1/2	CONVENTIONAL
WATERG	39-56	WATERG	S.C.	NO	56	221	175	83	CONVENTIONAL
LAKE L'ORE	41-3.6	BROAD	N.C.	YES	3.6	10	14	103	CONVENTIONAL
LAKE CHARLES	42-100	GREEN	N.C.	YES	100	331	9	161	CONVENTIONAL
F. XERO	42-5.0	GREEN	N.C.	YES	5	21	2.1	297	CONVENTIONAL
LAKE CHARLES	44-100	GREEN	N.C.	YES	100	331	9	161	CONVENTIONAL

TABLE 14 (Cont'd)

MAJOR GEOGRAPHIC DRAINAGE MAJOR RIVER BASIN HYDROELECTRIC PROJECT DEVELOPED			MAP SYMBOL	RIVER	STATE	IN APPALACHIAN REGION	INSTALLED CAPACITY MW	AVERAGE ANNUAL GENERATION 10 <sup>3</sup> MWH	USABLE POWER STORAGE 1,000 A-F	GROSS POWER HEAD FT	TYPE CONVENTIONAL, PUMPED STOR, COMBINED
UNDEVELOPED											
SARAS RIVER BASIN (CONTINUED)											
TRINER SHOALS	47-4.5	GREEN	N.C.	YES	5.5	15	1.3	89	CONVENTIONAL		
CLIFFSIDE	47-1.5	SECOND BROAD	N.C.	YES	1.5	2	N.A.	30	CONVENTIONAL		
LAUREL	48-1.9	FIRST BROAD	N.C.	NO	1.9	2.6	N.A.	30	CONVENTIONAL		
SHELDY	49-1.0	FIRST BROAD	N.C.	NO	0.9	1.3	N.A.	25	CONVENTIONAL		
ROSS CREEK	50-0.0	BROAD	N.C.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
GASTON SHOALS 2/	51-4.1	BROAD	S.C.	YES	4.1	32	N.A.	51	CONVENTIONAL		
YEAHNER LITTLE BROAD 2/	51-0.0	BROAD	S.C.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
CHEUKERS FALLS 2/	52-1.9	BROAD	S.C.	YES	1.9	5	N.A.	20	CONVENTIONAL		
SHAWNEE CREEK 2/	53-0.0	BROAD	S.C.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
SPARTANBURG 2/	53-1.8	BROAD	S.C.	YES	1.8	14	N.A.	70	CONVENTIONAL		
CLIFTON NOS. 1, 2 and 3	54-1.0	SOUTH PADOLET	S.C.	YES	1	1.1	N.A.	51	CONVENTIONAL		
TRONDI	54-1.0	PADOLET	S.C.	YES	1	2.9	N.A.	68	CONVENTIONAL		
PADOLET 2/	57-1.3	PADOLET	S.C.	YES	0.9	2.7	N.A.	27	CONVENTIONAL		
LOCKHART 2/	58-1.0	BROAD	S.C.	NO	1.0	70	N.A.	53	CONVENTIONAL		
GEORGE LOCKHART 2/	58-0.0	BROAD	S.C.	NO	0.0	0.0	0.0	0.0	CONVENTIONAL		
NEAL SHOALS 2/	59-1.0	BROAD	S.C.	NO	1.0	26	N.A.	26	CONVENTIONAL		
STARBUCK MILLS	60-1.0	MIDDLE TYGER	S.C.	YES	1.0	2.3	N.A.	54	CONVENTIONAL		
HEBBY SHOALS	62-2.0	SOUTH TYGER	S.C.	YES	2	3.4	N.A.	78	CONVENTIONAL		
NECKY	63-1.7	TYGER	S.C.	YES	1.7	17	0.0	37	CONVENTIONAL		
WYNN FACTORY	64-0.0	TYGER	S.C.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
VAN PATTON	64-1.8	SNORRE	S.C.	YES	0.8	2.8	N.A.	60	CONVENTIONAL		
WALTON	64-0.0	SNORRE	S.C.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
PARR SHOALS	67-1.0	BROAD	S.C.	NO	1.0	75	N.A.	35	CONVENTIONAL		
SARR SHOALS 2/	67-4.0	BROAD	S.C.	NO	4.0	1.0	0.0	0.0	CONVENTIONAL		
FRONT SHOALS	68-0.0	BROAD	S.C.	NO	0.0	0.0	0.0	0.0	CONVENTIONAL		
SEA FALLS	69-0.0	NO. FL. SALUDA	S.C.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
SALUDA (GREENVILLE)	70-0.0	SALUDA	S.C.	YES	0.0	8	N.A.	42	CONVENTIONAL		
PIEKEMONT	71-1.0	SALUDA	S.C.	YES	1	3.3	N.A.	24	CONVENTIONAL		
UPPER PRINCE	72-1.7	SALUDA	S.C.	YES	1.7	6	N.A.	25	CONVENTIONAL		
LOWER PRINCE	73-1.3	SALUDA	S.C.	YES	1.3	10	N.A.	42	CONVENTIONAL		
HOLLIS BRIDGE	74-1.0	SALUDA	S.C.	NO	1.0	0.9	0.9	4.3	CONVENTIONAL		
WARD SHOALS	75-1.3	SALUDA	S.C.	NO	1.3	19	N.A.	16	CONVENTIONAL		
TIMBLING SHOALS	76-1.3	REEDY	S.C.	NO	1.3	0.9	0.9	16	CONVENTIONAL		
BOYD MILL	77-1.0	REEDY	S.C.	NO	1	5.2	N.A.	49	CONVENTIONAL		
BUZZARDS ROOST	78-1.5	SALUDA	S.C.	NO	1.5	4.7	1.4	65	CONVENTIONAL		
SALUDA	79-0.0	SALUDA	S.C.	NO	0.0	208.3	1,614	189	CONVENTIONAL		
LEXINGTON	80-0.3	1 1/2 MILE CREEK	S.C.	NO	0.3	1	N.A.	51	CONVENTIONAL		
COLUMBIA 2/	81-1.1	CONGARREE	S.C.	NO	1.1	51	N.A.	33	CONVENTIONAL		
COLUMBIA 2/ 1/	81A-1.6	CONGARREE	S.C.	NO	1.6	4	0.0	0.0	CONVENTIONAL		
RODGERS CREEK	82-1.3	CONGARREE	S.C.	NO	1.3	100	0.0	40	CONVENTIONAL		
BRASS CREEK	83-1.0	CONGARREE	S.C.	NO	1.0	100	0.0	204	CONVENTIONAL		
SPILLWAY	84-1.0	SANTEE	S.C.	NO	1.0	13	1,100	50	CONVENTIONAL		
WILKINSON LANDING 1/	85-0.0	SANTEE	S.C.	NO	0.0	0.0	0.0	0.0	CONVENTIONAL		
JEFFRIES	85-1.3	COOPER CANAL	S.C.	NO	1.3	557	660	77	CONVENTIONAL		
JEFFRIES 2/	85-0.1	COOPER CANAL	S.C.	NO	0.1	0.0	0.0	0.0	CONVENTIONAL		
ST. STEPHEN	86-0.0	SANTEE	S.C.	NO	0.0	0.0	0.0	0.0	CONVENTIONAL		
SAVANNAH RIVER BASIN											
HURON	1-0.1	TALMULAH	GA.	YES	0.1	20	85	114	CONVENTIONAL		
NACOOCHIE	2-4.8	TALMULAH	GA.	YES	4.8	12	2	63	CONVENTIONAL		
TERORA	3-16	TALMULAH	GA.	YES	16	45	3.9	190	CONVENTIONAL		
TALMULAH FALLS	4-72	TALMULAH	GA.	YES	72	163	0.3	603	CONVENTIONAL		
WAS CREEK	5-0.0	CHATTAHOOCHEE	GA.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
WATSON CREEK	6-0.0	CHATTAHOOCHEE	GA.	YES	0.0	0.0	N.A.	121	CONVENTIONAL		
WATSON FORD	7-1.0	CHATTAHOOCHEE	GA.	YES	1.0	78	5	126	CONVENTIONAL		
CAMP CREEK	8-0.0	CHATTAHOOCHEE	GA.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
HATFIELD CREEK	9-0.0	CHATTAHOOCHEE	GA.	YES	0.0	100	200	130	CONVENTIONAL		
TUGALO	10-4.5	TUGALO	GA.	YES	4.5	111	3.5	144	CONVENTIONAL		
YONAH	11-23	TUGALO	GA.	YES	23	54	0.6	70	CONVENTIONAL		
HOBBSFACTORY	12-0.0	HOBBSFACTORY	N.C.	YES	0.0	0.0	0.0	1,300	CONVENTIONAL		
UPPER WILLOWATER	13-1.0	WILLOWATER	S.C.	YES	1.0	0.0	0.0	0.0	CONVENTIONAL		
LOWER WILLOWATER	14-0.0	WILLOWATER	S.C.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
JOHNSON	15-0.0	ROCKWELL	S.C.	YES	0.0	430	200	0.0	CONVENTIONAL		
KNOX	16-1.0	LETTS & CREEK	S.C.	YES	1.0	61	0.0	0.0	CONVENTIONAL		
NORRIS PLANT	17-0.0	1 1/2 MILE CREEK	S.C.	YES	0.0	4.2	N.A.	33	CONVENTIONAL		
HARTWELL	18-204	SAVANNAH	GA.	YES	204	450	1,428	185	CONVENTIONAL		
HARTWELL 2/	18A-0.0	SAVANNAH	GA.	YES	0.0	0.0	0.0	0.0	CONVENTIONAL		
ROCKY RIVER	19-2.3	ROCKY	S.C.	NO	2.3	0.0	0.0	0.0	CONVENTIONAL		
THOMAS SHOALS	20-1.0	SAVANNAH	S.C.	NO	1.0	47	0.0	150	CONVENTIONAL		
TALLAW HILL	21-172	BROAD	GA.	NO	172	0.0	0.0	197	CONVENTIONAL		
REDFORD SHOALS	22-100	BROAD	GA.	NO	100	62	1.0	68	CONVENTIONAL		
CLARK HILL	23-282	SAVANNAH	GA.	NO	282	700	1,340	152	CONVENTIONAL		
STEVENS CREEK	24-19	SAVANNAH	GA.	NO	19	90	11	28	CONVENTIONAL		
AUGUSTA CANAL 1/	25-1.0	SAVANNAH	GA.	NO	1.0	0.0	N.A.	12	CONVENTIONAL		
BLANCKE	26-0.3	AUGUSTA CANAL	GA.	NO	0.3	0.0	N.A.	40	CONVENTIONAL		
SIBLEY	26-2.1	AUGUSTA CANAL	GA.	NO	2.1	11	N.A.	40	CONVENTIONAL		
ENTERPRISE	27-1.2	AUGUSTA CANAL	GA.	NO	1.2	6.2	N.A.	30	CONVENTIONAL		
KING	28-2.3	AUGUSTA CANAL	GA.	NO	2.3	11	N.A.	33	CONVENTIONAL		
VAUGHN	29-0.4	HORSE CR.	S.C.	NO	0.4	0.8	N.A.	50	CONVENTIONAL		
GRANI TOWNSHIP	30-1.5	HORSE CR.	S.C.	NO	0.5	1.2	N.A.	40	CONVENTIONAL		
BURNING LANDING	31-0.0	SAVANNAH	GA.	NO	0.0	271	0.0	47	CONVENTIONAL		
SPANNAH SLUFF	32-0.0	SAVANNAH	GA.	NO	0.0	0.0	0.0	0.0	CONVENTIONAL		





TABLE 14 (Cont'd)

MAJOR GEOGRAPHIC DRAINAGE MAJOR RIVER BASIN HYDROELECTRIC PROJECT DEVELOPED UNDEVELOPED	MAP SYMBOL	RIVER	STATE	IN APPALACHIAN REGION	INSTALLED CAPACITY MW	AVERAGE ANNUAL GENERATION 10 <sup>6</sup> MWH	USABLE POWER STORAGE 1,000 A-F	GROSS POWER HEAD FT	TYPE CONVENTIONAL, PUMPED STOR., COMBINED
TENNESSEE RIVER BASIN (CONTINUED)									
COOKE NO. 1	49-51	COOKE	TENN.	YES	21	130	N.A.	255	CONVENTIONAL
COOKE NO. 1 1/2	51-52	COOKE	TENN.	YES	12	65	34	117	CONVENTIONAL
CHICKAMAUGA	50-102	TENNESSEE	TENN.	YES	104	760	221	42	CONVENTIONAL
NICKAJACK	51-97	TENNESSEE	ALA.	YES	97	666	21	39	CONVENTIONAL
HINTERSVILLE	95-97	TENNESSEE	ALA.	YES	97	740	132	79	CONVENTIONAL
TIMS FORD	96-95	SIX CR.	TENN.	NO	45	64	240	144	CONVENTIONAL
WHEELER	98-956	TENNESSEE	ALA.	YES	156	1,392	308	49	CONVENTIONAL
WILSON	99-625	TENNESSEE	ALA.	YES	625	2,552	47	93	CONVENTIONAL
PICKWICK LAUNCHING	60-216	TENNESSEE	TENN.	NO	216	1,300	239	55	CONVENTIONAL
KENTUCKY	61-160	TENNESSEE	KY.	NO	160	1,160	721	57	CONVENTIONAL
CUMBERLAND RIVER BASIN									
LAUREL	3-90	LAUREL	KY.	YES	50	56	195	253	CONVENTIONAL
WOLF CREEK	74-271	CUMBERLAND	KY.	YES	271	867	2,142	180	CONVENTIONAL
DALE HOLLOW	6-55	OHY	TENN.	YES	55	127	496	147	CONVENTIONAL
CORNEAL HILL	19-100	CUMBERLAND	TENN.	YES	100	190	54	59	CONVENTIONAL
GREAT FALLS	11-12	DANGY FORK	TENN.	YES	12	190	49	156	CONVENTIONAL
CENTER HILL	13-139	DANGY FORK	TENN.	YES	136	351	492	172	CONVENTIONAL
OLD HICKORY	14-100	CUMBERLAND	TENN.	NO	100	420	63	60	CONVENTIONAL
J. PERCY BRIST	14-24	STONE	TENN.	NO	24	70	124	102	CONVENTIONAL
ORATHAM	16-36	CUMBERLAND	TENN.	NO	36	160	20	26	CONVENTIONAL
BARLEY	17-130	CUMBERLAND	KY.	NO	130	382	299	57	CONVENTIONAL
KENTUCKY RIVER BASIN									
DIX DAM	4-28	DIX	KY.	YES	28	65	123	213	CONVENTIONAL
LOCK NO. 7	6-10	KENTUCKY	KY.	NO	2	11	N.A.	15	CONVENTIONAL
OHIO RIVER BASIN (MAIN STREAM)									
MARKLAND	11-81	OHIO	IND.-KY.	NO	81	450	17	35	CONVENTIONAL
OHIO FALLS	12-80	OHIO	IND.-KY.	NO	80	369	0	33	CONVENTIONAL
GREEN RIVER BASIN	1-30	GREEN	KY.	NO	30	100	20	20	CONVENTIONAL
SALT RIVER BASIN	1-30	SALT	KY.	NO	30	100	20	20	CONVENTIONAL
KANAWHA RIVER BASIN	1-30	KANAWHA	W.V.	YES	30	100	20	20	CONVENTIONAL
SHARP FALLS	1-30	SHARP	W.V.	YES	30	100	20	20	CONVENTIONAL
MOUTH OF WILSON	1-30	WILSON CR.	VA.	YES	30	100	20	20	CONVENTIONAL

TABLE 14 (Cont'd)

MAJOR GEOGRAPHIC DRAINAGE MAJOR RIVER BASIN HYDROELECTRIC PROJECT DEVELOPED UNDEVELOPED	MAP SYMBOL	RIVER	STATE	IN APPALACHIAN REGION	INSTALLED CAPACITY MW	AVERAGE ANNUAL GENERATION 10 <sup>3</sup> MWH	USABLE POWER STORAGE 1,000 A.F.	GROSS POWER HEAD FT.	TYPE CONVENTIONAL, PUMPED STOR., COMBINED
KANAWHA RIVER BASIN (CONTINUED)									
UPPER DAM	1-1	NEW	VA.	YES	200	2,200	100	190	PUMPED STOR.
LOWER DAM	1-2	NEW	VA.	YES	200	1,000	1,000	120	CONVENTIONAL
FRICK	6-1.1	NEW	VA.	YES	1.1	10	N.A.	20	CONVENTIONAL
RYLESBY	7-2	NEW	VA.	YES	20	40	0	30	CONVENTIONAL
WICK	8-1.1	NEW	VA.	YES	1.1	10	0	20	CONVENTIONAL
CLAYTON	10-75	NEW	VA.	YES	75	100	0	110	CONVENTIONAL
RAIFORD	11-1.1	LITTLE	VA.	YES	0.1	1	N.A.	20	CONVENTIONAL
ROBERTSON	11-1.2	NEW	W.VA.	YES	1.2	10	0	120	CONVENTIONAL
ROBERTSON	11-1.3	NEW	W.VA.	YES	1.3	10	0	120	CONVENTIONAL
ROBERTSON	11-1.4	NEW	W.VA.	YES	1.4	10	0	120	CONVENTIONAL
ROBERTSON	11-1.5	NEW	W.VA.	YES	1.5	10	0	120	CONVENTIONAL
HAWKS NEST	15-102	NEW	W.VA.	YES	102	100	0	150	CONVENTIONAL
ROBERTSON	11-1.6	NEW	W.VA.	YES	1.6	10	0	120	CONVENTIONAL
ROBERTSON	11-1.7	NEW	W.VA.	YES	1.7	10	0	120	CONVENTIONAL
ROBERTSON	11-1.8	NEW	W.VA.	YES	1.8	10	0	120	CONVENTIONAL
ROBERTSON	11-1.9	NEW	W.VA.	YES	1.9	10	0	120	CONVENTIONAL
ROBERTSON	11-1.10	NEW	W.VA.	YES	1.10	10	0	120	CONVENTIONAL
ROBERTSON	11-1.11	NEW	W.VA.	YES	1.11	10	0	120	CONVENTIONAL
ROBERTSON	11-1.12	NEW	W.VA.	YES	1.12	10	0	120	CONVENTIONAL
ROBERTSON	11-1.13	NEW	W.VA.	YES	1.13	10	0	120	CONVENTIONAL
ROBERTSON	11-1.14	NEW	W.VA.	YES	1.14	10	0	120	CONVENTIONAL
ROBERTSON	11-1.15	NEW	W.VA.	YES	1.15	10	0	120	CONVENTIONAL
ROBERTSON	11-1.16	NEW	W.VA.	YES	1.16	10	0	120	CONVENTIONAL
ROBERTSON	11-1.17	NEW	W.VA.	YES	1.17	10	0	120	CONVENTIONAL
ROBERTSON	11-1.18	NEW	W.VA.	YES	1.18	10	0	120	CONVENTIONAL
ROBERTSON	11-1.19	NEW	W.VA.	YES	1.19	10	0	120	CONVENTIONAL
ROBERTSON	11-1.20	NEW	W.VA.	YES	1.20	10	0	120	CONVENTIONAL
ROBERTSON	11-1.21	NEW	W.VA.	YES	1.21	10	0	120	CONVENTIONAL
ROBERTSON	11-1.22	NEW	W.VA.	YES	1.22	10	0	120	CONVENTIONAL
ROBERTSON	11-1.23	NEW	W.VA.	YES	1.23	10	0	120	CONVENTIONAL
ROBERTSON	11-1.24	NEW	W.VA.	YES	1.24	10	0	120	CONVENTIONAL
ROBERTSON	11-1.25	NEW	W.VA.	YES	1.25	10	0	120	CONVENTIONAL
ROBERTSON	11-1.26	NEW	W.VA.	YES	1.26	10	0	120	CONVENTIONAL
ROBERTSON	11-1.27	NEW	W.VA.	YES	1.27	10	0	120	CONVENTIONAL
ROBERTSON	11-1.28	NEW	W.VA.	YES	1.28	10	0	120	CONVENTIONAL
ROBERTSON	11-1.29	NEW	W.VA.	YES	1.29	10	0	120	CONVENTIONAL
ROBERTSON	11-1.30	NEW	W.VA.	YES	1.30	10	0	120	CONVENTIONAL
ROBERTSON	11-1.31	NEW	W.VA.	YES	1.31	10	0	120	CONVENTIONAL
ROBERTSON	11-1.32	NEW	W.VA.	YES	1.32	10	0	120	CONVENTIONAL
ROBERTSON	11-1.33	NEW	W.VA.	YES	1.33	10	0	120	CONVENTIONAL
ROBERTSON	11-1.34	NEW	W.VA.	YES	1.34	10	0	120	CONVENTIONAL
ROBERTSON	11-1.35	NEW	W.VA.	YES	1.35	10	0	120	CONVENTIONAL
ROBERTSON	11-1.36	NEW	W.VA.	YES	1.36	10	0	120	CONVENTIONAL
ROBERTSON	11-1.37	NEW	W.VA.	YES	1.37	10	0	120	CONVENTIONAL
ROBERTSON	11-1.38	NEW	W.VA.	YES	1.38	10	0	120	CONVENTIONAL
ROBERTSON	11-1.39	NEW	W.VA.	YES	1.39	10	0	120	CONVENTIONAL
ROBERTSON	11-1.40	NEW	W.VA.	YES	1.40	10	0	120	CONVENTIONAL
ROBERTSON	11-1.41	NEW	W.VA.	YES	1.41	10	0	120	CONVENTIONAL
ROBERTSON	11-1.42	NEW	W.VA.	YES	1.42	10	0	120	CONVENTIONAL
ROBERTSON	11-1.43	NEW	W.VA.	YES	1.43	10	0	120	CONVENTIONAL
ROBERTSON	11-1.44	NEW	W.VA.	YES	1.44	10	0	120	CONVENTIONAL
ROBERTSON	11-1.45	NEW	W.VA.	YES	1.45	10	0	120	CONVENTIONAL
ROBERTSON	11-1.46	NEW	W.VA.	YES	1.46	10	0	120	CONVENTIONAL
ROBERTSON	11-1.47	NEW	W.VA.	YES	1.47	10	0	120	CONVENTIONAL
ROBERTSON	11-1.48	NEW	W.VA.	YES	1.48	10	0	120	CONVENTIONAL
ROBERTSON	11-1.49	NEW	W.VA.	YES	1.49	10	0	120	CONVENTIONAL
ROBERTSON	11-1.50	NEW	W.VA.	YES	1.50	10	0	120	CONVENTIONAL
ROBERTSON	11-1.51	NEW	W.VA.	YES	1.51	10	0	120	CONVENTIONAL
ROBERTSON	11-1.52	NEW	W.VA.	YES	1.52	10	0	120	CONVENTIONAL
ROBERTSON	11-1.53	NEW	W.VA.	YES	1.53	10	0	120	CONVENTIONAL
ROBERTSON	11-1.54	NEW	W.VA.	YES	1.54	10	0	120	CONVENTIONAL
ROBERTSON	11-1.55	NEW	W.VA.	YES	1.55	10	0	120	CONVENTIONAL
ROBERTSON	11-1.56	NEW	W.VA.	YES	1.56	10	0	120	CONVENTIONAL
ROBERTSON	11-1.57	NEW	W.VA.	YES	1.57	10	0	120	CONVENTIONAL
ROBERTSON	11-1.58	NEW	W.VA.	YES	1.58	10	0	120	CONVENTIONAL
ROBERTSON	11-1.59	NEW	W.VA.	YES	1.59	10	0	120	CONVENTIONAL
ROBERTSON	11-1.60	NEW	W.VA.	YES	1.60	10	0	120	CONVENTIONAL
ROBERTSON	11-1.61	NEW	W.VA.	YES	1.61	10	0	120	CONVENTIONAL
ROBERTSON	11-1.62	NEW	W.VA.	YES	1.62	10	0	120	CONVENTIONAL
ROBERTSON	11-1.63	NEW	W.VA.	YES	1.63	10	0	120	CONVENTIONAL
ROBERTSON	11-1.64	NEW	W.VA.	YES	1.64	10	0	120	CONVENTIONAL
ROBERTSON	11-1.65	NEW	W.VA.	YES	1.65	10	0	120	CONVENTIONAL
ROBERTSON	11-1.66	NEW	W.VA.	YES	1.66	10	0	120	CONVENTIONAL
ROBERTSON	11-1.67	NEW	W.VA.	YES	1.67	10	0	120	CONVENTIONAL
ROBERTSON	11-1.68	NEW	W.VA.	YES	1.68	10	0	120	CONVENTIONAL
ROBERTSON	11-1.69	NEW	W.VA.	YES	1.69	10	0	120	CONVENTIONAL
ROBERTSON	11-1.70	NEW	W.VA.	YES	1.70	10	0	120	CONVENTIONAL
ROBERTSON	11-1.71	NEW	W.VA.	YES	1.71	10	0	120	CONVENTIONAL
ROBERTSON	11-1.72	NEW	W.VA.	YES	1.72	10	0	120	CONVENTIONAL
ROBERTSON	11-1.73	NEW	W.VA.	YES	1.73	10	0	120	CONVENTIONAL
ROBERTSON	11-1.74	NEW	W.VA.	YES	1.74	10	0	120	CONVENTIONAL
ROBERTSON	11-1.75	NEW	W.VA.	YES	1.75	10	0	120	CONVENTIONAL
ROBERTSON	11-1.76	NEW	W.VA.	YES	1.76	10	0	120	CONVENTIONAL
ROBERTSON	11-1.77	NEW	W.VA.	YES	1.77	10	0	120	CONVENTIONAL
ROBERTSON	11-1.78	NEW	W.VA.	YES	1.78	10	0	120	CONVENTIONAL
ROBERTSON	11-1.79	NEW	W.VA.	YES	1.79	10	0	120	CONVENTIONAL
ROBERTSON	11-1.80	NEW	W.VA.	YES	1.80	10	0	120	CONVENTIONAL
ROBERTSON	11-1.81	NEW	W.VA.	YES	1.81	10	0	120	CONVENTIONAL
ROBERTSON	11-1.82	NEW	W.VA.	YES	1.82	10	0	120	CONVENTIONAL
ROBERTSON	11-1.83	NEW	W.VA.	YES	1.83	10	0	120	CONVENTIONAL
ROBERTSON	11-1.84	NEW	W.VA.	YES	1.84	10	0	120	CONVENTIONAL
ROBERTSON	11-1.85	NEW	W.VA.	YES	1.85	10	0	120	CONVENTIONAL
ROBERTSON	11-1.86	NEW	W.VA.	YES	1.86	10	0	120	CONVENTIONAL
ROBERTSON	11-1.87	NEW	W.VA.	YES	1.87	10	0	120	CONVENTIONAL
ROBERTSON	11-1.88	NEW	W.VA.	YES	1.88	10	0	120	CONVENTIONAL
ROBERTSON	11-1.89	NEW	W.VA.	YES	1.89	10	0	120	CONVENTIONAL
ROBERTSON	11-1.90	NEW	W.VA.	YES	1.90	10	0	120	CONVENTIONAL
ROBERTSON	11-1.91	NEW	W.VA.	YES	1.91	10	0	120	CONVENTIONAL
ROBERTSON	11-1.92	NEW	W.VA.	YES	1.92	10	0	120	CONVENTIONAL
ROBERTSON	11-1.93	NEW	W.VA.	YES	1.93	10	0	120	CONVENTIONAL
ROBERTSON	11-1.94	NEW	W.VA.	YES	1.94	10	0	120	CONVENTIONAL
ROBERTSON	11-1.95	NEW	W.VA.	YES	1.95	10	0	120	CONVENTIONAL
ROBERTSON	11-1.96	NEW	W.VA.	YES	1.96	10	0	120	CONVENTIONAL
ROBERTSON	11-1.97	NEW	W.VA.	YES	1.97	10	0	120	CONVENTIONAL
ROBERTSON	11-1.98	NEW	W.VA.	YES	1.98	10	0	120	CONVENTIONAL
ROBERTSON	11-1.99	NEW	W.VA.	YES	1.99	10	0	120	CONVENTIONAL
ROBERTSON	11-2.00	NEW	W.VA.	YES	2.00	10	0	120	CONVENTIONAL
ROBERTSON	11-2.01	NEW	W.VA.	YES	2.01	10	0	120	CONVENTIONAL
ROBERTSON	11-2.02	NEW	W.VA.	YES	2.02	10	0	120	CONVENTIONAL
ROBERTSON	11-2.03	NEW	W.VA.	YES	2.03	10	0	120	CONVENTIONAL
ROBERTSON	11-2.04	NEW	W.VA.	YES	2.04	10	0	120	CONVENTIONAL
ROBERTSON	11-2.05	NEW	W.VA.	YES	2.05	10	0	120	CONVENTIONAL
ROBERTSON	11-2.06	NEW	W.VA.	YES	2.06	10	0	120	CONVENTIONAL
ROBERTSON	11-2.07	NEW	W.VA.	YES	2.07	10	0	120	CONVENTIONAL
ROBERTSON	11-2.08	NEW	W.VA.	YES	2.08	10	0	120	CONVENTIONAL
ROBERTSON	11-2.09	NEW	W.VA.	YES	2.09	10	0	120	CONVENTIONAL
ROBERTSON	11-2.10	NEW	W.VA.	YES	2.10	10	0	120	CONVENTIONAL
ROBERTSON	11-2.11	NEW	W.VA.	YES	2.11	10	0	120	CONVENTIONAL
ROBERTSON	11-2.12	NEW	W.VA.	YES	2.12	10	0	120	CONVENTIONAL
ROBERTSON	11-2.13	NEW	W.VA.	YES	2.13	10	0	120	CONVENTIONAL
ROBERTSON	11-2.14	NEW	W.VA.	YES	2.14	10	0	120	CONVENTIONAL
ROBERTSON	11-2.15	NEW	W.VA.	YES	2.15	10	0	120	CONVENTIONAL
ROBERTSON	11-2.16	NEW	W.VA.	YES	2.16	10	0	120	CONVENTIONAL
ROBERTSON	11-2.17	NEW	W.VA.	YES	2.17	10	0	120	CONVENTIONAL
ROBERTSON	11-2.18	NEW	W.VA.	YES	2.18	10	0	120	CONVENTIONAL
ROBERTSON	11-2.19	NEW	W.VA.	YES	2.19	10	0	120	CONVENTIONAL
ROBERTSON	11-2.20	NEW	W.VA.	YES	2.20	10	0	120	CONVENTIONAL
ROBERTSON	11-2.21	NEW	W.VA.	YES	2				


TABLE 15

ESTIMATED AT-MARKET POWER VALUES  
(15 Power Supply Areas)


Power Supply Area	Unit Size (mw)	Alternative Steam-Electric Plant Private Financing (Except Area 20)				Capacity Cost with Federal Financing (\$/kw/yr.)
		Capital Cost (\$/kw)	Fuel Cost (¢/M Btu)	Capacity Value (\$/kw/yr.)	Energy Value (Mills/kwh)	
3	1,000	160	Nuclear	29.75	1.20	14.00
4	1,000	160	Nuclear	31.00	1.20	14.00
5	800	130	18.0	20.00	1.50	11.50
6	1,000	155	Nuclear	26.50	1.20	14.00
7	500	135	19.0	24.50	1.60	12.75
8	750	155	Nuclear	33.75	1.20	14.25
9	800	130	18.0	24.25	1.50	11.25
10	800	130	18.0	22.50	1.50	11.25
12	800	125	21.0	22.50	1.80	11.00
18	650	120	29.5	21.80	2.50	11.35
19	800	125	21.2	21.90	1.80	11.10
20	1,000	120	18.4	14.05	1.55	10.55
21	650	110	28.0	21.65	2.35	10.65
22	500	110	22.8	18.90	2.00	10.70
23	500	110	28.4	19.35	2.45	11.00



Notes

1. Cost data used in preparing power-value estimates have been adjusted to January 1, 1968, price levels.
2. Capital cost of alternative plants exclude step-up substation.
3. Values are based on typical two-unit thermal-electric plants.
4. Capacity value of \$14.05 for P.S.A. 20 is based on TVA financing.
5. Values shown are suitable for screening purposes only.
6. Based on energy values shown, fuel for nuclear plants would be between 14 and 15 cents per million Btu.





21





OCEAN




FEDERAL POWER COMMISSION  
BUREAU OF POWER

---


HYDROELECTRIC POWER RESOURCES  
APPALACHIAN REGION

---

1968




2





### KEY MAP



### LEGEND

Appalachian Boundary	-----
River Basin Boundary	-----
County Line in Region	-----
Existing Project (first figure indicates order of project from source of stream and second figure indicates installed capacity in mw)	■ 2-50 ■ 50-100
Potential Project	□
Existing Project With Potential Additional Unit or Units Indicated By The Letter Suffix "A"	■ 5-100 ■ 100-200
Existing Project With Potential Redevelopment Indicated By The Letter Suffix "R"	■ 10-50 ■ 50-200

FEDERAL POWER COMMISSION  
BUREAU OF POWER

---

**HYDROELECTRIC POWER RESOURCES  
APPALACHIAN REGION**

---

1968

CHAPTER VII - WATER REQUIREMENTS FOR HYDROELECTRIC  
AND THERMAL-ELECTRIC POWER GENERATION

Hydroelectric Power Generation

The hydroelectric plants listed in Table 14 in the previous section on Hydroelectric Power Resources show various operating heads ranging from about eight to 1,207 feet. The lower head projects require larger, heavier, slower operating, and bulkier units per kilowatt of capacity than the higher head units. Also, they require a considerably greater quantity of water to be passed through their water wheels to produce a kilowatt-hour of energy.

Assuming an over-all water wheel-generator efficiency of about 86 percent, a kilowatt-hour produced will equal about  $0.073QH$ , where  $Q$  is the quantity of water required in cubic feet per second flow and  $H$  is the head in feet. In Table 16 is shown a range of water wheel requirements of flow in cubic feet per second per 1,000 kilowatts of power produced for various selected heads.

TABLE 16

WATER WHEEL REQUIREMENTS  
HYDROELECTRIC GENERATING PLANTS

<u>Head (feet)</u>	<u>Water Flow (cfs/1,000 kw)</u>
10	1,370
25	543
50	274
75	183
100	137
150	91
200	69
300	46
500	28
750	18
1,000	14

Thermal-Electric Power Generation

Electric energy for the added electric power requirements of the future will be supplied mostly by large and modern steam-electric generating plants which will be constructed as the use of electricity increases. Some undoubtedly, will be fossil-fuel fired and others atomic-fuel fired. For either or both, large quantities of heat will be rejected as waste in the thermal-cycle. This waste must be removed from the cycle as rapidly as it occurs in order to obtain full and efficient use of the thermal-mechanical conversion equipment. The best and cheapest method of dissipating and removing this heat from the

plants is accomplished by pumping large quantities of water through surface condensers where the exchange is made from the nearly spent steam to the flow-through waters.

Modern steam-electric plants of several hundred thousand to several million kilowatts are being built with over-all efficiencies of around 40 percent for fossil-fuel fired boilers and from 32 to 34 percent for atomic-fuel fired boilers. These efficiencies may improve some as the state of the art progresses, but improvement beyond 40 percent will be slow and slight.

Water needs for condensing and cooling purposes at modern, large steam-electric generating plants for selected plant efficiencies and temperature exchanges are shown in Table 17. As an example of the use of the data in the table, the column with the 40 percent over-all efficiency plant is adopted for explanation and discussion. Convenient references of conversion factors are given in the Glossary.

One kilowatt-hour of electric energy contains the equivalent of 3,413 British thermal units of heat. Therefore, a plant operating at 40 percent efficiency would require an input of 8,533 British thermal units per kilowatt-hour.

TABLE 17

ENERGY CONVERSION AND COOLING WATER REQUIREMENTS  
FOR MODERN, LARGE STEAM-ELECTRIC GENERATING PLANTS

Over-all plant efficiency	%	30	32	34	36	38	40	42	44	46
Plant total input energy requirement	Btu/kwh	11,377	10,566	10,038	9,481	8,982	8,533	8,126	7,757	7,420
Plant heat loss - 10% assumed to air	Btu/kwh	<u>1,138</u>	<u>1,067</u>	<u>1,006</u>	<u>948</u>	<u>898</u>	<u>853</u>	<u>813</u>	<u>776</u>	<u>742</u>
Energy input to turbine	Btu/kwh	10,239	9,599	9,034	8,533	8,084	7,680	7,313	6,981	6,678
Generator output	Btu/kwh	3,413	3,413	3,413	3,413	3,413	3,413	3,413	3,413	3,413
Heat rejected and wasted to water	Btu/kwh	6,826	6,186	5,621	5,120	4,671	4,267	3,900	3,566	3,265
Cooling water required for 10° temperature rise	gal/kwh	81.9	74.3	67.5	61.5	56.1	51.2	46.8	42.8	39.2
Cooling water required for 1,000,000 kilowatts										
For 10° temperature rise	cfs	3,040	2,760	2,510	2,280	2,080	1,900	1,740	1,590	1,450
For 12° temperature rise	cfs	2,530	2,300	2,090	1,900	1,730	1,580	1,450	1,330	1,210
For 14° temperature rise	cfs	2,170	1,970	1,790	1,630	1,490	1,360	1,240	1,140	1,060
For 16° temperature rise	cfs	1,900	1,720	1,570	1,430	1,300	1,190	1,090	990	910
For 18° temperature rise	cfs	1,690	1,530	1,390	1,270	1,160	1,060	970	880	810
For 20° temperature rise	cfs	1,520	1,380	1,250	1,140	1,050	950	870	800	730
Cooling water required for 1,000,000 kilowatt-hours										
For 10° temperature rise	acre-ft.	251	228	207	188	172	157	144	131	120
For 12° temperature rise	acre-ft.	209	190	173	157	146	131	120	109	100
For 14° temperature rise	acre-ft.	179	163	148	134	123	112	103	94	86
For 16° temperature rise	acre-ft.	157	143	129	118	108	98	90	82	75
For 18° temperature rise	acre-ft.	139	127	115	106	96	87	80	73	67
For 20° temperature rise	acre-ft.	126	114	104	96	86	79	72	66	60
Evaporation for 1,000,000 kilowatts <sup>1/</sup>	cfs	29.2	26.5	24.1	21.9	20.0	18.3	16.7	15.3	14.0
Evaporation for 1,000,000 kilowatt-hours <sup>1/</sup>	acre-ft.	2.41	2.19	1.99	1.81	1.65	1.51	1.38	1.26	1.16

Note: See Glossary of Equivalents, page B-60, for conversion quantities.

<sup>1/</sup> Assuming complete dissipation of heat by evaporation.

Between the heat input and the energy output there are numerous and varying losses. These may be conveniently divided into two categories: those lost to the air or atmosphere, and those lost or dissipated to the water exchange. The first category includes boiler, flue, stack, and other heat losses to the air. For a modern steam-electric plant burning fossil fuel, losses to the atmosphere are about 10 percent of the plant heat input; 8,533 times 0.10 equals 853 British thermal units per kilowatt-hour. Losses to the atmosphere for a nuclear-fired plant are a lesser percentage and amount.

The second category of losses includes all other losses and dissipation of heat. It is 8,533 minus 3,413 and 853, or 4,267 British thermal units per kilowatt-hour. One U. S. gallon of water weighs 8.33 pounds. Therefore, to dissipate the 4,267 British thermal units per kilowatt-hour of heat lost or rejected would require 4,267 divided by 8.33, or 512.2 gallons of water with an exchange of one degree Fahrenheit (1° F.) temperature rise to the water. If 10° F. per pound are exchanged, the quantity of water required would be 51.2 gallons per kilowatt-hour.

A 1,000,000-kilowatt generating unit would produce 1,000,000 kilowatt-hours of energy for each hour of full unit operation. The heat loss or rejection for 1,000,000 kilowatt-hours would be 4,267 million British thermal units and this would require 51.2 million gallons of water for a heat exchange of 10° F.

Quantities of water required for the heat exchange from large generating units or plants are usually expressed either as flow in cubic feet per second or as volume in acre-feet. The water flow required to operate 1,000,000 kilowatts of capacity with a 1° F. temperature rise would be

$$\frac{4,267 \times 1,000,000}{3,600 \times 62.425}, \text{ or } 19,000 \text{ cubic feet per second.}$$

The water volume or quantity required in the production of 1,000,000 kilowatt-hours of electric energy with a 1° F. temperature rise would be

$$\frac{4,267 \times 1,000,000}{62.425 \times 43,560}, \text{ or } 1,570 \text{ acre-feet.}$$

For a 10° F. heat exchange the flow and quantity required with a 40 percent plant efficiency would be 1,900 cubic feet per second and 157 acre-feet, respectively.

Cooling for heat exchange may be accomplished also by evaporation. This requires a substantially smaller quantity of water, but it results in consumptive use as the water is evaporated and lost to the atmosphere. The quantity of water evaporated will vary over the seasons and from time-to-time depending on temperature, wind, humidity, vapor pressure, etc. The greatest demand-use for water will occur during the hottest and muggiest weather, usually in July or August, and generally at the same time the electric suppliers are experiencing system peak loads. The heat exchange per unit of water at such times will be the smallest quantity. For 95° F. weather the exchange will be about

1,040 British thermal units for each pound of water evaporated. The evaporation losses of water for 1,000,000 kilowatts, assuming complete dissipation by evaporation, amount to

$$\frac{4,267 \times 1,000,000}{3,600 \times 62.425 \times 1,040}, \text{ or } 18.3 \text{ cubic feet per second.}$$

The quantity of water required as evaporation losses for 1,000,000 kilowatt-hours will be

$$\frac{4,267 \times 1,000,000}{62.425 \times 43,560 \times 1,040}, \text{ or } 1.51 \text{ acre feet.}$$

## CHAPTER VIII - CONCLUSIONS

Requirements for electric power in the Appalachian region and in the adjacent area are doubling about every 11 to 12 years. They will continue to increase at this rate, under normally expected growth conditions, until about 1980. Power requirements are expected to double about every 14 to 16 years between 1980 and 2000, and then double again from 2000 to 2020. Under "developmental benchmarks" conditions the requirements for the Appalachian region after 1980 may double about every 13 to 14 years until 2020.

About 124 million kilowatts more than the currently existing and committed supply will be needed by 1980 for the power requirements of the 15 power supply areas in which the Appalachian region is located. About 20 percent, or 25 million kilowatts, can be supplied from new hydroelectric projects consisting of some conventional and some pumped-storage developments. The remaining 99 million kilowatts can be from new fuel-electric capacity of the fossil- or nuclear-fuel fired types. The new supply needed beyond 1980 can be furnished at a ratio of about 20 percent hydroelectric to 80 percent fuel-electric as long as there are suitable sites remaining for economical development of sufficient hydroelectric power.

A large part of the tremendous amount of new supply needed for use in subsequent years, both hydroelectric and fuel-electric, may be physically located in the Appalachian region and the electric power transmitted to other areas both within and adjacent to the Appalachian region for ultimate consumption.

**GLOSSARY**  
**OF**  
**ABBREVIATIONS, EQUIVALENTS, AND TERMS**  
**As Used in this Appendix**

**ABBREVIATIONS**

Btu	British thermal unit
cfs	Cubic feet per second
cu ft	Cubic feet
(°)-F	Degrees - Fahrenheit
ft	Foot, or feet
gal	Gallon
gal/kwh	Gallons per kilowatt-hour
gw	Gigawatt
gwh	Gigawatt-hour
kw	Kilowatt
kwh	Kilowatt-hour
mw	Megawatt
mwh	Megawatt-hour
$10^3$ mwh	Thousand megawatt-hours
%	Percent
#	Pound

## EQUIVALENTS

### Energy

1 British thermal unit = 1 pound water changed  
1 degree Fahrenheit temperature.  
= 1/1,040.1 pound water evaporated to  
atmosphere at 95°F ambient temperature.

1 kilowatt-hour = 1 kilowatt x 1 hour.  
= 3,413 British thermal units.

1 megawatt-hour = 1,000 kilowatt-hours.

1 gigawatt-hour = 1,000 megawatt-hours.  
=  $10^3$  megawatt-hours.  
= 1,000,000 kilowatt-hours.

### Power

1 kilowatt = Basic electric unit.

1 megawatt = 1,000 kilowatts.

1 gigawatt = 1,000 megawatts.  
= 1,000,000 kilowatts.

### Volumes

1 cubic foot water = 7.48 U. S. gallons.

1 acre-foot = 1 acre x 1 foot.  
= 43,560 cubic feet.  
= 43,560 square feet x 1 foot.  
= 325,851 gallons.  
= 2,719,233 pounds water.  
= .5042 cubic feet per second flow.

### Miscellaneous Quantities

1 U. S. gallon water = 8.33 pounds.

1 cubic foot per second = 1.98 acre-feet per day.  
= 62,425 pounds water per second.  
= 224,730 pounds water per hour.  
= 5,393,500 pounds water per day.

## TERMS

At-market value - see power value

Base load - see generating plant

Capacity - the load, expressed in kilowatts, which an electrical unit, facility, or system is rated to carry.

Capacity value - see power value

Conventional plant - see generating plant

Coordinated operation - the operation of two or more electric facilities or systems as a single facility or system.

Demand - the rate, expressed in kilowatts, at which electric energy is delivered or used.

Duration diagram - a curve of quantities plotted in descending order of magnitude against time intervals for a specified period. The coordinates may be in quantities or percentages.

Electric energy - a measure of work, expressed in kilowatt-hours.

Electric market - see power requirements

Electric power - a term used to express capacity and energy.

Electric system - physically connected electrical facilities operated as a unit under one control.

Energy value - see power value

Fossil-fuel plant - see generating plant

Fuel-electric plant - see generating plant

Generating plant - where electric capacity is used to produce electric energy.

Base load plant - one normally operated near constant capacity and high plant factor to carry base load.

Conventional plant - one conforming substantially to past and present conventional design and operating procedures.

TERMS (Cont'd)

**Fossil-fuel plant** - one using fossil fuel (coal, gas, or oil) as its source of energy.

**Hydroelectric plant** - one using falling water as its motive force.

**Nuclear-fuel plant** - one using a nuclear reactor to provide its source of energy.

**Peak load plant** - one which operates, usually at a low plant factor, to supply power during maximum load periods.

**Pumped-storage plant** - one using an arrangement whereby water is pumped from a lower to a higher elevation during periods of low load for use by reverse flow during system peak-load periods to produce electric energy for load.

**Steam-electric plant** - one using steam for its motive force - the steam may be produced by a boiler using either fossil or nuclear fuel.

**Thermal-electric plant** - one using heat as the source of energy for the prime mover.

**Generating unit** - an electric generator, together with its prime mover and appurtenances.

**Head** - the difference in elevation of water for use in developing hydroelectric power.

**Heat rate** - the thermal rating of a thermal-electric generating unit or plant - expressed in British thermal units of heat input per kilowatt-hour of energy output.

**Heat rejected or wasted** - heat in the thermal cycle, other than for atmospheric and friction losses, that is not converted into electric energy.

**Interconnection** - a tie permitting the flow of electric power between the facilities of two or more electric systems.

**Load center** - where load is assumed to be concentrated.

**Load factor** - the ratio of average load to peak load occurring over a designated period.

TERMS (Cont'd)

Network - a system of connected transmission circuits over which power can flow to and between principal points.

Nuclear power - see generating plant

Outage - a period during which the services of an electric facility are lost from use.

Peak load - maximum electrical demand during a given period.

Peak load plant - see generating plant

Plant factor - the ratio of the average load on a facility over a given period to the capacity or load rating of the facility.

Power pool - two or more interconnected electric systems operated on a coordinated basis to economize and improve service in supplying load.

Power supply - a source of electric power.

Power requirements - the needs of power supply for designated loads, uses, and losses.

Power value - the value measured by the cost of producing and delivering equivalent power at a given point from an alternative source.

At-market value - power delivered to step-down substations at load centers.

Capacity value - that part of the at-market power value assigned to the capacity component of the power.

Energy value - that part of the at-market value assigned to the energy component.

Pumped storage - see generating plant

Rating - a design limit placed on a unit or facility.

Steam-electric - see generating plant

Substation - a facility for switching or changing the voltage of electricity.

TERMS (Cont'd)

**Thermal cycle** - the complete heat conversions involved in converting fuel to electricity in a thermal-electric generating plant.

**Thermal-electric plant** - see generating plant

**Transmission system** - an interconnected group of transmission lines and associated equipment over which bulk power can be supplied to or transmitted between points.

**Water for condensing** - water used to pull steam out of the generator turbine by condensation.

## BIBLIOGRAPHY

1. **F.P.C.** - Electric Power Statistics. Monthly pamphlets summarizing capacity and energy production by systems and groups of systems.
2. **F.P.C.** - Statistics of Electric Utilities. Annual information of financial and physical matter of individual utilities.
3. **F.P.C.** - Hydroelectric Power Resources of the United States, Developed and Undeveloped. Publication contains 13 tables with hydroelectric data.
4. **F.P.C.** Map - Principal Electric Facilities, 1966. Regional maps with transmission lines of 22 kv and above, and generating plants of 1,000 kw and above.
5. **F.P.C.** - National Power Survey, 1964. Report covering all aspects of the power industry.
6. **F.P.C.** - Prevention of Power Failures. Report prepared subsequent to Northeast Power Failure of November 9 and 10, 1965.
7. **F.P.C.** - Northeast Power Failure. Report on failure of November 9 and 10, 1965, with recommended measures aimed at preventing recurrence of massive blackout.
8. **F.P.C.** - Power Interruption - Pennsylvania-New Jersey-Maryland Interconnection. Report on failure of June 5, 1967.
9. **F.P.C.** - Power System Statements. Annual reports with semiannual and monthly supplements by utilities on physical facilities and operating quantities.
10. **F.P.C.** - Financial Statements. Annual reports with supplements by utilities on financial and physical quantities.
11. **F.P.C.** - Electric Power Supply and Requirements. Monthly summaries of data reported by major utilities and groups of utilities.
12. Resources for the Future - Water Demand for Steam-Electric Generation. Report on water requirements for condensing and other needs.
13. **F.P.C.** - Hydroelectric Power Evaluation - 1968.

---

Items 1-7 and 13 are for sale by the Superintendent of Documents, U. S. Government Printing Office, Washington, D. C., 20402.

CORPS OF ENGINEERS



U. S. ARMY