

AD-A041 689

ARMY ELECTRONICS COMMAND FORT MONMOUTH N J
SOLID-STATE LASER WAVELENGTH IDENTIFICATION USING A REFERENCE A--ETC(U)
JUN 77 K O WHITE, W R WATKINS

F/G 20/5

UNCLASSIFIED

ECOM-5820

NL

1 of 1
ADA041689



END

DATE
FILMED
8-77



12

AD

Reports Control Symbol
OSD-1366

RESEARCH AND DEVELOPMENT TECHNICAL REPORT
ECOM-5820

SOLID-STATE LASER WAVELENGTH IDENTIFICATION USING A REFERENCE ABSORBER

By

**Kenneth O. White
Wendell R. Watkins**


Atmospheric Sciences Laboratory

US Army Electronics Command
White Sands Missile Range, New Mexico 88002

and

**Stuart A. Schleusener
Ronald L. Johnson**
Electrical Engineering Department

New Mexico State University
Las Cruces, New Mexico 88003



June 1977

Approved for public release; distribution unlimited.

ECOM

UNITED STATES ARMY ELECTRONICS COMMAND - FORT MONMOUTH, NEW JERSEY 07703

AD A 041689

FILE COPY
DDC
AU NO.

NOTICES

Disclaimers

The findings in this report are not to be construed as an official Department of the Army position, unless so designated by other authorized documents.

The citation of trade names and names of manufacturers in this report is not to be construed as official Government indorsement or approval of commercial products or services referenced herein.

Disposition

Destroy this report when it is no longer needed. Do not return it to the originator.

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM	
1. REPORT NUMBER ECOM-5826	2. GOVT ACCESSION NO. 9 Research and development	3. RECIPIENT'S CATALOG NUMBER	
4. TITLE (and Subtitle) SOLID-STATE LASER WAVELENGTH IDENTIFICATION USING A REFERENCE ABSORBER.		5. TYPE OF REPORT & PERIOD COVERED R&D Technical Report.	
7. AUTHOR(s) Kenneth O. White, Stuart A. Schleusener Wendell R. Watkins, Ronald L. Johnson		6. PERFORMING ORG. REPORT NUMBER	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Atmospheric Sciences Laboratory White Sands Missile Range, New Mexico 88002		8. CONTRACT OR GRANT NUMBER(s)	
11. CONTROLLING OFFICE NAME AND ADDRESS US Army Electronics Command Fort Monmouth, New Jersey 07703		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 1161102B53A-S329	
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office) 12 28p.		12. REPORT DATE June 1977	
		13. NUMBER OF PAGES 21	
		15. SECURITY CLASS. (of this report) UNCLASSIFIED	
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE	
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.			
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)			
18. SUPPLEMENTARY NOTES			
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Spectroscopic technique Solid-state lasers			
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) A Fabry-Perot etalon is used to identify the relative wavelengths of individual spikes in the long-pulse output of a homogeneously broadened, solid-state laser. This identification is accomplished by positioning one side of a low finesse etalon bandpass such that it is coincident with the laser output. Different wavelength spikes experience different attenuations on passing through the etalon, thus enabling a relative wavelength determination from the etalon transmission value. The etalon is incorporated into a real-time minicomputer			

DD FORM 1473 1 JAN 73 EDITION OF 1 NOV 65 IS OBSOLETE

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

037620

DDC
REF ID: A61122
JUL 19 1977
RECEIVED
C

20. Abstract (cont)

controlled measuring system capable of storing, analyzing, and displaying various parameters encountered in laser interaction studies. By utilizing the narrow spectral width of individual laser spikes (< 0.0001 nm) and the large number of different wavelength spikes available in a single long pulse (tens to hundreds), many high-resolution spectral data points can be obtained within the period of one laser shot (< 4 ms). Experimental results of the transmission of erbium:YAG laser radiation in a methane-enriched atmosphere are shown to illustrate one use for the system.

This technique provides an accurate means of studying the interaction and propagation nature of certain solid-state lasers used by the Army. The causes of degradation in Army laser systems may be studied with a higher degree of precision, thereby allowing possible minimization or elimination of any such effects.

CONTENTS

	<u>Page</u>
INTRODUCTION	2
EXPERIMENTAL ARRANGEMENT	3
Laser Parameters	3
Wavelength Identifier	4
Other Systems	5
Data Analysis System	6
EXPERIMENTAL RESULTS AND COMMENTS	7
REFERENCES	13

ACCESSION for	
NTIS	White Section ☒
DDC	Defi Section ☐
UNANNOUNCED	☐
JUSTIFICATION.....	
.....	
BY.....	
DISTRIBUTION/AVAILABILITY CODES	
Dtsl.	AVAIL. and/or SPECIAL
A	

INTRODUCTION

The Army has a continuing need for lasers in field systems such as range finders and target designators. Since gases and particulates in the atmosphere will affect the performance of any laser system, their effects must be well understood before a total system analysis can be completed. For a complete understanding of laser propagation characteristics, the spectral nature of the laser energy must be known in addition to the absorption properties of the atmosphere. Previous atmospheric propagation studies for various solid-state lasers were hindered by limited spectrometer resolution [1]. To investigate the interaction of laser energy with atmospheric gas absorption lines, a new high-resolution measuring technique was developed. The system allows relative wavelength identification of the individual laser spikes in a long-pulse laser output.

The emission from a long-pulse solid-state laser consists of a series of spikes. If the laser is homogeneously broadened, or nearly so, and care is taken in the alignment [2], the spikes will consist of only one longitudinal mode. These spikes can be used for high-resolution gas absorption studies if a method of wavelength identification can be found, since the spikes do not occur in any predictable way within the gain envelope of the laser and vary in spectral position from shot to shot. Methods have been developed to identify wavelengths by using spectrometers [3]; however, the ultimate spectrometer resolution available (about 10^{-2} nm) is far from sufficient to allow accurate sorting of single mode laser spikes for high-resolution studies.

The new idea is simply to measure the transmission of a laser spike through a known absorber in which the absorption is a monotonic function of wavelength. The relative wavelength of the laser spike can be obtained from this measurement. One method of measuring is by positioning one side of a low finesse Fabry-Perot etalon bandpass such that it is coincident with the laser output spectrum. Different wavelength laser spikes experience different attenuations on passing through the etalon. Thus, a relative wavelength tag can be associated with the etalon transmission value of a given laser spike.

An investigation to study the atmospheric propagation characteristics of the erbium:ytterbium-aluminum-garnet (YAG) laser energy was the impetus for the development of the above technique. Carbon dioxide and water vapor are the principal infrared absorbers [4], but neither has a major absorption band in the spectral region of the $1.645\mu\text{m}$ laser emission. However, there are several minor absorption bands and many weak lines [5] which impart a considerable amount of spectral structure to this region. A close wavelength coincidence had been previously discovered [1] between the erbium:YAG laser radiation and the R(6) line in the $2\nu_3$ methane band at 1645.1 nm . The potential application of this coincidence to the remote sensing of atmospheric methane has been discussed elsewhere [6]. Theory predicts that this overtone line is composed of

six fine structure compacts [7,8], two groups of three separated by 0.22 nm [8,9]. The relative spectral positions of the methane absorption line, erbium:YAG laser emission, and etalon transmission are shown in Fig. 1. The new measuring technique was developed in an attempt to resolve this absorption interaction.

The experimental arrangement, including properties of the laser, etalon, and data acquisition system, and experimental results are presented in the following sections.

EXPERIMENTAL ARRANGEMENT

The experimental arrangement is illustrated in Fig. 2. The optical system consists of: (1) a reference amplitude detector, (2) the absorption cell and output detector, (3) the spike wavelength identifying mechanism (Fabry-Perot etalon and detector), and (4) a wavelength region identifying instrument (5-m spectrometer). The data acquisition system consists of three analog-to-digital converters (ADC), an ADC data identifier (ADI), an interactive terminal, and an HP 2100A minicomputer.

Laser Parameters

The laser consists of a 6 mm diameter by 75 mm long YAG rod doped with 0.4% erbium and sensitized with 5% ytterbium [10,11]. A linear xenon flash lamp is used in a close-wrap intersecting circle cavity which is cooled by flowing nitrogen gas. The laser interferometer consists of a plane parallel cavity with a 99.9% reflectivity back mirror and a 95% reflectivity output mirror 26.5 cm apart (the rod ends being antireflection coated). The laser cavity and the optical system are aligned by using a He-Ne laser beam coincident with the erbium laser beam. A nicol prism is placed at the laser output to obtain a vertically polarized beam. With this configuration the threshold is approximately 200 joules. The nominal output slightly above threshold is 10-30 millijoules per pulse in the long pulse mode of operation. Laser emission is centered at 1644.9 nm with a spectral bandwidth of approximately 0.6 nm.

In this laser the initial depopulation of the excited state is so large that lasing ceases until the population inversion can be restored by continued pumping--at which point the process repeats itself (Fig. 3). This procedure results in a long pulse mode output consisting of a 0.5 to 4 millisecond train of single-mode (frequency) spikes. Near threshold the spikes occur singly with respect to time. This behavior was enhanced by placing two 1 mm diameter apertures in the laser cavity and thereby reducing the usable gain medium volume. The above temporal behavior is a necessary condition for the data acquisition system to be able to analyze the individual spike peak intensities. The data analysis system automatically rejects spikes in very rapid succession and any spike overlapping due to detector decay time (Fig. 3).

Since the measuring system uses the absorption values for individual laser spikes, the system's resolving power is inherently a function of the spectral width of each spike. The erbium laser approaches being homogeneously broadened. In a homogeneously broadened system, there may be several cavity modes which have gains above threshold (Fig. 4a) at the start of laser action. As energy builds up at these frequencies, the modes compete with each other for the inverted population, and the total gain drops (gain saturation) [12], until only one mode is left above the threshold gain (Fig. 4b). The output thus ideally consists of a single frequency corresponding to the mode with the highest initial gain. If only one longitudinal mode was to oscillate, the bandwidth of a single spike should be extremely narrow (< 0.0001 nm, based on theoretical laser interferometer finesse).

Even though the erbium laser is not an ideal homogeneously broadened system, operation with single frequency spikes may be enhanced by aligning the cavity mirrors parallel to the ends of the laser rod [2]. This provides an intracavity mode-selecting resonator with a high effective finesse, since it contains the laser's gain medium. An upper limit for the spectral width of an individual spike was experimentally set at less than 0.01 nm [13] by using a 5 m grating spectrometer with a linear fiber optic bundle in its output plane (the maximum spectrometer resolution was 10^{-2} nm).

Wavelength Identifier

A Fabry-Perot etalon with plane parallel mirrors is used to identify the wavelength of the individual spikes with respect to each other. An etalon bandpass is positioned as in Fig. 5 by changing mirror spacing. For this positioning, shorter wavelength spikes (λ_0) give rise to lower etalon transmission values (T_0) than longer wavelength spikes (λ_n , T_n). Therefore, by plotting the gaseous transmission values for the spikes versus etalon transmission values, a profile of the absorption-line can be obtained.

By using a computer model [14] of the transmission characteristics of the etalon, the necessary mirror reflectivities and spacing were obtained for the wavelength region of interest. The objective was to obtain a bandpass which was linear over the desired spectral range (absorption line) while possessing the maximum dynamic range of transmission. For this case, 40% reflectivity mirrors with approximately 0.5 mm spacing gave these desired characteristics. The etalon has a finesse of 3.31 , with a free spectral range of 2.7 nm and bandpass full-width at half maximum of 0.82 nm. For studying specific sections of a highly structured absorption line, a narrower bandpass with an increased transmission versus wavelength slope might be used.

The measuring system's resolving ability is highly dependent on the resolution and stability of the etalon. About 0.1 nm of the etalon

bandpass (in the linear region) is used in the measurement. The detector signals obtained from the laser spikes in this spectral region can be made to range over a 10-V region which in turn is digitized by using 2048 channel resolution. Thus, a theoretical spectral resolution of about 5×10^{-5} nm is obtainable. This is on the order of the width of the single mode laser spikes. A 3 mm diameter aperture is used to limit the etalon mirror surface area used so that the spikes encounter minimal differences in mirror reflectivity and spacing; this procedure helps to ensure a linear and uniform bandpass for all spikes.

The etalon is Invar housed with piezoelectric electrometers for both mirror alignment and spacing. The construction minimizes thermal and mechanical stability problems [15]. Thermal shifts were seen to be minimal due to the Invar construction and thermal expansive compensation (one component expands in a direction opposite to another). A 61 nm change of the 0.5 mm etalon mirror spacing will cause a theoretical change of 20% in the transmission of a particular wavelength through the etalon. This shift would not be of any consequence if all the necessary data points could be accumulated within one long pulse since the mechanical vibration noise has a period longer than the 4 ms laser shot (the system is mounted on a massive optical table). For the methane absorption line under consideration, the laser is just partially coincident, so only a few of the spikes in a long pulse fall on the line. Therefore, more than one shot is needed to obtain a sufficient amount of data. Any etalon mirror spacing shift between laser shots would result in a corresponding offset in wavelength positions between the different sets of data.

Other Systems

A 5 m Fastie spectrometer is used to select portions of the laser spectral output for analysis (Fig. 5). The signal from a detector behind the spectrometer slit (Fig. 2) acts as a "gate" for the data acquisition system, allowing only those laser spikes with wavelengths within the spectrometer slit to be analyzed. This is used to observe etalon transmission values for positioning the bandpass and to analyze the absorption characteristics of specific wavelength regions. The computer/ADI sorts data in up to four separate memory sections depending on the coincident "gate" signal from different spectral positions in the output plane of the spectrometer [16]. This allows real-time system calibration to compensate for long-term changes.

Detector arrangement is shown in Fig. 6. Originally some problems were encountered with spikes hitting different parts of the active area of the photodiode and causing erratic results. A membrane filter was incorporated into the arrangement to diffuse the laser spike energy such that it is averaged over the entire active area.

The absorption cell (Fig. 2) is constructed from 7.5 cm diameter Pyrex tubing 0.62 m long with antireflection coated entrance and exit windows. The absorption path consists of a single pass through 100 torr of CH_4 broadened with 560 torr of N_2 . The cell temperature was maintained at 22°C and the pressures were monitored by a capacitance nanometer.

Data Analysis System

A minicomputer controlled pulse-height analyzer is used to store, analyze, and display the information from the three simultaneous signals: (1) reference (cell input), (2) absorption (cell output), and (3) etalon (etalon output). This basic data acquisition and analysis system has been described in detail elsewhere [17]. The peak amplitude of the signals from the reference, absorptions, and etalon detectors are sampled and digitized into corresponding 14-bit digital words (up to 8192 channels) by the three ADCs. These words are held in a buffer until the minicomputer signals that it is ready for data transfer. An additional two bits are added to the etalon ADC word via the ADI unit. This enables data to be routed into up to four different memory locations when some identifying coincidence signal is present on one of the four ADI inputs at the same time data is present. The three ADCs are run in coincidence mode, which means that they can only accept data when a coincidence pulse is present (e.g., spectrometer gating), thereby insuring correlation between the three signals for an individual spike.

Data transfer to memory is accomplished through the use of two direct-memory access (DMA) channels for the reference and absorption digital words and one microprogrammed channel for the etalon. To maintain the correlation between the three ADCs, the reference and absorption ADCs are hardware "slaved" to the etalon ADC.

The three digital heights for a spike are transferred to the minicomputer only when the etalon ADC signals that it has data to transfer. Also, no ADC can accept new data until the microprogrammed (etalon) channel has finished data transfer. This is necessary since the DMA channels operate basically independent from the minicomputer's central processor unit (CPU), while the microprogramming requires seven CPU cycles or 6.86 μs to transfer data. This and the minimum time between successive laser spikes determines the minimum usable ADC pulse height resolution. Once the three simultaneous ADC words for all spikes in a long pulse are in memory, computations can be initiated.

The ratio of the absorption cell signal to reference signal allows the transmittance of each spike through the gas to be calculated. The etalon signal to reference signal is the etalon transmittance and is used to identify laser spike wavelengths with respect to each other. Plotting the absorption cell transmission values versus the etalon transmission gives a visual display of any absorption feature. Scale magnification is possible with the computer system, allowing closer scrutiny of highly

structured sections. The data from several different laser shots can be plotted together or separately.

With this system, approximately 40 data points can be obtained within less than 4 ms, the time duration of one long-pulse laser shot. This insures minimal influence on system calibration by time-varying problems.

EXPERIMENTAL RESULTS AND COMMENTS

Positioning of the etalon bandpass is especially critical. To achieve correct positioning the spectrometer is used to "gate" the system for a specific wavelength range, while the etalon spacing crystal is scanned. A typical plot of this type of data is illustrated in Fig. 7 for spikes not coincident with the absorption line. As the etalon is scanned, the transmission range for a set wavelength increment (spectrometer slit width) changes. On the peak of the bandpass (Fig. 7a), dynamic transmission range is minimal while transmission is greatest. As the side of the bandpass is scanned, the total range of etalon transmission values increases and maximum dynamic range position is obtained (Fig. 7b). This is the desired position. Further scanning positions the wing region of the etalon bandpass on top of the wavelength range, again giving minimal dynamic range, but this time with minimum transmission.

Figure 8 is a sequence of data taken with different spectrometer slit positions after the etalon bandpass has been positioned on the absorption line as in Fig. 1. In Fig. 8a the spectrometer slit is located off of the absorption line. As the slit is moved, more of the absorption line can be seen (Figs. 8b and 8c). The total line could not be scanned since the erbium:YAG laser output did not span the entire absorption line. Other coincident absorption lines may be investigated in the future.

Use of this system is not limited to obtaining spectral profiles of coincident gas absorption lines. The system may be used in any long-pulse laser interaction study. Three ADCs were utilized in this system, but many more microprogrammed transfer channels may be added with a small increase in data acquisition time (10 μ s per ADC). The main resolution limitations in this system are the etalon stability and the timing requirements which determine the maximum usable number of ADC pulse height channels.




Figure 1. Relative wavelength positions of absorption cell transmission of R(6) $2v_3$ line of $^{12}\text{CH}_4$, YAG:Er, Yb laser output at 22°C, and typical etalon bandpass positioning.




Figure 2. Diagram of the experimental arrangement for observing laser energy interaction with gases. The darker lines are electrical signals. B: beamsplitter, D: detector.




Figure 3. Operation of laser in long pulse mode. (*) denotes spike pulse overlapping due to detector decay time.




Figure 4. Gain saturation in a solid-state laser.
 (a) Initial system condition.
 (b) System condition for laser action after gain saturation.




Figure 5. Etalon bandpass and possible spectrometer slit positioning.




Figure 6. Detector arrangement. TIXL68 is a germanium photodiode.




Figure 7. Etalon spacing positions. The different positions were obtained by changing the voltage on the piezoelectric spacing crystal.

- (a) Peak of bandpass.
- (b) Position for maximum dynamic transmission range.




Figure 8. Absorption line scan. The system is gated for different wavelength ranges by the spectrometer:

- (a) Off of absorption line (transmission is 1).
- (b) A wing region of line (lower data points).
- (c) Into line.

REFERENCES

1. White, K. O., and S. A. Schleusener. "Coincidence of Er:YAG Laser Emission with Methane Absorption at 1645.1 nm." Appl. Phys. Lett. 21 (1972): 419.
2. Bua, D., D. Fradin, and M. Bass. "A Simple Technique for Longitudinal Mode Selection." IEEE J. Quant. Electron QE-8 (1972): 916.
3. White, K. O., S. A. Schleusener, E. H. Holt, and R. F. Calfee. "High-Resolution-Laser Atmospheric-Transmission-Measurement Method." Appl. Phys. Lett. 19 (1971): 381.
4. Burch, D. E., D. A. Gryvnak, and R. R. Patty. "Absorption of Infrared Radiation by CO₂ and H₂O Experimental Techniques." J. Opt. Soc. Am. 57 (1967): 885.
5. Mohler, O. C., A. K. Pierce, R. R. McMath, and L. Goldberg. "Photometric Atlas of the Near Infrared Solar Spectrum λ 8465 to λ 25242." University of Michigan Press, Ann Arbor, Michigan, 1955.
6. White, K. O., and W. R. Watkins. "Erbium Laser as a Remote Sensor of Methane." Appl. Opt. 14 (1975): 2812.
7. Rank, D. H., D. P. Eastman, G. Skorinko, and T. A. Wiggins. "Fine Structure in the Lines of the 2 ν_3 Band of Methane." J. Mol. Spectry. 1 (1960): 78.
8. Fox, K. "Vibration-Rotation Interactions in Infrared Active Overtone Levels of Spherical Top Molecules; 2 ν_3 and 2 ν_4 of CH₄, 2 ν_3 of CD₄." J. Mol. Spectry 9 (1962): 381.
9. Fox, K. "Coincidence of Er:YAG Laser Emission with Methane Absorption at 6077 cm⁻¹." Appl. Phys. Lett. 24 (1974): 24.
10. Snitzer, E., and R. F. Woodcock. "Yb³⁺ - Er³⁺ Glass Laser." Appl. Phys. Lett. 6 (1965): 45.
11. Thornton, J. R., P. M. Rushworth, E. A. Kelly, R. W. McMillan, and L. L. Harper. "Erbium Laser Technology." OA 5291-2, Martin Marietta Corporation, Orlando, Florida, 1970.
12. Maitland, A., and M. H. Dunn. "Laser Physics." American Elsevier Publishing Company, Incorporated, New York, NY, 1970.
13. Schleusener, S. A., and K. O. White. "Application of Dual Parameter Analyzers in Solid-State Laser Tests." Rev. Sci. Instr. 43 (1972): 1520.

14. Yuriv, A. "Introduction to Optical Electronics." Holt, Rinehart, and Winston, New York, NY (1971): 50.

15. Caplan, J. "Temperature and Pressure Effects on Pressure-Scanned Etalons and Gratings." Appl. Opt. 14 (1975): 1585.

16. White, K. O., W. R. Watkins, S. A. Schleusener, and R. L. Johnson. "Multiwavelength Discriminator and Display System for Solid-State Laser." Rev. Sci. Instr. 47 (1976): 645.

17. White, K. O., G. T. Wade, and S. A. Schleusener. "The Application of Minicomputers in Laser Atmospheric Experiments." Proc. IEEE 61 (1973): 1596.

ATMOSPHERIC SCIENCES RESEARCH PAPERS

1. Lindberg, J.D., "An Improvement to a Method for Measuring the Absorption Coefficient of Atmospheric Dust and other Strongly Absorbing Powders," ECOM-5565, July 1975.
2. Avara, Elton P., "Mesoscale Wind Shears Derived from Thermal Winds," ECOM-5566, July 1975.
3. Gomez, Richard B., and Joseph H. Pierluissi, "Incomplete Gamma Function Approximation for King's Strong-Line Transmittance Model," ECOM-5567, July 1975.
4. Blanco, A.J., and B.F. Engebos, "Ballistic Wind Weighting Functions for Tank Projectiles," ECOM-5568, August 1975.
5. Taylor, Fredrick J., Jack Smith, and Thomas H. Pries, "Crosswind Measurements through Pattern Recognition Techniques," ECOM-5569, July 1975.
6. Walters, D.L., "Crosswind Weighting Functions for Direct-Fire Projectiles," ECOM-5570, August 1975.
7. Duncan, Louis D., "An Improved Algorithm for the Iterated Minimal Information Solution for Remote Sounding of Temperature," ECOM-5571, August 1975.
8. Robbiani, Raymond L., "Tactical Field Demonstration of Mobile Weather Radar Set AN/TPS-41 at Fort Rucker, Alabama," ECOM-5572, August 1975.
9. Miers, B., G. Blackman, D. Langer, and N. Lorimier, "Analysis of SMS/GOES Film Data," ECOM-5573, September 1975.
10. Manquero, Carlos, Louis Duncan, and Rufus Bruce, "An Indication from Satellite Measurements of Atmospheric CO₂ Variability," ECOM-5574, September 1975.
11. Petracca, Carmine, and James D. Lindberg, "Installation and Operation of an Atmospheric Particulate Collector," ECOM-5575, September 1975.
12. Avara, Elton P., and George Alexander, "Empirical Investigation of Three Iterative Methods for Inverting the Radiative Transfer Equation," ECOM-5576, October 1975.
13. Alexander, George D., "A Digital Data Acquisition Interface for the SMS Direct Readout Ground Station - Concept and Preliminary Design," ECOM-5577, October 1975.
14. Cantor, Israel, "Enhancement of Point Source Thermal Radiation Under Clouds in a Nonattenuating Medium," ECOM-5578, October 1975.
15. Norton, Colburn, and Glenn Hoidale, "The Diurnal Variation of Mixing Height by Month over White Sands Missile Range, N.M.," ECOM-5579, November 1975.
16. Avara, Elton P., "On the Spectrum Analysis of Binary Data," ECOM-5580, November 1975.
17. Taylor, Fredrick J., Thomas H. Pries, and Chao-Huan Huang, "Optimal Wind Velocity Estimation," ECOM-5581, December 1975.
18. Avara, Elton P., "Some Effects of Autocorrelated and Cross-Correlated Noise on the Analysis of Variance," ECOM-5582, December 1975.
19. Gillespie, Patti S., R.L. Armstrong, and Kenneth O. White, "The Spectral Characteristics and Atmospheric CO₂ Absorption of the Ho³⁺ YLF Laser at 2.05 μ m," ECOM-5583, December 1975.
20. Novlan, David J., "An Empirical Method of Forecasting Thunderstorms for the White Sands Missile Range," ECOM-5584, February 1976.
21. Avara, Elton P., "Randomization Effects in Hypothesis Testing with Autocorrelated Noise," ECOM-5585, February 1976.
22. Watkins, Wendell R., "Improvements in Long Path Absorption Cell Measurement," ECOM-5586, March 1976.
23. Thomas, Joe, George D. Alexander, and Marvin Dubbin, "SATTEL - An Army Dedicated Meteorological Telemetry System," ECOM-5587, March 1976.
24. Kennedy, Bruce W., and Delbert Bynum, "Army User Test Program for the RDT&E-XM-75 Meteorological Rocket," ECOM-5588, April 1976.

25. Barnett, Kenneth M., "A Description of the Artillery Meteorological Comparisons at White Sands Missile Range, October 1974 - December 1974 ('PASS' - Prototype Artillery [Meteorological] Subsystem)," ECOM-5589, April 1976.
26. Miller, Walter B., "Preliminary Analysis of Fall-of-Shot From Project 'PASS'," ECOM-5590, April 1976.
27. Avara, Elton P., "Error Analysis of Minimum Information and Smith's Direct Methods for Inverting the Radiative Transfer Equation," ECOM-5591, April 1976.
28. Yee, Young P., James D. Horn, and George Alexander, "Synoptic Thermal Wind Calculations from Radiosonde Observations Over the Southwestern United States," ECOM-5592, May 1976.
29. Duncan, Louis D., and Mary Ann Seagraves, "Applications of Empirical Corrections to NOAA-4 VTPR Observations," ECOM-5593, May 1976.
30. Miers, Bruce T., and Steve Weaver, "Applications of Meteorological Satellite Data to Weather Sensitive Army Operations," ECOM-5594, May 1976.
31. Sharenow, Moses, "Redesign and Improvement of Balloon ML-566," ECOM-5595, June, 1976.
32. Hansen, Frank V., "The Depth of the Surface Boundary Layer," ECOM-5596, June 1976.
33. Pinnick, R.G., and E.B. Stenmark, "Response Calculations for a Commercial Light-Scattering Aerosol Counter," ECOM-5597, July 1976.
34. Mason, J., and G.B. Hoidale, "Visibility as an Estimator of Infrared Transmittance," ECOM-5598, July 1976.
35. Bruce, Rufus E., Louis D. Duncan, and Joseph H. Pierluissi, "Experimental Study of the Relationship Between Radiosonde Temperatures and Radiometric-Area Temperatures," ECOM-5599, August 1976.
36. Duncan, Louis D., "Stratospheric Wind Shear Computed from Satellite Thermal Sounder Measurements," ECOM-5800, September 1976.
37. Taylor, F., P. Mohan, P. Joseph and T. Pries, "An All Digital Automated Wind Measurement System," ECOM-5801, September 1976.
38. Bruce, Charles, "Development of Spectrophones for CW and Pulsed Radiation Sources," ECOM-5802, September 1976.
39. Duncan, Louis D., and Mary Ann Seagraves, "Another Method for Estimating Clear Column Radiances," ECOM-5803, October 1976.
40. Blanco, Abel J., and Larry E. Taylor, "Artillery Meteorological Analysis of Project Pass," ECOM-5804, October 1976.
41. Miller, Walter, and Bernard Engebos, "A Mathematical Structure for Refinement of Sound Ranging Estimates," ECOM-5805, November, 1976.
42. Gillespie, James B., and James D. Lindberg, "A Method to Obtain Diffuse Reflectance Measurements from 1.0 to 3.0 μ m Using a Cary 17I Spectrophotometer," ECOM-5806, November 1976.
43. Rubio, Roberto, and Robert O. Olsen, "A Study of the Effects of Temperature Variations on Radio Wave Absorption," ECOM-5807, November 1976.
44. Ballard, Harold N., "Temperature Measurements in the Stratosphere from Balloon-Borne Instrument Platforms, 1968-1975," ECOM-5808, December 1976.
45. Monahan, H.H., "An Approach to the Short-Range Prediction of Early Morning Radiation Fog," ECOM-5809, January 1977.
46. Engebos, Bernard Francis, "Introduction to Multiple State Multiple Action Decision Theory and Its Relation to Mixing Structures," ECOM-5810, January 1977.
47. Low, Richard D.H., "Effects of Cloud Particles on Remote Sensing from Space in the 10-Micrometer Infrared Region," ECOM-5811, January 1977.
48. Bonner, Robert S., and R. Newton, "Application of the AN/GVS-5 Laser Rangefinder to Cloud Base Height Measurements," ECOM-5812, February 1977.

49. Rubio, Roberto, "Lidar Detection of Subvisible Reentry Vehicle Erosive Atmospheric Material," ECOM-5813, March 1977.
50. Low, Richard D.H., and J.D. Horn, "Mesoscale Determination of Cloud-Top Height: Problems and Solutions," ECOM-5814, March 1977.
51. Duncan, Louis D., and Mary Ann Seagraves, "Evaluation of the NOAA-4 VTPR Thermal Winds for Nuclear Fallout Predictions," ECOM-5815, March 1977.
52. Randhawa, Jagir S., M. Izquierdo, Carlos McDonald and Zvi Salpeter, "Stratospheric Ozone Density as Measured by a Chemiluminescent Sensor During the Stratcom VI-A Flight," ECOM-5816, April 1977.
53. Rubio, Roberto, and Mike Izquierdo, "Measurements of Net Atmospheric Irradiance in the 0.7- to 2.8-Micrometer Infrared Region," ECOM-5817, May 1977.
54. Ballard, Harold N., Jose M. Serna, and Frank P. Hudson Consultant for Chemical Kinetics, "Calculation of Selected Atmospheric Composition Parameters for the Mid-Latitude, September Stratosphere," ECOM-5818, May 1977.
55. Mitchell, J.D., R.S. Sagar, and R.O. Olsen, "Positive Ions in the Middle Atmosphere During Sunrise Conditions," ECOM-5819, May 1977.
56. White, Kenneth O., Wendell R. Watkins, Stuart A. Schleusener, and Ronald L. Johnson, "Solid-State Laser Wavelength Identification Using a Reference Absorber," ECOM-5820, June 1977.

DISTRIBUTION LIST

Director
US Army Ballistic Research Laboratory
ATTN: DRDAR-BLB, Dr. G. E. Keller
Aberdeen Proving Ground, MD 21005

Air Force Weapons Laboratory
ATTN: Technical Library (SUL)
Kirtland AFB, NM 87117

Commander
Headquarters, Fort Huachuca
ATTN: Tech Ref Div
Fort Huachuca, AZ 85613

6585 TG/WE
Holloman AFB, NM 88330

Commandant
US Army Field Artillery School
ATTN: Morris Swett Tech Library
Fort Sill, OK 73503

Commandant
USAFAS
ATTN: ATSF-CD-MT (Mr. Farmer)
Fort Sill, OK 73503

Director
US Army Engr Waterways Exper Sta
ATTN: Library Branch
Vicksburg, MS 39180

Commander
US Army Electronics Command
ATTN: DRSEL-CT-S (Dr. Swingle)
Fort Monmouth, NJ 07703
03

CPT Hugh Albers, Exec Sec
Interdept Committee on Atmos Sci
Fed Council for Sci & Tech
National Sci Foundation
Washington, DC 20550

Inge Dirmhirn, Professor
Utah State University, UMC 48
Logan, UT 84322

HQDA (DAEN-RDM/Dr. De Percin)
Forrestal Bldg
Washington, DC 20314

Commander
US Army Aviation Center
ATTN: ATZQ-D-MA
Fort Rucker, AL 36362

CO, USA Foreign Sci & Tech Center
ATTN: DRXST-ISI
220 7th Street, NE
Charlottesville, VA 22901

Director
USAE Waterways Experiment Station
ATTN: Library
PO Box 631
Vicksburg, MS 39180

US Army Research Office
ATTN: DRXRO-IP
PO Box 12211
Research Triangle Park, NC 27709

Mr. William A. Main
USDA Forest Service
1407 S. Harrison Road
East Lansing, MI 48823

Library-R-51-Tech Reports
Environmental Research Labs
NOAA
Boulder, CO 80302

Commander
US Army Dugway Proving Ground
ATTN: MT-S
Dugway, UT 84022

HQ, ESD/DRI/S-22
Hanscom AFB
MA 01731

Head, Atmospheric Rsch Section
National Science Foundation
1800 G. Street, NW
Washington, DC 20550

Office, Asst Sec Army (R&D)
ATTN: Dep for Science & Tech
HQ, Department of the Army
Washington, DC 20310

Commander
US Army Satellite Comm Agc
ATTN: DRCPM-SC-3
Fort Monmouth, NJ 07703

Sylvania Elec Sys Western Div
ATTN: Technical Reports Library
PO Box 205
Mountain View, CA 94040

William Peterson
Research Association
Utah State University, UNC 48
Logan, UT 84322

Defense Communications Agency
Technical Library Center
Code 205
Washington, DC 20305

Dr. A. D. Belmont
Research Division
PO Box 1249
Control Data Corp
Minneapolis, MN 55440

Commander
US Army Electronics Command
ATTN: DRSEL-WL-D1
Fort Monmouth, NJ 07703

Commander
ATTN: DRSEL-VL-D
Fort Monmouth, NJ 07703

Meteorologist in Charge
Kwajalein Missile Range
PO Box 67
APO
San Francisco, CA 96555

The Library of Congress
ATTN: Exchange & Gift Div
Washington, DC 20540
2

US Army Liaison Office
MIT-Lincoln Lab, Library A-082
PO Box 73
Lexington, MA 02173

Dir National Security Agency
ATTN: TDL (C513)
Fort George G. Meade, MD 20755

Director, Systems R&D Service
Federal Aviation Administration
ATTN: ARD-54
2100 Second Street, SW
Washington, DC 20590

Commander
US Army Missile Command
ATTN: DRSMI-RRR, Bldg 7770
Redstone Arsenal, AL 35809

Dir of Dev & Engr
Defense Systems Div
ATTN: SAREA-DE-DDR
H. Tannenbaum
Edgewood Arsenal, APG, MD 21010

Naval Surface Weapons Center
Technical Library & Information
Services Division
White Oak, Silver Spring, MD
20910

Dr. Frank D. Eaton
PO Box 3038
Universtiy Station
Laramie, Wyoming 82071

Rome Air Development Center
ATTN: Documents Library
TILD (Bette Smith)
Griffiss Air Force Base, NY 13441

National Weather Service
National Meteorological Center
World Weather Bldg - 5200 Auth Rd
ATTN: Mr. Quiroz
Washington, DC 20233

USAFETAC/CB (Stop 825)
Scott AFB
IL 62225

Director
Defense Nuclear Agency
ATTN: Tech Library
Washington, DC 20305

Director
Development Center MCDEC
ATTN: Firepower Division
Quantico, VA 22134

Environmental Protection Agency
Meteorology Laboratory
Research Triangle Park, NC
27711

Commander
US Army Electronics Command
ATTN: DRSEL-GG-TD
Fort Monmouth, NJ 07703

Commander
US Army Ballistic Rsch Labs
ATTN: DRXBR-IB
APG, MD 21005

Dir, US Naval Research Lab
Code 5530
Washington, DC 20375

Mil Assistant for
Environmental Sciences
DAD (E & LS), 30129
The Pentagon
Washington, DC 20301

The Environmental Rsch
Institute of MI
ATTN: IRIA Library
PO Box 618
Ann Arbor, MI 48107

Armament Dev & Test Center
ADTC (DLOSL)
Eglin AFB, Florida 32542

Range Commanders Council
ATTN: Mr. Hixon
PMTC Code 3252
Pacific Missile Test Center
Point Mugu, CA 93042

Commander
Eustis Directorate
US Army Air Mobility R&D Lab
ATTN: Technical Library
Fort Eustis, VA 23604

Commander
Frankford Arsenal
ATTN: SARFA-FCD-0, Bldg 201-2
Bridge & Tarcony Sts
Philadelphia, PA 19137

Director, Naval Oceanography and
Meteorology
National Space Technology Laboratories
Bay St Louis, MS 39529

Commander
US Army Electronics Command
ATTN: DRSEL-CT-S
Fort Monmouth, NJ 07703

Commander
USA Cold Regions Test Center
ATTN: STECR-OP-PM
APO Seattle 98733

Redstone Scientific Information Center
ATTN: DRDMI-TBD
US Army Missile Res & Dev Command
Redstone Arsenal, AL 35809

Commander
AFWL/WE
Kirtland AFB, NM 87117

Naval Surface Weapons Center
Code DT-22 (Ms. Greeley)
Dahlgren, VA 22448

Commander
Naval Ocean Systems Center
ATTN: Research Library
San Diego, CA 92152

Commander
US Army INSCOM
ATTN: IARDA-OS
Arlington Hall Station
Arlington, VA 22212

Commandant
US Army Field Artillery School
ATTN: ATSF-CF-R
Fort Sill, OK 73503

Commander and Director
US Army Engineer Topographic Labs
ETL-GS-AC
Fort Belvoir, VA 22060

Technical Processes Br-D823
NOAA, Lib & Info Serv Div
6009 Executive Blvd
Rockville, MD 20852

Commander
US Army Missile Research
and Development Command
ATTN: DRDMI-CGA, B. W. Fowler
Redstone Arsenal, AL 35809

Commanding Officer
US Army Armament Rsch & Dev Com
ATTN: DRDAR-TSS #59
Dover, NJ 07801

Air Force Cambridge Rsch Labs
ATTN: LCB (A. S. Carten, Jr.)
Hanscom AFB
Bedford, MA 01731

National Center for Atmos Res
NCAR Library
PO Box 3000
Boulder, CO 80307

Air Force Geophysics Laboratory
ATTN: LYD
Hanscom AFB
Bedford, MA 01731

Chief, Atmospheric Sciences Division
Code ES-81
NASA
Marshall Space Flight Center, AL 35812

Department of the Air Force
OL-C, 5WW
Fort Monroe, VA 23651

Commander
US Army Missile Rsch & Dev Com
ATTN: DRDMI-TR
Redstone Arsenal, AL 35809

Meteorology Laboratory
AFGL/LY
Hanscom AFB, MA 01731

Director CFD
US Army Field Artillery School
ATTN: Met Division
Fort Sill, OK 73503

Naval Weapons Center (Code 3173)
ATTN: Dr. A. Shlanta
China Lake, CA 93555

Director
Atmospheric Physics & Chem Lab
Code R31, NOAA
Department of Commerce
Boulder, CO 80302

Department of the Air Force
5 WW/DN
Langley AFB, VA 23665

Commander
US Army Intelligence Center and School
ATTN: ATSI-CD-MD
Fort Huachuca, AZ 85613

Dr. John L. Walsh
Code 4109
Navy Research Lab
Washington, DC 20375

Director
US Army Armament Rsch & Dev Com
Chemical Systems Laboratory
ATTN: DRDAR-CLJ-I
Aberdeen Proving Ground, MD 21010

R. B. Girardo
Bureau of Reclamation
E&R Center, Code 1220
Denver Federal Center, Bldg 67
Denver, CO 80225

Commander
US Army Missile Command
ATTN: DRDMI-TEM
Redstone Arsenal, AL 35809

Commander
US Army Tropic Test Center
ATTN: STETC-MO (Tech Library)
APO New York 09827

Commanding Officer
Naval Research Laboratory
Code 2627
Washington, DC 20375

Defense Documentation Center
ATTN: DDC-TCA
Cameron Station (Bldg 5)
Alexandria, Virginia 22314
12

Commander
US Army Test and Evaluation Command
ATTN: Technical Library
White Sands Missile Range, NM 88002

US Army Nuclear Agency
ATTN: MONA-WE
Fort Belvoir, VA 22060

Commander
US Army Proving Ground
ATTN: Technical Library
Bldg 2100
Yuma, AZ 85364

Office, Asst Sec Army (R&D)
ATTN: Dep for Science & Tech
HQ, Department of the Army
Washington, DC 20310