

40-A089 262

CIVIL ENGINEERING LAB (NAVY) PORT HUENEME CA
SEA/LAKE WATER AIR CONDITIONING AT NAVAL FACILITIES.(U)
MAY 80 J B CIANI
CEL-TN-1577

F/G 13/1

UNCLASSIFIED

NL

[40]


AL 10/10/80



--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

END
DATE
FILMED
10-80
DTIC



MICROCOPY RESOLUTION TEST CHART
NATIONAL BUREAU OF STANDARDS-1963-A

AD A089262

LEVEL II

(12)

Technical Note

TN no. N-1577

title: SEA/LAKE WATER AIR CONDITIONING
AT NAVAL FACILITIES

author: J. B. Ciani

date: May 1980

sponsor: Naval Material Command

program nos: Z0829-01-133B

DTIC
ELECTE
SEP 18 1980

A



CIVIL ENGINEERING LABORATORY

NAVAL CONSTRUCTION BATTALION CENTER
Port Hueneme, California 93043

Approved for public release; distribution unlimited.

DC FILE COPY

80 9 18 061

-TN-

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER TN-1577	2. GOVT ACCESSION NO. DN787037	3. RECIPIENT'S CATALOG NUMBER AD-A089262
4. TITLE (and Subtitle) SEA/LAKE WATER AIR CONDITIONING AT NAVAL FACILITIES		5. TYPE OF REPORT & PERIOD COVERED Final; Oct 1978 - Dec 1979
		6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) J. B. Ciani	8. CONTRACT OR GRANT NUMBER(s) /	
9. PERFORMING ORGANIZATION NAME AND ADDRESS CIVIL ENGINEERING LABORATORY Naval Construction Battalion Center Port Hueneme, California 93043		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 63724N; Z0829-01-133B
11. CONTROLLING OFFICE NAME AND ADDRESS Naval Material Command Washington, DC 20360		12. REPORT DATE May 1980
		13. NUMBER OF PAGES 19
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office) 9) FI. 1. Y. + 78- 4/5		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Seawater cooling, sea/lake water air conditioning.		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) The sea/lake water air conditioning (AC) work at CEL and related efforts by others are summarized, along with annotated references. Computer models for estimating the capital costs and energy use for sea/lake water air conditioning (AC) systems are introduced, and the output from these models exercised on two Naval facilities are presented. It was found that (1) the computer models produced reasonable estimates of the capital cost and (continued)		

DD FORM 1 JAN 73 1473 EDITION OF 1 NOV 65 IS OBSOLETE

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

20. Continued

energy use of seawater AC systems; (2) the capital cost and energy use of such systems are sensitive to the pipeline length, which is dependent on the seawater temperature near the seafloor; (3) at a hypothetical typical Naval facility represented by the average of the two trial facilities, seawater AC requires 80% less energy than conventional AC, but the capital cost of seawater AC is 60% greater; and (4) at this typical facility the life cycle cost for seawater AC is 25% less than that of conventional AC. Sea/lake water AC is recommended for consideration as an alternative to conventional AC at Naval facilities that adjoin bodies of water, and it is also recommended that the computer models be used to make estimates of the capital cost and energy use of sea or lake water AC systems.

Library Card

Civil Engineering Laboratory
SEA/LAKE WATER AIR CONDITIONING AT NAVAL
FACILITIES (Final), by J. B. Ciani
TN-1577 19 pp illus May 1980 Unclassified

1. Energy conservation 2. Air conditioning 1. Z0829-01-133B


The sea/lake water air conditioning (AC) work at CEL and related efforts by others are summarized, along with annotated references. Computer models for estimating the capital costs and energy use for sea/lake water air conditioning (AC) systems are introduced, and the output from these models exercised on two Naval facilities are presented. It was found that (1) the computer models produced reasonable estimates of the capital cost and energy use of seawater AC systems; (2) the capital cost and energy use of such systems are sensitive to the pipeline length, which is dependent on the seawater temperature near the seafloor; (3) at a hypothetical typical Naval facility represented by the average of the two trial facilities, seawater AC requires 80% less energy than conventional AC, but the capital cost of seawater AC is 60% greater; and (4) at this typical facility the life cycle cost for seawater AC is 25% less than that of conventional AC. Sea/lake water AC is recommended for consideration as an alternative to conventional AC at Naval facilities that adjoin bodies of water, and it is also recommended that the computer models be used to make estimates of the capital cost and energy use of sea or lake water AC systems.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

CONTENTS

	Page
INTRODUCTION	1
SEA/LAKE WATER AC INVESTIGATIONS	1
ECONOMICS AT TWO FACILITIES	2
Facilities	2
Computer Models	2
Sensitivity	3
Capital Costs and Energy Use	3
Life Cycle Costs	3
FINDINGS	4
RECOMMENDATIONS	4
ACKNOWLEDGMENTS	4
REFERENCES (ANNOTATED)	5



INTRODUCTION

While the demand for air conditioning (AC) at Naval facilities has stabilized, the cost of power has grown tremendously in recent years, and the availability of power plant fuel from the traditional domestic sources has declined sharply. Therefore, alternatives to the high power consuming AC systems are being sought. The Civil Engineering Laboratory (CEL) under the sponsorship of the Naval Material Command and the Naval Facilities Engineering Command has investigated the use of naturally cold sea or lake water as an alternative cooling and dehumidification medium for Naval facilities.

This report provides: (1) a summary of the work accomplished by CEL on sea/lake water AC for Naval facilities; (2) a description of the computer models developed to estimate the capital cost and energy use of such AC; (3) the results obtained by applying these models to two Naval facilities (Pacific Missile Test Center (PMTTC) Point Mugu, Calif., and Naval Shipyard (NSY) Pearl Harbor, Hawaii); (4) the results of an analysis to determine the sensitivity of capital cost and energy use of seawater AC at these facilities to the seawater intake location and water temperature; and (5) the life cycle cost (LCC) of such AC systems compared to the LCC of conventional AC.

SEA/LAKE WATER AC INVESTIGATIONS

At CEL the development effort on sea/lake water AC for Naval facilities included an assessment of the feasibility of sea/lake water cooling, the design of an operational test at Naval Security Group Activity (NSGA) Winter Harbor, Me., and the economics of Navywide application.

In FY76 an assessment of the feasibility of seawater cooling for Naval facilities was made. It was found that there is potential for cost and energy savings with this type of AC (Ref 1). The design of an operational test system for NSGA followed. Surveys there found that a small (84 tons refrigeration (TR)) seawater cooling system could be installed and operated at this facility at a lower LLC than a conventional AC system, but the control of biofouling in such a seawater cooling system at this site posed a problem that needed solving before implementation could be made (Ref 2 through 8). Assessments of the economics of Navywide application of sea/lake water AC indicated that cost and energy savings at the sites of some Naval facilities are possible, depending on the temperature in the adjoining water bodies, but that biofouling control and required maintenance remain risk issues (Ref 9 through 12).

CEL has not been alone in examining the use of natural waters for AC. In related work, AC with seawater off Florida, California, or Hawaii, or lake water from Lake Michigan, or well water in New Jersey has been found technically and economically feasible and can save energy (Ref 13 through 18).

ECONOMICS AT TWO FACILITIES

Facilities

In FY78, several sites of Naval facilities were identified as having high potential for the cost-effective application of sea/lake water AC (Ref 9). These findings were based on estimates of the energy demand at Naval facilities at these sites and the temperature of the sea or lake water in the adjoining water bodies. In FY79, water temperature measurements were made at two of these sites, Pearl Harbor and Point Mugu, which were determined to have the highest potential among the sites (Ref 12). The choice of specific Naval facilities at these two sites - the Naval Shipyard (NSY) Pearl Harbor and the Pacific Missile Test Center (PMTTC) Point Mugu - was based on proximity to the cold water source and requirement for AC.

Comfort cooling is the primary reason for AC at NSY, where three buildings were selected for evaluation (Bldg 1, Bldg 3A, and Bldg 214). The required AC of these buildings is 192 TR, 138 TR, and 205 TR, respectively. Cooling for computers is the primary reason for AC at PMTTC where three buildings (Bldg 761, Bldg 50, and Bldg 53) require AC of 465 TR, 255 TR, and 374 TR, respectively. The locations of these buildings are shown in Figures 1 and 2.

Estimates were made of the capital costs and energy use of seawater AC at these two facilities using computer models. These estimates compared well with the preliminary estimates given in Reference 9.

Computer Models

Mathematical models were developed for estimating the capital costs and energy usage in sea or lake water AC systems. The following models were developed to make these estimates:

1. Cold Water Supply Model - two computer programs were required, one for the offshore portion of the system (program IA) and one for the onshore portion (program IB) (Ref 10).
2. AC Equipment Model - only one computer program (program II) was required (Ref 11).

These programs were written such that the amount of site data and preliminary design assumptions required for input to the programs could be varied, depending on the level of detail in the available data and the level of expertise of the program operators in AC system and pipeline design. As a minimum, the data required for input to these programs are: (1) the temperature/distance from shore profile data for program IA, (2) estimates of land pipe inside diameter and length of sections for program IB, and (3) location and building parameters for program II. Of the three types of data required, item (2) can be easily estimated by anyone with a basic knowledge of pipeline design, and item (3) can be obtained from several commonly available handbooks. However, item (1) is not as readily available because it is based on water temperature data at the site for the time of the year when the water is warmest. Consequently, a special water temperature survey would probably be required at any specific site.

The site data and design assumptions made in these programs are given in References 10 and 11. It is notable that these design assumptions allow for only one intake pipeline for the cold water supply. Therefore, the computer-generated capital cost estimates for cold water supply must be modified in order to use a two-intake pipeline system. Such a system, which was referred to as three-pipe (inlet-outlet-standby), was recommended by Reference 8. Other biofouling control recommendations given in Reference 8 are fully covered in the computer models. The capital cost estimates made for PMTC and NSY were modified to account for two intake pipelines at these facilities.

Sensitivity

The capital cost and energy use sensitivity of seawater AC to the distance of the seawater intake location from shore and to the intake water temperature is shown in Table 1.* Cost and use data were taken from the output of runs of the computer programs for the two trial facilities.

It is seen from the estimates given in Table 1 that (1) the capital cost is sensitive to the pipeline length which is dependent on the seawater temperature near the seafloor and the distance of the intake from shore, (2) the energy use is also dependent on this distance and temperature, and (3) the ability of any site to support seawater AC depends on the temperature of the seawater at the intake.**

Capital Costs and Energy Use

Table 2 presents the capital costs and energy use of seawater AC at the two trial facilities based on two intake pipelines at a single location at each - PMTC II and NSY III (see Table 1). Similar capital costs and energy use figures are also given in this table for conventional AC. Averages of the estimates of capital costs and energy use for these two facilities are also given and taken to represent values for a hypothetically typical Naval facility. The figures in Table 2 are based on three buildings at each trial facility with a total of 1094 TR at PMTC and 535 TR at NSY. 815 TR for three buildings at a "typical" Naval facility is an average of those of the trial facilities.

By way of a check on how typical the cooling load average is, the AC requirements given in Reference 9 for four sites (Apra Harbor, Guam; Pearl Harbor, Hawaii; Chicago, Ill.; and Point Mugu, Calif.) of Naval facilities (19 facilities) were averaged and found to be 849 TR, which compares favorably with 815 TR.

Life Cycle Costs

The LCC of seawater and conventional AC at the typical Naval facility based on the computer output are given in Table 3 along with the differential LCC (i.e., conventional AC LCC minus seawater AC LCC). The

*Intake locations are designated by I, II, or III.

**With the intake seawater temperature values given in Table 1, it appears that 50°F is an upper limit for sea/lake water AC.

estimates of the capital cost of biofouling control equipment and annual maintenance costs included in this LCC are based on the estimates given in Reference 2 for NSGA Winter Harbor and corrected for the much larger AC tonnage at the typical Naval facility.

The sensitivity of the total LCC to a 100% increase in the estimated cost of biofouling control equipment and a 100% increase in the estimated annual cost of operation and maintenance (not including electricity) is only 15%. Consequently, there appears to be little need to improve these estimates.

FINDINGS

1. The computer models described in this report provided reasonable estimates of the capital cost and energy use of seawater AC systems at Point Mugu and Pearl Harbor.
2. The capital cost and energy use of seawater AC systems for the trial facilities are sensitive to the pipeline length, which is dependent on the seawater temperature near the seafloor versus the distance from shore at the sites.
3. At Point Mugu, seawater AC would use 80% less energy than conventional AC; at NSY Pearl Harbor, 70% less. The capital cost of seawater AC at PMTC is about equal to that of conventional AC, but at NSY the capital cost of seawater AC is three times greater than conventional AC. Therefore, though substantial energy savings are possible at both trial facilities, the capital cost of seawater AC is at least as much as conventional AC.
4. At a hypothetical typical Navy facility, seawater AC will use 80% less energy than conventional AC, but the capital cost of sea/lake water AC is 60% greater. The LCC of seawater AC at a typical Naval facility is 25% lower than the LCC of conventional AC.

RECOMMENDATIONS

1. Sea/lake water AC should be considered as an energy and LCC saving alternative to conventional AC at Naval facilities which adjoin bodies of water.
2. The computer models introduced in this report should be used to make estimates of the capital cost and energy use of sea or lake water AC systems.
3. No further research and development on sea/lake water AC is recommended.

ACKNOWLEDGMENTS

The author wishes to thank Robert Okazaki of the Public Works Office at the Naval Shipyard Pearl Harbor and Robert Owens of the Pacific Missile Test Center Point Mugu for information on their respective Naval

facilities and AC requirements there. Thanks are also in order to Nathan Shoemaker of the Civil Engineering Laboratory for his help in running the sea/lake water AC models.

REFERENCES (ANNOTATED)

1. Civil Engineering Laboratory. Technical Memorandum M-44-76-10: Seawater cooling for Naval facilities, by J. B. Ciani and A. W. McClaine. Port Hueneme, Calif., Aug 1976.

This feasibility assessment of seawater cooling showed that this type of air conditioning has potential for cost and energy savings at Naval facilities.

2. _____. Contract Report 78.008: A preliminary design, economic and energy analysis, and environmental impact assessment for a seawater cooling project, Naval Security Group Facilities at Winter Harbor, Maine, final report. Port Everglades, Fla., Tracor Marine, Mar 1977. (Contract No. N68305-77-C-0012)

This report provides tentative design, analysis, and specifications for a seawater cooling (AC) system which is the first of its kind.

3. _____. A review and analysis of the economic life cycle cost analysis of the final report by Tracor Marine on the seawater cooling project Naval Security Group Facilities at Winter Harbor, Maine. Laguna Beach, Calif., Malcolm Lewis Associates, Sep 1977. (Contract No. N62583-77-M-R632)

This report reviewed the economic analysis of Reference 2 and found that although the analysis technique used by Tracor is not strictly correct, it is true that for this facility the life cycle costs of seawater cooling are lower than those for conventional AC.

4. Naval Facilities Engineering Command, Northern Division. Energy and economic analysis of the heating, ventilating, and air conditioning systems and modifications to the systems to make them more energy efficient at Navy operations Building #153 Naval Security Group Activity, Winter Harbor, (Corea) Maine, by M. Flanders and C. Braley. Bangor, Me., Webster, Ebbeson, Baldwin and Day, Architects, Sep 1977. (Contract No. N62472-76-C-1101)

This investigation of the AC systems at NSGA Winter Harbor and six modifications, of which seawater cooling is one, to these systems to make them more energy efficient found that none of the modifications are economically justified but that (1) the life cycle cost of the seawater cooling system is much less than that of the existing systems or any of the modifications, (2) in a new building at Winter Harbor seawater cooling would be more economical than conventional AC, and (3) in a building with a much larger cooling load than that at NSGA Winter Harbor the installation of a seawater cooling system might be justified even if there exists a working AC system.

5. Civil Engineering Laboratory. Contract Report 78.009: Supplements no. 1 and no. 2 to a preliminary design, economic and energy analysis, and environmental impact assessment for a seawater cooling project, Naval Security Group Facilities at Winter Harbor, Maine (CR 78.008), Supplement no. 1: Bottom temperature measurements in Prospect Harbor, Supplement no. 2: Biofouling and its prevention in Prospect Harbor. Port Everglades, Fla., Tracor Marine, Nov 1977. (Contract No. N68305-77-C-0012)

Supplement 1 reports on the measurement of the temperature of the seawater near the bottom of the bay that adjoins Winter Harbor and found that the bottom water temperature is such that it will support seawater cooling at NSGA Winter Harbor through nine months of the year but that AC enhancement is required during the three warmest months.

Supplement 2 reports on biofouling in a seawater cooling system at Winter Harbor (Ref 5, Supplement no. 2) which concluded that such a system must cope with a serious biofouling problem whose most economical solution is a seawater well sunk into the bottom sediments or an infiltration gallery on the seafloor whose surface is cleaned by wave action provided such a well or gallery can support the required flow (permeability).

6. _____. Report of inspection and pipeline route survey (including land and offshore portions) for a seawater cooling project Naval Security Group Facilities Winter Harbor, Maine. Port Everglade, Fla., Tracor Marine, Nov 1977. (Contract No. N62583/77 M R620 and N62583/77 M R734)

This is a report of the selection/survey of the seawater intake pipeline route on land and on the seafloor which selected and inspected the route, measured the topography and bathymetry, probed the sediment, and took cores.

7. _____. Feasibility study and preliminary design for an offshore seawater intake well and/or infiltration gallery/bed for a seawater cooling system USNSGA, Corea, Maine. Port Everglades, Fla., Tracor Marine, May 1979. (Contract No. N62583-79-M-R290)

This report assesses the feasibility of a seawater well or an infiltration gallery for the intake of seawater for cooling at NSGA Winter Harbor (Ref 7) and concludes that such a well or gallery is not practical at this site but may be useful for seawater cooling systems elsewhere.

8. _____. Technical Memorandum M-52-79-03: Possible methods for the control of fouling of seawater cooling systems, by T. Roe, Jr. Port Hueneme, Calif., Jul 1979.

This report discusses biofouling control methods for seawater cooling systems and identifies twelve such methods; the advantages and disadvantages of each are given. This report recommended that:

- (1) The heat exchangers for a seawater cooling system be made of 90:10 copper nickel alloy

- (2) A three-pipe, inlet-outlet-standby system (two intakes and one outlet) be used for influent and effluent
- (3) Rigid thermoplastics or glass reinforced thermosetting pipe be used for the offshore pipelines

9. _____. Technical Note N-1528: Sea/lake water cooling for Naval facilities, by J. B. Ciani. Port Hueneme, Calif., Sep 1978.

This report assesses the Navywide potential of sea or lake water AC and found that \$3 million per year could be saved if this new type of AC were in operation at Naval facilities at 25 sites. These include four sites (Apra Harbor, Guam; Pearl Harbor, Hawaii; Chicago, Ill.; and Point Mugu, Calif.) where \$1 million per year could be saved.

10. _____. A computer model for estimating costs and energy usage for air conditioning systems using natural cold water, final report. Port Everglades, Fla., Tracor Marine, Mar 1979. (Contract No. N62583-78-M-R683)

This report describes a computer model for cold water supply to sea/lake water cooling (AC) systems. This model provides a set of computer programs that can be used to estimate the capital cost of a single intake and the energy required to supply sea or lake water to such an AC system at any facility. Another output of this program is the temperature of the water delivered to the sea/lake water cooling equipment on shore.

11. _____. A computer assisted model for estimating offshore and onshore water supply costs and energy usage for facilities using natural cold water to directly air condition buildings, final report. Port Everglades, Fla., Tracor Marine, Apr 1979. (Contract No. N62583-78-M-R406)

This report describes a computer model for air conditioning by sea/lake water cooling systems which provides a computer program that can be used to estimate the capital cost and energy required to air condition a single building using sea or lake water. An input to this program is the temperature of the water supplied to sea/lake water cooling systems (an output of the cooling water supply model above).

12. _____. Contract Report CR 79.001: Bathythermographic surveys near Naval facilities at Point Mugu, California and Pearl Harbor, Hawaii. La Jolla, Calif., Intersea Research Corporation, May 1979. (Contract No. N68305-78-C-0018)

This report describes the techniques and results of bathythermographic surveys performed at Point Mugu, Calif., and Pearl Harbor, Hawaii, which used existing water temperature data and the measured data to estimate profiles of maximum annual temperatures. These profiles showed that (a) at Point Mugu the maximum annual bottom water temperature can be expected in November at 50°F, 620 feet deep, 1.4 NM offshore and (b) at Pearl Harbor this temperature can be expected in February at 50°F, 1,380 feet deep, 4.0 NM offshore.

13. R. D. Gerard and O. H. Roels. "Deep Ocean Water as a Resource," Marine Technology Society Journal, vol 4, no. 5, Sep-Oct 1970, pp 69-79.

This report suggested the use of seawater off Florida, California, and Hawaii for AC at these sites.

14. Energy Research and Development Administration. Feasibility of a direct seawater cooling system utilizing cold seawater, by J. Hirshman, D. A. Whithaus, and I. H. Brooks. Port Everglades, Fla., Tracor Marine, Jun 1975. (ERDA Contract No. A.T.-(40-1)-4875)

This report presented a study of the feasibility of seawater cooling and concluded that seawater cooling is technically feasible and can result in AC energy savings of over 70%. This study also concluded that Honolulu, Hawaii, and Miami/Ft. Lauderdale, Fla., are sites which are suitable for concept development.

15. _____. District heating and cooling utilizing temperature differences of local waters, by W. Harrison, A. A. Frigo, G. T. Kartsounes, D. J. Santini, S. J. LaBelle, and F. H. Davis. Argonne, Ill., Argonne National Laboratory, May 1977. (ERDA Contract ANL/WR-77-1)

Harrison et al. investigated the use of cold water from Lake Michigan and heated water effluent from a power plant onshore with a heat pump system to provide cooling and heating in Chicago. They concluded that such a system was technically and economically feasible.

16. _____. Feasibility of a direct cooling system using natural cold waters, by J. Hirshman and R. H. Kirklin. Port Everglades, Fla., Tracor Marine, Aug 1977. (ERDA Report No. OMO-4875-B)

This study and preliminary design is of a seawater cooling system for Miami Beach which concluded that such a system is far more economically attractive than conventional AC. These authors also considered the use of naturally cold fresh water in the United States for AC. They concluded that the water in the Great Lakes has potential for direct cooling, the ground water in the northern and mountain states also has potential, but that in the southern states is unsuitable, and river water is likewise unsuitable except summer-melt water from streams near large mountains.

17. Naval Air Engineering Center. Study to determine the feasibility of using well water for air conditioning cooling, by J. C. Morris, Jr. Atlantic Highlands, N.J., John C. Morris Associates, Oct 1978. (Contract N62472-78-C-4947)

This study of the potential use of domestic well water to reduce energy consumption in the air conditioning systems in five buildings at Lakehurst concluded that this use is practical in two of the buildings but impractical in the other three.

18. B. E. Liebert, L. R. Berger, H. J. White, J. Moore, W. McCoy, J. A. Berger, and J. Larsen-Basse. "The effects of biofouling and corrosion on heat transfer measurements," Sixth OTEC Conference, 19-22 Jun 1979, Washington, D.C.

This paper presents data from measurements of the amount and rate of biofouling in test sections of heat exchanger tubes like those of the planned Ocean Thermal Energy Conversion (OTEC) system, a system with many of the same biofouling problems as seawater cooling systems. Mechanical cleaning with a spinning brush was found to reduce biofouling in these tube sections. This work will continue in OTEC experiments and may lead to a biofouling control system which can be applied to sea/lake water AC systems.

Table 1. Sensitivity Analysis

Pipeline Location	Intake		Total Capital Cost ^a (\$ Million)	Energy Use MBtu/yr TR
	Seawater Temperature (°F)	Distance From Shore (ft x 10 ³)		
PBTC I	49.1	8	1.8	1.7
PBTC II	47.3	11	2.1	1.6
PBTC III	45.1	16	2.6	1.7
NSY I	58.6	17	b	b
NSY II	54.1	20	b	b
NSY III	50.4	24	3.2	2.5

^aFiscal Year 1979.

^bThe temperature of the seawater reaching the buildings that require AC is not low enough to maintain design room conditions.

Table 2. Capital Costs and Energy Use

Item	Capital Costs in FY79 (\$ Million)			Energy Use (MBtu/yr x 10 ³)		
	Point Mugu	Pearl Harbor	Typical ^a Naval Facility	Point Mugu	Pearl Harbor	Typical ^a Naval Facility
Seawater AC	2.1	3.2	2.7	1.7	1.3	1.5
Conventional AC	2.2	1.1	1.7	9.3	4.6	7.0
Savings ^b	0.1	-2.1	1.0	7.2	3.3	5.5

^a"Typical" in this context is intended to mean typical for Naval facilities where sea/lake water AC has high potential.

^bSavings = conventional AC - seawater AC.

Table 3. Life Cycle Costs

Cost Basis at Typical Naval Facility	Life Cycle Cost (\$ x 10 ³ /MBtu)	
	Seawater AC	Conventional AC
AC Equipment	21	167
Cold Water Supply System	224	0
Biofouling Control Equipment ^a	<u>24</u>	<u>0</u>
Total Capital Contribution	269	167
O&M Costs ^b	39	2
Electricity Costs ^c	<u>75</u>	<u>343</u>
Total O&M Contribution	114	345
Total LCC (Capital and O&M)	383	512
Differential Life Cycle Cost	129	

^a Assumed to be 10% of the total system (AC plus cold water supply).

^b Not including electricity.

^c Per year cost - rather than life cycle cost.




Figure 1. Pacific Missile Test Center, Point Mugu, Calif.




Figure 2. Naval Shipyard, Pearl Harbor, Hawaii.

DISTRIBUTION LIST

AAP NAVORDSTA IND HD DET PW ENGRNG DIV. McAlester. OK
 AFB (AFIT/LD), Wright-Patterson OH: ABG/DEE (F. Nethers), Goodfellow AFB TX: AF Tech Office (Mgt & Ops), Tyndall, FL: AFCEC/XR, Tyndall FL: AUL/LSE 63-465, Maxwell AL: CESCH, Wright-Patterson; HQ Tactical Air Cmd (R. E. Fisher), Langley AFB VA: MAC/DET (Col. P. Thompson) Scott, IL: SAMSO MNND, Norton AFB CA: Samsco, Vandenburg, AFB, CA: Stinfo Library, Offutt NE
 ARMY BMDSC-RE (H. McClellan) Huntsville AL: DAEN-CWE-M (LT C D Binning), Washington DC: DAEN-MPE-D Washington DC: DAEN-MPU, Washington DC: ERADCOM Tech Supp Dir. (DELS-D-L) Ft. Monmouth, NJ: Engr District (Memphis) Library, Memphis TN: Natick Cen (Kwoh Hu) Natick MA: Tech. Ref. Div., Fort Huachuca, AZ
 ARMY - CERL Library, Champaign IL
 ARMY AMMUNITION PLANT Sarhw - FEM Hawthorne, NY
 ARMY CORPS OF ENGINEERS MRD-Eng. Div., Omaha NE: Seattle Dist. Library, Seattle WA
 ARMY CRREL G. Phetteplace Hanover, NH
 ARMY DARCOM AMCPM-CS (J. Carr), Alexandria VA
 ARMY ENG DIV HNDED-CS, Huntsville AL: HNDED-SR, Huntsville, AL
 ARMY ENGR DIST. Library, Portland OR
 ARMY ENVIRON. HYGIENE AGCY Water Qual Div (Doner), Aberdeen Prov Ground, MD
 ARMY MATERIALS & MECHANICS RESEARCH CENTER Dr. Lenoe, Watertown MA
 ARMY MISSILE R&D CMD Redstone Arsenal AL Sci. Info. Cen (Documents)
 ASO PWD (ENS J.A. Jenkins), Philadelphia, PA
 ASST SECRETARY OF THE NAVY Spec. Assist Energy (Leonard), Washington, DC
 BUREAU OF RECLAMATION Code 1512 (C. Selander) Denver CO
 CINCLANT Civil Engr. Supp. Plans. Ofc Norfolk, VA
 CNAVRES Code 13 (Dir. Facilities) New Orleans, LA
 CNM Code MAT-08T3, Washington, DC
 CNO Code NOP-964, Washington DC; Code OP 987 Washington DC; Code OP-413 Wash, DC; Code OPNAV 09B24 (H); OP987J (J. Boosman), Pentagon
 COMFLEACT, OKINAWA PWO, Kadena, Okinawa
 COMNAVAMARIANAS Code N4, Guam
 COMOCEANSYSPAC SCE, Pearl Harbor HI
 COMSUBDEVGRUONE Operations Offr. San Diego, CA
 DEFENSE CIVIL PREPAREDNESS AGENCY J.O. Buchanan, Washington DC
 DEFENSE DOCUMENTATION CTR Alexandria, VA
 DOD Staff Spec. Chem. Tech. Washington DC
 DOE F.F. Parry, Washington DC; INEL Tech. Lib. (Reports Section), Idaho Falls, ID; Liffick, Richmond, WA: P. Jordan Washington, DC
 DTNSRDC Code 4111 (R. Gierich), Bethesda MD; Code 42, Bethesda MD
 DTNSRDC Code 522 (Library), Annapolis MD
 ENVIRONMENTAL PROTECTION AGENCY Reg. VIII, 8M-ASL, Denver CO
 FLTCOMBATTRACENLANT PWO, Virginia Bch VA
 GSA Fed. Sup. Serv. (FMBP), Washington DC; Office of Const. Mgmt (M. Whitley), Washington DC
 KWAJALEIN MISLAN BMDSC-RKL-C
 MARINE CORPS BASE Camp Pendleton CA 92055; Code 43-260, Camp Lejeune NC: M & R Division, Camp Lejeune NC; PWO Camp Lejeune NC; PWO, Camp S. D. Butler, Kawasaki Japan
 MARINE CORPS HQS Code LFF-2, Washington DC
 MCAS Facil. Engr. Div. Cherry Point NC; CO, Kaneohe Bay HI; Code PWE, Kaneohe Bay HI; Code S4, Quantico VA; PWD, Dir. Maint. Control Div., Iwakuni Japan; PWO Kaneohe Bay HI; PWO, Yuma AZ; SCE, Futema Japan
 MCDEC NSAP REP, Quantico VA
 MCLSBPAC B520, Barstow CA; PWO, Barstow CA
 MCRD PWO, San Diego Ca
 NAF PWD - Engr Div. Atsugi, Japan; PWO Sigonella Sicily; PWO, Atsugi Japan
 NALF OINC, San Diego, CA
 NARF Code 100, Cherry Point, NC; Code 612, Jax, FL

NAS CO, Guantanamo Bay Cuba; Code 114, Alameda CA; Code 183 (Fac. Plan BR MGR); Code 187,
 Jacksonville FL; Code 18700, Brunswick ME; Code 18U (ENS P.J. Hickey), Corpus Christi TX; Code 6234
 (G. Trask), Point Mugu CA; Code 70, Atlanta, Marietta GA; Code 8E, Patuxent Riv., MD; Dir. Util. Div.,
 Bermuda; ENS Buchholz, Pensacola, FL; Lakehurst, NJ; Lead. Chief. Petty Offr. PW/Self Help Div.,
 Beeville TX; PW (J. Maguire), Corpus Christi TX; PWD Maint. Cont. Dir., Fallon NV; PWD Maint. Div.,
 New Orleans, Belle Chasse LA; PWD, Maintenance Control Dir., Bermuda; PWD, Willow Grove PA; PWO
 Belle Chasse, LA; PWO Chase Field Beeville, TX; PWO Key West FL; PWO Whiting Fld, Milton FL; PWO,
 Dallas TX; PWO, Glenview IL; PWO, Kingsville TX; PWO, Millington TN; PWO, Miramar, San Diego CA;
 PWO., Moffett Field CA; ROICC Key West FL; SCE Lant Fleet Norfolk, VA; SCE Norfolk, VA; SCE,
 Barbers Point HI; Security Offr, Alameda CA
 NATL RESEARCH COUNCIL Naval Studies Board, Washington DC
 NATNAVMEDCEN PWO Bethesda, MD
 NAVACT PWO, London UK
 NAVACTDET PWO, Holy Lock UK
 NAVAEROSPREGMEDCEN SCE, Pensacola FL
 NAVCOASTSYSTCTR CO, Panama City FL; Code 423 (D. Good), Panama City FL; Code 713 (J. Quirk)
 Panama City, FL; Library Panama City, FL
 NAVCOMMAREAMSTRSTA PWO, Norfolk VA; PWO, Wahiawa HI; SCE Unit 1 Naples Italy
 NAVCOMMSTA CO (61E) Puerto Rico; Code 401 Nea Makri, Greece; PWO, Exmouth, Australia; PWO, Fort
 Amador Canal Zone
 NAVEDTRAPRODEVCE Tech. Library
 NAVEDUTRACEN Engr Dept (Code 42) Newport, RI
 NAVENVIRHLTHCEN CO, Alexandria, VA
 NAVFAC PWO, Brawdy Wales UK; PWO, Cape Hatteras, Buxton NC; PWO, Centerville Bch, Ferndale CA;
 PWO, Guam
 NAVFAC PWO, Lewes DE
 NAVFACENGCOM Code 043 Alexandria, VA; Code 044 Alexandria, VA; Code 0451 Alexandria, VA; Code
 0454B Alexandria, VA; Code 046; Code 0461D (V M Spaulding) Alexandria, VA; Code 04B3 Alexandria,
 VA; Code 081B Alexandria, VA; Code 100 Alexandria, VA; Code 1023 (T. D. Stevens), Alexandria VA;
 Code 1113 (M. Carr) Alexandria, VA; Code 1113 (T. Stevens) Alexandria, VA; Morrison Yap, Caroline Is.
 NAVFACENGCOM - CHES DIV. Code 101 Wash, DC; Code 102, (Wildman), Wash, DC; Code 403 (H.
 DeVoe) Wash, DC; Code FPO-1 Wash, DC
 NAVFACENGCOM - LANT DIV. CDR E. Peltier; Code 10A, Norfolk VA; Code 111, Norfolk, VA; Eur. BR
 Deputy Dir. Naples Italy; European Branch, New York; RDT&ELO 102, Norfolk VA
 NAVFACENGCOM - NORTH DIV. AROICC, Brooklyn NY; CO; Code 09P (LCDR A.J. Stewart); Code
 1028, RDT&ELO, Philadelphia PA; Code 111 (Castranovo) Philadelphia, PA; Design Div. (R. Masino),
 Philadelphia PA; ROICC, Contracts, Crane IN
 NAVFACENGCOM - PAC DIV. (Kyi) Code 101, Pearl Harbor, HI; Code 402, RDT&E, Pearl Harbor HI;
 Commander, Pearl Harbor, HI
 NAVFACENGCOM - SOUTH DIV. Code 90, RDT&ELO, Charleston SC
 NAVFACENGCOM - WEST DIV. 102; 112; AROICC, Contracts, Twentynine Palms CA; Code 04B San
 Bruno, CA; 09P/20 San Bruno, CA; RDT&ELO Code 2011 San Bruno, CA
 NAVFACENGCOM CONTRACT AROICC, Quantico, VA; Code 05, TRIDENT, Bremerton WA; Code 09E,
 TRIDENT, Bremerton WA; Dir. Eng. Div., Exmouth, Australia; Eng Div dir, Southwest Pac, Manila, PI;
 Engr. Div. (F. Hein), Madrid, Spain; OICC (Knowlton), Kaneohe, HI; OICC, Southwest Pac, Manila, PI;
 OICC/ROICC, Balboa Canal Zone; ROICC AF Guam; ROICC, Keflavik, Iceland; ROICC, Pacific, San
 Bruno CA
 NAVHOSP LT R. Elsbernd, Puerto Rico
 NAVMAG SCE, Guam
 NAVNUPWRU MUSE DET Code NPU-30 Port Hueneme, CA
 NAVOCEANSYSCEN Code 31 San Diego, CA; Code 41, San Diego, CA; Code 523 (Hurley), San Diego, CA;
 Code 6700, San Diego, CA; Code 811 San Diego, CA; Research Lib., San Diego CA; Tech. Library, Code
 447
 NAVORDSTA PWO, Louisville KY
 NAVPETOFF Code 30, Alexandria VA
 NAVPETRES Director, Washington DC
 NAVPHIBASE CO, ACB 2 Norfolk, VA; Code S3T, Norfolk VA
 NAVRADRECFAC PWO, Kami Seya Japan

NAVREGMEDCEN Code 3041, Memphis, Millington TN; PWO Newport RI; SCE San Diego, CA; SCE, Camp Pendleton CA; SCE, Guam; SCE, Oakland CA
 NAVSCOLCECOFF C35 Port Hueneme, CA; CO, Code C44A Port Hueneme, CA
 NAVSEASYSOM Code 0325, Program Mgr, Washington, DC; Code OOC (LT R. MacDougal), Washington DC; Code SEA OOC Washington, DC
 NAVSEC Code 6034 (Library), Washington DC
 NAVSECGRUACT PWO, Adak AK; PWO, Edzell Scotland; PWO, Puerto Rico; PWO, Torri Sta, Okinawa
 NAVSHIPREPFAC Library, Guam
 NAVSHIPYD Code 202.4, Long Beach CA; Code 202.5 (Library) Puget Sound, Bremerton WA; Code 380, (Woodroff) Norfolk, Portsmouth, VA; Code 400, Puget Sound; Code 400.03 Long Beach, CA; Code 404 (LT J. Riccio), Norfolk, Portsmouth VA; Code 410, Mare Is., Vallejo CA; Code 440 Portsmouth NH; Code 440, Norfolk; Code 440, Puget Sound, Bremerton WA; Code 450, Charleston SC; Code 453 (Util. Supr), Vallejo CA; L.D. Vivian; Library, Portsmouth NH; PWD (Code 400), Philadelphia PA; PWO, Mare Is.; PWO, Puget Sound; SCE, Pearl Harbor HI
 NAVSTA CO Naval Station, Mayport FL; CO Roosevelt Roads P.R. Puerto Rico; Dir Mech Engr. Gtmo; Engr. Dir., Rota Spain; Long Beach, CA; Maint. Cont. Div., Guantanamo Bay Cuba; Maint. Div. Dir/Code 531, Rodman Canal Zone; PWD (LTJG.P.M. Motolenich), Puerto Rico; PWO Midway Island; PWO, Guantanamo Bay Cuba; PWO, Keflavik Iceland; PWO, Mayport FL; ROICC Rota Spain; ROICC, Rota Spain; SCE, Guam; SCE, San Diego CA; SCE, Subic Bay, R.P.; Utilities Engr Off. (A.S. Ritchie), Rota Spain
 NAVSUBASE ENS S. Dove, Groton, CT; SCE, Pearl Harbor HI
 NAVSUPACT CO, Seattle WA; Code 4, 12 Marine Corps Dist, Treasure Is., San Francisco CA; Code 413, Seattle WA; LTJG McGarrah, SEC, Vallejo, CA; Plan/Engr Div., Naples Italy
 NAVSURFWPCEN PWO, White Oak, Silver Spring, MD
 NAVTECHTRACEN SCE, Pensacola FL
 NAVUSEAWARENGSTA Keyport, WA
 NAVWPNCEN Code 2636 (W. Bonner), China Lake CA; PWO (Code 26), China Lake CA; ROICC (Code 702), China Lake CA
 NAVWPNEVALFAC Technical Library, Albuquerque NM
 NAVWPNSTA (Clebak) Colts Neck, NJ; Code 092, Colts Neck NJ; Code 092A (C. Fredericks) Seal Beach CA; Maint. Control Dir., Yorktown VA
 NAVWPNSTA PW Office (Code 09C1) Yorktown, VA
 NAVWPNSTA PWO, Seal Beach CA
 NAVWPNSUPPCEN Code 09 Crane IN
 NCBU 405 OIC, San Diego, CA
 NCBC Code 10 Davisville, RI; Code 155, Port Hueneme CA; Code 156, Port Hueneme, CA; Code 25111 Port Hueneme, CA; Code 400, Gulfport MS; NESO Code 251 P.R. Winter Port Hueneme, CA; PW Engrg, Gulfport MS; PWO (Code 80) Port Hueneme, CA; PWO, Davisville RI
 NCBU 411 OIC, Norfolk VA
 NCR 20, Commander
 NCSO BAHRAIN Security Offr, Bahrain
 NMCB 5, Operations Dept., Forty, CO; THREE, Operations Off.
 NOAA Library Rockville, MD
 NRL Code 8400 Washington, DC
 NSC Code 54.1 (Wynne), Norfolk VA
 NSD SCE, Subic Bay, R.P.
 NTC Commander Orlando, FL; OICC, CBU-401, Great Lakes IL
 NUSC Code 131 New London, CT; Code EA123 (R.S. Munn), New London CT; Code S332, B-80 (J. Wilcox); Code SB 331 (Brown), Newport RI
 OCEANSYSLANT LT A.R. Giancola, Norfolk VA
 OFFICE SECRETARY OF DEFENSE OASD (MRA&L) Pentagon (T. Casberg), Washington, DC
 ONR Code 221, Arlington VA; Code 700F Arlington VA; Dr. A. Laufer, Pasadena CA
 PHIBCB 1 P&E, Coronado, CA
 PMTC Code 3331 (S Opatowsky) Point Mugu, CA; Pat. Counsel, Point Mugu CA
 PWC (Lt E.S. Agony) Pensacola, FL; ACE Office (LTJG St. Germain) Norfolk VA; CO Norfolk, VA; CO, (Code 10), Oakland, CA; CO, Great Lakes IL; Code 10, Great Lakes, IL; Code 110, Oakland, CA; Code 120, Oakland CA; Code 120C, (Library) San Diego, CA; Code 128, Guam; Code 154, Great Lakes, IL; Code 200, Great Lakes IL; Code 200, Guam; Code 220 Oakland, CA; Code 220.1, Norfolk VA; Code 30C,

San Diego, CA; Code 400, Great Lakes, IL; Code 400, Oakland, CA; Code 400, Pearl Harbor, HI; Code 400, San Diego, CA; Code 420, Great Lakes, IL; Code 420, Oakland, CA; Code 42B (R. Pascua), Pearl Harbor HI; Code 505A (H. Wheeler); Code 600, Great Lakes, IL; Code 601, Oakland, CA; Code 610, San Diego Ca; Code 700, Great Lakes, IL; 1.TJG J.L. McClaine, Yokosuka, Japan; Utilities Officer, Guam; XO (Code 20) Oakland, CA

SPCC PWO (Code 120) Mechanicsburg PA
TVA Smelser, Knoxville, Tenn.
NAF PWO (Code 30) El Centro, CA
U.S. MERCHANT MARINE ACADEMY Kings Point, NY (Reprint Custodian)
US DEPT OF COMMERCE NOAA, Pacific Marine Center, Seattle WA
US GEOLOGICAL SURVEY Off. Marine Geology, Piteleki, Reston VA
USAF Jack S. Spencer, Washington, DC
USAF REGIONAL HOSPITAL Fairchild AFB, WA
USCG (G-ECV) Washington Dc; (Smith), Washington, DC
USCG R&D CENTER D. Motherway, Groton CT; Tech. Dir. Groton, CT
USDA Forest Products Lab, Madison WI; Forest Service, Bowers, Atlanta, GA; Forest Service, San Dimas, CA
USNA Ch. Mech. Engr. Dept Annapolis MD; Energy-Environ Study Grp, Annapolis, MD; Engr. Div. (C. Wu) Annapolis MD; Environ. Prot. R&D Prog. (J. Williams), Annapolis MD; Ocean Sys. Eng Dept (Dr. Monney) Annapolis, MD; PWD Engr. Div. (C. Bradford) Annapolis MD; PWO Annapolis MD

ARIZONA State Energy Programs Off., Phoenix AZ
AVALON MUNICIPAL HOSPITAL Avalon, CA
BONNEVILLE POWER ADMIN Portland OR (Energy Consv. Off., D. Davey)
BROOKHAVEN NATL LAB M. Steinberg, Upton NY
CALIFORNIA STATE UNIVERSITY LONG BEACH, CA (CHELAPATI)
COLUMBIA-PRESBYTERIAN MED. CENTER New York, NY
CORNELL UNIVERSITY Ithaca NY (Serials Dept, Engr Lib.)
DAMES & MOORE LIBRARY LOS ANGELES, CA
FLORIDA ATLANTIC UNIVERSITY Boca Raton, FL (McAllister)
FLORIDA TECHNOLOGICAL UNIVERSITY ORLANDO, FL (HARTMAN)
FOREST INST. FOR OCEAN & MOUNTAIN Carson City NV (Studies - Library)
FUEL & ENERGY OFFICE CHARLESTON, WV
HAWAII STATE DEPT OF PLAN. & ECON DEV. Honolulu HI (Tech Info Ctr)
INDIANA ENERGY OFFICE Energy Group, Indianapolis, IN
WOODS HOLE OCEANOGRAPHIC INST. Woods Hole MA (Winget)
KEENE STATE COLLEGE Keene NH (Cunningham)
LEHIGH UNIVERSITY BETHLEHEM, PA (MARINE GEOTECHNICAL LAB., RICHARDS); Bethlehem PA (Linderman Lib. No.30, Flecksteiner)
LIBRARY OF CONGRESS WASHINGTON, DC (SCIENCES & TECH DIV)
LOUISIANA DIV NATURAL RESOURCES & ENERGY Dept. of Conservation, Baton Rouge LA
MAINE OFFICE OF ENERGY RESOURCES Augusta, ME
MICHIGAN TECHNOLOGICAL UNIVERSITY Houghton, MI (Haas)
MISSOURI ENERGY AGENCY Jefferson City MO
MIT Cambridge MA (Rm 10-500, Tech. Reports, Engr. Lib.); Cambridge, MA (Harleman)
MONTANA ENERGY OFFICE Anderson, Helena, MT
NATL ACADEMY OF ENG. ALEXANDRIA, VA (SEARLE, JR.)
NEW HAMPSHIRE Concord, NH, (Governor's Council On Energy)
NEW MEXICO SOLAR ENERGY INST. Dr. Zwibel Las Cruces NM
NY CITY COMMUNITY COLLEGE BROOKLYN, NY (LIBRARY)
NYS ENERGY OFFICE Library, Albany NY
POLLUTION ABATEMENT ASSOC. Graham
PURDUE UNIVERSITY Lafayette, IN (Altschaeff), Lafayette, IN (CE Engr. Lib)
CONNECTICUT Hartford CT (Dept of Plan. & Energy Policy)
SCRIPPS INSTITUTE OF OCEANOGRAPHY LA JOLLA, CA (ADAMS)
SEATTLE U Prof Schwaegler Seattle WA
STANFORD UNIVERSITY Engr Lib, Stanford CA
STATE UNIV. OF NEW YORK Fort Schuyler, NY (Longobardi)
TEXAS A&M UNIVERSITY W.B. Ledbetter College Station, TX

UNIVERSITY OF CALIFORNIA DAVIS, CA (CE DEPT. TAYLOR); Energy Engineer, Davis CA;
 LIVERMORE, CA (LAWRENCE LIVERMORE LAB. TOKARZ); La Jolla CA (Acq. Dept. Lib. C-075A);
 Vice President, Berkeley, CA
 UNIVERSITY OF DELAWARE Newark, DE (Dept of Civil Engineering, Chesson)
 UNIVERSITY OF HAWAII HONOLULU, HI (SCIENCE AND TECH. DIV.)
 UNIVERSITY OF ILLINOIS URBANA, IL (LIBRARY); URBANA, IL (NEWMARK)
 UNIVERSITY OF MASSACHUSETTS (Heronemus), Amherst MA CE Dept
 UNIVERSITY OF NEBRASKA-LINCOLN Lincoln, NE (Ross Ice Shelf Proj.)
 UNIVERSITY OF TEXAS Inst. Marine Sci (Library), Port Arkansas TX
 UNIVERSITY OF TEXAS AT AUSTIN AUSTIN, TX (THOMPSON)
 UNIVERSITY OF WASHINGTON (FH-10, D. Carlson) Seattle, WA; Dept of Civil Engr (Dr Mattock),
 Seattle WA; Seattle WA (E. Linger); Seattle, WA Transportation, Construction & Geom. Div
 UNIVERSITY OF WISCONSIN Milwaukee WI (Ctr of Great Lakes Studies)
 URS RESEARCH CO. LIBRARY SAN MATEO, CA
 VIRGINIA INST. OF MARINE SCI. Gloucester Point VA (Library)
 ARVID GRANT OLYMPIA, WA
 ATLANTIC RICHFIELD CO. DALLAS, TX (SMITH)
 BAGGS ASSOC. Beaufort, SC
 BECHTEL CORP. SAN FRANCISCO, CA (PHELPS)
 BELGIUM HAECON, N.V., Gent
 BRITISH EMBASSY Sci. & Tech. Dept. (J. McAuley), Washington DC
 BROWN & CALDWELL E M Saunders Walnut Creek, CA
 BROWN & ROOT Houston TX (D. Ward)
 CANADA Nova Scotia Rsch Found, Corp. Dartmouth, Nova Scotia; Surveyor, Nenninger & Chenevert Inc.,
 Montreal; Trans-Mnt Oil Pipe Lone Corp. Vancouver, BC Canada
 CHEMED CORP Lake Zurich IL (Dearborn Chem. Div.Lib.)
 COLUMBIA GULF TRANSMISSION CO. HOUSTON, TX (ENG. LIB.)
 DESIGN SERVICES Beck, Ventura, CA
 DILLINGHAM PRECAST F. McHale, Honolulu HI
 DIXIE DIVING CENTER Decatur, GA
 DURLACH, O'NEAL, JENKINS & ASSOC. Columbia SC
 FORD, BACON & DAVIS, INC. New York (Library)
 GRUMMAN AEROSPACE CORP. Bethpage NY (Tech. Info. Ctr)
 HONEYWELL, INC. Minneapolis MN (Residential Engr Lib.)
 MATRECON Oakland, CA (Haxo)
 MCDONNELL AIRCRAFT CO. Dept 501 (R.H. Fayman), St Louis MO
 MEDERMOTT & CO. Diving Division, Harvey, LA
 MIDLAND-ROSS CORP. TOLEDO, OH (RINKER)
 NEWPORT NEWS SHIPBLDG & DRYDOCK CO. Newport News VA (Tech. Lib.)
 PACIFIC MARINE TECHNOLOGY Long Beach, CA (Wagner)
 PORTLAND CEMENT ASSOC. SKOKIE, IL (CORLEY; SKOKIE, IL (KLIEGER); Skokie IL (Rsch & Dev
 Lab, Lib.)
 RAYMOND INTERNATIONAL INC. E Colle Soil Tech Dept. Pennsauken, NJ
 SAFETY SERVICES, INC. A. Patton, Providence RI
 SANDIA LABORATORIES Albuquerque, NM (Vortman); Library Div., Livermore CA
 SCHUPACK ASSOC SO. NORWALK, CT (SCHUPACK)
 SEAFOOD LABORATORY MOREHEAD CITY, NC (LIBRARY)
 SEATECH CORP. MIAMI, FL (PERONI)
 SHELL DEVELOPMENT CO. Houston TX (C. Sellars Jr.)
 SWEDEN Cement & Concrete Research Inst., Stockholm; VBB (Library), Stockholm
 TEXTRON INC BUFFALO, NY (RESEARCH CENTER LIB.)
 TRW SYSTEMS REDONDO BEACH, CA (DAI)
 UNITED KINGDOM Cement & Concrete Assoc Wexham Springs, Slough Bucks; Library, Bristol; R. Browne,
 Southall, Middlesex; Taylor, Woodrow Constr (014P), Southall, Middlesex; Taylor, Woodrow Constr
 (Stubbs), Southall, Middlesex; Univ. of Bristol (R. Morgan), Bristol
 UNITED TECHNOLOGIES Windsor Locks CT (Hamilton Std Div., Library)
 WARD, WOLSTENHOLD ARCHITECTS Sacramento, CA
 WESTINGHOUSE ELECTRIC CORP. Annapolis MD (Oceanic Div Lib. Bryan); Library, Pittsburgh PA

WM CLAPP LABS - BATTELLE DUXBURY, MA (LIBRARY)
BRAHTZ La Jolla, CA
BRYANT ROSE Johnson Div. UOP, Glendora CA
ERVIN, DOUG Belmont, CA
KETRON, BOB Ft Worth, TX
KRUZIC, T.P. Silver Spring, MD
CAPT MURPHY Sunnyvale, CA
T.W. MERMEL Washington DC

END

DATE
FILMED

10-80

DTIC