



AD-A100 785 AIR FORCE INST OF TECH WRIGHT-PATTERSON AFB OH SCHOO--ETC F/G 14/2
COMPUTER ANALYSIS OF 400 HZ AIRCRAFT ELECTRICAL GENERATOR TEST --ETC
JUN 80 P G GABERDIEL
UNCLASSIFIED AFIT/GCS/EE/80-1

NL

1 of 2
AD
A100785





DISCLAIMER NOTICE

**THIS DOCUMENT IS BEST QUALITY
PRACTICABLE. THE COPY FURNISHED
TO DTIC CONTAINED A SIGNIFICANT
NUMBER OF PAGES WHICH DO NOT
REPRODUCE LEGIBLY.**

AFIT/GCS/EE/80-1

Accession For	
NTIS GRA&I	☒
DTIC TAB	☐
Unannounced	☐
Justification	
By	
Distribution/	
Availability Codes	
Avail and/or	
Dist	Special
A	23 CP

COMPUTER ANALYSIS OF 400 HZ
AIRCRAFT ELECTRICAL GENERATOR TEST DATA

Philip G. Gaberdiel

AFIT/GCS/EE/80-1

DTIC
SELECT
JUL 1 1981
D

AFIT/GCS/EE/80-1

COMPUTER ANALYSIS OF 400 HZ
AIRCRAFT ELECTRICAL GENERATOR TEST DATA .

THESIS

Presented to the Faculty of the School of Engineering
of the Air Force Institute of Technology
Air University
in Partial Fulfillment of the
Requirements for the Degree of
Master of Science

by
Philip G. Gaberdiel

1Lt

USAF

Graduate Computer Systems

June 1980

Preface

The purpose of this project was to develop software analysis and display systems for the Generator Test Facility of the Aero Propulsion Laboratory. This system is used to evaluate the performance of advanced aircraft electrical generating systems. The software systems presented in this thesis comprise a major portion of the test facility.

I would like to acknowledge the support and guidance given me by Joseph Walick, Engineering Technician, and William Borger, Project Engineer, both of the Aero Propulsion Laboratory. I would also like to thank my wife, Cherry for her effort in typing this thesis.

Philip G. Gaberdiel

Contents

	Page
Preface	ii
List of Figures	iv
Abstract	vi
I. Introduction	1
Background	1
Objective	7
Approach	7
II. Analysis Software System	10
Requirements	10
Design	17
Implementation	27
Accuracy Measurements	34
III. Display Software System	40
Requirements	40
Design	43
Implementation	43
IV. Conclusions	56
Bibliography	60
Appendix A: Analysis Software	61
Appendix B: Display Software	81
Appendix C: Display Software User's Manual	128
Vita	156

List of Figures

<u>Figure</u>		<u>Page</u>
1	Test Control System	3
2	Data Acquisition System	6
3	Voltage Waveform with Data Points	19
4	Zero Crossover Interpolation	20
5	Numerical Integration	23
6	Analysis Software Design	28
7	Data Stream	30
8	Accuracy Test - Simulated Input	36
9	Accuracy Test - Test Input	38
10a	Display Software Design	44
10b	Display Modules	45
11	Display Options	47
12	Test Summary Plot	49
13	RMS Values Plot	50
14	RMS Values Table	51
15	Instantaneous Values Plot	52
16	Instantaneous Values Table	53
17	Harmonic Content	54
18	Frequency Deviation	55
C-1	Data Acquisition Rate	131
C-2	Test Summary Plot	133
C-3	Display Format Menu	134

List of Figures

(Continued)

<u>Figure</u>		<u>Page</u>
C-4	Instantaneous Phase Values (w/o highlighting)	136
C-5	Instantaneous Phase Values (with highlighting)	137
C-6	Fourier Representation (frequency domain)	140
C-7	Fourier Representation (time domain)	141
C-8	Frequency and Voltage Deviations	145
C-9	RMS Phase Values	147
C-10	Instantaneous Phase Values Table	149
C-11	Instantaneous Values	151
C-12	RMS Phase Values Table	153

Abstract

A software system was specified which would derive the performance measures of MIL-STD-704B from the test data provided by the Generator Test Facility. This analysis software system was then designed and implemented. Accuracy tests on the system demonstrated that very precise measurements of generator performance can be obtained.

A software system was also designed and implemented to display the analysis results to the user. The display system employs a Tektronix 4010 terminal in an interactive mode to present the data. The user, therefore, selects the particular display and time range to be presented.

COMPUTER ANALYSIS OF 400 HZ AIRCRAFT ELECTRICAL GENERATOR TEST DATA

I. Introduction

Background

The Generator Test Facility of the Aero Propulsion Laboratory is a computer-controlled facility for conducting performance tests on aircraft electrical generating systems. The facility has three 350 horsepower motors capable of providing generator drive speeds up to 30,000 rpm. Electrical loading for the generator under test is supplied by 5 passive load banks, each designed to provide 3-phase, infinitely variable loads with ratings up to 120 kva, 0.75-1.0 power factor. The test facility also includes oil and air systems for supplying cooling to the generator system.


Computer control of a generator test is provided by a Modcomp minicomputer and a set of test control software. The software enables the test engineer to program the minicomputer to control execution of the generator test. The minicomputer, via various input/output systems, (1) controls generator speed and acceleration rate, (2) selects load bank settings, and (3) performs other contact-closure type functions related to controlling the generator test. The

minicomputer also monitors an array of safety conditions during generator testing. If any of these conditions exceed preset limits, the minicomputer invokes automatic test shut-down procedures.

In summary, a typical generator test consists of accelerating the generator to a specific operating speed and then applying a particular electrical load. Figure 1 illustrates the test control system of the Generator Test Facility. In order to determine the performance of the generator in response to a particular set of test conditions, the test engineer must examine the generator output during the test.

A method for examining the generator output is precisely the area in which other generator test facilities have had the most difficulties. Electrical measurement devices such as ammeters, voltmeters, oscilloscopes, oscillographs, etc. are used to display the generator output. These devices suffer from basic inaccuracies and slow response times. It is also difficult to synchronize the taking of data exactly with occurrence of the desired test conditions. Further, in order to examine all three phases of the generator output, it is often necessary to rerun a test several times. Generally the performance measurements which can be determined from the generator output are limited to those which can be displayed directly by an electrical instrument. In short, these methods for examining

TEST CONTROL AND DATA ACQUISITION



Note: Computer control includes safety condition monitoring and automatic shut-down provisions

Figure 1. Test Control System

electrical generator performance suffer from inaccuracy and inability to adequately measure transient response, require considerable skill and patience on the part of the analyst, and are cumbersome and inconvenient.

The Generator Test Facility includes a high speed data acquisition system to facilitate the task of examining aircraft electrical generator performance. The data acquisition system is based on the following scheme. First, a low level (0-5 volt) a.c. signal is developed which is proportional to the electrical signal being measured. For generator phase voltage, a resistive voltage divider is used to reduce the nominal 115 volts to 5 volts. The phase current is first reduced to a lower current level by passing it through a step-down current transformer. This lower level current (usually 0-5 amps) is impressed across a resistive shunt to produce a millivolt signal proportional to the phase current. This millivolt signal is then amplified to the desired 0-5 volt level with an instrumentation amplifier.

The a.c. voltage signals proportional to the generator output are then each converted to a 12 bit binary representation by a high speed (4 microsecond conversion time) analog-to-digital conversion assembly. An electronics multiplexing assembly then formats these binary data words into serial blocks which each include a reference timing word. The output of the multiplexing electronics is available as input to the test facility minicomputer.

One function of test control performed by the minicomputer is to input and store the output of the data multiplexing system over the time range specified by the test engineer. The magnetic disk of the minicomputer is currently used as a storage device for the generator test data. Thus at the completion of a test, a digitized representation of the output of the generator in response to the test conditions is stored on a dedicated file of the minicomputer magnetic disk.

The data acquisition system is illustrated in Figure 2. The system, from analog-to-digital conversion to storage on the magnetic disk, operates at a rate of approximately 8800 hertz. This rate provides a new digitized data point every 113 microseconds or 22 data points per cycle of 400 hertz generator output.

A measure of the performance of the generator in response to the conditions of a test can be determined by examining this digitized test data directly. In order to provide a fuller description of the generator performance, numerical calculations can be performed using the digitized representation of generator output and the reference timing word as input. The results of these calculations display the performance of the generator more clearly to the test engineer.

The goal of this project was to design and implement a software system to analyze the data available from the Generator Test Facility.




Figure 2. Data Acquisition System

Objective

The objective of this project was to design and implement a software analysis system for the Generator Test Facility of the Aero Propulsion Laboratory. The input to this analysis system is the digitized data blocks produced by the data acquisition system of the test facility. The analysis system must produce a set of electrical measurement calculations which describe the performance of an aircraft electrical generator system in response to the conditions of the test.

The software system must also include display routines which allow the test engineer to examine the results of the analysis. These routines must be interactive so that the user can display any analysis results over any time range.

Approach

This project was accomplished in the following manner. The first step was to specify a set of analysis computations to be performed on the generator test data. The results of these computations provide a measure of the performance of an aircraft electrical generation system in response to the conditions of the test. Military and industry electrical generator performance standards were used in selecting the particular set of analysis computations that were implemented.

After the analysis requirements were finalized, algorithms were chosen which would derive the selected computations from the generator test data available from the data acquisition system of the Generator Test Facility. In most instances, several algorithms were available to implement a particular analysis computation. In these cases, the particular algorithm chosen was selected by trading off ease of implementation, accuracy, and execution speed.

Next, a software system was designed to implement the required analysis computations using the algorithms selected in the previous step. This software design stressed an overall goal of structuring the system into individual modules each performing a distinct function. The design also emphasized high cohesion within each module and low coupling between modules. A software system which meets these design goals not only accomplishes the data analysis task but does so in a very straight forward manner. The well-designed software system is thus easy to maintain and therefore can expect a longer useful life.

The software system designed in the previous step was then implemented. Fully commented source listings of all routines were generated to document the software analysis system. A series of tests were conducted to determine the accuracy of the algorithms used in the analysis system. The next step of the project was to devise a method to present the analysis results to the user.

Therefore, next a software system was designed which displays the results of the data analysis to the test engineer. The output device used for this display is a Tektronix 4010 cathode-ray-tube terminal. The terminal's cross-hair cursor input feature is implemented to allow the engineer to select the particular analysis computation and time range to be displayed. Again, a structured design for the display software was derived to provide easy software maintenance. In addition to fully commented source listings for all display software, a user's manual was written to aid the test engineer.

The total software system, with both analysis and display features, provides the Generator Test Facility with a complete and very accurate mechanism for examining the performance of an aircraft electrical generator under test. The following text discusses each aspect of this thesis project in detail.

II. Analysis Software System

Requirements

The goal of the first phase of this project was to determine a set of analysis computations which would represent the performance of an aircraft electrical generation system. The set of performance parameters were limited to those dealing with electrical measurements of 400 hertz alternating current (a.c.) waveforms. By limiting the study to electrical measurements, mechanical measurements such as torque and heat output are specifically eliminated. These type measurements are useful in calculating system efficiencies; however, instruments to measure these parameters are not currently part of the Generator Test Facility.

By limiting the study to 400 hertz a.c. parameters, those dealing with direct current (d.c.) or wild frequency systems are specifically eliminated. Although those type of systems may have some value in future aircraft electrical systems, the management of the Aero Propulsion Laboratory is concentrating future development on 400 hertz a.c. systems.

The basic source for selecting this set of analysis computations is MIL-STD-704B, "Military Standard Aircraft Electric Power Characteristics".(Ref 1) This document defines standards for aircraft electrical power character-

istics present at utilization equipment power-input terminals, maintained during operation of the generation equipment. The purpose of this standard is to provide voltage and frequency limits and conditions for aircraft electric power to be used as criteria for system performance.

Documents describing the analysis procedures used in the test facilities of several generator manufacturers (Ref 2,3) were examined to determine if their analysis requirements differ from those given in MIL-STD-704B. No new information or substantial differences in definition of terms were found in these reports. Therefore, the set of analysis computations which are used as design requirements for the analysis software system are derived from MIL-STD-704B.

The analysis requirements and definitions are as follows:

1. Frequency - Frequency is equal to the reciprocal of the alternation period of the fundamental of the a.c. voltage. The alternation period of the fundamental is assumed to be equal to the time difference between two successive negative-to-positive crossovers of the a.c. voltage. The unit of frequency is the number of alternations per second and is designated hertz (Hz).
2. A.C. Voltage - The term a.c. voltage refers to the root mean square (rms) phase to neutral values, where rms voltage is defined by the formula

$$V_{rms} = \sqrt{\frac{1}{T} \int_0^T v^2(t) dt} \quad (1)$$

where

T = period of alternation

3. Distortion - A.C. distortion is the rms value of the a.c. waveform exclusive of the fundamental. A.C. distortion includes the components resulting from amplitude modulation as well as harmonic and non-harmonic components.

4. Distortion factor - The a.c. distortion factor is the ratio of the a.c. distortion to the rms value of the fundamental component of the waveform.

5. Distortion spectrum - The distortion spectrum quantifies a.c. distortion in terms of the amplitude of each frequency component. The distortion spectrum includes the components resulting from amplitude and frequency modulation as well as harmonic and non-harmonic components of the a.c. waveform.

6. Frequency transient - The frequency transient is the locus of values defined by the reciprocals of sequential alternation periods of the a.c. voltage, in instances when the frequency departs from the steady-state value.

7. Voltage surge - The voltage surge is defined as a transient departure of the peak values of

voltage from the peak instantaneous value of the steady state voltage, persisting for periods in excess of 500 microseconds, followed by recovery to within peak values corresponding to steady state. Surges are caused by load changes, switching, or power interruptions elsewhere in the system.

8. Voltage spike - The spike is a transient of total duration normally less than 500 microsecond and is superimposed on the otherwise unaltered instantaneous voltage. Because of the limited sampling rate of the Generator Test Facility, only spikes of approximately 250 microseconds or greater can be accurately measured. Spikes may be characterized in the time domain in terms of voltage with parameters of duration, risetime, and energy.

9. Voltage unbalance - Voltage unbalance is defined as the maximum difference among phase voltage magnitudes at the utilization equipment terminals.

10. Steady state - A steady state condition of a characteristic is one in which the characteristic shows only negligible change throughout an arbitrarily long period of time.

Following are several long-term (steady state) generator performance measurements.

11. Frequency drift - Frequency drift is the slow and random variation of the controlled frequency

level within steady state limits due to such influences as environmental effects and aging. When applicable, the time rate of frequency change due to frequency drift is the frequency drift rate.

12. Frequency modulation - Frequency modulation is defined as the difference between maximum and minimum values of $1/T$, where T is the alternation period of one cycle of the fundamental of the phase voltage. When applicable, the rate at which $1/T$ values repeat cyclically is called the frequency modulation rate.

Long-term or steady state performance measurements of this type were not implemented in this project. This is because the present design of the Generator Test Facility allows storage of data for times of generally 10 seconds or less. The long-term measurements given above are normally computed over a much longer time frame. However, it should be noted that the transient (short-term) performance of a generator is more difficult to measure than the steady state (long-term) performance. It is the transient response which other generator test facilities have had the most problem measuring accurately. If in the future the data storage time span possible with the Generator Test Facility is increased, steady state measurements should be included as part of the analysis software system.

Two additional parameters must be determined from the generator test data in order to accurately describe the elec-

trical conditions under which the generator is operating. These parameters describe the type and amount of electrical loading applied to the generator.

13. A.C. Current - A.C. current refers to the rms value of the phase current, where rms current is defined by

$$I_{rms} = \sqrt{\frac{1}{T} \int_0^T i^2(t) dt} \quad (2)$$

where

T = alternation period of phase voltage

14. Power Factor - Power factor is defined as the cosine of the phase angle between the voltage and the current of a particular phase of generator output. The phase angle defines the phase relationship between the voltage and current waveform of a particular phase of generator output. This phase relationship is determined by the type of electrical load applied to the generator. Therefore, the power factor helps describe the electrical conditions under which the generator was operating during the test. The power factor of any phase of generator output is given by the following formula:

$$P.F. = \frac{\int_0^T v(t)i(t)dt}{\sqrt{\frac{1}{T} \int_0^T v^2(t)dt} \sqrt{\frac{1}{T} \int_0^T i^2(t)dt}} \quad (3)$$

where

T = period

The next step of this project was to design a set of analysis software to derive the above-stated performance measures from the test data produced by the Generator Test Facility. First, however, design goals had to be specified for the accuracy of each analysis computation. These goals were determined by considering the types of analysis to be performed with the test facility and the built-in error present in the measurement circuitry.

A major function of the test facility is to compare the performance of aircraft electrical generating systems against their design requirements. The requirement specifications for several advanced generating systems (Refs 4,5,6,7) were reviewed. These systems are typically required to regulate steady-state voltage to ± 1 volt rms and steady-state frequency to ± 1 hertz. These requirements define the worst case error acceptable from the entire data acquisition system. In other words, the data acquisition system must be accurate enough to detect deviations of at least these magnitudes. Therefore, the design goal for the accuracy of the overall data acquisition and analysis system was chosen as ± 0.5 volts rms for voltage measurements, ± 1.0 amps rms for current measurements, and ± 0.5 hertz for frequency measurements.

However, this overall accuracy is determined by several factors. For current measurements, the current transformer-shunt combinations contribute a possible worst case error

of $\pm 0.517\%$ of full scale. This error represents ± 5.17 volts for voltage measurements and ± 1.29 amps for current measurements. Since this amount of inaccuracy is not acceptable, a detailed calibration procedure was devised for the overall measuring circuit. Use of the calibration procedure reduces the hardware measurement error to a negligible amount (± 0.054 volts and ± 0.023 amps). Therefore, the accuracy specifications given for the overall measurement process were used as design goals for the analysis software.

Design

Before designing the software for the analysis software, algorithms were determined to compute each of the performance measures selected above. Following is a discussion of each performance measurement and the algorithm which is used to derive it.

1. Frequency - Frequency is computed as the reciprocal of the period of the voltage waveform. The period of the voltage is taken to be the time difference between successive positive-sloped zero crossovers of the waveform. However, the exact time of zero crossover is not known. This is because data sampling and the generator output are not synchronized. This unsynchronization means that data points which correspond with an exact zero crossover are not guaranteed (in fact they are extremely rare). Thus the exact time for a zero crossover must be estimated by interpolating

between the data point just prior to crossover and the data point just after crossover. Figure 3 illustrates the voltage waveform with data points marked with small triangles.

Figure 4 presents the basis for the following linear interpolation used to estimate time of zero crossover.

$$Z_T = \frac{V_1}{V_1 - V_2} (T_2 - T_1) + T_1 \quad (4)$$

Using this linear interpolation assumes that the voltage waveform will be very linear in the short time span between the known data points. This is a valid assumption since a pure sine wave is indeed very linear about a zero crossover. In fact using a data sampling period of 100 microseconds, calculations show that the worst case error in determination of zero crossover of a 400 Hz sine wave is 0.102 microseconds. This represents a theoretical worst case error of 0.0008% in the calculation of the period of the waveform. Determination of the actual period measurement error of the analysis software is presented later in this thesis.

Therefore, to represent frequency of a particular phase of generator output, values for the period of each cycle of the voltage waveform are determined using the method stated above. It is important that these period values be determined independently for each of the three phases of generator output. This is because the frequency of the individual phases





Figure 3. Voltage Waveform with Data Points





Figure 4. Zero Crossover Interpolation

of the generator output can be different.

2. RMS values - The root mean square (rms) value of each cycle of phase voltage must be computed. Equation 1 defines the rms value of voltage.

A numerical integration technique was devised which will compute the average (mean) value of the squared phase voltage data points over each cycle. The rms value is then found by taking the square root of this mean value.

In addition to rms voltage, the rms value of phase current is also computed over each cycle. This current value is useful in displaying the type of electrical load under which the generator was operating during the test.

The numerical integration technique used in rms calculations is a modified trapezoidal rule. The basic trapezoidal rule requires that data points be equally spaced. This requirement is met in the generator test data except around the zero crossovers which occur at the beginning, middle, and end of each cycle of the waveform. Over these time intervals of irregular width, the integral is determined by computing the triangular area under the waveform between the known data point and the estimated zero crossover. For all other time intervals, the normal trapezoidal rule is used. Equation 5 presents the implementation of Equation 1 using this modified trapezoidal rule for the voltage waveform represented in Figure 5.

$$V_{rms} = \sqrt{\frac{1}{\text{PERIOD}} \left(\text{SUMA} + \text{SUMB} + \text{SUMC} + \text{SUMD} + \text{SUME} \right)} \quad (5)$$

where

$$\text{SUMA} = \frac{v^2(t_1)}{2} (t_1 - Z_{t_1}); \text{ first zero crossover}$$

$$\text{SUMB} = \frac{t_{\text{samp}}}{2} \sum_{n=1}^{10} (v^2(t_{n+1}) + v^2(t_n)); \text{ positive half cycle}$$

$$\text{SUMC} = \frac{v^2(t_{11})}{2} (Z_{t_2} - t_{11}) + \frac{v^2(t_{12})}{2} (t_{12} - Z_{t_2}); \text{ middle zero crossover}$$

$$\text{SUMD} = \frac{t_{\text{samp}}}{2} \sum_{n=12}^{21} (v^2(t_{n+1}) + v^2(t_n)); \text{ negative half cycle}$$

$$\text{SUME} = \frac{v^2(t_{22})}{2} (Z_{t_3} - t_{22}); \text{ final zero crossover}$$

and

$$\text{PERIOD} = Z_{t_3} - Z_{t_1}; \text{ period of alternation}$$

$$t_{\text{samp}} = t_{n+1} - t_n; \text{ time between data samples}$$

A determination of the accuracy of this method for calculating the rms value of a waveform was performed. A routine implementing this modified trapezoidal rule was executed on a test input consisting of a software-generated 400 Hz sine wave with data points occurring every





Figure 5. Numerical Integration

113 microseconds. This test input simulates very accurately the actual data available from the data acquisition system of the Generator Test Facility. The error in determining the rms value of the test input was found to be less than 0.04%. Determination of the actual voltage and current rms measurement errors of the analysis software is presented later in this thesis.

3. Power factor - A value for the power factor of each cycle of generator output is computed using the definition given in Equation 3. The numerical integration required in this equation is implemented using the modified trapezoidal rule defined in the discussion of rms values.

The preceding analysis computations - frequency, rms voltage, rms current, and power factor provide the information necessary to describe the performance of the electrical generator in response to the conditions of the test. Therefore the analysis software system processes the raw test data stored by the data acquisition system on a dedicated file of the minicomputer's magnetic disk and computes a value for each of the parameters for each cycle of each of the three phases of generator output over the entire test time. The results of this analysis are stored on another dedicated file of the magnetic disk. These results are then available to the display software for interactive presentation to the user.

Most of the remaining performance measurements selected as design requirements for the analysis software are available

upon display of the basic analysis computations just discussed. Therefore, the display software must present these results in the proper formats to portray these measurements.

One final set of analysis computations have not been discussed. These are the computations dealing with the a.c. distortion of the generator output voltage waveform.

4. Distortion - Distortion of the voltage waveform is determined by computing its Fourier representation. The Fourier representation will accurately portray all distortion components in the waveform if an infinite number of harmonics are computed. However, because of the finite data sampling rate of the data acquisition system, the Fourier representation of the test data is accurate for only a limited number of harmonics.

The data sampling rate of the data acquisition system is approximately 8800 hertz. By using the Nyquist sampling criteria, waveforms of up to 4400 hertz can be accurately analyzed. Therefore, the Fourier analysis procedure computes up to the 11th harmonic of the output voltage waveform.

The Fourier series representation used for this measure of waveform distortion is given by the following equation.

$$f(t) = \frac{a_0}{T} + \frac{2}{T} \sum_{n=1}^{11} (a_n \cos w_n t + b_n \sin w_n t) \quad (6)$$

where

$$T = \text{period and } w_n = \frac{2\pi n}{T}$$

The magnitude of the frequency component at each harmonic is given by

$$\sqrt{a_n^2 + b_n^2}$$

where

$$a_0 = \frac{2}{T} \int_0^T f(t) dt - \text{the average value of the waveform}$$

$$a_n = \frac{2}{T} \int_0^T f(t) \cos \frac{2n\pi t}{T} dt - \text{the cosine components} \quad (7)$$

$$b_n = \frac{2}{T} \int_0^T f(t) \sin \frac{2n\pi t}{T} dt - \text{the sine components}$$

Harmonic analysis of the generator output voltage waveform is generally of interest only during portions of the test in which conditions are essentially steady-state. During changes in electrical load or acceleration/deceleration of the generator, the output voltage will usually contain waveform distortion which is not of interest. Therefore, the computation of Fourier coefficients is not carried out over the entire range of test data as for the rms and frequency calculations. Doing this would require storing a large amount of mostly useless data on the intermediate disk file.

Instead, computation of the Fourier coefficients is deferred until display of the test data. At this time, the user selects the particular time range over which the harmonic analysis is to be performed. Additionally, it is possible to determine the Fourier representation of each

individual cycle of the voltage waveform. However, in order to compare the Fourier representation to those produced by instruments such as spectrum analyzers, it is usually more desirable to compute the magnitudes of the harmonic components based on an average over several cycles. The user also selects the number of cycles over which to carry out this computation. This completes the formulation of algorithms to derive the required calculations. Next, a software system was designed to implement these algorithms.

Figure 6 presents a top-level description of the software modules that comprise the analysis system. Basically, an executive routine drives three subordinate modules. One module handles input of the raw test data; one module performs the numerical analyses; and one module outputs the results to the storage device. The following section of this thesis presents the implementation of this software design.

Implementation

A source listing for the analysis software system is presented as Appendix A. These routines implement the generator performance computations described earlier. Presented here is a brief explanation of this software.

The basic task of the system, illustrated in Figure 6, is to input the raw test data stored on the disk, calculate the specified performance measurements, and store the results




Figure 6. Analysis Software Design

back on the disk. These results are then available to the display software system.

To perform this data analysis process, first a root module ANALYSIS was written to direct three other modules which each perform a basic function. The first of these routines READA supplies two successive values of each phase voltage and current to the root module. These data values are floating point representations of the A/D converter outputs. Also returned is the time of the data sample measured from the beginning of data acquisition. The time values are "adjusted" double precision representations of the output of a reference clock circuit which is part of the data acquisition electronics.

On the first call to READA, the first two blocks of generator test data must be obtained for return to the root module. On all subsequent calls, only one new data block is obtained. The routine READA obtains each individual data block by calling the routine GETBLK.

The routine GETBLK performs the conversion of the raw test data to a form useable by the numerical integration routine. An explanation of the format of the raw test data is now in order. The output of the multiplexing electronics of the data acquisition system consists of a stream of 10-word blocks, each word being 16 bits wide. Figure 7 illustrates this data stream.




Figure 7 - Data Stream

The first word of a data block is a null input produced by a data buffer in the acquisition electronics which is hardwired to logic zero. This null word is used by GETBLK to locate the beginning of data blocks. The second word of the block is the output of a 16-bit counter driven by a 10 MHz crystal. (This counter has been referred to previously as the reference clock circuit.) This time signal is required for the numerical integration performed in the data analysis. The next six words of the data block are each the 12-bit binary output of one of the six A/D converters. The four low-order bits of the 16-bit data word are hardwired to logic one. The ninth word of the block is a parity word computed for the eight previous words of the block by an electronic circuit located in the data acquisition system. The final word is a checksum word also computed for the first eight words by the data acquisition electronics. These two data integrity words are used by diagnostic software which can exercise the data acquisition system to detect possible transmission errors.

These 10-word data blocks are stored sequentially on a file of the magnetic disk during test execution. The routine GETBLK must access each data block, convert it to useable form, and supply it to the routine READA. GETBLK performs this task in the following manner. On the initial call, the raw data is scanned to find the first null word which marks the beginning of the first full data

block. Next, the reference timing word is processed. This timing word is produced by a 16-bit counter which resets to zero approximately every 13 milliseconds. Therefore the routine GETBLK keeps track of these "roll-overs" so as to provide a constantly increasing reference time. The time signal is also converted to double precision.

Next, each A/D converter reading is input and converted to floating point. This conversion consists of (1) multiplying by a factor which converts the 12-bit binary to floating point, (2) adding a zero offset value, and (3) multiplying by a scale factor to convert the A/D converter reading to equivalent volts or amps. The zero offset values and scale factors are computed for each A/D converter during a pre-test calibration procedure.

And, finally, GETBLK advances past the two data integrity words. Thus upon the next call to GETBLK, the data file should be positioned on a null word which marks the beginning of the next data block.

The routine READ30 handles the task of inputting each data word from the disk. READ30 returns the next sequential word from the data file on each successive call until an end-of-file mark is detected. An end-of-file flag is then set which signals the routine ANALYSIS that all raw test data has been processed. In addition, the initial call to READ30 rewinds the disk file and initializes all variables. Thus, this three-level set of routines supplies data values

to the routine ANALYSIS.

The routine ANALYSIS then passes these data values to the routine which carries out the numerical integrations required to implement the calculations described earlier in Section II. This routine is named NUMINT. A basic description of this routine is as follows. Since all of the numerical integrations must be performed over one complete cycle, the routine must detect positive-sloped zero crossovers which mark the beginning and end of a cycle. Thus the routine first searches the voltage values until it finds the beginning of a cycle. On each successive call, it accumulates the summations necessary to compute the integrals required in the calculations. When the end of a cycle is detected, the various calculations are completed and these values are returned to the routine ANALYSIS.

Each phase of test data must be processed separately. An independent integration range is required for each of the three phases of generator output data. This is due to the possibility of their slightly different frequencies noted earlier. The integrations involving phase currents are performed over the same time range as the corresponding phase voltage.

By processing each phase of data independently, no assumptions are made concerning the phase relationship or frequencies of the individual phases. This generality would allow 400 Hz data to be examined on one channel, 60 Hz data on another, and possibly d.c. on another. This flexibility

is generally not needed for standard generator performance tests, but it is quite useful in the analysis of other types of electronic systems.

Once ANALYSIS receives a completed set of analysis computations (indicated by flag values), it must place these results on a storage device for later use by the display system. ANALYSIS calls the routine DWRITE to accomplish this.

The routine DWRITE sequentially outputs each packet of analysis results along with a key denoting the phase which the data represents to a dedicated file of the magnetic disk. The assembly code routine WRIT29 is called to write each data word to the disk file. The routine DINIT is called by ANALYSIS to rewind this file at the beginning of analysis. The routine DWEOF is called to close the data file when ANALYSIS determines that all test data has been processed.

The final step of the implementation of the analysis software system was to perform accuracy measurements. The following section discusses the results of these accuracy tests.

Accuracy Measurements

As part of the design requirements for the analysis software system, error limits were specified. These limits were ± 0.5 volts rms for voltage measurements, ± 1.0 amps rms for current measurements, and ± 0.5 hertz for frequency

measurements. The algorithms selected to compute rms values and period measurements were shown to have theoretical errors much less than these goals. However, to provide complete assurance of the accuracy of the analysis software, two operational tests of the system were conducted.

The first test involved applying the analysis system to a software-generated input. This test input was provided by substituting the lowest level data handling routine, GETBLK, with a routine which supplied calculated sine function values so as to simulate actual generator test data. This test is very similar to the software testing which was performed on the individual algorithms during their selection; however, this represents a more complete test of the accuracy of the analysis system. The test input was selected to be a 400 Hz sine wave with peak magnitude of 162.61 volts. The calculated results should then be 115 volts rms and 400 Hz. Actual results of the analysis with this test input are displayed in Figure 8. As can be seen, calculated values for rms voltage and rms current differ from the expected results by at most +0.1 unit. This error is well within the design limits. The values for frequency are exact to one decimal place. However, since in this case data sampling and the data waveform are essentially synchronized, this test does not adequately measure the accuracy of the frequency calculation.

The other accuracy test performed with the system consisted of performing analysis on a known electrical input.

PHASE 1

EACH ENTRY REPRESENTS AN AVERAGE OF 1 READINGS

RMS VOLTAGE (VOLTS)	RMS CURRENT (AMPS)	FREQUENCY (HZ)	PF	TIME (SEC)
115.0	115.0	400.0	1.000	0.029998
115.0	115.0	400.0	1.000	0.032498
114.9	114.9	400.0	1.000	0.034998
114.9	114.9	400.0	1.000	0.037498
114.9	114.9	400.0	1.000	0.039998
114.9	114.9	400.0	1.000	0.042498
114.9	114.9	400.0	1.000	0.044998
114.9	114.9	400.0	1.000	0.047498
114.9	114.9	400.0	1.000	0.049998
114.9	114.9	400.0	1.000	0.052498
114.9	114.9	400.0	1.000	0.054998
114.9	114.9	400.0	1.000	0.057498
114.9	114.9	400.0	1.000	0.059998
114.9	114.9	400.0	1.000	0.062498
114.9	114.9	400.0	1.000	0.064998
114.9	114.9	400.0	1.000	0.067498
114.9	114.9	400.0	1.000	0.069998
114.9	114.9	400.0	1.000	0.072498
114.9	114.9	400.0	1.000	0.074998
114.9	114.9	400.0	1.000	0.077498
114.9	114.9	400.0	1.000	0.079998
114.9	114.9	400.0	1.000	0.082498
114.9	114.9	400.0	1.000	0.084998

Figure 8. Accuracy Test - Simulated Input

This input was supplied by a 400 Hz reference power supply. The voltage output of the source was measured by a true rms voltmeter having an accuracy of ± 0.008 volts. This voltage output was measured to be 128.4 volts rms. The frequency of the source was measured by a frequency counter to be exactly 400 hertz.

Figure 9 presents the results derived by the analysis software system for this test input. The average value of the calculated rms voltage over the time range displayed is 128.54. This differs from the measured value by +0.14 volts. The average value for frequency is 399.93 hertz. This differs from the measured value by -0.07 hertz. These error magnitudes are well within the design limits.

No error determinations for current measurements were performed as part of this test. This was because the method for developing current measurements makes it difficult to obtain an accurate ammeter reading for the current. However, the results of the previous test using a software-generated input insures that the analysis system will compute rms current with the required accuracy.

Thus, these two tests demonstrate that the analysis software system performs with the accuracy specified in the design goals. This level of accuracy makes the test facility and analysis system precise tools for determining generator performance measures. Next, a means was required to present the analysis results to the user. The next chapter discusses

PHASE 1

EACH ENTRY REPRESENTS AN AVERAGE OF 1 READINGS

RMS VOLTAGE (VOLTS)	RMS CURRENT (AMPS)	FREQUENCY (HZ)	PF	TIME (SEC)
128.7	2.156	400.0	0.077	0.028455
128.4	1.156	350.0	0.107	0.030954
128.5	1.156	350.0	0.237	0.033455
128.4	2.156	400.0	0.346	0.035956
128.3	1.156	350.0	0.070	0.038456
128.4	1.156	400.0	0.243	0.040958
128.4	1.156	350.0	0.095	0.043458
128.5	1.156	400.0	0.105	0.045959
128.5	1.156	350.0	0.026	0.048458
128.7	1.156	400.0	0.024	0.050959
128.7	1.156	350.0	0.058	0.053459
128.3	1.156	400.0	0.001	0.055960
128.5	2.156	350.0	0.032	0.058460
128.6	1.156	400.0	0.022	0.060962
128.0	1.156	350.0	0.072	0.063462
128.7	1.157	400.0	0.014	0.065962
128.7	1.156	350.0	0.134	0.068462
128.7	1.156	400.0	0.258	0.070961
128.6	1.156	350.0	0.351	0.073468
128.6	2.156	400.0	0.351	0.075953
128.6	1.156	350.0	0.191	0.078464
128.6	1.156	400.0	0.281	0.080964
128.6	1.156	350.0	0.205	0.083465

Figure 9. Accuracy Test - Test Input

the display software system which was developed to serve this function.

III. Display Software System

Requirements

The next major task in this project was to implement a set of display software. This software allows the test engineer to examine the performance measurements derived by the analysis software system. The first step in developing this software system was to specify its design requirements.

Following are the design requirements for the display software selected with concurrence of the laboratory sponsor for this project. First, the display system must be interactive so that the user can select the desired display option, display time range, and particular phase of generator test data. The output device used to implement the display was a Tektronix 4010 terminal with hard-copy option. Its cross-hair function was used to provide the user a method of interactive response.

Next, a set of display formats were selected which would present the generator performance measurements in a clear and concise manner.

Following is a list of the selected formats:

1. Instantaneous values (plot) - This display presents the instantaneous values of a selected phase voltage and current versus time over the time range

selected by the user. The actual plot is generated by connecting the individual A/D converter readings. A value for the average power factor is computed over the displayed time and presented on the plot.

2. Instantaneous values (table) - This display presents in tabular form the instantaneous voltage, current, and time values of a selected phase over a selected time range. The values displayed are the scaled A/D converter readings and the "adjusted" output of the reference timer.

3. RMS values (plot) - This display presents the rms values of a selected phase voltage and current versus time over the time range selected by the user. This plot is generated by connecting the rms values computed by the analysis software.

4. RMS values (table) - This display presents in tabular form a value for rms voltage, rms current, power factor, period, and test time for each cycle of the selected phase over a selected time range.

5. Frequency deviation - This display plots the frequency versus time for a selected phase over a selected time range. By centering the plot about 400 Hz (the nominal frequency for generator output), this plot will display frequency deviation. Presented in the same display is a plot of rms phase voltage versus time. This plot is for reference

purposes and usually demonstrates the cause for any frequency deviation.

6. Harmonic content - This display presents a histogram of the magnitudes of each integral harmonic of the base frequency. This harmonic analysis is performed for the number of harmonics, over the number of cycles, and for the phase selected by the user. Values for the base frequency and total harmonic distortion are computed and displayed.

To make the display system easy to use, the user should generally be able to select any of the display options after the display of any other. In several instances, this is not possible. In particular, the harmonic content calculation and display will be available only after plotting the instantaneous phase values. Only from the phase values display can the user select meaningful parameters necessary for the harmonic analysis computation.

Also since the two tabular displays have no time scale associated with them, these displays can not be used for selecting another option. Therefore after the display of one of the tabular options, a display which has a time scale must be generated before further plot options can be selected. This display was chosen to be a summary plot of the entire test as represented by rms values versus time of all six data channels over the full time range.

This concludes the discussion of the design requirements specified for the display software system. A set of required display options has been selected. The general user/software interfaces have also been presented. The next step in implementing the display software was to design a system of software modules to satisfy these requirements.

Design

The design of the display software lends itself very well to a modular approach. Figure 10 illustrates the structure of the display software system. First, a root module directs operation of the entire system. Submodules perform the actual implementation of the display. Two modules allow the user to specify the display option, phase, and time range of the next plot. Then a separate module generates the plot for each display option. Access to both the raw test data and the analysis results is required. The same routines which were used by the analysis system to access the raw test data are used by the display system. New routines are required to access the analysis results.

Implementation

The source listings for all routines used in the display software system are included as Appendix B. Following is a brief discussion of this software. Much of the explanation of this software is deferred to the display system user's manual included as Appendix C.




Figure 10a. Display Software Design




Figure 10b. Display Modules

The root module DISPLAY, as commanded by user responses, directs overall operation of the display system. The user is prompted to provide the responses which control execution of the display. First, the user is given the option of executing the routine ACSPEED. This routine determines the data sampling rate by calculating the frequency of the voltage waveform and counting the average number of data points present in several cycles.

Next the routine QKPLOTT is executed which produces a summary plot of all rms values over the entire test range. An averaging scheme is employed so that only 100 points are plotted for each signal. This summary plot is used initially to select further plot options and time ranges with which to examine the generator performance. This plot is also used after either of the tabular displays have been presented or whenever a larger display time range is required.

After presentation of the summary plot, the routine PICKOPT enables the user to select one of the plot options. The routine PICKTIME allows the user to select the beginning and ending times over which to present the selected display. The Tektronix Plot-10 subroutine VCURSR is invoked for use of the crosshairs of the terminal. The parameters selected by the user define the next display.

The display options and the routine which implements them are presented in Figure 11. A complete explanation of each option and its use are included in the user's manual.

OPTION		DESCRIPTION	ROUTINE
IS	-	Plot of chosen phase rms voltage and current over selected time range.	ISOLATE
PR	-	Table of chosen phase rms values over selected time range. Provision for 1-9 readings to be averaged before printout.	PRINTVAL
CY	-	Plot of instantaneous values of chosen phase over selected time range. Average power factor over time range is displayed.	PLOTCTY
PC	-	Table of instantaneous values of chosen phase over selected time range.	PRINTCTY
FQ	-	Plot of frequency deviation of chosen phase over selected time range. Plot of rms phase voltage over time range is also given.	FREQDEV
QK	-	Summary plot of all three phases of rms values. Values are averaged to produce 100 points.	QKPLOT

Figure 11. Display Options

Each display routine calls various Tektronix Plot-10 subroutines to produce required display. Figures 12-18 illustrate these display formats. Each plot is labelled to allow easy interpretation of the data, normally with the maximum values and the starting and ending test times

represented in the display. In initial plots, default values must be used in setting the display screen dimensions. Therefore, some parameters may be plotted "off screen". Later displays will use the proper screen dimensions which have been determined during earlier plotting.

Thus the user interactively controls the display software system to produce displays of the generator performance during the test. Fully commented source listings of all routines used by the display software system (excluding the Plot-10 routines) are included as Appendix B. A complete user's manual describing the use of the display system is included as Appendix C.

A-10 GENERATOR PERFORMANCE TEST






Figure 12. Test Summary Plc



56.24 MSSEC AFTER START OF TEST 4649.80
 REAL PWR = 2.06 KW REACTIVE PWR = 3.40 KVAR AVE PWR FACTOR = 0.52
 AVE RMS VOLTAGE = 115.03 VOLTS AVE RMS CURRENT = 34.55 AMPS

Figure 13. RMS Values Plot

EACH ENTRY REPRESENTS AN AVERAGE OF 1 READINGS

[illegible]

Figure 14. RMS Values Table






Figure 15. Instantaneous Values Plot

PHASE 1

VOLTAGE	CURRENT	TIME
161.5	69.4	0.329845
155.1	69.1	0.329853
138.6	72.2	0.329871
110.4	72.2	0.329891
71.5	64.3	0.329910
27.0	51.0	0.329927
9.7	34.7	0.329941
-10.9	17.2	0.329957
-51.1	5.0	0.329970
-99.1	0.0	0.329983
-132.0	0.0	0.329996
-155.7	0.0	0.330009
-151.4	0.0	0.330022
-157.4	0.0	0.330035
-141.9	0.0	0.330048
-116.1	0.0	0.330061
-78.1	0.0	0.330074
-34.2	0.0	0.330087
12.0	0.0	0.330100
50.0	0.0	0.330113
92.0	0.0	0.330126
127.0	0.0	0.330139
153.0	0.0	0.330152
161.0	0.0	0.330165
159.0	0.0	0.330178
145.0	0.0	0.330191
121.0	0.0	0.330204

Figure 16. Instantaneous Values Table

FOURIER COEFFICIENTS
OF
PHASE 1 VOLTAGE



NOTE: BASE FREQUENCY IS 396.80 HZ
MAGNITUDE OF COEFFICIENT = 162.7291
TOTAL HARMONIC DISTORTION = 0.0133
DC CONTENT = 344.6503 MV

Figure 17. Harmonic Content




Figure 18. Frequency Deviation

IV. Conclusions

In order to adequately discuss conclusions about the two software systems developed in this project, one must draw some conclusions about the Generator Test Facility itself. This test facility represents the most advanced system in the United States for conducting performance testing of aircraft electrical generating systems. Representatives from all leading generator manufacturers and other government agencies have witnessed operation of the facility and attest to its uniqueness.

Several factors distinguish this test facility from others like it. Computer control of the test facility allows a wide variety of different test conditions to be conducted and requires a minimum of personnel for operation. Computer control also facilitates safety monitoring of the test generator system.

The use of high speed analog-to-digital (A/D) converters represents a significant improvement in the acquisition of the generator test data. The fast conversion time of the A/D electronics provides the capability of examining relatively high speed transients in the generator output. Conversion of the analog representations of the generator output to digital format allows a wide range of sophisticated analysis techniques to be applied to the data.

This thesis project involved implementing a set of analysis computations to be performed on the generator test data. The selected set of computations derives numerical measures of the performance of an electrical generator in response to conditions of a test. Experience with the test facility has shown it to be a very valuable research and development tool. Extensive series of tests have been completed on several advanced aircraft electrical generator systems. The results of these tests have shown Air Force engineers aspects of the systems' performance which were previously unavailable. The two software systems developed during this project are critical components of the Generator Test Facility. They provide the facility with the analysis and display mechanisms necessary to make it a useful test tool.

The software systems themselves exhibit several distinguishing features. The accuracy of the analysis software system has been demonstrated. This accuracy was attained by implementing precise algorithms in careful programming to achieve the computations. The value of this accuracy is that great confidence can now be placed in the test results.

The structure of the analysis software itself is significant. The top-down, modular approach used in designing the software resulted in a very understandable and straightforward system. The system is easy to maintain and easy to update. As a result, the test facility is able to not

only fulfill its original mission but also can be restructured to serve other test functions. To date, the test facility and analysis system have been used for electric motor testing and aircraft power controller testing. These tests required some specialized analysis routines, but the modular design of the analysis software allowed them to be added easily. In summary, the distinguishing features of the analysis software system are its accuracy and modular design.

The display software system also has several distinguishing features. Foremost is the straightforward manner in which the displays are presented. The displays present the generator performance measures in formats which are clearly labelled and easy to understand. In fact, hard copies of the display plots have been used to produce viewgraphs for presentations to upper level management about both the test facility, itself, and the generator systems under test. Additionally, hard copies of the display presentations are used directly in the technical reports written to describe the performance of the generator system under test.

The interactive control of the display system is also noteworthy. By issuing prompt messages, the software instructs the user in his selection of the display formats. In addition, a comprehensive user's manual was written for the display system. As evidence of the ease of using the

display software, the engineering technician of the test facility has been trained to use the display system.

Again, the display software was modularly designed and implemented. This type of design provides easy software maintenance and update. This feature should prove very useful. The addition of a new display format will involve writing a new routine to provide the display and linking it into the system. Thus the system can be kept current to meet the needs of examining any new type of generation system.

Bibliography

1. Military Standard Aircraft Electric Power Characteristics, MIL-STD-704B (17 November 1975).
2. Test Procedure for 150 KVA Electrical Power Generating System, Sundstrand Model 150IDG02, Component Improvement Program, Contract Number F 33657-71-C-0810, Sundstrand Aviation Corporation (23 July 1971).
3. Power System Evaluation Test, Data Recording and Reduction System, T6-5813-1, The Boeing Company (October 1974).
4. Wall, Marly B. Electrical Power System of the Boeing 767 Airplane.
5. Electrical generating System, VSCF. General Electric Company (September 1979).
6. General Specification for Aircraft Electric Generating System, Variable Speed Constant Frequency. MIL-E-230001B(AS). (28 June 1976).
7. General Specification for Aircraft Generator System, 400 Hertz Alternating Current. MIL-G-21480A(AS). (30 September 1970).

Appendix A
Analysis Software

PROGRAM ANALYSIS

```

1  PROGRAM ANALYSIS
2
3  THIS ROUTINE COMPUTES THE RMS VALUES OF EACH OF THREE PHASES
4  OF VOLTAGE AND CURRENT. THE AVERAGE REQUIRED IN THE RMS
5  CALCULATION IS PERFORMED USING A NUMERICAL INTEGRATION
6  TECHNIQUE OVER THE PERIOD OF THE VOLTAGE OF EACH PHASE.
7
8
9  DIMENSION VAL1(20),VAL2(20),RMS(20),PF(3)
10  DOUBLE PRECISION CYTH(3),PER(3),TIM1,TIM2
11  INTEGER PHASEN(3),BUFULL(3),EOF
12  C RESERVE LOCATION AT WHICH TO OVERLAY DISPLAY ROUTINE
13  IN LINE
14  BIAS EQU $
15  FINI
16  C CHOOSE INTEGRATION RANGE
17  WRITE(9,200)
18  200 FORMAT(' ENTER NUMBER OF CYCLES OVER WHICH TO'
19  1,/, ' INTEGRATE, 11')
20  READ(7,300)
21  300 FORMAT(11)
22  C INITIALIZE DISK FILE FOR RESULTS
23  CALL DINIT
24  C INITIALIZE FLAGS TO INDICATE NUMERICAL INTEGRATION HAS NOT BEGUN
25
26  DO 5 NPN=1,3
27  PHASEN(NPN)=0
28  INIT. FLAGS TO INDICATE IF VALID RMS VALUE EXISTS
29  BUFULL(NPN)=0

```

```

39 C SET NUMBER OF A/D CONVERTERS IN USE
30 NADC=6
31 C INITIALIZE RAW DATA FILE
32 CALL GETBLK(N,N,N,2)
33 C SET FLAG TO INDICATE BEGINNING OF DATA
34 EOF=2
35 C GET TWO SETS OF DATA
36 10 CALL READA(NADC,VAL1,VAL2,TIM1,TIM2,EOF)
37 C CHECK IF END OF DATA WAS ENCOUNTERED
38 IF(EOF.EQ.1)GO TO 50
39 C PROCESS PHASE 1 DATA
40 CALL NUMINT<1,VAL1,VAL2,TIM1,TIM2,PHASON,BUFULL,RMS,CYTM,PER,
PF,L>
41 IF<PHASON<1>.EQ.0>GO TO 10
42 C CHECK IF RMS VALUE FOR PHASE 1 EXISTS
43 IF<BUFULL<1>.EQ.0>GO TO 20
44 C WRITE CALCULATED VALUES TO DISK
45 CALL DWRITE<1,RMS<1>,RMS<4>,PF<1>,PER<1>,CYTM<1>>
46 C RESET PHASE 1 FLAG
47 BUFULL<1>=0
48 C PROCESS PHASE 2 DATA
49 20 CALL NUMINT<2,VAL1,VAL2,TIM1,TIM2,PHASON,BUFULL,RMS,CYTM,PER,
PF,L>
50 C CHECK IF RMS FOR PHASE 2 EXISTS
51 IF<BUFULL<2>.EQ.0>GO TO 30
52 C WRITE CALCULATED VALUES TO DISK
53 CALL DWRITE<2,RMS<2>,RMS<5>,PF<2>,PER<2>,CYTM<2>>
54 C RESET PHASE 2 FLAG
55 BUFULL<2>=0
56 C PROCESS DATA FOR PHASE 3
57 30 CALL NUMINT<3,VAL1,VAL2,TIM1,TIM2,PHASON,BUFULL,RMS,CYTM,PER,
PF,L>
58 C CHECK IF RMS FOR PHASE 3 EXISTS
59 IF<BUFULL<3>.EQ.0>GO TO 10

```

```

80 C WRITE CALCULATED VALUES TO DISK
81 CALL DWRITE(3,RMS(3),RMS(6),PF(3),PER(3),CYTM(3))
82 C RESET PHASE 3 FLAG
83 BUFULL(3)=0
84 C GET NEXT SET OF DATA
85 GO TO 10
86 CALL DWRITE
87 C LOAD OVERLAY ROUTINE,DIS, WHICH DISPLAYS ANALYZED DATA
88 C BIAS IS ADDRESS TO LOAD DIS AT
89     INLINE
90     LDI,2 BIAS
91     REX,#2B
92     DEC ERROR
93     DEC GLM
94     DEC QDIS
95     DEC Q
96     BRU OUT
97 ERROR REX,#13
98     DEC QDIS
99     NOP
100    FINI
101    STOP
102    END
103 C
104 C SUBROUTINE NUMINT(NPH,U1,U2,T1,T2,PHON,BUFULL,RMS,CYTM,PER,PF
105 C
106 C THIS ROUTINE CARRIES OUT THE SUMMATION NECESSARY TO COMPUTE THE
107 C RMS VALUES OF EACH PHASE OF GENERATOR TEST DATA INDEPENDENTLY.
108 C
109     DIMENSION ZU(3),U1(1),U2(1),RMS(1),SUNK(6),PEAK(3),PF(1)
110     1,ZT1(3),ZT2(3),PERIOD(3),PFSUM(3)
111     DOUBLE PRECISION CYTM(1),T1,T2,PER(1)

```

```

103 C      INTEGER PHON(1),BUFULL(1),UNDX,CYKNT(3)
104 C      DERIVE VOLTAGE INDEX
105 C      UNDX=NPH+3
106 C      CHECK FOR POSITIVE ZERO CROSSING OF VOLTAGE
107 C      IF<<V1<UNDX>.LE.0.>.AND.<V2<UNDX>.GT.0.>>GO TO 20
108 C      SEE IF INTEGRATION HAS BEGUN FOR THIS PHASE
109 C      IF<PHON<NPH>.EQ.0>RETURN
110 C      UPDATE PEAK VALUE
111 C      IF<V2<UNDX>.GT. PEAK<NPH>>PEAK<NPH>=V2<UNDX>
112 C      CHECK FOR NEGATIVE Z. CROSS. OF VOLT.
113 C      IF<<V1<UNDX>.GE.0.>.AND.<V2<UNDX>.LT.0.>>GO TO 80
114 C      NOT A Z. CROSS; EVALUATE FULL TRAPEZOID
115 C      SUM<UNDX>=SUM<UNDX>+<V1<UNDX>+V2<UNDX>+2)*TDEL
116 C      CHECK FOR POS. Z. CROSS. OF CURRENT
117 C      IF<<V1<NPH>.LE.0.>.AND.<V2<NPH>.GT.0.>>GO TO 90
118 C      CHECK FOR NEG. Z. CROSS. OF CURRENT
119 C      IF<<V1<NPH>.GE.0.>.AND.<V2<NPH>.LT.0.>>GO TO 90
120 C      NOT A Z. CROSS.; EVALUATE FULL TRAPE.
121 C      SUM<NPH>=SUM<NPH>+<V1<NPH>+V2<NPH>+2)*TDEL
122 C      UPDATE POWER FACTOR SUM
123 C      PFSUM<NPH>=PFSUM<NPH>+<V1<UNDX>*V1<NPH> + V2<UNDX>*V2<NPH>+
124 C      1*TDEL
125 C      RETURN
126 C      CHECK IF THIS IS BEGINNING OF INTEGRATION
127 C      IF<PHON<NPH>.EQ.0>GO TO 50
128 C      COMPUTE TIME OF FINAL ZERO CROSSING
129 C      ZT2<NPH>=-V2<UNDX>/<V2<UNDX>-V1<UNDX>)*SNGL<T2-T1>+SNGL<T2>
130 C      COMPUTE AREA OF FINAL PORTION OF VOLT. BEFORE Z. CROSS.
131 C      SUM<UNDX>=SUM<UNDX>+V1<UNDX>+2)*ZT2<NPH>-SNGL<T1>
132 C      INCREMENT CYCLE COUNTER
133 C      CYKNT<NPH>=CYKNT<NPH>+1
134 C      CHECK FOR FINAL CYCLE OF INTEGRATION RANGE
135 C      IF<CYKNT<NPH>.EQ.NCY>GO TO 30
136 C      CONTINUE SUMMATION WITH NEXT CYCLE

```

```

127      SUM<UNDX>=SUM<UNDX>+V2<UNDX>**2*(SNGL<T2>-ZT2<NPH>)>
128      CHECK FOR ZERO CROSSING OF CURRENT
129      IF<<V1<NPH>.LE.0.>AND.<V2<NPH>.GT.0.>>GO TO 25
130      IF<<V1<NPH>.GE.0.>AND.<V2<NPH>.LT.0.>>GO TO 25
131      NO Z. CROSS., EVALUATE FULL TRAPEZOID
132      SUM<NPH>=SUM<NPH>+(V1<NPH>**2+V2<NPH>**2)*TDEL
133      GO TO 27
134      FIND TIME OF ZERO CROSSING OF CURRENT
135      ZT=-V2<NPH>/<V2<NPH>-V1<NPH>)*TDEL+SNGL<T2>
136      EVALUATE SUM AROUND Z. CROSS.
137      SUM<NPH>=SUM<NPH>+(V1<NPH>**2*(ZT-SNGL<T1>)>+
138      1*(V2<NPH>)*ZT*SNGL<T2>-ZT)>
139      UPDATE POWER FACTOR SUM
140      PFSUM<NPH>=PFSUM<NPH>+(V1<UNDX>)*V1<NPH>*(ZT2<NPH>-SNGL<T1>)>+
141      1*(V2<UNDX>)*V2<NPH>*(SNGL<T2>-ZT2<NPH>)>
142      RETURN
143      FINAL CYCLE OF INTEGRATION RANGE
144      C
145      CALCULATE PERIOD OF INTEGRATION
146      PERIOD<NPH>=ZT2<NPH>-ZT1<NPH>
147      CALCULATE RMS OF VOLTAGE
148      RMX<UNDX>=SQRT<DO<SUM<UNDX>/2./PERIOD<NPH>>>
149      CALCULATE CREST FACTOR
150      CF<NPH>=PEAK<NPH>/RMX<UNDX>
151      BEGIN SUMMATION OF VOLTAGE FOR NEXT CYCLE
152      SUM<UNDX>=V2<UNDX>**2*(SNGL<T2>-ZT2<NPH>)>
153      RESTART PEAK VALUE
154      PEAK<NPH>=V2<UNDX>
155      CALCULATE VALUE OF CURRENT AT VOLT. Z. CROSS.
156      ZUK<NPH>=<V2<NPH>-V1<NPH>)*ZT2<NPH>-SNGL<T1>)>
157      1/SNGL<T2-T1>)*V1<NPH>
158      CHECK FOR Z. CROSS. OF CURRENT
159      IF<<V1<NPH>.LE.0.>AND.<ZUK<NPH>.GT.0.>>GO TO 35
160      IF<<V1<NPH>.GE.0.>AND.<ZUK<NPH>.LT.0.>>GO TO 35

```

```

161 C NO Z. CROSS., EVALUATE FULL TRAPEZOID
162 SUM(NPH)=SUM(NPH)<<(U1(NPH)**2+ZU(NPH)**2)<<ZT2(NPH)-SNGL(T1)>>

163 GO TO 40
164
165 C FIND TIME OF ZERO CROSSING
166 ZT=-ZU(NPH)<<ZU(NPH)-U1(NPH)>><<ZT2(NPH)-SNGL(T1)>>+ZT2(NPH)
167 C EVALUATE SUM AROUND Z. CROSS.
168 SUM(NPH)=SUM(NPH)<<U1(NPH)**2<<ZT-SNGL(T1)>>
169 1<<ZU(NPH)**2<<ZT2(NPH)-ZT>>
170 C CALCULATE RMS OF CURRENT
171 RMS(NPH)=SQRT<<SUM(NPH)/2.><<PERIOD(NPH)>>
172 C BEGIN SUMMATION OF CURRENT FOR NEXT INTEGRATION PERIOD
173
174 C CHECK FOR ZERO CROSSING
175 IF<<ZU(NPH).LE.0.>>AND.<<U2(NPH).GT.0.>>GO TO 42
176 IF<<ZU(NPH).GE.0.>>AND.<<U2(NPH).LT.0.>>GO TO 42
177 C NO Z. CROSS., EVALUATE FULL TRAPEZOID
178 SUM(NPH)=<<ZU(NPH)**2+U2(NPH)**2)<<SNGL(T2)-ZT2(NPH)>>
179 GO TO 45
180
181 C FIND TIME OF Z. CROSS.
182 ZT=-U2(NPH)<<U2(NPH)-ZU(NPH)>><<SNGL(T2)-ZT2(NPH)>>+SNGL(T2)
183 SUM(NPH)=<<ZU(NPH)**2<<ZT-ZT2(NPH)>>+<<U2(NPH)**2<<SNGL(T2)-ZT>>

184 C UPDATE BUFFER FULL FLAG
185 BUFULL(NPH)=BUFULL(NPH)+1
186 C RESET CYCLE COUNTER
187 CYCNT(NPH)=0
188 C UPDATE POWER FACTOR SUM
189 PFSUM(NPH)=PFSUM(NPH)<<U1<UNDX>*U1(NPH)<<ZT2(NPH)-SNGL(T1)>>
190 C COMPUTE POWER FACTOR
191 PFC(NPH)=PFSUM(NPH)/2.<<PERIOD(NPH)>>/RMS<UNDX>/RMS(NPH)
192 C BEGIN SUMMATION OF POWER FACTOR FOR NEXT CYCLE
193 PFSUM(NPH)=U2<UNDX>*U2(NPH)<<SNGL(T2)-ZT2(NPH)>>
194 C COMPUTE PERIOD OF WAVEFORM
195 PER(NPH)=DBLE<<PERIOD(NPH)>>/NCY>

```

```

194 C SET IDENTIFYING TIME FOR RMS DATA
195 CYTM(NPH)=DBLE(ZT1(NPH))
196 EXCHANGE Z. CROSS. TIMES
197 ZT1(NPH)=ZT2(NPH)
198 RETURN
199 BEGINNING OF INTEGRATION
200 IF(NPH.NE.1)GO TO 55
201 DETERMINE SAMPLE PERIOD
202 TDEL=SNGL(T2-T1)
203 FIND TIME OF BEGINNING Z. CROSS.
204 ZT1(NPH)=-V2(UNDX)/(V2(UNDX)-V1(UNDX))*SNGL(T2-T1)+SNGL(T2)
205 INITIALIZE VOLTAGE PEAK VALUE
206 PEAK(NPH)=V2(UNDX)
207 INITIALIZE CYCLE COUNTER
208 CYKNT(NPH)=0
209 DETERMINE VALUE OF CURRENT AT Z. CROSS.
210 ZUK(NPH)=(V2(NPH)-V1(NPH))/(ZT1(NPH)-SNGL(T2-T1)+V1(
NPH)
211 START INTEGRATION OF NEW CYCLE
212 SET FLAG
213 PHOK(NPH)=1
214 BEGIN SUMMATION OF VOLTAGE
215 SUK(UNDX)=V2(UNDX)**2**SNGL(T2)-ZT1(NPH))
216 CHECK IF CURRENT HAS Z. CROSS.
217 IF(ZUK(NPH).LE.0.)AND.(V2(NPH).GT.0.)GO TO 70
218 IF(ZUK(NPH).GE.0.)AND.(V2(NPH).LT.0.)GO TO 70
219 IF NO Z. CROSS., BEGIN SUMMATION OF CURRENT
220 SUK(NPH)=(ZUK(NPH)**2+V2(NPH)**2)**SNGL(T2)-ZT1(NPH))
221 GO TO 75
222 FIND TIME OF Z. CROSS.
223 ZT=-V2(NPH)/(V2(NPH)-ZUK(NPH))*SNGL(T2)-ZT1(NPH)+SNGL(T2)
224 BEGIN SUMMATION OF CURRENT
225 SUK(NPH)=ZUK(NPH)**2**ZT-ZT1(NPH)+V2(NPH)**2**SNGL(T2)-ZT)
226 BEGIN SUMMATION OF POWER FACTOR

```

```

227 75 PFSUM(NPH)=(V2<UNDX)*V2<NPH)>*(SNGL<T2>-ZT1<NPH>)>
228 RETURN
229 C NEG. Z. CROSS. OF VOLTAGE
230 C FIND TIME OF Z. CROSS.
231 80 ZT=-V2<UNDX>/<V2<UNDX>-V1<UNDX>)*SNGL<T2-T1>+SNGL<T2>
232 C UPDATE VOLT. SUM.
233 SUM<UNDX>=SUM<UNDX>+<V1<UNDX>*(ZT-SNGL<T1>)>
234 1+<V2<UNDX>)*SNGL<T2>-ZT>
235 C CHECK FOR Z. CROSS. OF CURRENT
236 IF<V1<NPH>.LE.0.>.AND.<V2<NPH>.GT.0.>GO TO 90
237 IF<V1<NPH>.GE.0.>.AND.<V2<NPH>.LT.0.>GO TO 90
238 C NOT A Z. CROSS. EVALUATE FULL TRAPE. FOR CURRENT SUM
239 SUM<NPH>=SUM<NPH>+<V1<NPH>*(Z2+V2<NPH>*(Z2)*TDEL
240 C UPDATE POWER FACTOR SUM
241 PFSUM<NPH>=PFSUM<NPH>+<V1<UNDX>*(V1<NPH>*(ZT-SNGL<T1>)>
242 1+<V2<UNDX>)*V2<NPH>)*SNGL<T2>-ZT>
243 RETURN
244 C ZERO CROSS. OF CURRENT
245 C FIND Z. CROSS. TIME
246 90 ZT=-V2<NPH>/<V2<NPH>-V1<NPH>)*SNGL<T2-T1>+SNGL<T2>
247 C UPDATE CURRENT SUM.
248 SUM<NPH>=SUM<NPH>+<V1<NPH>*(ZT-SNGL<T1>)>+<V2<NPH>*(Z
249 1*(SNGL<T2>-ZT)>
250 C UPDATE POWER FACTOR SUM
251 PFSUM<NPH>=PFSUM<NPH>+<V1<UNDX>*(V1<NPH>*(ZT-SNGL<T1>)>
252 1+<V2<UNDX>)*V2<NPH>)*SNGL<T2>-ZT>
253 RETURN
254 END
255 C
256 C SUBROUTINE DWRITE(N,CURRENT,VOLTAGE,PF,PERIOD,TIME)
257 C
258 C ROUTINE WRITES ONE SET OF ANALYSIS RESULTS TO DISK
259 C
260 C

```

```

261 INTEGER CURRENT<1>, VOLTAGE<1>, PERIOD<1>, TIME<1>, PF<1>
262 C OUTPUT PHASE #
263 CALL WRIT29<N,0>
264 C OUTPUT RMS CURRENT
265 DO 10 I=1,2
266 CALL WRIT29<CURRENT<I>,0>
267 C OUTPUT RMS VOLTAGE
268 DO 20 I=1,2
269 CALL WRIT29<VOLTAGE<I>,0>
270 C OUTPUT POWER FACTOR
271 DO 30 I=1,2
272 CALL WRIT29<PF<I>,0>
273 C OUTPUT PERIOD
274 DO 40 I=1,3
275 CALL WRIT29<PERIOD<I>,0>
276 C OUTPUT TEST TIME OF CYCLE
277 DO 50 I=1,3
278 CALL WRIT29<TIME<I>,0>
279 RETURN
280 END
281 C
282 C
283 SUBROUTINE DINIT
284 CALL WRIT29<0,2>
285 RETURN
286 END
287 C
288 C
289 SUBROUTINE DNEOF
290 CALL WRIT29<0,1>
291 CALL READ29<0,2>
292 RETURN
293 END
TOTAL RECORDS WRITTEN = 294

```

```

1  SUBROUTINE READAKNADC,U1,U2,T1,T2,EOF>
2
3  ROUTINE MAKES TWO CONSECUTIVE BLOCKS OF "RAW" GENERATOR DATA
4  AVAILABLE TO THE CALLING ROUTINE
5
6  * * * * *
7  * * * * * CATALOGUED ON UL 10,9,79 * * * * *
8  * * * * *
9
10 EXTERNAL SUBROUTINES REQUIRED:
11
12 NAME LOCATION
13 1.GETBLK UL
14
15 DIMENSION U1(1),U2(1)
16 INTEGER EOF
17 DOUBLE PRECISION T1,T2
18 EOF=2 SIGNIFIES FIRST CALL TO THIS ROUTINE
19 TWO FULL BLOCKS OF DATA MUST BE RECEIVED FROM ROUTINE GETBLK
20 LATER CALLS WILL USE LATTER "OLD" SET OF DATA
21 AND ONE "NEW" SET
22 IF(EOF.NE.2)GO TO 5
23 EOF=0
24 GET FIRST SET OF DATA
25 CALL GETBLK(NADC,U1,T1,EOF>
26 GO TO 15
27
28 C ON ALL CALLS EXCEPT FIRST, USE SECOND SET OF "OLD" DATA

```

```

29 C AS FIRST IN "NEW" PAIR
30 5 DO 10 J=1,NADC
31 10 U1<J>=U2<J>
32 T1=T2
33 C GET SECOND SET OF DATA
34 15 CALL GETBLK<NADC,U2,T2,EOF>
35 RETURN
36 END
TOTAL RECORDS WRITTEN = 37
EXIT
$AUR CI 4
$END LIST

```

```

1  SUBROUTINE GETBLK(NADC,DATA,TIME,EOF)
2
3  ROUTINE GETS A BLOCK OF RAW TEST DATA FROM FILE 30, CONVERTS
4  THE A/D DATA TO EQUIVALENT FLOATING POINT VALUES OF VOLTAGE AND
5  AMPS, AND CONVERTS CLOCK READING TO DOUBLE PRECISION TIME VALUE
6  CORRESPONDING TO NUMBER OF SECONDS AFTER FIRST COMPLETE BLOCK
7  OF DATA.
8  NOTE: BODY OF ROUTINE IS WRITTEN IN ASSEMBLY LANGUAGE TO SPEED
9  EXECUTION.
10
11
12
13

```

```

14  * * * * *
15  * * * * *
16  * * * * *
17  * * * * *
18  * * * * *
19  * * * * *
20  * * * * *
21  * * * * *
22  * * * * *
23  * * * * *
24  * * * * *
25  * * * * *
26  * * * * *
27  * * * * *
28  * * * * *

```

EXTERNAL SUBROUTINES REQUIRED:

NAME	LOCATION
------	----------

1. READ	LB
2. READ30	UL

```

DOUBLE PRECISION CLOCK,ZERO,TIMCONST,DSLE
REAL DATA(1),SCALEF(6),OFFSET(6)
INTEGER DATADER,NORD,BUF(120),UET(10),EOF,NEWCLK(3)
INTEGER TIME(3),TEMP(4),OLDCLK(5)
EQUIVALENCE (OFFSET(1),BUF(2)),(SCALEF(1),BUF(14))

```

```

500 C SET UP UFT FOR READING CALIBRATION DATA FROM FILE 30
501 C NOTE: ZBFBS = 0, CODE FOR 30
502 C DATA UFT<0,ZBFBS,ZA400,7*0/
503 C SET UP CONSTANTS TO BE USED IN ASSEMBLY LANGUAGE CODE
504 C DATA ZERO,TIMCONST,K12/0.D0,200.D-9,12/
505 C NOTE: TIMCONST = 200 * 1000-9 BECAUSE EACH INCREMENT OF CLOCK
506 C CORRESPONDS TO 200 NANoseconds (I.E., FREQUENCY = 5MHZ)
507 C
508 C DATADDR=0
509 C IEOF=0
510 C CHECK FOR EOF=2 INPUT WHICH IS REQUIRED BEFORE ANY READING CAN
511 C TAKE PLACE
512 C IF<EOF.NE.2>GO TO 10
513 C IF EOF=2 (THIS IS FIRST READING OF DATA), EXECUTE FOLLOWING
514 C INSTRUCTIONS
515 C
516 C READ CALIBRATION DATA FROM FILE 30
517 C NOTE EQUIVALENCES SET UP ABOVE FOR ARRAY BUF
518 C UFT<4>=23
519 C CALL READ<BUF,256,UFT>
520 C INITIALIZE KEY IN NEWCLK<1> TO INDICATE THIS IS BEGINNING OF
521 C READING OF DATA
522 C NEWCLK<1>=0
523 C MUST INITIALIZE READ30 ROUTINE
524 C CALL READ30<WORD,EOF>
525 C RETURN
526 C FOLLOWING INSTRUCTIONS BUILD BLOCK OF "ADJUSTED" TEST DATA
527 C
528 C GET DATA WORD FROM FILE 30
529 C CALL READ30<WORD,EOF>
530 C CHECK FOR END OF FILE
531 C IF<EOF.EQ.1>RETURN
532 C FIND BEGINNING OF BLOCK (WORD=0)
533 C IF<WORD.EQ.0>GO TO 20

```

```

63 IF(NEWCLK<1>.EQ.0)GO TO 10
64 C IF NULL WORD DOES NOT OCCUR EVERY 10TH WORD, NOTIFY USER
65 WRITE(2,100)
66 FORMAT(' BLOCK ERROR - SUBROUTINE GETBLK'>
67 GO TO 10
68 C SKIP "0" WORD, GET CLOCK READING
69 CALL READ33(WORD.EOF)
70 IF(FOF.EQ.1)RETURN
71 INLINE
72 * CHECK KEY IN NEWCLK<1> TO SEE IF A PREVIOUS DATA BLOCK EXISTS
73 LDM,1 NEWCLK ;REG1 = NEWCLK<1>
74 TRB,1,1 A1 ;IF PREVIOUS DATA EXISTS, GO TO A1
75 IF NO PREVIOUS BLOCK EXISTS, SET UP STRUCTURE FOR DOUBLE
76 PRECISION FLOATING POINT
77 *****
78 INITIALIZE EXPONENT, #4900 PLACES DECIMAL AFTER END OF LAST BIT
79 (EXPONENT = 126 HEX)
80 LDI,1 #4900
81 STM,1 NEWCLK ;NEWCLK<1>=#4900
82 * ZERO MIDDLE WORD
83 ZGR,1
84 STM,1 NEWCLK+1 ;NEWCLK<2>=0
85 * PLACE DATA IN LAST WORD
86 LDM,1 WORD
87 STM,1 NEWCLK+2 ;NEWCLK<3>= CLOCK READING
88 BRU A2
89 IF PREVIOUS DATA BLOCK EXISTS, CHECK TO SEE IF CLOCK READING
90 HAS "ROLLED OVER"
91 NOTE: ROLL OVER OCCURS APPROX. EVERY 13 MSEC. SEE WRITE-UP
92 FOR CLK CARD IN CUSTOM ELECTRONICS MANUAL FOR DETAILS
93 LDM,1 WORD ;REG1 = CLOCK READING
94 STM,1 NEWCLK+2 ;NEWCLK<3> = CLOCK READING
95 CHECK TO SEE IF SIGN OF LAST WORD OF PREVIOUS CLOCK READING
96 DIFFERS FROM SIGN OF LAST WORD OF PRESENT CLOCK READING

```

```

97 LDM,2 OLDCLK+2 ;REG2 = OLDCLK<3>
98 TOR,2,2 ;INVERT
99 ORR,2,1 ;COMPARE PREVIOUS TO PRESENT
100 TERB,2,0 A2 ;WERE SIGNS SAME?
101 * IF NOT, INCREMENT MIDDLE WORD OF PRESENT READING
102 ASHM,15 NEWCLK+1
103 ** CHECK TO SEE IF THIS CAUSED ENTIRE READING TO ROLL OVER
104 <I.E., SIGN CHANGE FROM PREVIOUS>
105 LDM,1 NEWCLK+1 ;REG1 = NEWCLK<2>
106 LDM,2 OLDCLK+1 ;REG2 = OLDCLK<2>
107 TOR,2,2 ;INVERT REG 2
108 ORR,2,1 ;COMPARE TWO READINGS
109 TERB,2,0 A2 ;WERE SIGN BITS SAME?
110 * IF NOT, INCREMENT EXPONENT OF PRESENT READING
111 ASHM,15 NEWCLK
112 ** FOLLOWING INSTRUCTIONS CONVERT CLOCK READING TO SECONDS
113 LFM,4 NEWCLK ;REGS 4,5,6 = CLOCK READING
114 FAND,4 ZERO ;NORMALIZE
115 FAND,4 TIMCONST ;CONVERT TO SECONDS
116 * STORE REGS 4,5,6,7 IN TEMPORARY LOCATION
117 SFM,4 TEMP
118 ** GET USEFUL INFORMATION <DOUBLE PRECISION FLOATING POINT
119 REPRESENTATION OF TIME> IN REGS 5,6,7
120 LFM,5 TEMP
121 * STURE TIME READING IN RETURN VARIABLE
122 SFR,5 TIME
123 ** SAVE PRESENT CLOCK READING TO BE USED FOR CHECKING IF NEXT
124 READING HAS ROLL OVER
125 LFM,5 NEWCLK
126 SFM,5 OLDCLK
127 ** FOLLOWING CODE INPUTS 6 DATA WORDS AND ADJUSTS EACH BY
128 SUBTRACTING OFFSET AND MULTIPLYING BY SCALE FACTOR
129 ****
130 INITIALIZE LOOP COUNTER IN REG 1

```

```

151  ZRR,1
152  * OBTAIN ADDRESS OF DATA (RETURN VARIABLE)
153  LDM,2 DATA ;GET ADDR OF DATA
154  STM,2 DATADDR
155  * FOLLOWING IS LOOP WHICH INPUTS AND ADJUSTS SIX DATA WORDS
156  STM,1 TEMP ;SAVE LOOP COUNTER IN TEMP(1)
157  * CALL READ30 WHICH INPUTS A DATA WORD FROM DISK FILE 30
158  BLN,8 READ30
159  DFC 2,WORD,IEOF ;PASS PARAMETERS
160  LDM,1 TEMP ;RESTORE LOOP COUNTER
161  LDM,3 WORD ;GET A/D DATA WORD
162  TTR,3,3 ;MUST INVERT IT
163  * SET UP EXPONENT OF SINGLE PRECISION FLOATING POINT NUMBER.
164  * #4100 REPRESENTS EXPONENT OF 107 HEX WHICH PLACES DECIMAL
165  * AFTER FIRST BIT OF BINARY FRACTION (A/D READING IS < 1)
166  LDI,2 04100
167  * CHECK IF DATA WORD IS NEGATIVE
168  TEB,3,0 00 ;IF NEGATIVE, GO TO A5
169  * SUBTRACT APPROPRIATE OFFSET VALUE WHICH IS LOCATED BY USING
170  * REG 1 AS AN INDEX
171  FSN,2,1 OFFSET
172  FDM,2,1 SCALEF ;MULTIPLY BY APPROPRIATE SCALE FACTOR
173  * STORE EXPONENT IN FIRST WORD OF DATA WHICH IS POINTED TO
174  * BY DATADDR
175  STM,2 DATADDR
176  * INCREMENT DATADDR TO POINT TO SECOND WORD OF DATA
177  ADDM,15 DATADDR
178  * STORE BINARY FRACTION IN DATA
179  STM,3 DATADDR
180  * INCREMENT DATADDR TO POINT TO FIRST WORD OF NEXT ELEMENT
181  * OF DATA AREA.
182  ADDM,15 DATADDR
183  PER,1,14 ;INCREMENT LOOP COUNTER BY 2
184  CRAB,1 K12,0-4,A3 ;CHECK FOR END OF LOOP, IF NOT BRANCH B

```

ACK

```

165      BRU A6
166      FOR A NEGATIVE R/D DATA WORD, MUST ADJUST SIGN BIT IN
167      EXPONENT AND ADJUST DATA WORD
168      ERG,4
169      ERG,5      ;PREPARE REGS 4,5
170      TTR,3,3    ;INVERT REG 3,BINARY FRACTION PART OF DATA WORD
171      FSR,4,2    ;SUBTRACT 0,BUT ADJUST WORD
172      TTR,2,4
173      TTR,3,5    ;PLACE BACK IN REGS 2,3
174      BRU A4     ;BRANCH BACK TO ADJUSTING ROUTINE
175      NOP       ;EXIT ASSEMBLY LANGUAGE CODE
176      FINI
177      C SKIP PARITY AND CHECKSUM WORDS
178      CALL READCHKWORD,ECF>
179      CALL READCHKWORD,EOF>
180      RETURN
181      END
TOTAL RECORDS WRITTEN = 102
EXIT
$AUR CI 4
$END LIST

```

```

1  CGM READ30
2  INT READ30
3  SUBROUTINE READ30(WORD,EOF)
4  THIS ROUTINE READS ONE WORD FROM DEVICE 30 AND RETURNS
5  A VALUE EOF=0 OR IF END OF FILE ENCOUNTERED,EOF=1
6  IF THIS ROUTINE IS CALLED WITH EOF=2,ALL POINTERS WILL BE
7  INITIALIZED,WHICH MUST BE DONE BEFORE ANY READING
8  IS ATTEMPTED
9  READ30 TRR,7,8
10 LDAX,1,7
11 CRMB,1
12 BRU A14
13 ZRR,1
14 STM,1
15 AER,1,15
16 STM,1
17 LDI,1
18 STM,1
19 BRU,7
20 ZRR,1
21 STM,1,7 2
22 LDM,1
23 CRMB,1 K2944,A10,5*6
24 BRU
25 LDM,2,1
26 STM,2,7 1
27 AEM,15
28 BRU,7

          *****
          READ30 TRR,7,8
          LDAX,1,7
          CRMB,1
          BRU A14
          ZRR,1
          STM,1
          AER,1,15
          STM,1
          LDI,1
          STM,1
          BRU,7
          ZRR,1
          STM,1,7 2
          LDM,1
          CRMB,1 K2944,A10,5*6
          BRU
          LDM,2,1
          STM,2,7 1
          AEM,15
          BRU,7

          TRKNUM
          MAXTRK
          3000
          POINT
          3

          TRKNUM=0
          MAXTRK=1
          POINT=3000
          RETURN

          ;GET CALL LOCATION FOR INDEXING
          ;GET EOF
          K2,5*6,A14 ;SEE IF =2,GO TO A14 OF NOT

          ;IF<POINT.GE.2944>GO TO A10
          ;WORD=BUFF<POINT>
          ;POINT=POINT+1
          ;RETURN

```

29	A10	LDM,1	TRKNUM	
30		CRMS,1	MAXTRK, \$+4, A11	; IF< TRKNUM.LT.MAXTRK>GO TO A11
31		LDI,1,1		
32		STM#,1,7	2	; EOF=1
33		BRU,7	3	; RETURN
34	A11	LDM,1	TRKNUM	
35		TERS,1,1	A13	; IF< TRKNUM.NE.0>GO TO A13
36		LDI,1	23	
37		STM,1	UFT+3	; SET UP UFT FOR SECTOR 23
38		LDI,2	UFT	
39		REX,0		
40		DFC BUFF,2		
41		LDM,1	BUFF	
42		STM,1	MAXTRK	; SAVE TRACK COUNT
43		LDM,1	TRKNUM	
44	A13	MM,1	K24	
45		STM,1	UFT+3	; UFT+3=TRKNUM*24
46		LDI,2	UFT	
47		REX,0		; CALL READ< BUFF,2944*2,UFT>
48		DFC BUFF,2944*2		
49		ADDM,15	TRKNUM	; TRKNUM=TRKNUM+1
50		ZDR,1		
51		STM,1	POINT	; POINT=0
52		BRU	A12	
53	BUFF	RES 2944		
54	UFT	DFC 0,030 , #9499,0,0,0		
55	POINT	RES 1		
56	TRKNUM	RES 1		
57	MAXTRK	RES 1		
58	K2	DFC 2		
59	K2944	DFC 2944		
60	K24	DFC 24		
61		END		
TOTAL RECORDS WRITTEN =			62	

Appendix B
Display Software

PROGRAM DISPLAY

ROUTINE PRESENTS VARIOUS PLOTS OF GENERATOR TEST DATA.
 TEST DATA WAS ACQUIRED DURING EXECUTION OF ROUTINE RUNSYS.
 THIS RAW DATA WAS ANALYZED BY ROUTINE ANALYSIS AND STORED
 ON DISK FILE 29.
 THIS ROUTINE READS THE CONDENSED DATA AND DISPLAYS IT TO
 THE USER VIA A TEKTRONIX TERMINAL.
 USER SELECTS DISPLAY BY ENTERING OPT COMMANDS.
 LIST OF OPT COMMANDS AND DEFINITION:

- IS - ISOLATE ON RMS VALUES OF CHOSEN PHASE
- CY - CYCLES: ACTUAL WAVEFORM
- RE - FULL REPLOT OF INITIAL PLOT
- QK - QUICK REPLOT OF INITIAL PLOT
- FQ - PLOT OF FREQUENCY DEVIATION
- PR - PRINT RMS VALUES PER CYCLE

FURTHER EXPLANATION OF EACH OPTION IS GIVEN IN TEXT OF
 SUBROUTINE IMPLEMENTING IT.

FILE ASSIGNMENTS NEEDED FOR THIS ROUTINE:

- 7 = TKI (TEKTRONIX INPUT) - FOR ENTERING OPT COMMANDS
- 8 = TKO (TEKTRONIX OUTPUT) - PLOT LABELS, ERROR MESSAGES, ETC.
- 21 = GPI - SCRATCH FILE FOR PLOT ROUTINE
- 10 = LST - PRINT TABULAR DATA, CONTROLLED BY LST TASK

1 C
 2 C
 3 C
 4 C
 5 C
 6 C
 7 C
 8 C
 9 C
 10 C
 11 C
 12 C
 13 C
 14 C
 15 C
 16 C
 17 C
 18 C
 19 C
 20 C
 21 C
 22 C
 23 C
 24 C
 25 C
 26 C
 27 C
 28 C

```

*** ** * CATALOGUED ON LM 4,22,89 *** ** *
EXTERNAL SUBROUTINES REQUIRED BY MAIN AND SUBROUTINES:

NAME      LOCATION
1. READ29   UL
2. INITT    UL
3. UCURSR   UL
4. DMINDO   UL
5. TRINDO   UL
6. MOVEA    UL
7. DATA    UL
8. UNDEL    UL
9. FOUT     UL
10. PLACL   UL
11. ICUT    UL
12. GETBLK  UL
13. WISOOT  UL
14. DRIDEL  UL
15. MOVABG  UL
16. ANSTR   UL
17. READA   UL
18. FOURPLOT UL
19. CKPLOT  UL

DIMENSION RMSPK(6), JADK(2), TIME(2), PLOTPK(2), DUMPK(
INTEGER CPI,FPOINT,ECP
DOUBLE PRECISION PERIODX(3),TEEGIN
SET RMS PEAKS TO VALUE FOR INITIAL PLOT
DATA RMSPK/3x500.,5x150./

```

```

63 C NADC = NUMBER OF A/D CONVERTERS USED IN TEST
64 C I.E. NUMBER OF CHANNELS OF DATA
65 NADC=6
66 C NOTIFY USER THAT DATA IS AVAILABLE FOR DISPLAY
67 C ERASE SCREEN
68 CALL INITK(S60)
69 WRITEK(8,100)
70 FORMAT(1X,40(' '),/, ' ***** TEST DATA AVAILABLE'
71 1, ' FOR DISPLAY *****',/,1X,40(' '),/,)
72 C ALLOW USER TO SELECT "SPECIAL" OPTIONS
73 WRITEK(9,150)
74 FORMAT( ' ***** FOR DATA ACQUISITION RATE INFORMATION'
75 1,/, ' ENTER 'YE'', OTHERWISE, ENTER 'GO'',)
76 READK(7,200)IANS
77 FORMAT(2)
78 IF(IANS.EQ.'YE')CALL ACSPED(NADC)
79 WRITEK(9,250)
80 FORMAT( ' ***** FOR SPECIAL PLOT OF DRIVE STAND SPEED DATA'
81 1,/, ' ENTER 'YE'', OTHERWISE FOR GENERATOR'
82 1,/, ' TEST SUMMARY PLOT, ENTER 'GO'',)
83 READK(7,300)IANS
84 IF(IANS.EQ.'YE')CALL DCSPEED(TIME,TBEGIN,NAVE,RMSPK)
85 C FIND TIME OF FIRST DATA POINT
86 CALL GETBLKN(N,N,2)
87 EOF=0
88 CALL GETBLKNADC,DUM,TBEGIN,EOF)
89 C DISPLAY INITIAL PLOT OF 3 PHASE VOLTS AND AMPS
90 C SET FLAG TO INDICATE INITIAL PLOT AFTER ANALYSIS
91 INIT=1
92 CALL GETPLOT(NADC,TBEGIN,RMSPK,INIT)
93 C SET FLAG TO INDICATE VERTICAL PLOT
94 IF(EOF)
95 C SELECT FURTHER PLOT OPTIONS
96 999 WRITEK(8,300)

```

```

97 380  FORMAT' ENTER PLOT OPTIONS,'
98 1,/, ' FOR LIST OF OPTIONS, ENTER '??''>
99  CALL PICKOPT(LINE)
100 GO TO (99,1030,2000,4000,5000,6000,7000),LINE
101 PRINT RMS VALUES OF SELECTED PHASE OVER SELECTED TIME
102 RMSE=
103 SELECT NULL INPUT (JAD<1>), PHASE TO BE DISPLAYED (JAD<2>),
104 BEGINNING TIME OF DISPLAY (TIME<1>), AND ENDING TIME (TIME<2>)
105 1000 CALL PICKTIME(JAD, TIME, INCR)
106 CALL ISOLATE(MAGC, JAD, TIME, RMSPK, TBEGIN)
107 C SET FLAG TO INDICATE HORIZONTAL PLOTTING
108 INCR=1
109 C SELECT PLOT OPTIONS
110 GO TO 909
111 C PLOT ACTUAL WAVEFORMS OF SELECTED PHASE
112 SELECT PHASE TO BE DISPLAYED, JAD<1>, AND FLAG WHETHER DATA
113 POINTS ARE TO BE HIGHLIGHTED (YES, JAD<2>=1) NO, JAD<2>=0),
114 BEGINNING (TIME<1>) AND ENDING (TIME<2>) PLOT TIMES
115 2000 CALL PICKTIME(JAD, TIME, INCR)
116 CALL PLOTCK(JAD, MAGC, TIME, RMSPK, TBEGIN)
117 C SET FLAG TO INDICATE HORIZONTAL PLOTTING
118 INCR=1
119 C ASK USER IF HE WANTS FOURIER ANALYSIS
120 WRITE(6,2000)
121 FORMAT' TO PERFORM FOURIER ANALYSIS,'
122 1' ENTER 'Y' YES, OTHERWISE ENTER, 'GO''>
123 READ(7,200)IGNS
124 IF (IGNS.NE.'Y') GO TO 909
125 PICK PHASE AND CYCLE FOR ANALYSIS
126 CALL PICKTIME(JAD, TIME, INCR)
127 PERFORM FOURIER ANALYSIS
128 CALL FOURIER(JAD<1>, TIME, IANS)
129 DETERMINE IF ORPLOT WAS INVOCKED
130 IF NOT, GO TO NEW PLOT IMMEDIATELY

```

```

131 IF IANS.NE.'OK'>GO TO 4000
132 IF SO, WAIT FOR USER RESPONSE
133 READ<7,200>IANS
134 C MUST NOW PRODUCE QUICK PLOT IN ORDER TO CHOOSE NEW OPTION
135 GO TO 4000
136 C REPLOT QUICK (AVERAGED) PLOT OF 3 PHASE VOLTS AND AMPS.
137 USED MAINLY FOR SELECTING TIME RANGE TO BE USED IN
138 OTHER PLOT OPTIONS
139 4000 GO TO 10
140 C PRODUCE FREQUENCY DEVIATION DISPLAY
141 SELECT PHASE VOLTAGE TO BE DISPLAYED (JACK<1>),NULL
142 INPUT (JACK<2>), BEGINNING TIME OF DISPLAY (TIME<1>),
143 AND ENDING TIME (TIME<2>)
144 5000 CALL PICKTIME<JAD,TIME,INCR>
145 C PLOT FREQUENCY DEVIATION
146 CALL FREQU<JACK<2>,TIME<1>,TIME<2>,TEEGIN>
147 C SET FLAG TO INDICATE HORIZONTAL PLOTTING
148 INCR=1
149 C SELECT PLOT OPTIONS
150 GO TO 500
151 C PRODUCE TABULAR DISPLAY OF TEST DATA
152 SELECT PHASE TO BE DISPLAYED (JACK<1>), NUMBER OF READINGS
153 TO BE AVERAGED BEFORE DISPLAYING (JACK<2>=1,9), BEGINNING
154 TIME OF DISPLAY (TIME<1>), AND ENDING TIME (TIME<2>)
155 6000 CALL PICKTIME<JAD,TIME,INCR>
156 C PRODUCE TABLE
157 CALL PRINT<JAD,TIME,TEEGIN>
158 C WAIT FOR OPERATOR ACTION
159 GO TO 7000
160 C PRODUCE TABULAR DISPLAY OF RAW DATA
161 7000 CALL PICKTIME<JAD,TIME,INCR>
162 C PRODUCE TABLE
163 CALL PRINT<JAD,TIME,TEEGIN>
164 C WAIT FOR OPERATOR ACTION

```


AIR FORCE INST OF TECH WRIGHT-PATTERSON AFB OH SCMOO--ETC F/G 14/2
COMPUTER ANALYSIS OF 400 HZ AIRCRAFT ELECTRICAL GENERATOR TEST --ETC(1)
JUN 80 P G GABERDIEL
AFIT/GCS/EE/80-1

COMPUTER ANALYSIS OF 400 HZ AIRCRAFT ELECTRICAL GENERATOR TEST --ETC(1)

UNCLASSIFIED

AFIT/GCS/EE/80-1

21

2 OF 2

4D
5100336

END

DATE _____

FILMED

7-8

DTIC

```

199 LINE=0
200 IF(OPT.EQ.'IS')LINE=2
201 IF(OPT.EQ.'CY')LINE=3
202 IF(OPT.EQ.'CK')LINE=4
203 IF(OPT.EQ.'FG')LINE=5
204 IF(OPT.EQ.'PR')LINE=6
205 IF(OPT.EQ.'PC')LINE=7
206 IF(LINE.NE.0)RETURN
207 C PRINT ERROR MESSAGE
208 WRITE(9,200)
209 FORMAT(' INVALID COMMAND' )
210 GO TO 10
211 LINE=1
212 RETURN
213 END
214 C
215 C
216 C
217 C
218 C
219 C
220 C
221 C
222 C
223 C
224 C
225 C
226 C
227 C
228 C
229 C
230 C
231 C
232 C

SUBROUTINE PICKTIME(JAD,TIME,OPT)

ROUTINE ALLOWS USER TO SELECT A BEGINNING AND ENDING TIME
FOR USE IN PLOT. THIS IS DONE BY POSITIONING CURSOR TO
SELECTED TIME AND PRESSING A KEYBOARD CHARACTER THEN
CARRIAGE RETURN. THESE CHARACTERS (JAD(1) AND JAD(2))
ARE RETURNED TO THE CALLING ROUTINE AS INTEGER VALUES.
NOTE: OPT IS INPUT VARIABLE WHICH SPECIFIES WHETHER
IN PRESENT PLOT TIME AXIS IS VERTICAL (OPT=3) OR
HORIZONTAL (OPT=1).

    DIMENSION JAD(1),TIME(1)
    INTEGER OPT
    SELECT 2 TIME VALUES AND CHARACTERS
    DO 2 K=1,2
    ADJUST OPT SO THAT IT CAN BE USED IN COMPUTED GO TO
    STATEMENT

```

```

233 1 KOPT=OPT+1
234 C GO TO ROUTINE WHICH HANDLES TIME AXIS SPECIFIED BY OPT
235 15 GO TO(10,20),KOPT
236 C ROUTINE WHICH HANDLES VERTICAL TIME AXIS.
237 C GET A CHARACTER AND TIME VALUE
238 C NOTE: VAL IS X VALUE OF CURSOR AND IS NOT USED
239 10 CALL UCURSR(JADK),VAL,TIMEK>>
240 C GO TO 30
241 C ROUTINE WHICH HANDLES HORIZONTAL TIME AXIS
242 C NOTE: VAL IS Y VALUE OF CURSOR AND IS NOT USED
243 C CALL UCURSR(JADK),TIMEK,VAL>
244 C CONVERT ASCII CHARACTER TO INTEGER VALUE
245 30 JADK)=IAND(ILEFT(JADK),-8),227F)-2230
246 C CHECK FOR VALID CHARACTER
247 IF(JADK).LT.0.OR.JADK).GT.9)GO TO 15
248 2 CONTINUE
249 RETURN
250 END
251 C
252 C
253 C
254 C
255 C
256 C
257 C
258 C
259 C
260 C
261 C
262 C
263 C
264 C
265 C
266 C

```

SUBROUTINE QKPL0T(NADC,TBEGIN,PEAK,INIT)
 ROUTINE PLOTS A SUMMARY OF GENERATOR TEST DATA CONSISTING
 OF 3 PHASE RMS VOLTAGES AND 3 PHASE RMS CURRENTS.
 THIS PLOT IS USED IN SELECTING FURTHER PLOT OPTIONS
 FOLLOWING ANY DISPLAY WHICH DOES NOT HAVE A TIME SCALE
 (E.G., INITIAL PLOT, TABLES, FOURIER COEFFICIENTS, ETC.)
 NOTE: DATA IS AVERAGED SO THAT ONLY 100 POINTS ARE PLOTTED.
 PLOTS ARE SCALED TO ACCOMMODATE MAXIMUM READING.
 FIRST CALL OF THIS ROUTINE AFTER ANALYSIS OF DATA
 (INDICATED BY INIT=1) DETERMINES MAXIMUM RMS VALUES FOR
 EACH PHASE VOLTS AND AMPS (PEAK), A MAXIMUM SCALE FOR
 VOLTS AND AMPS (SCALE), AND ACTUAL STARTING AND ENDING
 TIMES OF ANALYZED DATA (ZTIME AND ZTIME).

```

267 C DIMENSION PEAK(1), TEMPK(6), SCALE(2)
268 INTEGER ECF
269 DOUBLE PRECISION ZTIF, ZTIML, TEGIN, TIME, PER
270 C DETERMINE IF INITIAL CALL
271 IF (INIT.NE.1) GO TO 5
272 C SET START TIME FOR PLOT EQUAL TO TIME OF FIRST
273 C DATA POINT
274 ZTIF=TEGIN
275 C DEFAULT END TIME FOR PLOT
276 ZTIML=DELE(6.)
277 C INITIALIZE ARRAY TO DETERMINE MAX. OF EACH SIGNAL
278 DO 10 J=1, NADC
279 TEMPK(J)=0
280 C SET INITIAL VALUES FOR SCALES
281 SCALE(1)=PEAK(1)
282 SCALE(2)=PEAK(4)
283 C ERASE SCREEN
284 CALL INITK(50)
285 C PRINT LABEL INFORMATION STORED DURING PRE-TEST CALIBRATION
286 C OF A/D CONVERTERS
287 CALL LABL
288 C DETERMINE SIZE OF TIME INCREMENT REQUIRED TO PLOT
289 C 100 POINTS
290 TINDIV=(SKEL(ZTIML-ZTIF))/100.
291 C SET PHASE NUMBER
292 NPH=1
293 C REWIND DATA FILE
294 CALL READ2(0,2)
295 C INITIALIZE END OF FILE FLAG
296 ECF=0
297 C INITIALIZE TIME MARKER
298 TIMARK=TINDIV
299 C INITIALIZE POINT COUNTER
300

```

```

301 IPTS=0
302 C INITIALIZE RUNNING TOTALS
303 VOLTSUM=0.
304 AMPSUM=0.
305 C COMPUTE FIRST AVERAGE
306
307 C GET FIRST DATA SET
308 C CALL DREAD(NPH,AMP,VOLT,PF,PER,TIME,EOF)
309 C UPDATE PEAK VALUES
310 IF(INIT.NE.1)GO TO 25
311 IF(AMP.GT.TEMPKNPH)>TEMPKNPH)=AMP
312 IF(VOLT.GT.TEMPKNPH+3)>TEMPKNPH+3)=VOLT
313 C ADD NEW VALUES TO RUNNING TOTALS
314 AMPSUM=AMPSUM+AMP
315 VOLTSUM=VOLTSUM+VOLT
316 C INCREMENT POINT COUNTER
317 IPTS=IPTS+1
318 C CHECK IF TIME MARKER EXCEEDED,
319 IF NOT, GET NEXT DATA SET
320 IF(SNEL<TIME).LT.TIME)GO TO 20
321 C COMPUTE AVERAGE VALUES AND SAVE FOR PLOTTING
322 FLOTA=AMPSUM/IPTS
323 FLOTV=VOLTSUM/IPTS
324 C SAVE TEST TIME FOR PLOTTING
325 PLOTTM=SNEL<TIME)
326 C INCREMENT TIME MARKER
327 TIMMRK=TIMMRK+TIMDIV
328 C COMPUTE SECOND AVERAGED PLOT VALUE
329
330 C RESET POINT COUNTER
331 IPTS=0
332 C RESET TOTALS
333 AMPSUM=0.
334 VOLTSUM=0.

```

```

335 C GET NEXT DATA SET
336 C CALL DREADK(NPH,AMP,VOLT,PF,PER,TIME,EOF)
337 C IF END OF FILE REACHED, CHANGE PHASE
338 C IF(EOF.EQ.1)GO TO 40
339 C UPDATE PEAK ARRAY
340 C IF(INIT.NE.1)GO TO 35
341 C IF(AMP.GT.TEMPKNPH)>TEMPKNPH)=AMP
342 C IF(VOLT.GT.TEMPKNPH+3)>TEMPKNPH+3)=VOLT
343 C ADD NEW VALUES TO TOTALS
344 C AMPSUM=AMPSUM+AMP
345 C VOLTSUM=VOLTSUM+VOLT
346 C INCREMENT POINT COUNTER
347 C IPTS=IPTS+1
348 C CHECK IF TIME MARKER EXCEEDED
349 C IF(SNEL<TIME).LT.TIMARK)GO TO 30
350 C COMPUTE AVERAGE VALUES
351 C AMPSUM=AMPSUM/IPTS
352 C VOLTSUM=VOLTSUM/IPTS
353 C PLOT TWO AVERAGED CURRENT VALUES
354 C
355 C SET VIRTUAL WINDOW
356 C CALL DWINDK-SCALE(1),0.,SNEL<ZTIME>,SNEL<ZTIME>>
357 C COMPUTE VALUE TO BE USED IN SETTING SCREEN WINDOW
358 C INC=170<NPH-1>
359 C SET SCREEN WINDOW
360 C CALL TWINDK(10+INC,160+INC,120,760)
361 C MOVE TO FIRST POINT
362 C CALL MOVEK-PLOTA,PLOTTM)
363 C DRAW TO SECOND POINT
364 C CALL DRAWK-AMPEUM,SNEL<TIME>>
365 C SAVE SECOND POINT FOR NEXT PLOT
366 C PLOTA=AMPEUM
367 C PLOT TWO AVERAGED VOLTAGE VALUES
368 C

```

```

369 C SET VIRTUAL WINDOW
370 C CALL DWINDOK-SCALE(2),0.,SNGL(ZTIME),SNGL(ZTIME)>>
371 C COMPUTE VALUE TO BE USED IN SETTING SCREEN WINDOW
372 C INC=170*(NPH+3-1)
373 C SET SCREEN WINDOW
374 C CALL TWINDOK(10+INC,160+INC,120,760)
375 C MOVE TO FIRST POINT
376 C CALL MOVEAK-PL0TV,PLOTTM>
377 C DRAW TO SECOND POINT
378 C CALL DRAWAK-VOLTSUM,SNGL(TIME)>>
379 C SAVE SECOND POINT FOR NEXT PLOT
380 C PLOTU=VOLTSUM
381 C SAVE TIME
382 C PLOTTM=SNGL(TIME)
383 C GET NEXT DATA SET
384 C GO TO 27
385 C DRAW CURRENT AXIS
386 C
387 C SET VIRTUAL WINDOW
388 C CALL DWINDOK-SCALE(1),0.,SNGL(ZTIME),SNGL(ZTIME)>>
389 C SET SCREEN WINDOW
390 C INC=170*(NPH-1)
391 C CALL TWINDOK(10+INC,160+INC,120,760)
392 C CALL MOVEAK(0.,SNGL(ZTIME))
393 C CALL DRAWAK(0.,SNGL(ZTIME)),12>
394 C DRAW VOLTAGE AXIS
395 C CALL DWINDOK-SCALE(2),0.,SNGL(ZTIME),SNGL(ZTIME)>>
396 C INC=170*(NPH+3-1)
397 C CALL TWINDOK(10+INC,160+INC,120,760)
398 C CALL MOVEAK(0.,SNGL(ZTIME))
399 C CALL DRAWAK(0.,SNGL(ZTIME)),12>
400 C CHANGE PHASE NUMBER
401 C NPH=NPH+1
402 C CHECK FOR COMPLETION

```

```

403 IF(NPH.LE.3)GO TO 15
404 C LABEL EACH PLOT WITH ITS PEAK VALUE
405 WRITE(8,1500)(TEMPK(J),J=1,6)
406 1500 FORMAT(/,1X,6('PEAK=',F5.0,2X))
407 C LABEL WITH PHASE INFO
408 WRITE(8,1000)
409 1000 FORMAT(1X,/,2(2X,'PHASE 1',4X,'PHASE 2',4X,
410 1'PHASE 3',2X))
411 WRITE(8,2000)
412 2000 FORMAT(1X,3(2X,'CURRENT',3X),3(2X,'VOLTAGE',3X))
413 C SAVE FIRST DATA TIME
414 IF(INIT.NE.1)GO TO 60
415 ZTIME=TIME
416 C SET PEAK ARRAY
417 DO 200 J=1,NABC
418 200 PEEK(J)=TEMPK(J)
419 C DETERMINE ACTUAL SCALE VALUES
420 SCALE(1)=PEAK(1)
421 IF(PEAK(2).GT.SCALE(1))SCALE(1)=PEAK(2)
422 IF(PEAK(3).GT.SCALE(1))SCALE(1)=PEAK(3)
423 SCALE(2)=PEAK(4)
424 IF(PEAK(5).GT.SCALE(2))SCALE(2)=PEAK(5)
425 IF(PEAK(6).GT.SCALE(2))SCALE(2)=PEAK(6)
426 C RESET INITIAL CALL FLAG
427 INIT=0
428 C WAIT FOR USER RESPONSE
429 60 READ(7,3000)IANS
430 3000 FORMAT(A2)
431 RETURN
432 END
433 C
434
435 SUBROUTINE LABL
436 INTEGER UFT(6),LABEL(36)

```

```

437 C      PROGRAM PUTS TEXT FROM ADDISK PROGRAM ON TOP OF SCREEN
438 DATA UFT,2*0,2A400,3*0,
439 UFT(2)=ICAN(30)
440 UFT(4)=47
441 CALL READ(LABEL,72,UFT,.TRUE.)
442 CALL HLABEL(0,775,LABEL,72)
443 RETURN
444 END
445
446 C      SUBROUTINE ISOLATE(NADC,JAD,TIME,PEAK,TBEGIN)
447
448 C      ROUTINE WHICH PLOTS RMS VALUES FOR VOLTAGE AND CURRENT OF
449 C      PHASE SELECTED IN JAD(1) OVER TIME RANGE TIME(1) TO TIME(2)
450
451 C      DIMENSION JAD(1),TIME(1),PEAK(1)
452 C      INTEGER EOF
453 C      DOUBLE PRECISION ZTIM1,ZTIM2,TBEGIN,PERIOD
454 C      ERASE SCREEN
455 C      CALL INITK(50)
456 C      SET PHASE NUMBER
457 C      NPH=JAD(1)
458 C      INITIALIZE DISC READ
459 C      CALL READ(0,2)
460 C      INITIALIZE EOF OF FILE FLAG (EOF)
461 C      EOF=0
462 C      READ FIRST SET OF DATA
463 C      CALL DREAD(NPH,AMP1,VOLT1,PF,PERIOD,ZTIM1,EOF)
464 C      CHECK TO SEE IF IN TIME RANGE REQUESTED
465 C      IF (ENCL(ZTIM1),LT,TIME(1)) GO TO 1
466 C      INITIALIZE VARIABLES FOR COMPUTING AVERAGE OF PF, VOLTAGE,
467 C      AND CURRENT OVER TIME RANGE DISPLAYED
468 C      PFSUM=PF
469 C      VAVE=VOLT1
470

```

```

471 CAVE=AMP1
472 INITIALIZE POINT COUNTER
473 NCNT=1
474 READ NEXT SET OF DATA
475 CALL DRAKK(NPH,AMP2,VOLT2,PF,PERIOD,ZTIM2,EOF)
476 UPDATE AVERAGE ACCUMULATION VARIABLES
477 PFSUM=PFSUM+PF
478 VAUE=VAUE+VOLT2
479 CAVE=CAVE+AMP2
480 INCREMENT POINT COUNTER
481 NCNT=NCNT+1
482 CHECK TO SEE IF EOF ENCOUNTERED
483 IF(EOF.EQ.1)GO TO 15
484 SET SCREEN TO PLOT PHASE VOLTAGE
485 CALL DWHIOKTIME(1),TIME(2),-.5,PEAK(NPH+3))
486 CALL THIOK(100,990,400,700)
487 MOVE TO PRECEDING POINT AND THEN PLOT CURRENT POINT
488 CALL MOVEXSNEL(ZTIM1),VOLT1)
489 CALL DRAKXSNEL(ZTIM2),VOLT2)
490 SET SCREEN FOR PHASE CURRENT
491 CALL DWHIOKTIME(1),TIME(2),-.5,PEAK(NPH))
492 CALL THIOK(100,990,100,400)
493 PLOT CURRENT VALUES
494 CALL MOVEXSNEL(ZTIM1),AMP1)
495 CALL DRAKXSNEL(ZTIM2),AMP2)
496 CHECK TO SEE IF REQUESTED TIME RANGE HAS BEEN EXCEEDED
497 IF(SNEL(ZTIM2).GE.TIME(2))GO TO 15
498 INTERCHANGE PREVIOUS AND PRESENT DATA VALUES
499 ZTIM1=ZTIM2
500 VOLT1=VOLT2
501 AMP1=AMP2
502 GET NEXT SET OF DATA
503 GO TO 5
504 COMPUTE AVERAGE VALUES FOR PF,VOLTAGE, AND CURRENT

```

```

505 15 PPAVE=PPFSUM/NCNT
506 UAVE=UAVE/NCNT
507 CAVE=CAVE/NCNT
508 C COMPUTE REAL AND REACTIVE POWER VALUES BASED ON AVERAGE
509 C VALUES COMPUTED FOR VOLTAGE, CURRENT, AND POWER FACTOR
510 REALPR=UAVE*CAVE
511 PPAVE=PPAVE/CAVE
512 RECOPIR=SQRT((PPRIM**2)-(REALPR*1000.)*2))/1000.
513 C PLOT AXIS
514 C SET SCREEN TO LABEL VOLTAGE PLOT
515 CALL DTIMEOUT(1),TIME(2),-.5,PEAK(NPH+3))
516 CALL THINBOX(100,500,400,700)
517 C DRAW AXES FOR VOLTAGE PLOT
518 CALL MOVEC(TIME(1),PEAK(NPH+3))
519 CALL DRAWC(TIME(1),0.)
520 CALL DRAWC(TIME(2),0.)
521 C LABEL VOLTAGE PLOT
522 CALL THINBOX(10,1010,400,700)
523 CALL VLOC(50,650,'VOLTS',5)
524 C LABEL PEAK VOLTAGE VALUE
525 CALL FOUT(20,750,PEAK(NPH+3),2)
526 CALL HLOC(50,750,'-',1)
527 C SET SCREEN TO LABEL CURRENT PLOT
528 CALL DTIMEOUT(1),TIME(2),-.5,PEAK(NPH))
529 CALL THINBOX(100,500,100,400)
530 C DRAW AXES
531 CALL MOVEC(TIME(1),PEAK(NPH))
532 CALL DRAWC(TIME(1),0.)
533 CALL DRAWC(TIME(2),0.)
534 C LABEL CURRENT AXIS
535 CALL THINBOX(10,1010,50,400)
536 CALL VLOC(50,300,'AMPS',4)
537 C LABEL PEAK CURRENT VALUE
538 CALL FOUT(20,400,PEAK(NPH),2)

```

```

539 CALL HLABEL(95,350,'-',1)
540 LABEL TEST TIME
541 STTM=(TIME(1)-SNGL(TBEGIN))*1000.
542 CALL FOUT(90,55,STTM,2)
543 FHTM=(TIME(2)-SNGL(TBEGIN))*1000.
544 CALL FOUT(90,55,FHTM,2)
545 CALL HLABEL(359,55,'MSEC AFTER START OF TEST',24)
546 LABEL PHASE NUMBER
547 CALL TWIND(10,1010,103,760)
548 CALL VLABEL(20,600,'PHASE',5)
549 CALL IOUT(20,400,100,1)
550 C OUTPUT POWER INFORMATION
551 CALL TWIND(10,1010,10,60)
552 CALL IVALUES(15,55)
553 WRITE(6,100)REALPAR,REACTPAR,PFAVE
554 FORMAT('REAL PAR = ',F5.2,' KU, REACTIVE PAR = ',F5.2
555 1,' KV, AVE PAR FACTOR = ',F5.2)
556 C OUTPUT AVERAGE VOLTAGE AND CURRENT VALUES
557 WRITE(8,2000)VAVE,CAVE
558 FORMAT('AVE RMS VOLTAGE = ',F9.2,' VOLTS',
559 1,' AVE RMS CURRENT = ',F9.2,' AMPS')
560 CALL TWIND(100,500,100,400)
561 C WAIT FOR USER RESPONSE
562 READ(7,3000)IANS
563 FORMAT(A2)
564 RETURN
565 END
566
567 SUBROUTINE PLOTCK(JJ,NADC,TM,PK,TBEGIN)
568
569 C
570 C ROUTINE WHICH PLOTS ACTUAL WAVEFORM OF PHASE VOLTAGE
571 C AND PHASE CURRENT OF THE PHASE SPECIFIED BY JK(1)
572

```

```

573 C JK2> SPECIFIES WHETHER DATA POINTS ARE TO BE HIGHLIGHTED
574 C (=1, YES; =0, NO)
575 C PLOT IS OVER TIME RANGE BETWEEN TK1> AND TK2>
576 C PK IS AN ARRAY CONTAINING THE PEAK RMS VALUES OF
577 C EACH SIGNAL
578 C
579 C
580 C DIMENSION JK1>, TK1>, PK1>, DATA6>
581 C INTEGER EOF, OPT, UNDX, CNDX
582 C REAL NOUTH, NOW, NOWC
583 C DOUBLE PRECISION TIME, TEGIN, CYTM, PER
584 C ACOSD CONVERTS POWER FACTOR INTO PHASE ANGLE
585 C ACOSD(X)=DATA6GRT(1.-X*X)/X*183./3.1415926
586 C UNDX IS INDEX INTO ARRAYS FOR VOLTAGE VALUES
587 C UNDX=JK1>+3
588 C CNDX IS INDEX INTO ARRAYS FOR CURRENT VALUES
589 C CNDX=JK1>
590 C COMPUTE ABSOLUTE PEAKS FROM RMS PEAKS
591 C PK=PK(UNDX)/.707 + 20.
592 C CPK=PK(CNDX)/.707 + 50.
593 C ERASE SCREEN
594 C CALL INITK99>
595 C INITIALIZE ROUTINES WHICH READ FROM DISK
596 C CALL DINIT
597 C CALL GETLK(N,N,2>)
598 C CALL READESK(0,2>)
599 C INITIALIZE EOF FLAG
600 C EOF=0
601 C READ FIRST BLOCK OF DATA
602 C I CALL GETLK(NADD,DATA,TIME,EOF>
603 C CHECK FOR END OF FILE
604 C IF(EOF.EQ.1)RETURN
605 C CONVERT TIME READING TO SINGLE PRECISION AND STORE
606 C IN NOUTH

```

```

607      NOUTH=SNGL<TIME>
608      CHECK TO SEE IF IN TIME RANGE REQUESTED
609      IF<NOUTH.LT.TMK1>>GO TO 1
610      WANT TO DETERMINE MAXIMUM VALUE OF DATA PLOTTED
611      FOR USE IN LABELLING PLOTS <UMAX,CMAX>
612      UMAX=ABS<DATA<CNDX>>
613      CMAX=ABS<DATA<CNDX>>
614      C SAVE PRESENT VOLTAGE, CURRENT, AND TIME READINGS
615      TEMPU=DATA<CNDX>
616      TEMPC=DATA<CNDX>
617      TEMPT=NOUTH
618      C READ NEXT BLOCK OF DATA
619      CALL GETBLK<NADC,DATA,TIME,EOF>
620      CHECK FOR EOF
621      IF<EOF.EQ.1>RETURN
622      C SAVE PRESENT TIME, VOLTAGE, AND CURRENT READINGS
623      NOUTH=SNGL<TIME>
624      NOUTV=DATA<CNDX>
625      NOUTC=DATA<CNDX>
626      C PERFORM CHECKS FOR MAX VALUES
627      IF<ABS<NOUTV>>.GT.UMAX>UMAX=ABS<NOUTV>
628      IF<ABS<NOUTC>>.GT.CMAX>CMAX=ABS<NOUTC>
629      C SET SCREEN TO PLOT VOLTAGE VALUE
630      400 CALL DWINDX<TMK1>,TMK2>,-UPK,UPK>
631      CALL TRINDX<120,500,400,700>
632      C MOVE TO PRECEDING POINT THEN PLOT PRESENT POINT
633      CALL MOVEX<TEMP,TEMPU>
634      C CHECK IF HIGHLIGHT FLAG IS ON
635      IF<JK<2>.EQ.0>>GO TO 450
636      C DRAW SMALL TRIANGLE AT EACH DATA POINT
637      CALL DWATRI<10>
638      CALL DWINDX<NOUTH,NOUTV>
639      C SET SCREEN TO PLOT CURRENT VALUE
640      CALL DWINDX<TMK1>,TMK2>,-CPK,CPK>

```

```

641 CALL TWINDOK(120,930,100,400)
642 C PLOT CURRENT VALUE
643 CALL HOUERX(TEMP,TEMPC)
644 CALL DREAS(NONTM,NOMC)
645 C CHECK TO SEE IF TIME RANGE EXCEEDED
646 IF(NONTM.LT.TMK2)GO TO 2
647 C INITIALIZE VARIABLES TO COMPUTE AVERAGE OF POWER
648 C FACTORS OVER MEANINGFUL TIME RANGE
649 PF=0.
650 IPTS=0
651 C INITIALIZE ROUTINE WHICH READS FROM DISK
652 CALL READ2(0,2)
653 EOF=0
654 C READ BLOCK OF RMS DATA; ONLY VALUES OF INTEREST
655 ARE POWF (4TH PARAMETER)
656 10 CALL DREAD(CNDX,A,V,POWF,PER,CYTM,EOF)
657 C CHECK TO SEE IF IN TIME RANGE REQUESTED
658 IF(SNGL(CYTM).LT.TMK1)GO TO 10
659 C SET FLAG TO INDICATE IF NO VALID PARSE ANGLE WAS COMPUTED
660 NOPH=1
661 C IF NO CURRENT IS PRESENT, SKIP THIS READING
662 20 IF(A.LT.PK(CNDX))-10.GO TO 25
663 C CLEAR FLAG
664 NOPH=0
665 C SUM PF VALUES
666 PF=PF+POWF
667 C UPDATE COUNTER
668 IPTS=IPTS+1
669 C READ ANOTHER BLOCK OF RMS VALUES
670 25 CALL DREAD(CNDX,A,V,POWF,PER,CYTM,EOF)
671 C CHECK FOR EOF
672 IF(EOF.EQ.1)GO TO 253
673 C CHECK TO SEE IF TIME RANGE EXCEEDED
674 IF(SNGL(CYTM).LE.TMK2)GO TO 20

```

```

675 C IF NO VALID PHASE ANGLE WAS COMPUTED, SKIP
676 250 IF(NOPH.EQ.1)GO TO 26
677 C COMPUTE AVERAGE VALUE FOR PHASE ANGLE FROM
678 C AVERAGE FF VALUE
679 PHANG=ACOSD(FF/IPTS)
680 C ADJUST PHANG TO VALUE BETWEEN 0 AND 180
681 IF(PHANG.LT.0.)PHANG=PHANG+180.
682 C PLOT VOLTAGE AXIS
683 26 CALL DNINDO(TK1),TK2,-UPK,UPK)
684 CALL THINDO(120,560,460,760)
685 C DRAW VERTICAL AXIS
686 CALL MOVE(TK1),UPK)
687 CALL DRAW(TK1),-UPK)
688 C DRAW HORIZONTAL AXIS
689 CALL MOVE(TK1),0.)
690 CALL DRAW(TK2),0.)
691 C SET LARGER SCREEN LIMITS FOR DRAWING LABELS
692 CALL THINDO(10,1010,460,760)
693 C LABEL VERTICAL AXIS
694 CALL VLABEL(500,630,'VOLTS',5)
695 PRINT REFERENCE VALUES
696 IF ACTUAL MAX. VOLTAGE VALUE WAS GREATER THAN EXPECTED,
697 DON'T PRINT ITS REFERENCE VALUE
698 IF(U1MAX.GT.UPK)GO TO 30
699 ULABEL=U1MAX
700 GO TO 35
701 VLABEL=UPK
702 CALL WINDO(TK1),VLABEL,IX,IY)
703 CALL FOUT(20,IY,VLABEL,2)
704 CALL FLABEL(115,IY-10,'-',1)
705 CALL WINDO(TK1),-VLABEL,IX,IY)
706 CALL FOUT(10,IY,-VLABEL,2)
707 CALL FLABEL(115,IY-10,'-',1)
708 CALL WINDO(TK1),0.,IX,IY)

```

```

709      CALL FOUT(20, IY, 0, 2)
710      IF NO PHASE ANGLE INFO., SKIP
711      IF (NORH.EQ.1) GO TO 35
712      LABEL HORIZ. AXIS WITH AVERAGE PHASE ANGLE
713      CALL THINDO(10, 1010, 440, 760)
714      CALL HL3EL(350, 440, 'PHASE ANGLE = ', 14)
715      CALL FOUT(550, 440, PHANG, 2)
716      CALL HL3EL(650, 440, 'DEGREES', 7)
717      C PLOT CURRENT AXIS
718      36      CALL EHINDO(TK1), TK(2), -CPK, CPK)
719      CALL THINDO(120, 560, 100, 400)
720      C DRAW VERTICAL AXIS
721      CALL MOVER(TK1), CPK)
722      CALL DRAWO(TK1), -CPK)
723      C DRAW HORIZONTAL AXIS
724      CALL MOVER(TK1), 0.)
725      CALL DRAWO(TK2), 0.)
726      C SET LARGER SCREEN LIMITS FOR LABELLING
727      CALL THINDO(10, 1010, 100, 400)
728      C LABEL VERTICAL AXIS
729      CALL VL3EL(500, 500, 'AMPS', 4)
730      C PRINT REFERENCE VALUES
731      IF ACTUAL MAX. CURRENT HAS GREATER THAN EXPECTED, DON'T
732      PRINT ITS REFERENCE VALUE
733      IF (CMAX.GT.CPK) GO TO 40
734      CLABEL=CMAX
735      GO TO 45
736      CLABEL=CPK
737      CALL WINDO(TK1), CLABEL, IX, IY)
738      CALL FOUT(20, IY, CLABEL, 2)
739      CALL HL3EL(115, IY-10, '-', 1)
740      CALL WINDO(TK1), -CLABEL, IX, IY)
741      CALL FOUT(10, IY, -CLABEL, 2)
742      CALL HL3EL(115, IY-10, '-', 1)

```

```

743 CALL WINDOT(TMK1),0.,IX,IY>
744 CALL FOUT(20,IY,0.,2)
745 LABEL HORIZ. AXIS WITH TIME INFO
746 STTN IS STARTING TIME OF PLOT
747 CALL TINDOK(10,1010,50,400)
748 STTN=(TK1)-SNEL(TEEGIN)*1000.
749 CALL FOUT(50,50,STTN,2)
750 C FHTM IS FINISHING TIME OF PLOT
751 FHTM=(TK2)-SNEL(TEEGIN)*1000.
752 CALL FOUT(50,50,FHTM,2)
753 CALL HLOC(350,50,'MSEC AFTER START OF TEST',24)
754 C SET SCREEN TO LABEL PHASE INFO
755 CALL TINDOK(10,1010,100,800)
756 CALL HLOC(450,700,'PHASE',5)
757 CALL ICUT(530,700,JUK1)
758 C RESET SCREEN LIMITS SO THAT VCURSR WILL WORK
759 C CORRECTLY
760 CALL TINDOK(100,950,100,400)
761 C WAIT FOR USER RESPONSE
762 READ(7,10)IANS
763 FORMAT(A2)
764 C IF A TRANSIENT TOO BIG TO BE DISPLAYED OCCURRED, THE USER
765 C NOW HAS THE OPPORTUNITY TO DISPLAY IT BY REPLOTTING
766 C THIS DISPLAY USING UMAX AND CMAX TO SCALE SCREEN
767 C TO SELECT REPLOTT, ENTER: RE
768 C TO CONTINUE, ENTER: GO
769 WRITE(6,150)
770 FORMAT(' FOR REPLOTT USING ACTUAL SCALING, '
771 1' ENTER 'RE', OTHERWISE ENTER 'GO'.')
772 READ(7,10)IANS
773 IF(IANS.NE.'RE')RETURN
774 C RESET SCALES
775 UPK=UMAX
776 CPK=CMAX

```

```

777 C REPLOT
778   GO TO 9
779   END
780
781 C
782 C
783 C SUBROUTINE FOURIER(IPH, TIME, IANS)
784
785 C THIS ROUTINE COMPUTES FOURIER COEFFICIENTS FOR ONE CYCLE OF
786 C PHASE VOLTAGE SPECIFIED BY IPH. THE CALCULATIONS ARE PERFORMED
787 C OVER THE FIRST FULL CYCLE WHICH OCCURS AFTER TIME(1). A PLOT
788 C OF THE FOURIER COEFFICIENTS VERSUS FREQUENCY IS PRESENTED TO
789 C DISPLAY THE RESULTS OF THIS ROUTINE.
790
791 C DIMENSION CSUK(60), DELUX(60), TIME(1), COEFF(60)
792 C 1, VALU(6), VALUE(6)
793 C INTEGER EOF
794 C DOUBLE PRECISION ZTIM, TIM1, TIM2, TDEL, ZTIM1, PERIOD, PERAVE
795 C 1, ZTIME
796 C DATA PI/3.1415927/
797
798 C ADJUST IPH TO INDEX VOLTAGE DATA OF SELECTED PHASE
799 C NTH=IPH+3
800 C SET NUMBER OF A/D CONVERTERS IN USE
801 C NADCEG
802 C DEFINE CONSTANT TO CONVERT DEGREES TO RADIANS FOR USE WITH
803 C SINE AND COSINE FUNCTIONS
804 C RAD=2.*PI
805 C COMPUTE AVERAGE PERIOD OF FIRST FIVE CYCLES OF TEST DATA TO
806 C DETERMINE BASE FREQUENCY TO BE USED IN ANALYSIS.
807
808 C INITIALIZE DISK READ ROUTINE
809 C CALL READ(0.2)
810 C INITIALIZE END OF FILE FLAG
811 C EOF=0

```

```

811 C INITIALIZE AVERAGE
812 PERAVE=0
813 CALL DREADK IPH,AMP,VOLT,PF,PERIOD,ZTIME,EOF>
814 IF<EOF,EO.1>GO TO 15
815 IF<SNG<ZTIME>.LT.TIME<1>>GO TO 5
816 C ACCUMULATE VALUES FOR PERIOD
817 DO 10 J=1,5
818 CALL DREADK IPH,AMP,VOLT,PF,PERIOD,ZTIME,EOF>
819 IF<EOF,EO.1>GO TO 15
820 PERAVE=PERAVE+PERIOD
821 C CALCULATE AVERAGE PERIOD
822 PERAVE=PERAVE/5
823 C CALCULATE BASE FREQUENCY BASED ON AVERAGE PERIOD
824 FREQ=1./SNG<PERAVE>
825 C SET NUMBER OF HARMONICS FOR WHICH FOURIER COEFFICIENTS ARE
826 C TO COMPUTED
827 WRITE<8,1000>
828 FORMAT<' ENTER NUMBER OF HARMONICS TO BE COMPUTED, I2'>
829 READ<7,2000>NHAZ
830 C SELECT NUMBER OF CYCLES OVER WHICH TO DETERMINE FOURIER
831 C COEFFICIENTS
832 WRITE<8,3000>
833 FORMAT<' ENTER NUMBER OF CYCLES OVER WHICH HARMONIC',IX
834 ' / , ANALYSIS WILL BE PERFORMED, I2'>
835 READ<7,4000>NHAUG
836 C INITIALIZE ROUTINES WHICH READ RAW TEST DATA FROM DISK
837 CALL DINIT
838 CALL GETTELK<N,N,N,2>
839 C SET EOF FLAG TO CAUSE READA ROUTINE TO BEGIN READING OF DATA
840 EOF=2
841 CALL READK NADC,VALU1,VALU2,TIM1,TIM2,EOF>
842 C CHECK FOR END OF FILE
843
844

```

```

845 IF<EOF.NE.1>GO TO 20
846 NOTIFY USER THAT END OF FILE OCCURRED AND RETURN TO
847 CALLING ROUTINE
848 WRITE<8,100>
849 FORMAT<' EOF ENCOUNTERED IN FOURIER'>
850 RETURN
851 CHECK IF IN TIME RANGE REQUESTED
852 IF<SNEL<TIM1>.GE.TIME<1>>GO TO 30
853 GET NEXT SET OF VALUES
854 CALL READ<NADC,VALU1,VALU2,TIM1,TIM2,EOF>
855 IF<EOF.EQ.1>GO TO 15
856 GO TO 20
857 CHECK FOR POSITIVE ZERO CROSSING OF PHASE VOLTAGE SELECTED
858 IF<(<VALU1<NPH>).LE.0.>AND(<VALU2<NPH>).GT.0.>>GO TO 35
859 IF NOT, GET NEXT SET OF VALUES
860 CALL READ<NADC,VALU1,VALU2,TIM1,TIM2,EOF>
861 IF<EOF.EQ.1>GO TO 15
862 GO TO 30
863 INTERPOLATE TO FIND TIME OF ACTUAL ZERO CROSSING
864 NOTE: THIS TIME WILL BE SUBTRACTED FROM ALL TIME VALUES
865 USED IN SINE AND COSINE FUNCTIONS DURING CALCULATION OF
866 FOURIER COEFFICIENTS. I.E., ZTIM1 IS TAKEN TO BE THE
867 POINT WHERE TIME=0.
868 ZTIM1=-VALU2<NPH>/(<VALU2<NPH>-VALU1<NPH>)*(<TIM2-TIM1>+TIM2)
869
870 COMPUTE POINT-BY-POINT NUMERICAL INTEGRATION OF TEST DATA
871 MULTIPLIED TIMES SINE AND COSINE COMPONENTS OF FREQUENCIES
872 CORRESPONDING TO MULTIPLES OF BASE FREQUENCY.
873
874 INTEGRATION IS PERFORMED USING A TRAPEZOIDAL TYPE COMPUTATION
875
876 DETERMINE WIDTH OF FIRST TRAPEZOID
877 TDEL=TIM2-ZTIM1
878 INITIALIZE CYCLE COUNTER

```

```

879 NCNT=0
880 C INITIALIZE D.C. CONTENT VALUE
881 DCONT=0.
882 C INITIALIZE VALUES OF VARIABLES WHICH WILL ACCUMULATE
883 C INTEGRATION DATA
884 DO 35 N=1,NHAR
885 CSUM(N)=0.
886 DSUM(N)=0.
887 C UPDATE D.C. CONTENT VALUE
888 DCONT=DCONT+VALU2(NPH)*SNGL(TDEL)
889 DO 40 N=1,NHAR
890 CSUM IS ACCUMULATION ARRAY FOR COSINE COEFFICIENTS
891 CSUM(N)=VALU2(NPH)*COS(N*FREQ*RAD*SNGL(TIM2-ZTIM1))
892 1*SNGL(TDEL)
893 C DSUM IS ACCUMULATION ARRAY FOR SINE COEFFICIENTS
894 DSUM(N)=VALU2(NPH)*SIN(N*FREQ*RAD*SNGL(TIM2-ZTIM1))
895 1*SNGL(TDEL)
896 C GET NEXT SET OF VALUES
897 CALL READ(NDC,VALU1,VALU2,TIM1,TIM2,EOF)
898 IF(EOF.EQ.1)GO TO 15
899 C CHECK FOR POSITIVE ZERO CROSSING, WHICH SIGNALS COMPLETE CYCLE
900 IF(VALU1(NPH).LE.0.)AND.(VALU2(NPH).GT.0.)GO TO 65
901 C CHECK FOR NEGATIVE ZERO CROSSING
902 NOTE: TWO TRAPEZOIDs, ONE FOR EACH SIDE OF ZERO CROSSING, MUST
903 BE COMPUTED AT NEGATIVE ZERO CROSSING
904 IF(VALU1(NPH).GE.0.)AND.(VALU2(NPH).LT.0.)GO TO 55
905 C DETERMINE WIDTH OF TRAPEZOID
906 TDEL=TIM2-TIM1
907 C ACCUMULATE INTEGRATION VALUES
908 DCONT=DCONT+(VALU1(NPH)+VALU2(NPH))*SNGL(TDEL)
909 DO 50 N=1,NHAR
910 CSUM(N)=CSUM(N)+(VALU1(NPH)*COS(N*FREQ*RAD*SNGL(TIM1-ZTIM1))
911 1+VALU2(NPH)*COS(N*FREQ*RAD*SNGL(TIM2-ZTIM1)))*SNGL(TDEL)
912 DSUM(N)=DSUM(N)+(VALU1(NPH)*SIN(N*FREQ*RAD*SNGL(TIM1-ZTIM1))

```

```

913      1+VALU2<NPH>)*SINK*N*FREQ*RAD*SNGL<TIM2-ZTIM1>>)*SNGL<TDEL>
914      C GET NEXT SET OF VALUES
915      GO TO 45
916      C INTERPOLATE TO DETERMINE TIME OF NEGATIVE ZERO CROSSING
917      ZTIM=-VALU2<NPH>*(VALU2<NPH>-VALU1<NPH>)*(TIM2-TIM1)+TIM2
918      C CALCULATE AREA OF TRAPEZOID JUST BEFORE NEGATIVE ZERO CROSSING
919      DCONT=DCONT+VALU1<NPH>)*SNGL<ZTIM-TIM1>
920      1+VALU2<NPH>)*SNGL<TIM2-ZTIM>
921      DO 60 N=1,NMAX
922      CSUNKN)=CSUNKN)+VALU1<NPH>)*COS(N*FREQ*RAD*SNGL<TIM1-ZTIM1>>
923      1*SNGL<ZTIM-TIM1>
924      DSUNKN)=DSUNKN)+VALU1<NPH>)*SINK*N*FREQ*RAD*SNGL<TIM1-ZTIM1>>
925      1*SNGL<ZTIM-TIM1>
926      C CALCULATE AREA JUST AFTER ZERO CROSSING
927      CSUNKN)=CSUNKN)+VALU2<NPH>)*COS(N*FREQ*RAD*SNGL<TIM2-ZTIM1>>
928      1*SNGL<TIM2-ZTIM>
929      DSUNKN)=DSUNKN)+VALU2<NPH>)*SINK*N*FREQ*RAD*SNGL<TIM2-ZTIM1>>
930      1*SNGL<TIM2-ZTIM>
931      C GET NEXT SET OF VALUES
932      GO TO 45
933      C INTERPOLATE TO DETERMINE TIME OF FINAL POSITIVE ZERO CROSSING
934      ZTIM=-VALU2<NPH>*(VALU2<NPH>-VALU1<NPH>)*(TIM2-TIM1)+TIM2
935      C CALCULATE AREA OF FINAL TRAPEZOID
936      DCONT=DCONT+VALU1<NPH>)*SNGL<ZTIM-TIM1>
937      DO 70 N=1,NMAX
938      CSUNKN)=CSUNKN)+VALU1<NPH>)*COS(N*FREQ*RAD*SNGL<TIM1-ZTIM1>>
939      1*SNGL<ZTIM-TIM1>
940      DSUNKN)=DSUNKN)+VALU1<NPH>)*SINK*N*FREQ*RAD*SNGL<TIM1-ZTIM1>>
941      1*SNGL<ZTIM-TIM1>
942      C INCREMENT CYCLE COUNTER
943      NCONT=NCONT+1
944      C INTERCHANGE ZERO CROSSING TIMES
945      ZTIM1=ZTIM
946      C CHECK IF CORRECT NUMBER OF CYCLES HAVE BEEN PROCESSED

```

```

947 IF(NENT.LT.NAUG+1)GO TO 37
948 C PERFORM CALCULATION TO COMPLETE INTEGRATION
949 DCONT=(DCONT/2.)/<SNEL<PERIOD>*NAUG>
950 DO 75 N=1,NHAR
951 CSUM(N)=(CSUM(N)/2.)/<SNEL<PERAVE>/2.>
952 DSUM(N)=(DSUM(N)/2.)/<SNEL<PERAVE>/2.>
953 C CALCULATE MAGNITUDE VALUE FOR COEFFICIENT OF EACH HARMONIC
954 C AND DETERMINE MAXIMUM (IGNORING BASE FREQUENCY) FOR USE IN
955 C PLOTTING
956 COMAX=0.
957 DO 80 N=1,NHAR
958 COEFF(N)=SQRT(CSUM(N)**2+DSUM(N)**2)
959 IF(COEFF(N).GT.COMAX.AND.N.NE.1)COMAX=COEFF(N)
960 CONTINUE
961 C CALL ROUTINE WHICH PRODUCES A PLOT OF MAGNITUDES OF FOURIER
962 C COEFFICIENTS VERSUS FREQUENCY
963 CALL FOURPLOT(COEFF,NHAR,IPH,COMAX,FREQ,DCONT)
964 READ(7,200)IANS
965 FORMAT(A2)
966 WRITE(8,300)
967 FORMAT(' FOR PLOT OF WAVEFORM REPRESENTED BY FOURIER COEFFICI
ENTS'
968 1,/, ' ENTER "CK"; OTHERWISE ENTER "GO"')
969 READ(7,200)IANS
970 IF(IANS.NE.'CK')GO TO 99
971 CALL CKPLOT(CSUM,DSUM,NHAR,FREQ)
972 RETURN
973 END
974 C
975 C SUBROUTINE FOURPLOT<COEFF,NHAR,IPH,COMAX,FREQ,DCONT>
976 C
977 C ROUTINE WHICH PRODUCES A DISPLAY OF THE MAGNITUDE OF FOURIER
978 C COEFFICIENTS (CALCULATED BY THE ROUTINE FOURIER) VERSUS THE
979

```

```

990 C CORRESPONDING INTEGRAL HARMONIC OF THE BASE FREQUENCY.
991 C
992 C DIMENSION COEFF(1)
993 C COMPUTE TOTAL HARMONIC DISTORTION
994 C
995 C INITIALIZE RESULT
996 C THD=0
997 C ACCUMULATE CONTRIBUTIONS OF ALL HARMONICS EXCEPT BASE FREQ.
998 C DO 5 N=2,NHAR
999 C THD=THD+COEFF(N)**2
1000 C COMPLETE CALCULATION
1001 C THD=(SQRT(THD)/2.)*(COEFF(1)/SQRT(2.))
1002 C ERASE SCREEN
1003 C CALL INIT(500)
1004 C OUTPUT LABELS
1005 C WRITE(0,100)IFH
1006 C FORMAT(//,3X,'FOURIER COEFFICIENTS',/,3X,'OF',/,3X,
1007 C '1'PHASE',11,'VOLTAGE')
1008 C WRITE(0,200)FREQ,COEFF(1)
1009 C FORMAT(2X/,5X,'NOTE: BASE FREQUENCY IS ',F7.2,' HZ',/,11X,
1010 C '1'AMPLITUDE OF COEFFICIENT = ',F10.4)
1011 C WRITE(0,300)THD
1012 C FORMAT(1X,'TOTAL HARMONIC DISTORTION = ',F10.4)
1013 C CONVERT D.C. CONTENT TO MILLIVOLTS
1014 C DCNT=DCNT*1000
1015 C WRITE(0,400)DCNT
1016 C FORMAT(1X,'DC CONTENT = ',F10.4,' MV')
1017 C SET VIRTUAL WINDOW FOR PLOT
1018 C CALL DIMIN(0.,FLOAT(NHAR),0.,COMAX)
1019 C SET SCREEN SIZE
1020 C CALL THIN(200,500,200,600)
1021 C PLOT MAGNITUDES OF HARMONICS VERSUS HARMONIC NUMBER
1022 C DO 10 N=2,NHAR
1023 C CALL MOVEA(FLOAT(N),0.)

```

```

1014 10      CALL DRAWK(FLOAT(N),COEFF(N))
1015 C      DRAW HORIZ. AXIS
1016      CALL HOVERK(FLOAT(NHAR+1),0.)
1017      CALL DRAWK(0.,0.)
1018 C      DRAW VERT. AXIS
1019      CALL DRAWK(0.,COMAX)
1020 C      LABEL MAGNITUDES OF COEFFICIENTS
1021      CDEL=COMAX/13.
1022      CLABEL=COMAX
1023      IFOS=003
1024      CALL THINOK(100,500,200,600)
1025      DO 20 N=1,10
1026      CALL FOUR(50,IP05,CLABEL,4)
1027      IFOS=IP03-40
1028      CLABEL=CLABEL-CDEL
1029 C      DRAW "HARMONIC" MARKS
1030      CALL THINOK(150,500,200,600)
1031      CLABEL=COMAX
1032      DO 30 N=1,10
1033      CALL HOVERK(0.,CLABEL)
1034      CALL DRAWK(10,0)
1035      CLABEL=CLABEL-CDEL
1036 C      LABEL HARMONIC NUMBER
1037      CALL THINOK(200,500,180,600)
1038      DO 40 N=2,NHAR
1039      CALL HOVERK(FLOAT(N),0.)
1040      CALL FOUR(-1,-1,N)
1041 C      LABEL VERT. AXIS
1042      CALL THINOK(10,500,200,600)
1043      CALL ULADK(10,500,'MAGNITUDE',9)
1044 C      LABEL HORIZ. AXIS
1045      CALL THINOK(500,500,150,600)
1046      CALL HLADK(500,150,'HARMONIC OF BASE FREQUENCY',26)
1047      RETURN

```

```

1048      END
1049
1050      SUBROUTINE CKPLOT<CSUM,DSUM,NHAR,FREQ>
1051
1052      ROUTINE PRODUCES A DISPLAY WAVEFORM REPRESENTED BY FOURIER
1053      COEFFICIENTS CALCULATED BY ROUTINE FOURIER.
1054
1055      DIMENSION CSUM<1>,DSUM<1>
1056      SET RADIAN CONVERSION FACTOR
1057      RADI=2.83.1415927
1058      ERASE SCREEN
1059      CALL INIT<999>
1060      SET VIRTUAL WINDOW FOR PLOTTING
1061      CALL ERINDO<-0.00001,0.00251,-200.,200.>
1062      SET SCREEN SIZE
1063      CALL THIRDO<100,500,100,700>
1064      INITIALIZE TIME VALUE
1065      TIME=0.
1066      SET TIME STEP SIZE <NUMBER OF POINTS PLOTTED>
1067      TDEL=0.00250/22.
1068      INITIALIZE PLOT VALUE
1069      VALUE=0.
1070      COMPUTE VALUE AT FIRST TIME INCREMENT
1071      DO 10 N=1,NHAR
1072      VALUE=VALUE+CSUM<N>*COS<N*FREQ*RADI*TIME>
1073      DSUM<N>=SIN<N*FREQ*RADI*TIME>
1074      MOVE TO FIRST VALUE ON PLOT
1075      CALL MOVE<TIME,VALUE>
1076      INCREMENT TIME
1077      TIME=TIME+TDEL
1078      CHECK FOR COMPLETION
1079      IF<TIME.GT.0.00250>GO TO 30
1080      RESET VALUE
1081

```

```

1082 VALUE=0
1083 C COMPUTE NEXT VALUE
1084 DO 20 N=1,NMAX
1085 VALUE=VALUE+CSUM(N)*COS(N*FREQ*RAD*TIME)
1086 1+DSUM(N)*SIN(N*FREQ*RAD*TIME)
1087 C PLOT VALUE
1088 CALL DRAWAX TIME, VALUE
1089 C COMPUTE NEXT VALUE
1090 GO TO 15
1091 C DRAW TIME AXIS
1092 CALL MOVEAX 0.00250, 0.
1093 CALL DRAWAX 0., 0.
1094 RETURN
1095 END
1096
1097 C
1098 C
1099 C
1100 C
1101 C ROUTINE PRODUCES A PLOT OF RMS VOLTAGE DEVIATION ABOUT
1102 C 100 V RMS OF PHASE SELECTED (IPH) AND A PLOT OF
1103 C FREQUENCY DEVIATION ABOUT 400 HZ OF
1104 C PHASE USED AS KEY (PRESENTLY PHASE 2)
1105 C PLOT IS OVER TIME RANGE TIME TO TIME
1106 C
1107 C
1108 C
1109 C
1110 C
1111 C SET INITIAL LIMITS FOR PLOTTING VOLTAGE DEVIATION
1112 VALUE=101.
1113 UNIN=0.
1114 C INITIALIZE ROUTINE WHICH READS FROM DISK (REWIN)
1115 10 CALL REWEX 0.2

```

```

1116 C RESET END OF FILE FLAG
1117 EOF=0
1118 ERASE SCREEN
1119 CALL INITT<50>
1120 C SET SCREEN SIZE TO PLOT FREQUENCY DEVIATION
1121 CALL DWINDO<TIME,TIML,350,441.>
1122 CALL TWINDO<100,900,100,300>
1123 C LABEL FREQUENCY AXIS
1124 DO 20 I=350,440,20
1125 CALL MOVEK<TIME,FLOAT<I>>
1126 CALL IOUT<-1,-1,1>
1127 CALL THINDO<140,900,100,300>
1128 DO 30 I=350,440,20
1129 CALL MOVEK<TIME,FLOAT<I>>
1130 CALL DWINDO<10,0>
1131 C N= NUMBER OF A/D C'S IN USE
1132 N=5
1133 C GET FIRST CLOCK OF DATA
1134 40 CALL LREAD<IPH,A,U,PF,PERIOD,Z,EOF>
1135 C CHECK FOR EOF
1136 IF<EOF.EQ.1>GO TO 60
1137 C CHECK IF IN TIME RANGE REQUESTED
1138 IF<SNEL<2>.LT.TIME>GO TO 40
1139 C CONVERT PERIOD TO FREQUENCY
1140 FREQ=1./SNEL<PERIOD>
1141 C MOVE TO STARTING TIME AND FREQUENCY VALUE
1142 CALL MOVEK<SNEL<2>,FREQ>
1143 C GET ANOTHER BLOCK OF DATA
1144 50 CALL LREAD<IPH,A,U,PF,PERIOD,Z,EOF>
1145 C CHECK FOR EOF OR TIME RANGE EXCEEDED
1146 IF<EOF.EQ.1.OR.SNEL<2>.GT.TIME>GO TO 60
1147 C CONVERT PERIOD TO FREQUENCY
1148 FREQ=1./SNEL<PERIOD>
1149 C DRAW TO NEW TIME AND FREQUENCY VALUE

```

```

1150 CALL DRAWK(SNGL(Z),FREQ)
1151 GET NEXT BLOCK OF DATA
1152 GO TO 53
1153 C PLOT REFERENCE FREQUENCY
1154 60 CALL MOVEK(TIME,400.)
1155 CALL DASHK(TIME,400.,12)
1156 C END OF TIME RANGE REQUESTED
1157 C SET SCREEN TO LABEL REQUESTED
1158 CALL THINCK(10,500,50,300)
1159 C OUTPUT MESSAGE IDENTIFYING FREQUENCY DEVIATION PLOT
1160 CALL MOVEK(500,50)
1161 CALL ANSK(9,MES1)
1162 C SET SCREEN FOR VOLTAGE DEVIATION PLOT
1163 CALL ENINCK(TIME,TIME,UNIT,UNIT)
1164 CALL THINCK(10,500,400,700)
1165 C LABEL VOLTAGE AXIS
1166 1ST=UNIT
1167 IEND=UNIT-1
1168 DO 70 I=1ST,IEND,10
1169 CALL MOVEK(TIME,FLOAT(I))
1170 CALL ICURK(-1,-1,I)
1171 CALL THINCK(10,500,400,700)
1172 DO 80 I=1ST,IEND,10
1173 CALL MOVEK(TIME,FLOAT(I))
1174 CALL DASHK(10,0)
1175 C REVIND DATA FILE
1176 CALL READK(2)
1177 C GET FIRST BLOCK OF DATA
1178 90 CALL DASHK(IPH,A,U,PF,PERIOD,Z,EOF)
1179 C CHECK FOR EOF
1180 IF(EOF.EQ.1)GO TO 110
1181 C CHECK IF IN TIME RANGE REQUESTED
1182 IF(SNGL(Z).LT.TIME)GO TO 90
1183 C MOVE TO STARTING TIME AND VOLTAGE VALUE

```

```

1184 CALL MOVER(SNGL(Z),V)
1185 GET ANOTHER BLOCK OF DATA
1186 CALL DRAW(IPH,A,V,PF,PERIOD,2,EOF)
1187 CHECK FOR EOF OR TIME RANGE EXCEEDED
1188 IF(EOF.EQ.1.OR.SNGL(Z).GT.TIML)GO TO 110
1189 C DRAW TO TIME AND VOLTAGE VALUE
1190 CALL DRAW(SNGL(Z),V)
1191 C GET NEXT BLOCK OF DATA
1192 GO TO 100
1193 C PLOT REFERENCE VOLTAGE
1194 CALL MOVER(TIME,115.)
1195 CALL DRAW(TIME,115.,12)
1196 C SET SCREEN TO LABEL PHASE INFORMATION
1197 CALL TINDX(110,503,303,403)
1198 CALL MOVER(300,300)
1199 C DETERMINE WHICH PHASE VOLTAGE WAS PLOTTED
1200 GO TO(120,130,140),IPH
1201 MESZ(4)=1
1202 GO TO 150
1203 MESZ(4)=2
1204 GO TO 150
1205 MESZ(4)=3
1206 CALL ANSTR(12,MESZ)
1207 CALL TINDX(10,1010,53,700)
1208 PTIME=(TIME-SNGL(TIME))#1000.
1209 CALL FOUT(110,50,PTIME,2)
1210 CALL HLAL(370,50,'MESZ',4)
1211 PTIME=(TIME-SNGL(TIME))#1000.
1212 CALL FOUT(500,50,PTIME,2)
1213 C WAIT FOR USER RESPONSE
1214 READ(7,1000)ANS
1215 FORMAT(A2)
1216 C IF VOLTAGE DEVIATION PEAK, WAS "OFF SCALE", USER
1217 C CAN ENTER 'RE' TO GET PLOT WITH EXPANDED SCALE

```

```

1218 WRITE(8,2000)
1219 FORMAT(' FOR REPLOT WITH EXPANDED VOLTAGE SCALE, '
1220 1, ENTER 'RE', OTHERWISE ENTER 'GO',')
1221 READ(7,1000)IANS
1222 IF(IANS.NE.'RE')GO TO 160
1223 C CHANGE VOLTAGE SCALES
1224 UMAX=UMAX*10.
1225 UMIN=UMIN*10.
1226 C REPLOT
1227 GO TO 10
1228 C CHANGE SCREEN WINDOW BACK SO THAT PICKTIME WILL WORK
1229 160 CALL TWINDX(140,900,10,1010)
1230 RETURN
1231 END
1232 C
1233 C
1234 SUBROUTINE PRINTVAL(JAD,TIME,TBEGIN)
1235 C
1236 C ROUTINE PRODUCES TABULAR DISPLAY OF TEST DATA
1237 JAD(1) SELECTS PHASE TO BE DISPLAYED
1238 JAD(2) SELECTS NUMBER OF READINGS TO BE AVERAGED BEFORE
1239 DISPLAYING (RANGE OF 1 TO 9)
1240 C TABLE SPANS TIME RANGE TIME(1) TO TIME(2)
1241 C
1242 DIMENSION TIME(1),JAD(1)
1243 INTEGER EOF
1244 DOUBLE PRECISION ZTH,TBEGIN,PERIOD
1245 NADDC=6
1246 INLINE
1247 LD1,2 UFT
1248 REX,07
1249 BRU OUT
1250 UFT DFC 0,010,0000,0,0,0
1251 OUT NOP

```

1252	FINI	
1253	CALL INITTS60	
1254	WRITE(10,160)JACK(1),JACK(2)	
1255	FORMAT(34X,'PHASE',11,'/',14X,'EACH ENTRY REPRESENTS'	100
1256	1,1X,'AN AVERAGE OF',12,' READINGS',///,11X,	
1257	1'RMS VOLTAGE RMS CURRENT FREQUENCY',5X,'PF',	
1258	15X,'TIME',/,14X,'(VOLTS)',7X,'(AMPS)',8X,'(HZ)',	
1259	114X,'(SEC)',///)	
1260	CALL READ29(0,2)	
1261	VSUM=0.	1
1262	CSUM=0.	
1263	FSUM=0.	
1264	PSUM=0.	
1265	JJ=JACK(2)	
1266	DO 10 J=1,JJ	
1267	EOF=0	
1268	CALL DREAD(JACK(1),AMP,VOLT,PF,PERIOD,ZTM,EOF)	2
1269	IF(EOF.EQ.1)GO TO 53	
1270	IF(SNEL(ZTM).LT.TIME(1))GO TO 2	
1271	IF(SNEL(ZTM).GT.TIME(2))GO TO 60	
1272	VSUM=VSUM+VOLT	
1273	CSUM=CSUM+AMP	
1274	PSUM=PSUM+1./SNEL(PERIOD)	
1275	FSUM=FSUM+PF	10
1276	VOLTS=VSUM/JACK(2)	
1277	AMPS=CSUM/JACK(2)	
1278	FREQ=FSUM/JACK(2)	
1279	PF=PSUM/JACK(2)	
1280	RELTIM=SNEL(ZTM-TOBEGIN)	
1281	WRITE(10,200)VOLTS,AMPS,FREQ,POWF,RELTIM	200
1282	FORMAT(14X,F6.1,7X,F6.1,5X,F3.3,3X,F9.6)	
1283	GO TO 1	
1284	WRITE(10,300)	50
1285	FORMAT('EOF ENCOUNTERED')	300

```

1286 60 RETURN
1287 END
1288
1289
1290 SUBROUTINE PRINTCK(JJ,NADC,TM,TEGIN)
1291
1292 ROUTINE PRODUCES A TABULAR DISPLAY OF RAW TEST DATA
1293 JJK1> SELECTS PHASE TO BE DISPLAYED
1294 TABLE SPANS FROM TMK1> TO TMK2>
1295
1296
1297 DIMENSION JJK1>,TMK1>,DATA(20)
1298 INTEGER EOF
1299 REAL NONTM
1300 DOUBLE PRECISION TIME,TEGIN
1301 JJK1> IS INDEX INTO DATA ARRAY FOR VOLTAGE VALUES
1302 UNDX=JJK1>NADC-3
1303 CNDX IS INDEX FOR CURRENT VALUES
1304 CHDX=JJK1>NADC-6
1305 INITIALIZE ROUTINES WHICH READ FROM DISK
1306 CALL DINIT
1307 CALL GETCLK(N,N,N,2)
1308 INITIALIZE END OF FILE FLAG
1309 EOF=3
1310 ADVANCE FILE 10 (RESETS LST LINE COUNTER)
1311 INLINE
1312 LOD,2 UFT
1313 REX,#7
1314 BRU OUT
1315 DFC 0,010,#0000,0,0,0
1316 NOP
1317 FINI
1318 CALL WAIT(2,2,M)
1319 WRITE(10,100)JJK1>

```

```

1320 100  FORMAT(34X,'PHASE  ',11,/,11X,'VOLTAGE',7X,'CURRENT'
1321 1,7X,'TIME',/,/)
1322 READ FIRST BLOCK OF DATA
1323 CALL GETBLK(NADC,DATA,TIME,EOF)
1324 CHECK FOR END OF FILE
1325 IF(EOF) GO.1,RETURN
1326 CONVERT TIME READING TO SINGLE PRECISION
1327 NONTM=SNEL(TIME)
1328 CHECK TO SEE IF IN TIME RANGE REQUESTED
1329 IF(NONTM.LT.TNK1)GO TO 1
1330 OUTPUT DATA
1331 CONVERT TIME TO ACTUAL ELAPSED TIME
1332 NONTM=NONTM-SNEL(TOEGIN)
1333 WRITE(10,200)DATA(VNOX),DATA(CNDX),NONTM
1334 200  FORMAT(118,F6.1,7X,F6.1,7X,F9.6)
1335 READ NEXT BLOCK OF DATA
1336 CALL GETBLK(NADC,DATA,TIME,EOF)
1337 CHECK FOR EOF
1338 IF(EOF) GO.1,RETURN
1339 CONVERT TIME TO SINGLE PRECISION
1340 NONTM=SNEL(TIME)
1341 CHECK TO SEE IF TIME RANGE EXCEEDED
1342 IF(NONTM.LT.TNK2)GO TO 2
1343 RETURN
1344 END
1345
1346 SUBROUTINE ACCEED(NADC)
1347
1348 ROUTINE WHICH DETERMINES RATE AT WHICH DATA WAS ACQUIRED
1349 DURING PRESENT GENERATOR TEST
1350
1351 DIMENSION V1(6),V2(6)
1352 DOUBLE PRECISION T1,T2
1353

```

```

1354 INTEGER EOF
1355 COMPUTE AVERAGE RATE OF DATA ACQUISITION AND AVERAGE
1356 NUMBER OF DATA POINTS PER CYCLE OVER 10 CYCLES
1357 KNT=0
1358 KPTS=0
1359 C INITIALIZE RAW DATA FILE
1360 CALL GETBLK(N,N,2)
1361 C SET FLAG TO INDICATE BEGINNING OF DATA
1362 ECF=2
1363 C GET TWO SETS OF DATA
1364 10 CALL READXNADC,U1,U2,T1,T2,EOF>
1365 C CHECK FOR END OF DATA
1366 IF(EOF.EQ.1)RETURN
1367 C FIND INITIAL ZERO CROSSING
1368 IF(.NOT.(U1<4).LE.0.).AND.(U2<4).GT.0.)>>XGO TO 10
1369 C INCREMENT POINT COUNT
1370 KPTS=KPTS+1
1371 C GET NEXT SET OF DATA
1372 20 CALL READXNADC,U1,U2,T1,T2,EOF>
1373 C CHECK FOR EOF
1374 IF(EOF.EQ.1)RETURN
1375 C CHECK FOR END OF CYCLE
1376 IF(U1<4).LE.0.).AND.(U2<4).GT.0.)>>XGO TO 25
1377 C INCREMENT POINT COUNT
1378 KPTS=KPTS+1
1379 C GET NEXT SET OF DATA
1380 GO TO 20
1381 C INCREMENT CYCLE COUNT
1382 KNT=KNT+1
1383 C CHECK FOR 10 CYCLES
1384 IF(KNT.EQ.10)GO TO 30
1385 C INCREMENT POINT COUNT
1386 KPTS=KPTS+1
1387 C GET NEXT SET OF DATA

```

```

1399 GO TO 20
1399 C CALCULATE AVE. NUMBER OF POINTS PER CYCLE
1399 30 KPTS=KPTS/10
1399 C CALCULATE AVE. DATA RATE
1399 AVRATE=50.*KPTS
1399 C DISPLAY DATA RATE INFO
1399 CALL INITK(50)
1399 WRITE(8,10)AURATE,KPTS
1399 FORMAT(////,1X,110,' DATA WAS ACQUIRED AT A RATE OF ',F10.2,
1399 1,' HERTZ',////,1X,110,' DATA POINTS PER CYCLE')
1399 C WAIT FOR OPERATOR ACTION
1399 WRITE(8,150)
1399 FORMAT(//,1X,'TYPE 'GO' TO CONTINUE')
1399 READ(7,200)IDUM
1399 FORMAT(A2)
1399 RETURN
1399 END
C
C
SUBROUTINE DSSPEED(TN,ZTIME,NAVE,RMSPK)
DIMENSION TK(1),RMSPK(1)
DOUBLE PRECISION ZTIME
WRITE(2,100)
FORMAT(' DSSPEED IS CURRENTLY NOT IMPLEMENTED')
RETURN
END
100
C
C
SUBROUTINE REFPLOT(TIME,PEAK)
ROUTINE PLOTS RMS VOLTAGE AND CURRENT OF PHASE 2 OVER
RANGE TIME(1) TO TIME(2)
ROUTINE IS CALLED BY DSSPEED AND RMS PLOTS ARE USED
FOR REFERENCE

```

```

1422 C      DIMENSION TIME<1>,PEAK<1>,RMS1<20>,RMS2<20>
1423 1,PEAK<5>
1424 INTEGER EOF
1425 LOUPEL PRECISION ZTIM1,ZTIM2
1426 INITIALIZE DISC READ
1427 CALL READDISC(0,2)
1428 C      INITIALIZE EOF OF FILE FLAG <EOF>
1429 EOF=0
1430 NADCS=5
1431 C      READ FIRST SET OF DATA
1432 CALL DREAD(NADCS,RMS1,PF,ZTIM1,PERIOD,EOF)
1433 C      CHECK TO SEE IF IN TIME RANGE REQUESTED
1434 IF(SNGL(ZTIM1)>LT.TIME<1>)>EO TO 1
1435 C      READ NEXT SET OF DATA
1436 CALL DREAD(NADCS,RMS2,PF,ZTIM2,PERIOD,EOF)
1437 C      CHECK TO SEE IF EOF ENCOUNTERED
1438 IF(EOF=1)>EO TO 10
1439 C      SET SCREEN TO PLOT PHASE VOLTAGE
1440 CALL DWRITE(TIME<1>,TIME<2>,-.5,PEAK<5>)
1441 CALL THINDB(120,523,520,750)
1442 C      MOVE TO PRECEDING POINT AND THEN PLOT CURRENT POINT
1443 CALL MOVE(SNGL(ZTIM1),PEAK<5>)
1444 CALL DWRITE(SNGL(ZTIM2),PEAK<5>)
1445 C      SET SCREEN FOR PHASE CURRENT
1446 CALL DWRITE(TIME<1>,TIME<2>,-.5,PEAK<2>)
1447 CALL THINDB(120,523,340,523)
1448 C      PLOT CURRENT VALUES
1449 CALL MOVE(SNGL(ZTIM1),PEAK<2>)
1450 CALL DWRITE(SNGL(ZTIM2),PEAK<2>)
1451 C      CHECK TO SEE IF REQUESTED TIME RANGE HAS BEEN EXCEEDED
1452 IF(SNGL(ZTIM2)>GE.TIME<2>)>EO TO 15
1453 C      INTERCHANGE PREVIOUS AND PRESENT DATA VALUES
1454 ZTIM1=ZTIM2
1455

```

```

1456 RMS1<5>=RMS2<5>
1457 RMS1<2>=RMS2<2>
1458 C GET NEXT SET OF DATA
1459 GO TO 5
1460 C PLOT AXES
1461 C PLOT VOLTAGE AXIS
1462 15 CALL TIME2<1>,TIME<2>,-.5,PEAK<5>>
1463 CALL TIME2<20,950,520,760>
1464 CALL MOVE<1>,PEAK<5>>
1465 CALL DRAW<1>,0.>
1466 CALL DRAW<2>,0.>
1467 C LABEL VERTICAL AXIS
1468 CALL TIME2<10,1010,570,760>
1469 CALL VLAB<100,680,'VOLTS',5>
1470 C LABEL PEAK
1471 CALL FOUT<20,760,PEAK<5>,2>
1472 CALL PLAB<115,750,'-',1>
1473 C PLOT CURRENT AXIS
1474 CALL TIME2<1>,TIME<2>,-.5,PEAK<2>>
1475 CALL TIME2<120,930,340,520>
1476 CALL MOVE<1>,PEAK<2>>
1477 CALL DRAW<1>,0.>
1478 CALL DRAW<2>,0.>
1479 C LABEL VERTICAL AXIS
1480 CALL TIME2<10,1010,290,520>
1481 CALL VLAB<100,400,'AMPS',4>
1482 C LABEL PEAK
1483 CALL FOUT<20,520,PEAK<2>,2>
1484 CALL PLAB<100,510,'-',1>
1485 RETURN
1486 END
1487 C
1488 C
1489 SUBROUTINE DREAD<N,A,U,PF,P,T,EOF>

```

```

1490      INTEGER A(1),U(1),PF(1),P(1),T(1),EOF
1491      INPUT PHASE NUMBER OF DATA SET
1492      CALL READ2(K,EOF)
1493      CHECK FOR END OF FILE
1494      IF(EOF.EQ.1)RETURN
1495      C INPUT RMS CURRENT
1496      DO 10 I=1,2
1497      CALL READ2(A(I),EOF)
1498      IF(EOF.EQ.1)RETURN
1499      C INPUT RMS VOLTAGE
1500      DO 20 I=1,2
1501      CALL READ2(U(I),EOF)
1502      IF(EOF.EQ.1)RETURN
1503      C INPUT POWER FACTOR
1504      DO 30 I=1,2
1505      CALL READ2(PF(I),EOF)
1506      IF(EOF.EQ.1)RETURN
1507      C INPUT PERIOD
1508      DO 40 I=1,3
1509      CALL READ2(P(1),EOF)
1510      IF(EOF.EQ.1)RETURN
1511      C INPUT TEST TIME
1512      DO 50 I=1,3
1513      CALL READ2(T(1),EOF)
1514      IF(EOF.EQ.1)RETURN
1515      C CHECK FOR SELECTED PHASE
1516      IF(K.NE.N)GO TO 5
1517      RETURN
1518      END
1519      C
1520      SUBROUTINE DINIT
1521      CALL WRIT2(0,2)
1522      RETURN
1523

```

1524
END
TOTAL RECORDS WRITTEN = 1525
EXIT
\$AUR CI 4
\$END LIST

Appendix C : Display Software User's Manual

Introduction

This manual describes the user interaction with the display software system. This software allows the user to display the generator test data on the Tektronix 4010 terminal in a number of formats. The user selects the particular format by entering a two character option word. He selects the time range of the display by using the crosshairs of the display terminal. Thus the user selects the format and time range of the data to be displayed. Messages are output with each display directing the user in what display options are available and how to invoke them. The following discussions describe each display format and the associated user interactions.

Execution of Routine

There are two methods in which to initiate execution of the display software. First, the display software is automatically executed at the completion of the analysis software. In instances where the analysis and display software have been executed previously and a re-display is required, the user can initiate execution of the display software by typing the following commands on the Tektronix keyboard.

JOB
EXE DIS LM

The routine will respond with the following message.

```
*****  
*** TEST DATA AVAILABLE FOR DISPLAY **  
*****
```

```
**** FOR DATA ACQUISITION RATE INFORMATION  
ENTER 'YE'; OTHERWISE, FOR GENERATOR  
TEST SUMMARY PLOT, ENTER 'CO'
```

Sample Rate Display

At this point, both the data file containing the raw test data and the file containing the analysis results have been rewound. Since the data acquisition system can run at several data rates, the user can determine the particular sample rate in effect for this set of test data. The routine accesses the first few cycles of raw test data and counts the average number of data samples per cycle. This information is displayed in the format illustrated in Figure C-1.

When the user has finished with this display, he must respond by entering "GO". This causes the Tektronix screen to be erased and the test summary plot to be displayed.

DATA WAS ACQUIRED AT A RATE OF 8800.00 HERTZ

22 DATA POINTS PER CYCLE

TYPE 'GO' TO CONTINUE

Fig C-1. Data Acquisition Rate

Test Summary Plot

The test summary plot is the first data plot displayed whenever the display software is executed. This format displays the rms values of all six data channels versus time. Figure C-2 illustrates the test summary plot.

Each point plotted is averaged over a time range such that only 100 points per channel are displayed. This format displays the entire time range of the test and thus serves as a test summary.


From this initial plot, all other display options can be selected. When the entire display has been plotted and all labelling is complete, the user can produce a hard copy of the display by depressing the COPY switch on the Tektronix keyboard. When the user is finished with this display, he must enter "GO". The following message is then displayed.

```
ENTER PLOT OPTIONS,  
FOR LIST OF OPTIONS, ENTER '??'
```

If the user responds with "??", the routine lists a menu of the available display format options. This menu is illustrated in Figure C-3.

Following is a discussion of each display option and its use. The options are discussed in alphabetical order since, in general, they may be chosen in any order.

A-10 30-40 KVA IDG TEST



PEAK= 54. PEAK= 54. PEAK= 54. PEAK= 125. PEAK= 125. PEAK= 125.
 PHASE 1 PHASE 2 PHASE 3 PHASE 1 PHASE 2 PHASE 3
 CURRENT CURRENT CURRENT VOLTAGE VOLTAGE VOLTAGE

Fig C-2. Test Summary Plot

[illegible][illegible]

Fig C-3. Display Format Menu

Instantaneous Phase Values (CY)

This format presents the instantaneous values of the voltage and current of the phase selected versus the time range selected.

The user selects this display format by entering "CY". The user must now select four parameters which determine how the instantaneous phase value display is to be plotted. First, he must position the appropriate crosshair along the time axis of the current display to the desired starting time. Next the user must enter the phase (1,2, or 3) of generator data to be displayed. Now the user must position the crosshair to select the ending time for the display and set the highlight flag on or off.

The highlight flag determines whether individual data points in the voltage waveform will be highlighted. To set the flag, the user enters a "1"; to reset, a "0". Figure C-4 presents an instantaneous phase value display without highlighting; Figure C-5, with highlighting.

When the user is finished with the display, he enters "GO". The following message is then displayed.

```
FOR REPLOT USING ACTUAL SCALING  
ENTER 'RE'; OTHERWISE ENTER 'GO'
```

The initial plot has been scaled to accomodate the largest instantaneous value present over the entire time range. In plots of a lesser time range, this scaling is often not appropriate. By entering "RE", the user causes the previous





FIG C-4. Instantaneous Phase Values
(without highlighting)





Fig C-5. Instantaneous Phase Values
(with highlighting)

display to be replotted with scaling to accommodate the maximum value over the range displayed.

When the user is finished with the display or if the replot is not chosen, he enters "GO". The following message is then displayed.

```
TO PERFORM FOURIER ANALYSIS  
ENTER 'YE'; OTHERWISE ENTER 'GO'
```

By entering "YE", the user directs the software to calculate a Fourier representation of the voltage waveform displayed over the time range and according to the option he now selects.

The user must now select the beginning cycle of the range over which the harmonic analysis will be performed. He aligns the horizontal crosshair to a position just before the beginning of that cycle and enters the number of the phase to be analyzed. To complete the procedure, he must position the crosshair to a later time and strike another key. This last time value and input are not used by the software. The user defines the extent of the analysis later.

The routine will then display the following message.

```
ENTER NUMBER OF HARMONICS TO BE COMPUTED, 12
```

Because the data sampling rate is variable, the user must specify to what extent the harmonic analysis will be valid.

At the usual sampling rate of approximately 8800 hertz, the analysis for 400 hertz waveforms is accurate up to the 11th harmonic. Therefore the user should enter an integer from 2 to 11 in an I2 format.

The routine will then output this message.

ENTER NUMBER OF CYCLES OVER WHICH HARMONIC
ANALYSIS WILL BE PERFORMED, I2

The software can calculate a Fourier representation over a single cycle of the voltage waveform. However in order to compare the results to those produced by a spectrum analyzer, it is usually more useful to perform the computation over several cycles. The user selects a range of from 1 to 60 cycles in an I2 format.


The routine will now compute a Fourier representation for the waveform selected. Figure C-6 is an example of the resulting display. When the user is finished with the display, he enters "GO".

The routine will respond with the following message.

FOR PLOT OF WAVEFORM REPRESENTED BY FOURIER COEFFICIENTS
ENTER "CK"; OTHERWISE ENTER "GO"

Choosing this option produces a display of the calculated Fourier representation back in the time domain. This plot gives the user confidence in the results of the harmonic analysis. Figure C-7 is an example of this display.

FOURIER COEFFICIENTS OF PHASE 1 VOLTAGE



NOTE: BASE FREQUENCY IS 395.52 HZ
 MAGNITUDE OF COEFFICIENT = 162.0209
 TOTAL HARMONIC DISTORTION = 0.0133
 DC CONTENT = 326.9954 MV

Fig C-6. Fourier Representation
 (Frequency domain)

MAGNITUDE




Fig. C-7. Fourier Representation
(time domain)

When the user is finished with the time domain plot or if that option is not chosen, he enters "GO". The routine will automatically replot the original test summary plot. This plot must be displayed when a format has just been produced which has no time axis (as in this case) or when a larger time range is desired than the one in the current display.

Frequency Deviation (FQ)

This format displays a plot of the frequency deviation about 400 hertz of the phase selected versus the time range selected. A plot of the rms phase voltage deviation about 115 volts over the time range is also presented.

The user selects this display format by entering "FQ". Next, he must enter the starting time for the display and the phase to be displayed. To do so, he aligns the appropriate crosshair to the position on the time axis which corresponds to the desired starting time and enters the phase number (1,2, or 3). Then he selects the ending time of the display by aligning the crosshair and striking any character. This second character is not used but for clarity should correspond to the phase number.

Figure C-8 presents a typical display of the frequency deviation option. When the user is finished, he must enter "GO". The routine will respond with the following message.

```
FOR REPLOT WITH EXPANDED VOLTAGE SCALE  
ENTER 'RE'; OTHERWISE ENTER 'GO'
```

In some instances, the voltage deviation exceeds that allowed by the initial display thus plotting some values "off-screen". By selecting this replot, the voltage scale is expanded to accommodate the deviation.

When the user is finished with the replot or if that option is not selected, the user enters "GO". At this point, the "ENTER PLOT OPTIONS" message is output and the

user is allowed to select any of the other possible display options.





Fig C-8. Frequency and Voltage Deviations

Rms Phase Values (IS)

This format displays the rms voltage and current values of the phase selected versus the time range selected. Several power calculations are performed over the time range and their results are also displayed.

The user selects this display format by entering "IS". He then positions the crosshair along the time axis of the current display to select the starting time for the rms display and enters the phase (1,2, or 3) to be displayed. Next, he positions the crosshair to select the ending time and strikes another character. Again this second character is not used but it is recommended that the phase number again be entered.

Figure C-9 presents a typical plot of rms values. When the user is finished with this display, he enters "GO". Again, the "ENTER PLOT OPTIONS" message is output and any of the display options can now be selected.



65.49 MSEC AFTER START OF TEST 1057.39
 REAL PWR = 4.20 KW; REACTIVE PWR = 3.67 KUVR; AVE PWR FACTOR = 0.75
 AVE RMS VOLTAGE = 114.96 VOLTS; AVE RMS CURRENT = 48.55 AMPS

FIG C-9. RMS Phase Values

Instantaneous Phase Values Table (PC)

This format displays a table of instantaneous voltage and current values and the corresponding test times of the phase selected over the time range selected.

The user selects this option by typing "PC". Then the user positions the crosshair along the time axis of the current display to select the starting time for the table and then enters the phase (1,2, or 3) to be displayed. Then he selects the ending time and strikes any character. Again, this second character is not used but for clarity should be the phase to be displayed.

The routine then begins outputting the table of instantaneous values. The routine lists a screen full of values, issues a beep allowing the user time to make a hard copy. When the user is finished with the current display, he strikes any two characters which causes the routine to erase the screen and output the next screen full of values.

Figure C-10 presents a typical display of a table of instantaneous values. When the user is finished with the last screen full of values, he enters "GO". Since this display format has no time axis, the test summary plot is again produced automatically

PHASE 1

VOLTAGE	CURRENT	TIME
149.8	38.6	0.379339
161.0	53.3	0.379452
160.0	65.2	0.379555
149.4	72.5	0.379678
125.0	73.8	0.379791
98.7	66.5	0.379904
48.2	57.1	0.380017
2.5	42.1	0.380130
-43.2	26.5	0.380243
-82.1	5.2	0.380356
-118.5	-17.4	0.380469
-147.2	-33.5	0.380582
-160.4	-55.6	0.380695
-160.4	-65.9	0.380808
-151.1	-72.3	0.380921
-127.8	-75.3	0.381034
-94.7	-70.6	0.381147
-54.9	-60.7	0.381260
-38.7	-45.7	0.381373
38.5	-39.7	0.381486
76.8	-10.5	0.381599
114.8	13.3	0.381712
144.5	33.6	0.381825
159.5	50.1	0.381938
161.0	62.5	0.382051
152.7	70.6	0.382164

Fig C-10. Instantaneous Phase Values Table


General Plot of Instantaneous Values (PL)

This display format is similiar to the plot of instantaneous phase values (CY) except that the user can select a plot of the values of any two data channels.


The user selects this option by entering "PL". Next, the user positions the crosshair to select the starting time for the display and enters the number of the data channel (1-6) to be plotted in the upper portion of the display. Then the user positions the crosshair to select the ending time for the display and enters the number of the data channel to be plotted in the lower portion of the display.

Figure C-11 presents a typical display of this type of instantaneous values plot. When the user is finished with the display, he enters "GO". The "ENTER PLOT OPTIONS" message is output and the user can now select any of the other display options.

ARCH 4



ARCH 5



333.55

RECORD AFTER START OF 1937

233.70

Fig C-11. Instantaneous Values

Rms Phase Values Table (PR)

This format presents a table of rms voltage values, rms current values, power factors, frequency values, and the corresponding test times.

The user selects this option by entering "PR". Next, the user positions the crosshair along the time axis of the current display to select the starting time for the table and enters the phase (1,2, or 3) to be displayed. Then he positions the crosshair to select the ending time and enters the number of cycles over which to average the instantaneous values before display (1-9). Normally no averaging is necessary, but in some instances this averaging feature is useful.

The output paging described with the instantaneous values table is also used with the rms values table. Figure C-12 presents a typical display of this type. When the user is finished with the last screen full of rms values, he enters "GO". Again since this format has no time axis, the test summary plot is automatically produced.

PHASE 1
EACH ENTRY REPRESENTS AN AVERAGE OF 1 READINGS

RMS VOLTAGE (VOLTS)	RMS CURRENT (AMPS)	FREQUENCY (HZ)	PF	TIME (SEC)
115.1	0.77	397.5	0.066	0.121976
115.0	0.77	397.2	0.009	0.124489
114.7	0.77	397.1	0.023	0.127005
114.6	0.97	397.1	0.015	0.129522
114.7	0.77	397.2	0.119	0.132037
114.6	0.66	397.4	0.143	0.134549
114.8	0.66	397.7	0.051	0.137067
114.7	0.77	397.3	0.022	0.139583
105.4	45.7	391.3	0.723	0.142098
107.8	50.0	395.1	0.817	0.144653
112.5	52.0	395.1	0.819	0.147182
115.6	53.2	395.7	0.819	0.149735
117.0	53.8	394.1	0.818	0.152234
117.4	53.8	395.2	0.817	0.154768
116.0	53.4	394.6	0.816	0.157298
115.0	53.0	395.0	0.818	0.159833
115.1	53.5	395.6	0.820	0.162359
114.4	53.4	395.4	0.814	0.164897
114.2	53.1	397.3	0.818	0.167459
114.4	53.3	397.4	0.819	0.169926
114.4	53.3	397.0	0.819	0.172443
114.7	53.3	397.7	0.820	0.174962
114.9	53.5	397.8	0.820	0.177476

Fig C-12. Rms Phase Values Table

Quick Replot (QK)

In instances where the current display format has no time axis from which to select starting and ending times or when a larger time range is desired, the user must select a replot of the original test summary by entering "QK". Discussion of this display format has been presented earlier.

Exiting Display Software

When all desired displays of generator test data have been produced, the user exits the display software by answering the "ENTER PLOT OPTIONS" message with "\$\$".

VITA

Philip Glen Gaberdiel was born on 31 May 1952 in Elk City, Oklahoma. He graduated from high school in Hobart, Oklahoma in 1970 and attended the University of Oklahoma, Norman, Oklahoma, until early 1972. He enlisted in the United States Air Force in 1972 and was accepted for the Airman's Education and Commissioning Program in 1973. He then returned to the University of Oklahoma and received the Bachelor of Science in Electrical Engineering in May 1976. After his commissioning in September 1976, he was assigned to the Aerospace Power Division of the Aero Propulsion Laboratory at Wright-Patterson, AFB, Ohio. Since then he has worked as project engineer in the development of the Generator Test Facility and has pursued the class work requirements for the Computer Systems degree at the Air Force Institute of Technology on a part-time basis.

Permanent address: 2629 S.W. 57th. St.

Oklahoma City, Oklahoma 73119

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER AFIT/GCS/EE/80-1	2. GOVT ACCESSION NO AD-A100 285	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) COMPUTER ANALYSIS OF 400 HZ AIRCRAFT ELECTRICAL GENERATOR TEST DATA		5. TYPE OF REPORT & PERIOD COVERED MS Thesis
7. AUTHOR(s) Philip G. Gaberdiel 1Lt USAF		6. PERFORMING ORG. REPORT NUMBER
9. PERFORMING ORGANIZATION NAME AND ADDRESS Air Force Institute of Technology (AFIT-EN) Wright-Patterson AFB, Ohio 45433		8. CONTRACT OR GRANT NUMBER(s)
11. CONTROLLING OFFICE NAME AND ADDRESS Aero Propulsion Laboratory Air Force Wright Aeronautical Laboratories (AFSC) Wright-Patterson AFB, Ohio 45433		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		12. REPORT DATE June 1980
		13. NUMBER OF PAGES 156
		15. SECURITY CLASS. (of this report) UNCLASSIFIED
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES Approved for public release; IAW AFR 190-17 <i>Fredric C. Lynch</i> FREDRIC C. LYNCH, Major, USAF Director of Public Affairs 16 JUN 1981		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) 400 Hertz Waveforms Aircraft Electrical Generators Electrical Transients		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) A software system was specified which would derive the performance measures of MIL-STD-704B from the test data provided by the Generator Test Facility. This analysis software system was then designed and implemented. Accuracy tests on the system demonstrated that very precise measurement of generator performance can be obtained. A software system was also designed and implemented to display the analysis results to the user. The display system employs a Tektronix 4010 terminal in		

DD FORM 1 JAN 73 1473

EDITION OF 1 NOV 65 IS OBSOLETE

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

an interactive mode to present the data. The user, therefore, selects the particular display and time range to be presented.

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

END

DATE
FILMED

7-81

DTIC