

AD-A187 454

NAVAL POSTGRADUATE SCHOOL MONTEREY CA
DESIGN MODEL FOR THE HEAT TRANSFER IN A SHORT STRAIGHT TUBE BOI--ETC(U)
JUN 81 L W VOLLMER


F/O 13/1


BOI--ETC(U)

UNCLASSIFIED

NL

1 of 2
AD-A187 454





MICROCOPY RESOLUTION TEST CHART
NATIONAL BUREAU OF STANDARDS 1963-A

AD A107454

NAVAL POSTGRADUATE SCHOOL
Monterey, California

LEVEL



THESIS

DTIC
ELECTE
NOV 19 1981
S D

DESIGN MODEL FOR THE HEAT TRANSFER
IN A SHORT STRAIGHT TUBE BOILER

by

Leo W. Vollmer, Jr.

June 1981

Thesis Advisor:

P.F. Pucci

Approved for public release; distribution unlimited.

DTIC FILE COPY

81 11 18 030

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER	2. GOVT ACCESSION NO. AD-A107454	3. RECIPIENT'S CATALOG NUMBER (9)
4. TITLE (and Subtitle) Design Model for the Heat Transfer in a Short Straight Tube Boiler.		5. TYPE OF REPORT & PERIOD COVERED Master's Thesis, June 1981
7. AUTHOR(s) Leo W. Vollmer, Jr.		6. PERFORMING ORG. REPORT NUMBER
9. PERFORMING ORGANIZATION NAME AND ADDRESS Naval Postgraduate School Monterey, California 93940		8. CONTRACT OR GRANT NUMBER(s)
11. CONTROLLING OFFICE NAME AND ADDRESS Naval Postgraduate School Monterey, California 93940		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		12. REPORT DATE June 1981
		13. NUMBER OF PAGES 181
		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
19. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Waste heat recovery Short straight tube boiler Stagnation boiler Boiling heat transfer		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) A design model for the Short Straight Tube Boiler with a segmented fin-tube arrangement was developed. This model was integrated for a single tube applied in a computer program written in BASIC for the Hewlett Packard 9845 model B desk-top computer. Water-side Reynolds numbers were varied in order to investigate the performance of this boiler. For an overall tube length of 39.4 inches, a Reynolds number of 840 (29.65 lbm/hr) resulted in obtaining 50° superheat for an		

DD FORM 1473 JAN 73

EDITION OF 1 NOV 68 IS OBSOLETE
S/N 0102-014-6001

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE/When Data Entered

Item 20 continued:

operating pressure of 600 psig. With these conditions, saturated boiling begins at 11.45 inches and superheating at 21.88 along the tube length.

Accession For	
NTIS GRA&I	☒
DTIC TAB	☐
Unannounced	☐
Justification	
By	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A	

Approved for public release; distribution unlimited.

Design Model for the Heat Transfer
in a Short Straight Tube Boiler

by

Leo W. Vollmer, Jr.
Lieutenant, United States Navy
B.S.E.E. Purdue University, 1974

Submitted in partial fulfillment of the
requirements for the degree of

MASTER OF SCIENCE IN MECHANICAL ENGINEERING

from the

NAVAL POSTGRADUATE SCHOOL

June 1981

Author:

Leo W. Vollmer Jr.

Approved by:

Paul J. Green Thesis Advisor

P.J. Martin Co-Advisor/Second Reader

P.J. Martin
Chairman, Department of Mechanical Engineering

William M. Toller
Dean of Science and Engineering

ABSTRACT

A design model for the Short Straight Tube Boiler with a segmented fin-tube arrangement was developed. This model was integrated for a single tube and applied in a computer program written in BASIC for the Hewlett Packard 9845 model B desk-top computer.

Water-side Reynolds numbers were varied in order to investigate the performance of this boiler. For an overall tube length of 39.4 inches, a Reynolds number of 840 (29.65 lbm/hr) resulted in obtaining 50° superheat for an operating pressure of 600 psig. With these conditions, saturated boiling begins at 11.45 inches and superheating at 21.88 along the tube length.

TABLE OF CONTENTS

I.	INTRODUCTION	15
A.	BOILER	15
1.	An Overview	15
2.	History	16
3.	Boiler Types	21
a.	Fire-Tube Boilers	22
b.	Water-Tube Boilers	31
4.	Water Circulation	50
5.	Heat Source	52
B.	RACER AND THE SST	54
C.	OBJECTIVE	58
II.	MODEL DESCRIPTION	60
A.	AN OVERVIEW	60
B.	GEOMETRY	64
1.	Segmented Fins	65
2.	Pin Fins	65
C.	GAS-SIDE HEAT TRANSFER/PRESSURE DROP	70
D.	WATER-SIDE HEAT TRANSFER	73
E.	OVER-ALL HEAT TRANSFER	84
III.	RESULTS AND CONCLUSIONS	90
A.	BACKGROUND	90
B.	DESIGN VARIABLES	91
1.	S.S.T. Operating Pressure	92

2. Frontal Diminsions -----	92
3. Gas Flow Rate and Temperatures -----	92
4. Superheater Outlet Steam Temperature ----	92
5. Water Inlet Temperature -----	92
6. Fin Geometry -----	92
C. THE DATA SET -----	93
D. CONCLUSION -----	108
IV. RECOMMENDATIONS FOR FURTHER RESEARCH -----	136
APPENDIX A: PROGRAM LISTING -----	138
LIST OF REFERENCES -----	178
INITIAL DISTRIBUTION LIST -----	181

LIST OF FIGURES

FIGURE 1:	BRONZE WATER-COOLED TUBES AND WATER-COOLED FURNACE CHAMBER WALL -----	17
FIGURE 2:	THOMAS SAVERY'S FIRST BOILER - 1698 -----	22
FIGURE 3:	THOMAS SAVERY'S IMPROVED BOILER - 1702 -----	23
FIGURE 4:	DR. DESAGULIER'S WINDING FLUE BOILER - 1718 -----	24
FIGURE 5:	HAYSTACK BOILER - 1725 -----	25
FIGURE 6:	JAMES WATTS WAGON-TYPE BOILER - 1795 -----	25
FIGURE 7:	CYLINDRICAL BOILER - 1790 -----	26
FIGURE 8:	OLIVER EVAN'S RETURN-FLUE BOILER - 1800 ----	27
FIGURE 9:	RICHARD TREVITHICKS' CORNISH BOILER -----	28
FIGURE 10:	VERTICAL BOILER TYPES -----	29
FIGURE 11:	FIRST WATER-TUBE BOILER - 1766 -----	32
FIGURE 12:	BOX-SHAPE WATER-TUBE BOILER - 1793 -----	33
FIGURE 13:	JOHN STEVEN'S PORCUPINE BOILER - 1804 -----	33
FIGURE 14:	JOHN COX STEVENS' WATER-TUBE BOILER - 1805 -----	34
FIGURE 15:	THE FIRST SECTIONAL WATER-TUBE BOILER - JOSEPH EVE - 1825 -----	35
FIGURE 16:	GOLDWORTHY GURNEY'S CARRIAGE BOILER - 1826 -----	36
FIGURE 17:	STEPHEN WILCOX'S BOILER WITH INCLINED TUBES - 1856 -----	37
FIGURE 18:	FIRST SECTIONAL WATER-TUBE BOILER WITH INCLINED TUBES -TWBILL - 1865 -----	37
FIGURE 19:	SIDE VIEW OF HEADER-TYPE BOILER -----	40
FIGURE 20:	BASIC "A" TYPE BOILER -----	42

FIGURE 21:	YARROW TYPE BOILER -----	43
FIGURE 22:	"A" TYPE BOILER WITH UNCONTROLLED INTEGRAL SUPERHEAT -----	43
FIGURE 23:	SECTIONAL EXPRESS TYPE BOILER - 1939 -----	44
FIGURE 24:	SEPARATELY FIRED SUPERHEATER BOILER - 1930 -----	44
FIGURE 25:	"A" TYPE BOILER FOR GENERATING SUPERHEATED STEAM WITH CONTROLLED, INTEGRAL, INTERDECK SUPERHEAT -----	45
FIGURE 26:	"M" TYPE BOILER WITH CONTROLLED, INTEGRAL SUPERHEATER -----	46
FIGURE 27:	MODIFIED "A" OR GUEST BOILER -----	47
FIGURE 28:	"D" TYPE BOILER -----	48
FIGURE 29:	NEWER 1200 PSIG SINGLE-FURNACE BOILER FOR POST WORLD WAR II DESTROYERS -----	49
FIGURE 30:	THE "BENSON" BOILER -----	51
FIGURE 31:	SCHEMATIC DIAGRAM OF CONTROLLED CIRCULATION BOILER -----	53
FIGURE 32:	SHORT STRAIGHT-TUBE BOILER UNIT -----	57
FIGURE 33:	SEGMENTED FIN PROFILE -----	66
FIGURE 34:	PIN FIN PROFILE -----	67
FIGURE 35:	MODEL TUBE LAYOUT -----	69
FIGURE 36:	HEAT TRANSFER CONSTANTS -----	71
FIGURE 37:	SURFACE HEAT FLUX VS. INLET SUBCOOLING -----	75
FIGURE 38:	METHOD OF ROHSENOW -----	77
FIGURE 39:	TWO-PHASE FLOW DEVELOPMENT -----	79
FIGURE 40:	SUPPRESSION FACTOR, S -----	91
FIGURE 41:	WATER MASS FLOW VS. REYNOLDS NO. -----	94
FIGURE 42a:	SUPERHEAT VS. REYNOLDS NO. -----	96
FIGURE 42b:	STEAM MASS FLOW VS. SUPERHEAT -----	97

FIGURE 43:	REYNOLDS NO. = 310	-----	98
FIGURE 44;	REYNOLDS NO. = 300	-----	99
FIGURE 45:	REYNOLDS NO. = 310	-----	100
FIGURE 46:	REYNOLDS NO. = 380	-----	101
FIGURE 47:	REYNOLDS NO. = 310	-----	102
FIGURE 48:	REYNOLDS NO. = 380	-----	103
FIGURE 49:	LOCATION OF ZERO% QUALITY	-----	104
FIGURE 50"	LOCATION OF 100% QUALITY	-----	105
FIGURE 51a:	REYNOLDS NO. = 840	-----	109
FIGURE 51b:	REYNOLDS NO. = 840	-----	110
FIGURE 51c:	REYNOLDS NO. = 840	-----	111
FIGURE 52a:	REYNOLDS NO. = 840	-----	112
FIGURE 52b:	REYNOLDS NO. = 840	-----	113
FIGURE 52c:	REYNOLDS NO. = 840	-----	114
FIGURE 53a:	REYNOLDS NO. = 840	-----	115
FIGURE 53b:	REYNOLDS NO. = 840	-----	116
FIGURE 53c:	REYNOLDS NO. = 840	-----	117
FIGURE 54a:	REYNOLDS NO. = 840	-----	118
FIGURE 54b:	REYNOLDS NO. = 840	-----	119
FIGURE 54c:	REYNOLDS NO. = 840	-----	120
FIGURE 55a:	REYNOLDS NO. = 840	-----	121
FIGURE 55b:	REYNOLDS NO. = 840	-----	122
FIGURE 55c:	REYNOLDS NO. = 840	-----	123
FIGURE 55d:	REYNOLDS NO. = 840	-----	124
FIGURE 56a:	REYNOLDS NO. = 840	-----	125
FIGURE 56b:	REYNOLDS NO. = 840	-----	126

FIGURE 56c: REYNOLDS NO. = 840 -----	127
FIGURE 56d: REYNOLDS NO. = 840 -----	128
FIGURE 57a: REYNOLDS NO. = 840 -----	129
FIGURE 57b: REYNOLDS NO. = 840 -----	130
FIGURE 57c: REYNOLDS NO. = 840 -----	131
FIGURE 58a: REYNOLDS NO. = 840 -----	132
FIGURE 58b: REYNOLDS NO. = 840 -----	133
FIGURE 59a: REYNOLDS NO. = 840 -----	134
FIGURE 59b: REYNOLDS NO. = 840 -----	135

LIST OF TABLES

Table 1.	HEAT BALANCE RESULTS -----	106
Table 2.	TUBE/FIN DIMENSIONS AND AREAS -----	107

NOMENCLATURE

English Letter Symbols

A	- Area (FT ²)
A _b	- Frontal Area Blocked by Tubes and Fins (FT ²)
A _{bt}	- Bare Tube Area (FT ²)
A _f	- Heat Exchanger Frontal Area (FT ²)
A _{fin}	- Fin Area (FT ²)
A _{ff}	- Cross-Sectional Area for Fluid Flow (FT ²)
A _{min}	- Minimum Cross-Sectional Area for Gas Flow (FT ²)
A _{si}	- Inside Heat Transfer Area (FT ²)
A _{so}	- Outside Heat Transfer Area
C _{max}	- Maximum Heat Capacity (BTU/Hr-F)
C _{min}	- Minimum Heat Capacity (BTU/Hr-F)
C _{pf}	- Specific Heat of Water/Steam (BTU/lbm-F)
C _{pg}	- Specific Heat of Gas (BTU/lbm-F)
d _f	- Fin Outside Diameter (FT)
d _i	- Inside Tube Diameter (FT)
d _o	- Outside Tube Diameter (FT)
D _p	- Pin Outside Diameter (FT)
f'	- Friction Factor
F	- Reynolds Number Factor
G _{max}	- Maximum Gas Flow Rate Per Square Foot (lbm/hr-FT ²)
h	- Heat Transfer Coefficient (BTU/Hr-FT ² °F)
H _{ps}	- Horizontal Pin Spacing (FT)

I	- Enthalpy (BTU/lbm)
I_f	- Enthalpy of Saturated Water (BTU/lbm)
I_{fs}	- Enthalpy of Vaporization (BTU/lbm)
j	- Heat Transfer Colburn j -Factor
k_g	- Thermal Conductivity of Gas (BTU-Hr-FT-F)
l	- Fin Height (FT)
l_c	- Length of Cut from Fin Tip (FT)
L_p	- Average Pin Length (FT)
L_T	- Tube Length (FT)
N, NTU	- Number of Transfer Units
N_f	- Number of Fins Per Inch
N_s	- Number of Segments in One Fin
ϕ_{ONB}	- Heat Flux to Initiate Boiling (BTU/Hr-FT ²)
P	- Pressure (psia)
Q	- Heat Transfer Rate (BTU/Hr)
R_i	- Heat Exchanger Inside Resistance (Hr-FT ² °F/BTU)
R_o	- Heat Exchanger Outside Resistance (Hr-FT ² °F/BTU)
R_{th}	- Thermal Resistance (Hr-FT ² -F/BTU)
T_f	- Fin Thickness (FT)
T_g	- Gas Temperature (°F)
T_{sat}	- Temperature of Saturated Water (F)
T_{TO}	- Outside Tube Wall Temperature (°F)
T_{Ti}	- Inside Tube Wall Temperature (°F)
U_{oi}, U_{oo}	- Overall Heat Transfer Coefficient (BTU/Hr-FT ² -F)
V_{ps}	- Vertical Pin Spacing (FT)

x	- Steam Quality
x_e	- Equilibrium Quality
x_T	- True Quality
x_{TT}	- Martinelli Parameter

Dimensionless Groups

Nu	- Nusselt Number
Pr	- Prandtl Number
Re	- Reynolds Number
Re_{TP}	- Two-Phase Reynolds Number
St	- Stanton Number

Greek Letter Symbols

σ	- Water Surface Tension (lbf/FT)
α	- Void Fraction
ΔP	- Pressure Change (psia)
ΔT	- Temperature Change (F)
ϵ	- Effectiveness
μ_b	- Viscosity at Bulk Temperature (lbm/FT-Hr)
μ_w	- Viscosity at Tube Wall Temperature (lbm/FT-Hr)
η	- Fin Efficiency
η_s	- Surface Efficiency
ρ	- Density (lbm/FT ³)
ρ_l	- Density of Saturated Water (lbm/FT ³)
ρ_v	- Density of Saturated Vapor (lbm/FT ³)

I. INTRODUCTION

A. BOILER

1. An Overview

A boiler is an apparatus in the form of a closed vessel constructed for the continuous generation of vapor under pressure through the transference of heat to the liquid which is contained in it. The energy for most boilers is provided by the combustion of the fossil fuels - coal, oil, coke, or gas. Coal is the major fuel, but most boilers are convertible from one fuel to another. Other fuels such as wood, waste gases from industrial processes, and solid wastes such as bagasse (from sugarcane), sawdust, and even trash and garbage serve as energy sources. An increasing number of large steam plants built since 1960 for generating electricity are designed to use nuclear fuel, which provides heat from nuclear fission.

The simple term "boiler" ordinarily refers to the steam boiler which utilizes available heat energy to convert water into steam. Because a boiler produces saturated steam only, it must be distinguished from the steam generator which may include a superheater, economizer, and air preheater as integral and necessary parts of the equipment. In their simplest form, boilers are closed caldrons of water placed over an open fire. Boilers range in size and function from

the compact units in domestic heating systems to 20-story complexes that drive giant steam turbines for electrical power production. They are built in many forms with rated steaming capacities from 40 lbm/hr to 1,000,000 lbm/hr steam production and operating pressures ranging from 2 psia to the critical pressure of water, 3208 psia.

2. History

The development of the boiler was initiated and has been sustained by the development of the steam engine and steam turbine. Early versions of both, more toys than serious inventions, are referred to in the writings of Hero of Alexandria during the third century B.C. Contrary to popular belief, the principles used in boiler design are not recent developments but are of ancient origin. As early as 200 B.C., boilers were employed for warming water, heating, and household services. An example of this type of boiler is shown in Fig. 1. In this boiler, found in the ruins of Pompeii, the grate consisted of bronze water-cooled tubes and a water-cooled furnace chamber wall. The boiler was internally fired, a feature which did not appear again until the early 18th century. Water-cooled furnaces and water tubes also were innovations not incorporated in boiler design until recent.

However, basic principles for boiler construction, comparable to those set down in 1769 by James Watt for the steam engine, were not widely known until the 19th century. Beginning with Hero, the caldron form of boiler was used.




FIGURE 1: BRONZE WATER-COOLED TUBES AND WATER-COOLED FURNACE CHAMBER WALL

It was not until the latter part of the 17th century that boilers in a real sense appeared on the scene. During this period, the greatest potential use for power seemed to be pumping water out of mines, and a number of engines were invented for this purpose.

These pumping engines, from those first successfully pioneered by Thomas Savery in 1699, to the engine patented in 1769 by James Watt, were not true steam engines, but atmospheric engines. Steam was used to fill a cylinder in which a piston was mounted. When the steam was suddenly condensed by a spray of water, a partial vacuum was created, and the piston was forced down by atmospheric pressure. The steam pressure that raised the piston, with the help of a counterweight on each cycle of operation, was only slightly above atmospheric pressure. The steam pressure was so low that without the counterweight the piston would not have moved. Consequently, the boilers for these engines were of relatively simple design.

The wagon boiler, designed by James Watt, and in use from about 1774, was hardly more than a long, riveted, metal water tank placed over a brick setting or narrow brick oven. The furnace was at one end and the stack of chimney at the other. The combustion gases passed along the bottom of the boiler to the other end where they were channeled back to heat the sides before entering the chimney at the hearth end. Although many odd forms were tried between 1780 and 1820, the wagon boiler was most common until the invention of the

internal flue by Oliver Evans in the United States and, independently, between 1800-1805 by Richard Trevithick in England.

In true steam engines, where steam does mechanical work, it is advantageous to impart the highest pressure possible to the steam before it is released into the pressure cylinder. Both Evans and Trevithick saw the necessity of high pressure engines for marine and locomotive applications and were chiefly responsible for the adoption of higher steam pressures. Built in two forms, the boiler was a long cylindrical shell with a large internal cylindrical tube. In one form the flue contained a furnace at one end and opened to a stack at the other. In the second a brick setting was used. Hot gases from the furnaces were drawn through the setting, heating the lower surface of the shell, and then returned through the internal flue to the stack above the furnace.

With the addition of a number of small internal flues, called fire tubes, operating pressures increased rapidly. The usual pressure in the time of Watt was only 5-7 psi above atmospheric. Evans, Trevithick, and John Stevens of New York early in the 19th century used pressures from 50-75 psia. Jacob Perkins of Massachusetts, in work done between 1823 and 1827, actually obtained 1400 psia. But in general, fire-tube boilers are limited to relatively low operating pressures because of the difficulty of constructing a shell strong enough to withstand the high pressure required for efficient operation. As pressure demands of steam engines and turbines increased,

the fire-tube boiler was supplemented by the water-tube boiler. During the 1820's, steam pressures on the Mississippi steamboats and elsewhere in the United States had been raised to 100 and 150 psia, but explosions were frequent.

It was early recognized that the strength requirements for increased pressure could be met if the tubes contained the water rather than the hot gases. Two problems impeded the development of the water-tube boiler. First, adequate circulation of the water within the tubes had to be maintained in order to absorb the heat transferred through the tube wall. Without this circulation the tube-wall temperature and the tube would be burned out. A second difficulty was the explosion hazard of high pressure operation where relatively large amounts of water are in contact with heating surfaces liable to fail because of overheating. In the event of such failure, liquid water at the saturation temperature corresponding to a high pressure, flashes to steam with explosive force. If, however, the total amount of water in a boiler flows in a sufficient number of parallel circuits, as in a sectioned boiler, a failure in the heating surface will not be serious. Although these problems were recognized by Joseph Eve and Goldsworth Gurney in 1825 and 1826, the only successful water-tube boiler prior to 1870 was that patented by Babcock and Wilcox in 1867.

The period from 1870 to 1900 was one of improvements. The multiple drum bent-tube (Stirling) boiler, successfully

introduced in 1893 is actually the most recent form of boiler construction. Subsequent improvements in materials and methods of construction increased the steaming capacity of the largest central power plant boilers from 30,000 lbm/hr in 1905 to 1,000,000 lbm/hr by 1935. In 1926, Iving Moulthrop was responsible for the increase in operating pressures from 350 to 1200 psia. By 1935 this pressure had gone to 1600 psia. Modern plants are built to operate above critical temperature at 4500 to 5000 psia. The steam generator superheat temperatures have likewise increased from a maximum of 550°F in 1905 to 750°F in 1925 and 950°F in 1938. Modern plants are designed to operate at 1050°F to 1100°F.

3. Boiler Types

There are basically two types of boilers: fire-tube and water-tube boilers. All boilers that restrict the passage of the hot gases through flues or tubes where they transfer their heat to the surrounding liquid are called fire-tube boilers. In the water-tube boiler the flue gases pass over the exterior surface of the tubes while the water being heated passes within the tube. Another distinguishing feature between these two types of boilers is that the fire-tube boiler is supported by the setting sidewalls or the fire box and the water-tube boiler is usually suspended from the overhead steel work and columns.

a. Fire-Tube Boilers

Figures 2 to 10 show a historical development of the fire-tube boiler from the first boiler used by Savery in 1698 to the famous Cornish boiler designed by Trevithick.




FIGURE 2: THOMAS SAVERY'S FIRST BOILER - 1698




FIGURE 3: THOMAS SAVERY'S IMPROVED BOILER - 1702

Modern engineering practice limits the use of fire-tube boilers to about 500 horsepower and a working pressure of 150 psig. Designers of pressure vessels proportion the shell thickness to the diameter and working pressure to be encountered. Upon reaching the above limits the shell thickness requirement becomes such that it is difficult to fabricate. These limitations are also placed for safety reasons; for an explosion of one of the larger fire-tube




FIGURE 4: DR. DESAGULIER'S WINDING FLUE BOILER - 1718

boilers can be quite disastrous due to the instant release of large volumes of steam having tremendous expansive power.

The Watt wagon-type boiler, Fig. 6, and the cylindrical or flueless boiler, Fig. 7, are made up of flat plates rolled to shape and riveted or welded longitudinally and also circumferentially when several plate lengths are required to obtain the desired capacity provided with a




FIGURE 5: HAYSTACK BOILER - 1725




FIGURE 6: JAMES WATTS WAGON-TYPE BOILER - 1785

water-inlet, a condensate return, a steam outlet, a gauge glass for ascertaining the water level, and a safety valve for the relief of excess pressure makes the simplest kind of boiler when mounted over a suitable refractory combustion box or chamber and entirely insulated against heat loss. This elementary design is rather awkward and requires much space since the tank or drum is limited in its pressure withstanding capabilities. The use of this type of boiler is restricted to a moderate working pressure and stationary applications only.




FIGURE 7: CYLINDRICAL BOILER - 1790

Cylindrical boilers function by burning fuel in a refractory combustion chamber constructed under the cylindrical drum. The combustion products flow along the underside of the drum from front to back and then exit through an uptake to the chimney or stack. The heat in the flue gases must be transmitted through the metal drum into the liquid in order to preheat and vaporize it. Since the time element is short, with the gases passing from front to back only once, then exiting, the overall efficiency of this arrangement is low. The boiler is a notorious slow steamer; however, once the steaming action has started, it is a steady steamer. These boilers are limited to small capacities, usually to 350 boiler horsepower, because of their inherent tendency to explode.




FIGURE 8: OLIVER EVAN'S RETURN-FLUE BOILER - 1800




FIGURE 9: RICHARD TREVITHICKS' CORNISH BOILER

The flue boiler is an improvement over the cylindrical boiler, see Figures 8 and 9, in that one or more inner flues are incorporated for the purpose of conducting the flue gases through the center of the shell, cylinder or drum. There are many variations of design with some using these flues as actual combustion chambers. The use of flues increases the ratio of heating surface to the volume of water to be evaporated; therefore, the flue boiler generates steam more quickly than the ordinary cylindrical boiler. When the flue boiler is arranged so that combustion takes place within the flue greater savings in weight and space can be effected rendering the design highly applicable to locomotion and propulsion applications because of its portability.

The vertical upright fire-tube boiler, Figure 10, is available in ranges from 5 to 300 horsepower, and consists of a cylindrical steel shell completely filled with tubes vertically mounted over a fire box. The flue gases pass in single flow directly through the tubes and into the stack at the top. While the vertical boiler is not highly efficient it has other virtues such as portability, a small floor requirement, a large heat surface in a small volumetric space, and an extreme ruggedness which has won it the name of "The Donkey Boiler". The popular fire engine "pumper" of several




FIGURE 10: VERTICAL BOILER TYPES

decades ago used this type of boiler to generate high pressure steam in order to motivate a reciprocating piston plunger pump. It also found wide use in the inaccessible, mountainous terrain of the Pacific Northwest during the logging boom of the late 1880's.

Fire-tube boilers become limited as capacity and pressure requirements increase. Larger shell diameters require thicker plates to withstand the temperature and pressure stresses. Temperature differentials in the boiler create high stresses. These stresses combined with the effects of precipitates and other deposits have caused many boiler explosions [Ref. 2]. Other disadvantages include long warm-up time requiring up to 15 hours to produce steam for propulsion, unequal expansion of metal parts at an increased firing rate, faster expanding fire tubes tend to pull loose from the boiler shell, heavy weight, up to 15 lbs of boiler and water to produce 1 lb of saturated steam per hour and inefficiency requiring large amounts of fuel to produce a relatively small amount of steam.

Fire-tube boilers tend to be dangerous at high steam pressures. This is partly due to inherent structural problems and partly due to the relatively large quantity of water and steam contained in the boiler. In the event of a rupture in the boiler, the large amount of water and steam releases great destructive energy. With this ever-increasing demand for more and more steam at higher and higher pressure

the water-tube boiler was developed. When steam and water at elevated pressure are confined within a tube of small or moderate diameter the thickness requirement is reasonable and practical.

b. Water-Tube Boilers

The water-tube boiler is composed of drums and tubes which are external to the drums and serve as interconnections for them. The drums store water and steam and contain no tubular heating surface, thereby allowing for these vessels to be much smaller in diameter than a fire-tube boiler shell and resulting in resisting higher pressures. This boiler may be a straight or bent-tube type, and in both cases, the tubes possess the entire heating surface.

The principle of using water tubes is an old one as shown by the use of the Pompeian household boiler. Modern development of the horizontal, straight water-tube boiler began in 1766 by William Blakely who patented an improvement in the Savery engine which included a novel steam generator. The arrangement of heat transfer surfaces shown in Figure 11, probably was the first step toward the development of water-tube boilers, which has resulted in the modern high pressure water-tube boiler.

Three men, James Rumsey, John Fitch, and James Marlow, worked independently upon a box-shaped water-tube boiler with horizontal tubes, as shown in Fig. 12. The disadvantages of this design were the weak box-shaped pressure




FIGURE 11: FIRST WATER-TUBE BOILER - 1766

vessels and the restricted water circulation in the horizontal tubes. This was not critical since steam pressures were between 3 to 7 psig.

In 1804, John Stevens designed a boiler for a steamboat operating on the Hudson River. This boiler, Fig. 13, had slightly inclined tubes connected at one end with a

reservoir. The Steven's Porcupine boiler, as it is known, marked a definite advance in design of high pressure steam-generating apparatus, as its working pressure was 50 psig. Again, lack of proper water circulation in the tubes was a




FIGURE 12: BOX-SHAPE WATER-TUBE BOILER - 1793




FIGURE 13: JOHN STEVENS' PORCUPINE BOILER - 1804

serious defect. Stevens' son, John Cox Stevens, designed a water-tube boiler in 1805. This boiler, shown in Fig. 14, consisted of 20 vertical tubes arranged in a circle, connecting a water space at the bottom and a steam space at the top. The steam and water chambers were annular spaces of small cross section and small volume.



FIGURE 14: JOHN COX STEVENS' WATER-TUBE BOILER - 1805

Figures 15, 16, 17 and 18 show the development of the water-tube boiler in the next sixty years. The first sectional water-tube boiler with well defined circulation was built by Joseph Eve in 1825. Sectional boilers have the




FIGURE 15: THE FIRST SECTIONAL WATER-TUBE BOILER - JOSEPH EVE - 1825

water-steam spaces divided into small sections, none of which is subject to disastrous explosion. Basically all water-tube boilers are sectional in character. Figure 15 shows the sectional composed of small tubes, practically vertical but with a slight double curve. The tubes were fixed in larger horizontal tubes called headers, which, in turn, were connected to a steam space above and a water space below. The steam and water spaces were joined by outside pipes (down-comers) to

secure a circulation of water up through the sections and down through the external pipes. In 1826, Goldworthy Gurney built a number of boilers for use on his steam carriages, one of which is shown below. This boiler consisted of a number of




FIGURE 16: GOLDWORTHY GURNEY'S CARRIAGE BOILER - 1826

small "U" tubes, laid sidewise, with the ends connected to larger horizontal pipes. These, in turn, were connected by vertical pipes to permit circulation and also were connected to vertical cylinders serving as steam and water reservoirs. In 1856, Stephen Wilcox first used inclined water-tubes to connect water spaces at the front and rear with a steam space above, Fig. 17. The first to use inclined tubes in a sectional form was George Twbill in 1865, Fig. 18. He used wrought iron




FIGURE 17: STEPHEN WILCOX'S BOILER WITH INCLINED TUBES - 1856




FIGURE 18: FIRST SECTIONAL WATER-TUBE BOILER WITH INCLINED TUBES - TWBILL - 1865

tubes connected at the front and rear to standpipes. These standpipes carried the steam to horizontal cross-drums at the top, the entrained water being separated and led to the rear standpipe. In the following years, development of water-tube boilers continued with great vigor. Steam drums soon were substituted for the nest of cast iron tubes and pipes originally used for steam and water storage. Steel replaced cast iron for the generating tubes. Large tubes were replaced by small tubes to increase heat transfer areas. The transition to water-tube boiler design didn't arrive until the end of the 19th century when the triple expansion reciprocating steam engine was introduced to the navies of the world.

The head type boiler was the first form of water-tube boiler to displace the fire-tube type for use in steam vessels. A header type boiler was installed in the yacht *Reverie* in 1889 with a designed pressure of 225 psig. The success of this and other similar installations led to a decision by the Admiralty to use this boiler in the British Navy. In 1896, the U. S. Navy installed this type in three vessels, *Marietta*, *Annapolis*, and *Chicago*.

Although the *Reverie* design was an outstanding success and proved to be far more satisfactory in service than other boilers previously used by the Navy, combustion was not entirely satisfactory. The shape of the furnace made it necessary to slope the grates down toward the rear to gain furnace volume. At high ratings, this furnace was not suitable

for good combustion. Also, the fittings and water gages were not readily accessible from the firing aisle because of the steam drum location.

To overcome these difficulties, the design was modified to permit firing from the opposite end. Combustion conditions improved since the furnace was enlarged in the direction in which combustion took place. The grates were relocated and the accessibility of the tubes for cleaning from the fireroom floor was improved greatly. The steam drum was now at the firing end of the boiler, where the water gage could be seen easily and all fittings were more accessible. These modifications, seemingly very simple, revolutionized marine water-tube boiler design. The many improvements throughout the years have resulted in the sectional header type boiler, shown in Fig. 19, as we know it today.

The necessity for more steam brought on experimentation with forced draft to accelerate combustion of marine boilers. Although Robert Stevens tried in 1827 to supply air by forced draft, it was not until 1880 before a successful forced draft system was designed by James Howden. Interestingly, his design also included means by which waste heat in flue gases was used to heat the incoming air for combustion. The increased steam pressures and rapidity of steam generation led to serious trouble arising from overheating of tube ends and tube-sheets, causing many breakdowns and explosions from endeavors to work cylindrical fire-tube boilers under forced




FIGURE 19: SIDE VIEW OF HEADER-TYPE BOILER

draft. The proponents of this boiler type, satisfied with the partial solution of installing tube inserts in the tube ends, argued that the generated pressures were sufficient for their needs.

Then in 1894, Charles A. Parsons developed and proved the superiority of the steam turbine for marine propulsion. The advantages of the turbine were immediately apparent and within a relatively short time (1894-1914) almost all important ships of the world navies were driven by turbines. Higher pressures, greater steam capacity and utilization of propulsion turbines concurrently accelerated the development of the water-tube boiler. A major contribution to higher pressure and greater steam capacity was the evolution of treating boiler water to prevent scale formation and boiler corrosion.

From the days of the caldron boiler until well into the turn of the 20th century there was very little improvement in steam generation except in the larger power-generating stations operated by the greater public utilities. At the end of the 19th century the new fast torpedo boats and destroyers, demanding boilers of light and compact design, brought forth the drum-type express boiler. The name "express" is used in its sense "dispatched with special speed" and is applied to this type boiler because of the "speed" with which steam can be raised and with which this boiler can answer steam demand changes.




FIGURE 20: BASIC "A" TYPE BOILER

The development of drum-type boilers as applicable to naval vessels to present time is shown in Figs. 20-29. Figure 20 illustrates the basic design of A-type boilers (so named because of the shape of the generating elements resembling the letter "A") which evolved from such early designs as the Yarrow express boiler shown in Fig. 21. The A-type boiler was originally designed as a coal-fired boiler (converted from coal to oil during the decade between 1905-1915) and was widely used for many years with only minor changes and additions.




FIGURE 21: YARROW TYPE BOILER




FIGURE 22: "A" TYPE BOILER WITH UNCONTROLLED INTEGRAL SUPERHEAT




FIGURE 23: SECTIONAL EXPRESS TYPE BOILER - 1939




FIGURE 24: SEPARATELY FIRED SUPERHEATER BOILER - 1930

World War II created a huge demand for powerful, packaged, compact steam generators simple to operate and easy to maintain for use by the armed forces ashore and afloat. Under this stimulus, designs were developed that are capable of delivering two to three times the output of earlier boilers containing the same heating surface. In some cases this can be accomplished in one-quarter the previous volumetric space requirement at great savings in weight and with efficiencies running on the average of 80% [Ref. 3]. This was extremely important to offset the increasingly congested space conditions aboard destroyers.




FIGURE 25: "A" TYPE BOILER FOR GENERATING SUPERHEATED STEAM WITH CONTROLLED, INTEGRAL, INTERDECK SUPERHEAT

The general design most widely used for combat vessels built during WW II is shown in Fig. 26. The "M"-type boiler, as this design is commonly called because of the shape of its generating elements, was a two furnace, single-uptake, controlled superheat type boiler generally designed to operate at 600 psig-850°F. The modified "A" or Guest-type, Fig. 27, had a separately fired superheater of the radiant-convection type temperature control. However, this type superheater did not prove well adapted to naval requirements for rapid load changes and steaming at low rates for considerable period of




FIGURE 26: "M" TYPE BOILER WITH CONTROLLED, INTEGRAL SUPERHEATER




FIGURE 27: MODIFIED "A" OR GUEST BOILER

time. Another boiler used mainly in WW II destroyer escorts is the single furnace boiler shown in Fig. 28. The "D" boiler is the progenitor of boilers used in post-World War II ship construction. Figure 29 shows the 1200 psig boiler which has become the major naval fossil-fired steam generator.




FIGURE 28: "D" TYPE BOILER




FIGURE 29: NEWER 1200 PSIG SINGLE-FURNACE BOILER FOR POST
WORLD WAR II DESTROYERS

4. Water Circulation

The majority of the previously discussed boilers have depended upon natural convection for the water-side circulation. That is, the difference in density between the water near the combustion chamber being heated and the cooler water in more remote parts of the boiler causes a natural flow away from the combustion chamber which in many cases is adequate. As boiler pressure increases, however, there is less difference between the densities of water and steam. At pressures over 1000 psig the density of steam differs so little from the density of water that natural circulation is harder to achieve than it is at lower pressures [Ref. 6]. At high pressures positive circulation boilers have a distinct advantage because their circulation is controlled by pumps and is independent of differences in density. The utilization of pumps to circulate and agitate boiler water increases heat transference, thereby increasing the output of a boiler without increasing the heating surface.

There are two main kinds of positive circulation boilers; one type is known as a controlled circulation or forced recirculation boiler and the other is known as a once-through or forced-flow boiler. In both types of boilers external pumps are used to force the water through the boiler circuits; the essential difference between the two lies in the amount of water supplied to the boiler.

In a once-through forced circulation boiler all (or very nearly all) of the feedwater pumped to the boiler is converted to steam the first time through without any recirculation. In its course along the full length of the tube, the water is heated, evaporated and superheated as additional enthalpy is applied. The steam generation rate is numerically equal to the water content supplied. Conventionally this type of boiler does not require a steam and water drum. Because no excess water is forced through the boiler, pumping other than that provided by feedwater pumps is not required. The very small amount of water that is not converted to steam in the generating circuit is separated from the steam and discharged to the feed pump suction. The once-through type of positive circulation boilers include the Benson and Besler boilers.




FIGURE 30: THE "BENSON" BOILER

The Benson Boiler, Fig. 30, is characterized by the complete absence of steam separating drums. The unit responds sensitively to combustion rate changes and is therefore well adapted for use with a special turbine design in which variable pressure is used to accomodate a variable load. This boiler was first built in England (1923) by Mark Benson, a Czechoslovakian, but was developed by Siemens, Inc., in Germany. It has been built with capacities as large as 220,000 lbm/hr at 3200 psig.

Figure 31 shows the boiler circuit of a controlled circulation (or forced recirculation) boiler. In this boiler the water in the tubes is not evaporated to complete dryness but only to the point at which dissolved salts and solids are retained in solution. The mixture of water and steam passes to the steam-and-water drum where the steam is separated. The steam is passed through a separator where excess water is removed, then passed to a superheater. The separated water, along with feedwater, is returned to (or recirculated through) the heating circuit through the downcomers. The quantity of water passing through the boiler (circulation rate) is from 3 to 20 times the amount evaporated. This ratio requires constant speed recirculating pumps in addition to the boiler feedwater pumps.

5. Heat Source

The heat may be derived from (1) the combustion of fuel (solid, liquid, or gaseous); (2) the hot waste gases of




FIGURE 31: SCHEMATIC DIAGRAM OF CONTROLLED CIRCULATION BOILER

other chemical reactions; (3) the application of electrical energy; or (4) the utilization of nuclear energy.

Items 1, 3, and 4 are the most prevalent methods of supplying a heat source, but the increasing need for energy conservation has necessitated increased utilization of waste heat recovery.¹ Wherever a process waste product or gas is continuously discharged at a temperature of 1,000°F or higher, heat recovery should be considered. In addition to producing useful steam, the lowering of the flue gas temperature reduces maintenance of flues, fans, and stacks. One proposal for "by-product heat recovery" utilizes the hot exhaust gases from a shipboard gas-turbine propulsion plant as the heat source for a conventional Rankine cycle. This provides the means by which useful work can be extracted from a once wasted energy source.

B. RACER AND THE SST

The realization of finite petroleum resources has prompted researchers to accelerate the development of alternative fuels and energy sources, the employment energy conservation methods for short term relief, and the investigation of long term conservation techniques. The Navy, having made a major commitment to gas turbine propulsion systems, is currently investigating a means of fuel conservation without a reduction in steaming

¹Waste heat is a misnomer; a more appropriate term is "by-product heat."

time. The Rankine Cycle Energy Recovery (RACER) system is being developed to recover some of the heat contained in the gas turbine exhaust gases.

The DD-963, FF6-7, and the DDG-47 class of ships are powered by the General Electric LM 2500 Marine gas turbine engine. The RACER system, an unfired waste heat recovery system, will function as a bottoming cycle for the LM 2500. Program requirements specify the development of a high efficiency cruise engine that utilizes hot exhaust gases to heat the working fluid (water) and convert it to useful energy through a steam turbine. It is intended that the design be compatible with the basic LM 2500 Marine gas turbine providing one shafts worth of power to the DD-963 and FFG-7, U.S. Navy surface combatants. Further, specifications require provisions that will permit satisfactory inspection and cleaning of watersides/steamsides. It is important that internal surfaces can be properly observed for corrosion, scaling, defects, repairs, etc. Cleaning methods and techniques should be simple, easy to use, and practical for use with the proposed design.

The boiler, placed in the exhaust ducting, would by necessity have to be compact and lightweight, have a high steam generation rate and excellent response characteristics as well as simplicity in design, installation, and maintenance. LCDR Combs [Ref. 7], in his thesis conducted a feasibility study for propulsion assistance on waste heat recovery as applied to the Spruance class destroyers. Results of the study indicate that this

proposal provides for substantial fuel savings based upon operational considerations. The proposed Rankine cycle included a once-through (O.T.) boiler having an optimal operating pressure of 600-800 psig.

For this application, the O.T. boiler is particularly attractive due to its small size. A special class of once-through boilers, which provides a possible design alternative, is the Short Straight Tube (S.S.T.) boiler. Also known as the "stagnation" (non-flow) boiler, it has excellent performance as a steam generation unit. This boiler has the same components as the O.T. boiler; however, in contrast, its construction consists of short (1-2 meters) and straight tubes with toroidal headers, Fig. 32. Due to boiler water level control and water chemistry problems, the S.S.T. boiler all but disappeared since the early 1900's. With the advancements made in water chemistry procedures and with the development of automatic boiler control systems, these problems should be alleviated, allowing present day application.

When compared to the normal forced or natural convection boilers, the once-through boiler is more desirable for waste heat recovery on the Spruance class destroyer. The O.T. boiler is lighter and safer, since no steam drum is required and the total mass of water is substantially less. However, a review of its construction reveals, Fig. 33, a complicated arrangement of headers and long "serpentine" tubes. This leads one to question its applicability, especially in terms




FIGURE 32: SHORT STRAIGHT-TUBE BOILER UNIT

of simplicity. In contrast, the S.S.T. boiler has a characteristic which makes it very attractive for this purpose. As it is the simplest of boiler designs, it lends itself to lower fabrication cost and simplified maintenance.

C. OBJECTIVE

The S.S.T. boiler is undergoing a resurgence in Japan for industrial usage due to its performance and construction [Ref. 8]. These industrial applications are for steam supplied up to 150 psig. In order to employ such a design at higher pressures, it is necessary to obtain some essential information.

In general, this need for information arises from three sources. First, the designer requires detailed information in order to provide for an optimal design. This entails a detailed quantitative study, for example, of heat transfer coefficients and two phase pressure drop. Secondly, operational conditions must be evaluated to ascertain the optimal steady state and transient operating conditions. Inclusive is casualty control data to diagnose faults due to the departure from the optimal conditions. Finally, and most paramount, is the requirement for the precise maximum safe operational limit. For these reasons, experimental investigation to ascertain design, operation and safety criteria is necessary. Firm establishment of the characteristics unique to the Short-Straight Tube Boiler is required to provide the means by which performance evaluation and comparison with other evaporators can be made. However, a lack of design and operational experience doesn't

allow the engineer to anticipate S.S.T. characteristics a priori. Therefore, the logical beginning to experimentation is having a model from which predictions can be made.

The objective of this thesis therefore, is the development of a suitable model and computer program to provide the means for analytic study of the S.S.T. principle.

II. MODEL DESCRIPTION

A. AN OVERVIEW

The Short Straight Tube Boiler is modeled as a cross-flow heat exchanger with one fluid mixed; the other unmixed. The model is applied in a computer program for use in heat exchanger analysis for a phase change, or boiling situation. The same program could be easily adapted for general cross-flow heat exchanger performance study.

The two basic tools required to perform any heat transfer analysis are the first law of thermodynamics and the applicable rate equation.

A first law consideration of each fluid with mass flow rate $\dot{m}$, for an incremental area ΔA of the exchanger, yields

$$\Delta Q = (\dot{M}C_p\Delta T)_{\text{gas}} = (\dot{M}C_p\Delta T)_{\text{water}} \quad (1a)$$

Another expression for ΔQ is achieved using the rate equation and writing an expression for the conditions at ΔA ; the resulting equation is

$$\Delta Q = U\Delta A (T_g - T_w) \quad (1b)$$

where T_g is the gas temperature in $^{\circ}\text{F}$, T_w is the water temperature in $^{\circ}\text{F}$, and U is the overall heat transfer coefficient in $\text{BTU}/(\text{Hr FT}^2 \text{ }^{\circ}\text{F})$. For this analysis, U is assumed to remain constant throughout the incremental heat exchanger. Equations 1a and 1b can also be written as

$$\Delta Q = (\dot{M}C_p)_{\min} \Delta T_{\max} = U\Delta A(T_g - T_w) \quad (2)$$

which can be written as

$$\frac{\Delta T_{\max}}{(T_g - T_w)} = \frac{U \Delta A}{(\dot{m} c_p)_{\min}} \quad (3)$$

For the incremental heat exchanger area, ΔA , the number of transfer units, ΔNTU is defined by the following equation:

$$\Delta NTU = \frac{\Delta T_{\max}}{(T_g - T_w)} = \frac{U \Delta A}{(\dot{m} c_p)_{\min}} \quad (4)$$

The number of transfer units is a measure of a heat exchanger's ability to transfer heat. For a number of heat exchangers in series, the number of transfer units for the system can be written as follows:

$$\text{let } C_{\min} = (\dot{m} c_p)_{\min}$$

$$NTU = \frac{U_1 \Delta A_1}{C_{\min 1}} + \frac{U_2 \Delta A_2}{C_{\min 2}} + \dots + \frac{U_n \Delta A_n}{C_{\min n}}$$

or

$$NTU = \sum_{j=1}^N \frac{U_j \Delta A_j}{C_{\min j}} \quad (5)$$

where N represents the total number of incremental heat exchangers; ΔA_j 's are the incremental heat transfer areas, and U_j 's are the overall heat transfer coefficients for the j^{th} elemental heat exchanger [Ref. 9].

For a particular type of heat exchanger, a mathematical relationship can be calculated between NTU , the number of transfer units; ϵ , the effectiveness of heat transfer; and C , the heat capacity rate ratio. If two of these quantities

are known, this mathematical relationship can be used to calculate the unknown. Reference [10] lists this relationship for cross-flow as follows:

$$C = \frac{C_{\min}}{C_{\max}} ; \quad N = NTU = \frac{UA}{C_{\min}}$$

$C_{\max}$ mixed, $C_{\min}$ unmixed

$$\epsilon = (1/C) \left[1 - \exp \left\{ -C(1 - e^{-N}) \right\} \right] \quad (6a)$$

$C_{\max}$ unmixed, $C_{\min}$ mixed

$$\epsilon = 1 - \exp \left[1(1/C) \left\{ 1 - \exp(-NC) \right\} \right] \quad (6b)$$

If the hotter fluid is a condensing vapor or the cooler fluid is a boiling liquid, the heat capacity ratio $C = 0$. For this case, Kays and London [Ref. 11] show that equation 6 reduce to

$$\epsilon = 1 - \exp(-NTU) \quad (7)$$

The proposed model utilizes this procedure to determine the overall heat transfer coefficient for the straight-vertical-tube cross-flow heat exchanger used as a boiler.

In the development of the model, the following assumptions were made:

- 1) A tube could be modeled as a group of N heat exchangers connected in series. The value of N is determined from fin geometry as the product of tube length times the number of fins per inch.

2) Each "elemental" heat exchanger has an overall heat transfer coefficient which can be considered constant over the segment area. With this assumption, equation 5 can now be applied to find the tube NTU.

3) The "elemental" applied heat flux (Q_s/A_{si}) is constant for each individual tube segment with Q_s given by

$$Q_s = \epsilon (\dot{m} c_p)_{\min} (T_g - T_w) \quad (8)$$

where Q_s is the segment heat transfer rate in BTU/hr, and ϵ is the segment effectiveness.

4) The water side pressure drop is negligible.

The SST model is divided into three principal sections: heating, boiling and superheating. The specified initial conditions for the model are: (1) gas temperature into the heat exchanger ($T_{g_{in}}$); (2) minimum average gas exit temperature from the heat exchanger ($T_{g_{out}}$); (3) gas flow rate ($\dot{m}_g$); (4) water inlet temperature ($T_{w_{in}}$); (5) water/steam pressure (P_w); (6) amount of superheat at the tube exit (T_{sh}).

Since each tube is separated into N segments, it will be possible to determine axial temperature distribution of both the gas and water. At this point, a simplification should be noted; that is, what happens for any particular segment of any given tube is taken to be representative of the entire tube row. This varying gas-to-water temperature difference across each row of tubes is then utilized to determine a possible profile for the non-uniform gas temperature distribution across the entire heat exchanger.

B. GEOMETRY

Two different fin-tube configurations were selected for this model. The fins can be either segmented or pin fins. Tube banks can be arranged with either in-line or staggered tube rows. From heat transfer and pressure drop measurements made on in-line and staggered banks, Weierman [Ref. 12] stated "it was seen that even tube rows in an in-line layout produced about the same heat duty as four tube rows in a staggered layout for the same pressure drop." He further stated "in-line layouts should be reserved for those cases when a serious justification exists. When cleaning lanes are required, a staggered 45° layout should be considered." From this information, the advantage of staggered layout is obvious, and it is for these reasons that in-line banks are not considered.

The tube length, L_T , and the number of tubes per row, N_{tr} are chosen by the designer. For this model the tube length and heat exchanger height are constrained to that associated with the S.S.T. boiler, that is, 3.2808 to 6.5616 feet (1-2 meters) in length. Additionally, it should be noted that the maximum width is limited by shipboard space to 12 feet.

Since this model dissects a tube into N "elemental" heat exchangers, all heat transfer areas are those associated with one tube segment. These areas are essentially entire tube areas divided by N ; therefore, the following equations represent "elemental" heat exchanger areas.

1. Segmented Fins

This fin profile is shown in Fig. 33 and the description of the segmented finned tubes is as follows:

d_i = tube inside diameter = 1.86 in.

d_o = tube outside diameter = 2.00 in.

N_f = fins per inch = 5.94

ℓ = fin height = 1.015 in.

ℓ_c = length of cut from fin tip = 0.82 in.

d_f = fin outside diameter = 4.03 in.

t_f = fin thickness = 0.048 in.

w_s = fin segment width = 0.17 in.

N_s = number of segments in 360 degrees = 38

In order to establish the minimum gas flow cross-sectional area the total "blocked" frontal area, A_b , of the "elemental" heat exchanger must be calculated from:

$$A_b = \frac{L_T d_o + 2L_T N_f \ell t_f}{N} \quad (9)$$

The fin surface area is

$$A_{fin} = [N_s (2\ell_c w_s + 2t_f \ell_c + w_s t_f) + \frac{\pi}{2} (d_f - 2\ell_c)^2 - d_o^2)] \quad (10)$$

and the bare tube area is

$$A_{bt} = \frac{\pi d_o L_T}{N} (1 - t_f N_f) \quad (11)$$

2. Pin Fins

This fin profile is shown in Fig. 34 and the description of the pin finned tubes is as follows:

d_i = tube inside diameter = 1.86 in.




FIGURE 33: SEGMENTED FIN PROFILE




FIGURE 34: PIN FIN PROFILE

d_o = tube outside diameter = 2.00 in.

d_r = fin root diameter = 2.00 in.

N_f = pin groups per inch = 2.00

l_p = average pin length = 1.015 in.

d_p = pin diameter = .125 in.

N_s = number of pins per group = 12

V_{ps} = vertical pin spacing = .375 in.

h_{ps} = horizontal pin spacing = .20 in.

The "blocked" frontal area is

$$A_b = \frac{L_T d_o + 2L_T N_f d_p l_p}{N} \quad (12)$$

The fin surface area is found from

$$A_{fin} = \pi d_p N_s (l_p + d_p/4) \quad (13)$$

and the bare tube area is

$$a_{bt} = \frac{\pi d_o L_T}{N} (1 - N_s \frac{d_p^2}{4} N_f) \quad (14)$$

The previously determined areas are those which are particular to the given fin profile. With this information, the minimum gas flow area is

$$A_{min} = A_f - A_b \quad (15)$$

where A_f is the frontal area. The inside area available for heat transfer per segment heat exchanger is

$$A_{si} = \frac{\pi d_i L_T}{N} \quad (16)$$

and the outside heat transfer area is

$$A_{so} = A_{fin} + A_{bt} \quad (17)$$

Finally, the cross-sectional fluid flow area is calculated from

$$A_{ff} = \frac{\pi}{4} d_i^2 \quad (18)$$

For both segmented and pin fin-tube configurations, the center-to-center tube spacing in the transverse direction is 4.5 inches. Following Weierman's suggestion (45° staggered layout) leads to a spacing normal to the gas flow, S_n , of 4.5 inches and a spacing parallel to the gas flow, S_p , of 2.25 inches. This tube layout is shown in Fig. 35.




FIGURE 35: MODEL TUBE LAYOUT

With the mass flow rates, terminal temperatures and heat exchanger geometry established, the remainder of the model may be solved for the number of tube rows or passes, actual iterim temperatures, and gas side pressure drop.

C. GAS-SIDE HEAT TRANSFER/PRESSURE DROP

For both the segmented and pinned-tube profiles, the gas-side Reynolds number is calculated initially using the gas bulk temperature to find the gas properties. With this Reynolds number, the segmented fin, j -factor, is obtained from a polynomial fit to the data for tube layout number 5 in Ref. [12]. The j -factor is related to the heat transfer coefficient h_g by the following relationship.

$$j = St Pr^{2/3}$$

By introducing

$$St = \frac{Nu}{Re Pr}$$

the previous expression can be written as

$$j = \frac{Nu}{Re_g Pr_g} Pr_g^{2/3} = \frac{Nu}{Re_g Pr_g^{1/3}},$$

and

$$Nu = j Re_g Pr_g^{1/3},$$

where

$$Nu = \frac{h_g d_o}{K_g}.$$

Therefore, a relationship may be written for the heat transfer coefficient as follows:

$$h_g = j \frac{K_g}{d_o} Re_g Pr_g^{1/3}. \quad (19)$$

For this equation all gas properties are evaluated at the film temperature.

For the pin fin, the gas-side heat transfer coefficient has contributions from the pins and bare tube, Equation 6-14 of Ref. [10], supplies the pin heat transfer coefficient

$$h_g = \frac{k_f}{d_p} C Re_g^N Pr_g^{1/3} \quad (20)$$

where the constants C and n are listed in Fig. 36.

Re_g	C	n
0.4-4	0.989	0.330
4-40	0.911	0.385
40-4000	0.683	0.466
4000-40,000	0.193	0.618
40,000-400,000	0.0266	0.805

FIGURE 36: HEAT TRANSFER CONSTANTS

Properties for use with the above equation are evaluated at the film temperature.

Eckert and Drake [Ref. 13] recommend the following relations for heat transfer from tubes in cross-flow:

$$Nu = (0.43 + 0.50 Re^{0.5}) Pr^{0.38} \left(\frac{Pr_f}{Pr_w} \right)^{0.25} \quad (21)$$

for $1 < Re < 10^3$

$$Nu = 0.25 Re^{0.6} Pr^{0.38} \left(\frac{Pr_f}{Pr_w} \right)^{0.25} \quad (22)$$

for $10^3 < Re < 2 \times 10^5$

For gases the Prandtl number ratio may be dropped, and fluid properties are evaluated at the film temperature. The pressure drop for flow of gases over a bank of tubes may be calculated from

$$\Delta p = \frac{333.4 f' (G_{\max})^2 N_T}{\rho_f} \left(\frac{\mu_w}{\mu_b} \right)^{0.14} \quad (23)$$

Δp = pressure drop = inches H_2O

$G_{\max}$ = mass velocity = $lbm/(FT^2-s)$

ρ = free-stream density = lbm/FT^3

N_T = number of transverse rows

The empirical friction factor f' is given by Jakob [Ref. 14] as

$$f' = 0.25 + \left[\frac{0.118}{(S_n - d)/d} \right] Re_{\max}^{-0.16} \quad (24a)$$

for staggered tube arrangements and

$$f' = 0.044 + \left\{ \frac{0.08 S_p/d}{[(S_n - d)/d]^{0.43 + 1.13 d/S_p}} \right\} Re_{\max}^{-0.15} \quad (24b)$$

for in-line tube arrangements. For pin fins both friction factor expressions are required. Although the tubes are arranged in the staggered tube arrangements, the pins are essentially an in-line configuration.

The same equation is used for the segmented fin profile with the friction factor, f' , obtained from a polynomial fit to the data for tube layout Number 5 in Ref. [12], (Fig. 5).

D. WATER-SIDE HEAT TRANSFER

Water-side heat transfer involved the heating, boiling and superheating of water or steam. A multitude of correlations are currently available to describe each individual mode. Although not prohibitive, a literature review resulted in several being chosen to represent the S.S.T. model.

With little known about this boiler type, four heat transfer correlations were candidates to represent the heating mode. One could reasonably surmise that the laminar situation is the most probable; turbulent correlations however, are also considered. An empirical correlation based on experimental data that takes into account the effect of varying physical properties and free convection is listed below [Ref. 15]:

$$h_{H_2O} = .17 \frac{k_f}{d_i} Re^{.33} Pr^{.43} \left(\frac{Pr_f}{Pr_w} \right)^{.25} \left(\frac{d_i^3 \rho^2 g_c \beta \Delta T}{\mu^2} \right)^{.1} \quad (25)$$

This relationship is valid for heating in vertical upflow for $Re < 2000$. Water properties are evaluated at the film temperature; Pr_w , at the wall temperature.

The work done by Sieder and Tate [Ref. 16], resulted in two simple empirical relationships which take into account fluid property variations. For laminar heat transfer in tubes, use the following equation

$$h_{H_2O} = 1.86 \frac{k}{d_i} (RePr)^{1/3} \left(\frac{d_i}{L_T} \right)^{1/3} \left(\frac{\mu}{\mu_w} \right)^{.14} \quad (26)$$

for

$$RePr \frac{d_i}{L_T} > 10$$

and for turbulent heat transfer

$$h_{H_2O} = .027 \frac{k}{d_i} Re^{.8} Pr^{1/3} \left(\frac{\mu}{\mu_w} \right)^{.14} \quad (27)$$

for

$$.7 < Pr < 16.700$$

$$Re > 10,000$$

For both situations, all fluid properties are evaluated at the mean bulk temperature of the fluid, except μ_w , which is evaluated at the wall temperature. Recommended by Dittus and Poelter [Ref. 17] for turbulent flow is

$$h_{H_2O} = .023 \frac{k}{d_i} Re^{.8} Pr^{.4} \quad (28)$$

The properties in this equation are evaluated at the fluid bulk temperature. This variety of expressions allows the designer to study a greater range of possibilities.

Consider now the conditions under which boiling will be initiated in the vertical heated tube. No boiling can occur while the temperature of the heating surface remains below the saturation temperature of the fluid at that particular location. It should be realized that fully developed subcooled boiling is not initiated whenever the heated surface first exceeds the saturation temperature. As shown in Fig. 37, a region of "partial boiling" exists between the subsaturation zone, A, and fully developed subcooled boiling, B. This "partial boiling" zone consists of comparatively few nucleation sites and in this zone, a proportion of the heat would be transferred by normal single-phase convection between patches or bubbles.




FIGURE 37: SURFACE HEAT FLUX VS. INLET SUBCOOLING

For forced convective flow, Bergles and Rohsenow [Ref. 18] developed a criterion based on analysis by Hsu [Ref. 19] and Han [Ref. 20] for the incipience of boiling. In this work, Bergles proposed a convenient numerical expression to determine the wall superheat required to initiate boiling. This expression is for the steam-water system in the 15-2000 psia pressure range.

$$q_{onb} = 15.60 p^{1.156} (T_{wall} - T_{sat})^{(2.3/p^{.234})} \quad (29)$$

where ϕ_{onb} (Btu/hr.ft²) is the heat flux to cause nucleation at a wall superheat $T_{wall} - T_{sat}$ and at a system pressure p (psia).

As the surface temperature is increased further, the whole surface is covered by bubble sites, boiling is "fully developed" and the single-phase component reduces to zero. In the "fully developed" boiling region, velocity and subcooling have little or no effect on the surface temperature as observed experimentally. Throughout the partial boiling region Rohsenow [Ref. 21] suggests that

$$\phi_{Total} = \phi_{SPL} + \phi_{SCB}$$

where ϕ_{Total} is the total average surface heat flux, ϕ_{SPL} is the average surface heat flux transferred by single-phase convection, and ϕ_{SCB} is the average surface heat flux transferred by boiling. This method of superposition, shown in Fig. 38, utilizes the single-phase component given by

$$\phi_{SPL} = h_c (T_{wall} - T_{bulk})$$

where h_c is found by the familiar Dittus-Poelter equation.

The boiling contribution was successfully correlated with the experimental data using the equation suggested by Rohsenow [Ref. 22] for saturated nucleate pool boiling

$$\phi_{SCB} = \mu I_{fg} \left[\frac{g(\rho_f - \rho_g)}{g_c \sigma} \right]^{\frac{1}{2}} \left[\frac{c_p (T_{wall} - T_{sat})}{Pr C_{sf} I_{fg}} \right]^3 \quad (30)$$

where C_{sf} is a constant described by the liquid surface combination. The data reduced and correlation used a value of $C_{sf} = .006$. The surface-tension is calculated from [Ref. 23].




FIGURE 38: METHOD OF ROHSENOW

$$\sigma = 58 \times 10^{-4} (1 - .000142T) \text{ lbf/FT}$$

with T in °F

In their introduction to Chapter 8, Hsu and Graham [Ref. 24] delineate the metamorphosis of two-phase flow typically shown in Fig. 39.

A fluid enters the heating section as a subcooled liquid. Some distance downstream, subcooled boiling begins on the wall, but the bubbles do not leave the wall. Farther downstream, the bubbles begin to grow and depart into the main stream (low subcooled boiling region). As the fluid is near the saturation temperature, enough bubbles are generated to populate the whole cross section (bubbly flow) and finally coalesce into slug flow. However, slug flow exists only over a narrow range of void fractions. As the void fraction is increased, the flow pattern quickly undergoes a transition into annular flow with a dispersed mist in the core (dispersed annular flow). The annular film is gradually depleted and thinned out. In the final stage, the flow is a mist flow with droplets carried by the superheated vapor. The wall region can be dry.

This excerpt from Hsu and Graham should raise the question of when do these individual changes occur. Reference [24] states that Haberstroh and Griffith found that the transition between slug and annular two-phase flow occurred at the void fraction between .8 to .9. The void fraction, α , can be determined from

$$\frac{\alpha}{1 - \alpha} = \left(\frac{x}{1 - x} \right) \left(\frac{u_f}{u_v} \right) \left(\frac{\rho_f}{\rho_v} \right)$$

with the vapor velocity found from

$$u_v = \frac{Gx}{\rho_v} ; \quad G = \frac{\dot{m}_{\text{TOTAL}}}{A_{\text{REA}}}$$

and the fluid velocity is

$$u_f = \frac{G(1-x)}{\rho_f(1-\alpha)}$$




FIGURE 39: TWO-PHASE FLOW DEVELOPMENT

where x is the mass quality, and is defined as

$$x = \frac{\dot{m}_v}{\dot{m}_{\text{Total}}} \quad ; \quad 1 - x = \frac{\dot{m}_f}{\dot{m}_{\text{Total}}} .$$

Now provided both liquid and vapor are in thermodynamic equilibrium, i.e., they exist at the saturation pressure and temperature, then an alternative definition of mass quality x can be given on the basis of thermodynamic properties.

$$x_e = \frac{I - I_f}{I_{fg}}$$

Only when the thermodynamic equilibrium exists are the values of x and x_e identical.

However, this result was obtained for the adiabatic condition. Some important features of flow patterns in boiling two-phase flow and differences between this and the adiabatic case are discussed in Hsu and Graham. Furthermore, it has been suggested that the Haberstroh-Griffith criteria for this transition overpredict the flow quality. According to The Handbook of Heat Transfer, [Ref. 25], Rohsenow observed that the slug-to-annular flow transition occurs for qualities between 5-10%. In this thesis a local true quality of 10% was used as the accepted transition.

Slug flow occurs when the flow equilibrium enthalpy is near saturation, the actual quality when $x_e = 0$ can be determined by using the analysis for the subcooled boiling regime. Based upon Hsu's [Ref. 19] postulate, Levy proposed a criterion for bubble detachment, and therefore, a condition

for fully developed subcooled boiling. He showed that the true quality can be related to the equilibrium quality through the expression [Ref. 26]

$$x_T = x_e - x_d \text{ EXP } (x_e/x_d - 1) \quad (31)$$

where

$$x_d = \frac{-c_p (T_{\text{sat}} - T_{\text{bulk}})}{i_{\text{fg}}}$$

Using Levy's approach, the fraction of heat flux used for evaporation ϕ_{ev} can be determined from

$$\phi_{\text{ev}} = \phi_{\text{Total}} \left[1 - \text{EXP } (x_T/x_d - 1) \right] \quad (32)$$

At the present, a workable analysis of annular two-phase heat transfer is not available; therefore, empirical correlations must be employed. References 24, 25 and 27, contain expressions derived from the work of Dengler and Addoms, Schrock and Grossman, and Collier and Pulling, for example. Chen [Ref. 28] compared the existing correlations and found while the expression obtained by a particular research group represented their own data fairly well, it failed to represent any other groups' data with any reasonable accuracy. In general, none of the existing correlations appeared satisfactory for general use. As did Rohsenow, Chen postulated that two basic mechanisms take part in the heat transfer process for boiling of saturated fluids with flow.

The macroconvective mechanism, or single-phase convection, is described by a modified form of the Dittus-Roelter relationship.

$$h_{\text{mac}} = .023 \frac{k}{d_i} \text{Re}^{.8} \text{Pr}^{.4} F \quad (33)$$

In this expression the factor F is the ratio of the two-phase Reynolds number (Re_{TP}) to the liquid Reynolds number (Re), where Re_{TP} is defined by $\text{Re}_{\text{TP}} = \text{Re} F^{1.25}$. Chen reasoned and verified that this ratio is a function of the Martinelli parameter, X_{TT} , given by

$$X_{\text{TT}} = \left(\frac{1 - X_T}{X_T} \right)^{.9} \left(\frac{\rho_v}{\rho_f} \right)^{.5} \left(\frac{\mu_f}{\mu_v} \right)^{.1}$$

The work of Foster and Zuber was expanded to include the previously neglected effective and wall superheat difference in order to obtain an expression for the microconvective, or bubble nucleation and growth (boiling) term. A suppression factor given by

$$S = \frac{\Delta T_e}{\Delta T}^{.99}$$

where

$$\Delta T = T_{\text{wall}} - T_{\text{sat}}$$

ΔT_e = effective superheat with flow

was defined and later verified to be a function of $\text{Re}_{\text{TP}} (\text{Re} F^{1.25})$.

Manipulating S through the Clausius and Clapeyron equation and combining with the modified Foster and Zuber expression, Chen obtained an expression for microconvection in terms of the suppression factor and total superheat, ΔT .

$$h_{\text{mic}} = .00122 \frac{k^{.79} c_p^{.45} \rho_f^{.49} g_c^{.25}}{\sigma^{.5} u_f^{.29} I_{fg}^{.24} \rho_v^{.24}} \Delta T^{.24} \Delta P^{.75} S \quad (34)$$

where σ is the surface tension of water previously defined,
and

ΔP = pressure difference between the saturation
pressure correspondint to T_{wall} minus the
bulk saturation pressure and is in lbf/ft².

The total heat transfer coefficient is then obtained as the
sum

$$h_{Total} = h_{mac} + h_{mic}$$

This correlation was tested with available data for water
and organic fluids. The average deviation between calculated
and measured boiling coefficients for all (over 600) data points
from ten experimental cases was $\pm 12\%$. They include those for
water in the pressure range of 1 to 35 atm with liquid flow
velocities up to 14.7 ft/sec, heat flux up to 760,000 Btu/hr.
ft², and quality up to 71%. However, no substantiating evi-
dence was found to refute using this correlation up to a quality
of 100%.

Computation of the water-side heat transfer coefficient
from a true quality of 10-100% is accomplished by the utiliza-
tion of the Chen correlation. Both the Reynolds number factor,
 F , and the Suppression factor, S , are obtained from polynomials
fit to the data of Reference 27, Figs. 6 and 7 respectively.
From the point of 100 percent quality to the tube exit, the
evaluation of the water-side heat transfer coefficient becomes
a choice of the previously discussed forced convection heat
transfer correlations which are obviously dependent upon the
Reynolds number.

E. OVER-ALL HEAT TRANSFER

Newton's law of cooling may be written as

$$Q = hA\Delta T$$

It is often convenient to express the heat transfer rate for a combined conductive-convective problem in this form with h replaced by an overall heat transfer coefficient U .

The primary objective in the thermal design of heat exchangers is to determine the necessary surface area required to transfer heat at a given rate for given fluid temperatures and flow rates. The utilization of U facilitates this procedure in the above fundamental heat transfer relation

$$Q = UA\Delta T_{LM}$$

where ΔT_{LM} is the average effective temperature difference known as the log-mean temperature difference.

It is well known that the primary purpose of fins is to increase the effective heat transfer surface area exposed to a fluid in a heat exchanger. The performance of fins is often expressed in terms of the fin efficiency, η_f

$$\eta_f = \frac{\text{[actual heat transfer]}}{\text{heat transfer if entire fin were at the base temperature}}$$

Analytical expressions for η_f are readily obtained for several common fin configurations.

For this model, both segmented and pin fins are considered to have ends that are at the free-stream temperature. Using a corrected length L_c (as was suggested by Harper and Brown) the insulated tip fin equation can be utilized, as follows

$$\eta_f = \frac{\tanh(mL_c)}{mL_c} \quad (36)$$

where $L_c = L + t/2$. However, for the fin dimensions utilized in this thesis $L \gg t$ which allows Equation 36 to be approximated by:

$$\eta_f = \frac{\tanh(mL)}{mL} \quad (37)$$

where $m = \frac{h_g P}{k A}$

h_g = gas-side heat transfer coefficient

P = "wetted" fin perimeter

k = fin thermal conductivity

A = fin cross-sectional area

L = fin length

Now in terms of η_f , the heat transfer rate is given by the simple expression

$$Q = h (A_{bt} + \eta_f A_{fin}) \Delta T$$

remembering that A_{bt} is essentially

$$A_{bt} = A_{so} - A_{fin}$$

allows the heat transfer equation to be rewritten in terms of an "elemental" heat exchanger efficiency as

$$Q = h \eta_s A_{so} \Delta T$$

$$\text{where } \eta_s = 1 - (1 - \eta_f) \frac{A_{fin}}{A_{so}}$$

Using the tube wall resistance, together with the gas-side and water-side heat transfer coefficients and the "segment" efficiency, the overall heat transfer coefficient can be found as follows:

(a) in terms of the inside area

$$U_{o_i} = \frac{1}{\frac{1}{h_{H_2O}} + \frac{A_{si} \ln(d_o/d_i)}{2\pi k_{tube} L_s} + \frac{A_{si}}{A_{so} \eta_s h_g}} \quad (38)$$

(b) in terms of the outside area

$$U_{o_o} = \frac{1}{\frac{A_{so}}{A_{si} h_{H_2O}} + \frac{A_{so} \ln(d_o/d_i)}{2\pi k_{tube} L_s} + \frac{1}{\eta_s h_g}} \quad (39)$$

Using the effectiveness - NTU method, an average "segment" effectiveness is calculated from equations 7a or 7b; if a phase change is occurring, equation 8. The expression for ϵ is now used in an iterative fashion. Each time an effectiveness is calculated it is compared to the previously found ϵ until a difference of less than .001 is obtained. This difference represents the convergence of the "elemental" heat exchanger effectiveness. During each iteration, the gas and water temperatures are determined in the following way. The total heat transfer rate is, per segment,

$$Q_s = \epsilon C_{min} \Delta T_{max}$$

then the outlet gas temperature is

$$T_{g_{out}} = T_{g_{in}} - Q_s / C_{gas} \quad (40a)$$

and for the water/steam temperature

$$T_{w_{out}} = T_{w_{in}} + Q_s / C_{H_2O} \quad (40b)$$

or if boiling is present, the outlet enthalpy of water is found from

$$I_{out} = I_{in} + Q_s / \dot{m}_{H_2O} \quad (40c)$$

where I = enthalpy in BTU/lbm

With these segment terminal temperatures, inside and outside tube wall temperatures may be calculated as follows:

$$T_{g_{bulk}} = \frac{T_{g_{out}} + T_{g_{in}}}{2} = T_{g_b}$$

$$T_{w_{bulk}} = \frac{T_{w_{out}} + T_{w_{in}}}{2} = T_{w_b}$$

Now performing a heat balance upon the "elemental" heat exchanger

$$Q_s = \frac{T_{g_b} - T_{w_b}}{R_{th}} \quad (41)$$

$$\text{with } R_{th} = \frac{1}{A_{si} U_{oi}} = \frac{1}{A_{so} U_{oo}}$$

$$\text{or } Q_s = \frac{T_{g_b} - T_{TO}}{R_o} = \frac{T_{Ti} - T_{w_b}}{R_i}$$

here T_{TO} = outside tube wall temperature

T_{Ti} = inside tube wall temperature

$$R_o = \frac{1}{\eta_s h_g A_{so}}$$

$$R_i = \frac{1}{A_{si} h_{H_2O}}$$

Combining to find the outside tube wall temperature in terms of the overall temperature difference as

$$T_{TO} = T_{g_b} - \frac{R_o}{\Sigma R_{th}} (T_{g_b} - T_{w_b}) \quad (42)$$

and for the inside wall

$$T_{Ti} = T_{w_b} + \frac{R_i}{\Sigma R_{th}} (T_{g_b} - T_{w_b}) \quad (43)$$

these wall temperatures are then utilized to find the gas-side and water-side film temperatures

$$T_{g_f} = \frac{T_{g_b} + T_{T_o}}{2}$$

$$\text{and } T_{w_f} = \frac{T_{w_b} + T_{T_i}}{2}$$

which are used in calculations requiring fluid property evaluation of the film temperature.

This completes the required calculations for the "elemental" heat exchanger. The final values of the water-side variables are used as the inlet conditions for the next segment, and the whole of the aforementioned procedure is repeated N (total number of elemental heat exchangers per tube) times. This represents the end of the tube.

At this point an overall tube heat balance is written based upon enthalpy considerations. The total heat transfer rate is found from

$$Q_{\text{Total}} = \sum_{j=1}^N Q_{s_j}$$

$$\text{and } Q_{\text{Total}} = \dot{m}_{\text{H}_2\text{O}} (I_{\text{exit}} - I_{\text{inlet}})$$

solving for the water mass flow rate yields

$$\dot{m}_{\text{H}_2\text{O}} = \frac{Q_{\text{Total}}}{I_{\text{exit}} - I_{\text{inlet}}} \quad \frac{\text{lbm}}{\text{hr}}$$

Obviously as the gas transverses the rows of tubes in the heat exchanger, its temperature decreases, producing a corresponding decrease in the gas-to-water temperature difference. The heat transfer rate being a function of this temperature difference also becomes less, however, the inlet and exit conditions are specified design parameters which remain constant. Since one of the assumed parameters was a water-side

Reynolds number, this step allows for the actual mass flow rate, and Reynolds number to be compared with the original.

If the relative error defined here as

$$E_r = \frac{\dot{m}_{H_2O \text{ calc}} - \dot{m}_{H_2O \text{ INITIAL}}}{\dot{m}_{H_2O \text{ calc}}}$$

is greater than 5%, the entire set of calculations is repeated using the calculated mass flow rate as the initial $\dot{m}_{H_2O}$. In this manner, a profile of the water mass flow rates is found on a row basis for this type of heat exchanger.

A matrix of the segment outlet gas temperatures is utilized at the inlet of the next row. The total number of rows is obtained when the following condition is satisfied

$$T_{g_o} = \frac{1}{N} \sum_{j=i}^N T_{g_{out,j}} = \text{Design outlet gas temperature} .$$

III. RESULTS AND CONCLUSIONS

A. BACKGROUND

The foregoing model was applied in a computer simulation program written in BASIC for the Hewlett Packard 9845 model B desktop computer. Inclusive are a set of supporting subprograms for the determination of water, steam and air properties. Finally, one subprogram was included to provide a choice for the thermal conductivity of both the selected fin and tube metal. With the establishment of the design variables to test the model and to develop an understanding of the behavior of the S.S.T., the program was activated to produce a heat exchanger design.

A review of the initial results revealed that the proposed model required modification in order to produce more realistic simulated data. The problem arose from the attempt to match Rohsenow's and Chens correlation at 10% steam quality. It is well known that boiling heat transfer is associated with rather high heat transfer coefficients, and these results reflected this fact up to the 10% quality point. The heat transfer coefficients were of the order of 20,000 BTU/HR FT² °F. However, upon program transfer to the Chen correlation for the determination of the water-side heat transfer coefficient, these values were of the order of 6-20 BTU/HR FT² °F. Obviously, this tremendous difference in magnitudes is definitely not a

real simulation of the probable actual situation. This mismatch in heat transfer coefficients no doubt arises from the suppression factor, to utilize in the Chen microconvective term (Eq. 35), way below the lower limit of approximately 18,000 for the Reynolds number as shown in Figure 40.




FIGURE 40: SUPPRESSION FACTOR, S

Therefore, the proposed model was changed to utilize the Rohsenow method for the entire range of 0-100% steam quality. The single phase contribution was calculated by using a value for the heat transfer coefficient, h_c , being determined by the local Reynolds number. Remember that initially h_c was calculated from the Dittus-Boelter correlation. A listing of the final program appears in Appendix A.

B. DESIGN VARIABLES

The following set of design variables was selected to produce the basic set of data.

1. S.S.T. Operating Pressure

The previous work of Combs [Ref. 7] indicated that the optimal operating pressure ranged from 600-800 psig. For this simulation, 600 psig was selected.

2. Frontal Diminsions

Space constraints for a DD-963- type engineroom limits the maximum heat exchanger width to 12 feet. To be consistent with this constraint, the frontal dimension of 3.658 m x 1m (12'x3.2808') was selected for the design.

3. Gas Flow Rate and Temperatures

The outlet from the gas turbine was taken to be 145 lbm/sec (522,000 lbm/hr) at 900°F under steady state and steady flow conditions.

4. Superheater Outlet Steam Temperature

The target superheat at the outlet was specified to be 50°F. At 600 psig this corresponds to 536°F. This amount of superheat will vary with water-side mass flow rate.

5. Water Inlet Temperature

The water inlet temperature was fixed at 50°F subcooling or 436°F.

6. Fin Geometry

The segmented fin profile was selected for the gas-side heat transfer.

C. THE DATA SET

A set of data was produced for the combination of design variables just discussed. This data was generated by varying the inlet Reynolds number, or if one prefers, the inlet mass flow rate, and was the result from the investigation of 60 different such numbers. The following set of output variables was considered.

1. Gas bulk temperature variation
2. Gas-side heat transfer coefficient
3. Overall heat transfer coefficient based upon the outside area
4. Tube wall temperature variation
5. Water/steam mass flow rate
6. Water-side heat transfer coefficient
7. Overall heat transfer coefficient based upon the inside area
8. Inside surface heat flux
9. Water-bulk temperature variation
10. Thermodynamic quality variation

This investigation included a Reynolds number range of 75 to 1650. Figure 41, shows graphically the water/steam mass flow rate corresponding to each Reynolds number in order to provide information concerning the range of mass flow rates involved. It should be re-emphasized that these Reynolds numbers are those associated with the water properties at the tube inlet temperature of 436°F. The outlet Reynolds number




FIGURE 41

becomes simply $Re_{out} = Re_{in} \frac{u_{INLET}}{u_{EXIT}}$.

A logical expectation is the decrease in outlet superheat with an increase in mass flow rate. This trend is displayed in figure 42a. Point A corresponds to a Reynolds number of 310 and a superheat of 61°; whereas, point B, 380 and 91. Figures 43 and 44 show that there is very little difference in the water-side heat transfer coefficient for these two values of Reynolds numbers during the preheating of the water toward the saturation temperature. However, the value of h representative during superheating for $Re = 380$ is approximately twice the value of h for $Re = 310$ (Figures 45 and 46).

The logical question to be raised at this point is why this difference exists. Outwardly, there definitely appears no logical explanation. Although not a specific part of the data set, the Reynolds number variation with axial position should have been plotted. It was observed on the CRT of the computer that in this "transition" region the Reynolds number gradient steadily increased along the tube for the inlet values of 310 and 380. This observation revealed the greatest magnitude of the Reynolds number was obtained at the point of 100% steam quality inside the tube.

For a Reynolds number of 310 the maximum value obtained was approximately 2100, whereas a Reynolds number of 380 the maximum value obtained was approximately 3300. The effect on heat transfer is observed as the water-side tube flow trans-
verses from the laminar to turbulent regime, with the steam

AD-A107 454

NAVAL POSTGRADUATE SCHOOL MONTEREY CA

F/S 13/1

DESIGN MODEL FOR THE HEAT TRANSFER IN A SHORT STRAIGHT TUBE BOI--ETC(U)


JUN 81 L W VOLLMER

UNCLASSIFIED

NL

2-2
A107 454

END
DATE
FILMED
DTIC



MICROCOPY RESOLUTION TEST CHART
NATIONAL BUREAU OF STANDARDS 1963-A

SUPERHEAT VS REYNOLDS NO.




FIGURE 42a

STEAM MASS FLOW VS SUPERHEAT




FIGURE 42b




FIGURE 43

REYNOLDS NO. = 380




FIGURE 44

REYNOLDS NO. = 310




FIGURE 45

REYNOLDS NO. = 380




FIGURE 46




FIGURE 47




FIGURE 48




FIGURE 49




FIGURE 50

bulk temperature variation reflecting this fact. In figure 47, the change in steam temperature is approximately $24.4^{\circ}\text{F}/\text{FT}$ whereas in Figure 48, it is $38.6^{\circ}\text{F}/\text{FT}$.

Figures 49 and 50 show the axial location of initiation of boiling (zero percent quality) and that of complete evaporation (100 percent quality) as a function of the inlet Reynolds number.

The target of 50 degrees superheat was obtained with an inlet Reynolds number of 840.

Table I. HEAT BALANCE RESULTS

Inlet water-side Reynolds number	840	
Outlet water-side Reynolds number	5180.19	
Overall water mass flow rate	29.648202	lbm/hr
Total overall heat addition rate	24621.249	BTU/hr
The inlet water temperature	436.21	$^{\circ}\text{F}$
The saturation temperature	486.21	$^{\circ}\text{F}$
The outlet steam temperature	536.22	$^{\circ}\text{F}$
The amount of superheat	50.01	$^{\circ}\text{F}$
The inlet enthalpy	414.867	BTU/lbm
The outlet enthalpy	1245.314	BTU/lbm

Figures 51 through 59 graphically represent the data obtained from the model simulation for $\text{Re} = 840$.

These figures show the axial distribution of the associated variables under the prescribed design conditions for the segmented fin profile.

Table 2: TUBE/FIN DIMENSIONS AND AREAS

The selected fin profile is the segmented-fin

The outside tube diameter	2	Inches
The inside tube diameter	1.86	Inches
The tube length	39.37	Inches
The total outside tube area	1.71889	Square Feet
The total inside tube area	1.59857	Square Feet
The fin root diameter	2	Inches
The number of 'fins' per inch	5.94	
The number of 'segments' per fin	38	
The fin height	1.015	Inches
The fin thickness	.048	Inches
The transverse tube pitch	4.5	Inches
The longitudinal tube pitch	2.25	Inches
The fin outside diameter	4.03	Inches
The fin segment width	.17	Inches
The length of cut from fin tip	.82	Inches
The total integer number of fins	234	Fins
Actual tube length will be	39.394	Inches
The fin thermal conductivity	144	BTU/Hr.Ft./F
The tube thermal conductivity	20	BTU/Hr.Ft./F

Calculated heat transfer areas in square feet:

Total heat exchanger frontal area	39.394
Total fin area	26.950951
Total bare tube area	1.228802
Total outside tube area	28.179753
Single fin area	.115175
Outside 'elemental' area	.120426
Inside 'elemental' area	.006831
'Elemental' frontal area	.005261
'Elemental' blocked area	.003015
'Elemental' minimum gas-flow area	.002246

This data shows what would reasonably be expected. That is, relatively low values for heat transfer coefficients and heat flux for the preheat and superheating sections and high values for the boiling section.

D. CONCLUSION

The short straight tube model and the accompanying graphical data provide the basic framework for additional study of the stagnation, or S.S.T boiler. This model, as formulated, provides a fairly reasonable estimate of the possible performance for the fin-tube configuration considered. Performance estimates are encouraging even considering the assumptions involved.




FIGURE 51a

REYNOLDS NO. = 840




FIGURE 51b

REYNOLDS NO. = 840




FIGURE 51C

REYNOLDS NO. = 840




FIGURE 52a




FIGURE 52b

REYNOLDS NO. = 840




FIGURE 52c

REYNOLDS NO. = 840




FIGURE 53a

REYNOLDS NO. = 840




FIGURE 53b

REYNOLDS NO. = 840




FIGURE 53c




FIGURE 54a

REYNOLDS NO. = 840




FIGURE 54b

REYNOLDS NO. = 840




FIGURE 54c

REYNOLDS NO. = 840




FIGURE 5.5a




FIGURE 55b

REYNOLDS NO. = 840




FIGURE 55C

REYNOLDS NO. = 840




FIGURE 55d

REYNOLDS NO. = 840




FIGURE 56a




FIGURE 56b

REYNOLDS NO. = 840




FIGURE 56c

REYNOLDS NO. = 840




FIGURE 56d

REYNOLDS NO. = 840




FIGURE 57a




FIGURE 57b

REYNOLDS NO. = 840




FIGURE 57c




FIGURE 58a

REYNOLDS NO. = 840




FIGURE 58b




FIGURE 59a




FIGURE 59b

IV. RECOMMENDATIONS FOR FURTHER RESEARCH

Investigation of the Short Straight Tube Boiler model in this thesis was essentially the adjustments of the water/steam mass flow rate to determine some possible operating conditions and heat transfer characteristics. This investigation was conducted upon only one tube under steady state steady flow operation. Additionally, the model consisted of preheat, boiling, and superheat with accompanying single phase flow.

In order to increase the precision of the model and lead to greater insight into the possible performance of the S.S.T., consideration must be given to the inclusion of two phase heat transfer; in particular to "frothy" flow correlations. Possible sources of this information may exist in research and experimentation conducted in "flash-type" water distillation systems.

Secondly, consideration should be given to apply enhanced heat transfer configurations to the inside of the tubes; helical wire inserts or helical vane inserts. This enhancement would be required to increase the heat transfer in the preheat and superheat sections and would be very important especially as gas temperatures decreased.

Finally, the program should be transferred to the IBM 3033 computer in order to more efficiently process an expanded

program to determine actual heat exchanger size. Although a powerful tool the HP 9845-B lacks the storage capability, especially, disk storage, to handle a complete heat exchanger design analysis that would be required in order to make a reasonable comparison with other heat exchangers.

With the aforementioned analytic changes implemented, the calculated heat transfer coefficients should be compared with those coefficients obtained experimentally. The single tube experiment should also include the capability for the observation of the boiling regime in order to gain possible greater qualitative insight into the most probable flow patterns in existence in the boiling regions within the tube.

APPENDIX A: PROGRAM LISTING

```

10 Alpha: DEF FNtanh(X)=EXP(X)/(EXP(X)+EXP(-X))*2+1
20 DEF FNRhoair(T,P)=144.00*P/(53.345*(T+459.69))
30 DEF FNCjseg(R)=.0396176083718-.00334741588638*LOG(R)
40 DEF FNCfseg(R)=1.08824815212-.077121846786*LOG(R)
50 DEF FNDb(V,K,D,P,R)=.023*(K/D)*R*.8*F^.4
60 DEF FNLam(B,M,K,D,P,R,L)=1.86*(K/D)*(R*P)^(1/3)*(D/L)^(1/3)*(B/W)^(.14
70 DEF FNColl(K,D,R,F,M,Rd,Gc,B,V,T)=.17*(D) *R*.33*F^.43*(F/W)^(.25*(D^3*Rd^
2*Gc*B*T/V^2)^(.10
80 DEF FNBoiltest(P,T,Q)=T+(Q/(15.6*P^1.156))^(P^.0234/2.3)
90 Gc=32.174
100 !
110 ! THIS SEGMENT OF THE PROGRAM ALLONS THE OPERATOR TO INPUT ALL REQUIRED
    VARIABLES TO PERFORM " SST" BOILER TYPE HEAT EXCHANGER ANALYSIS
120 !
130 OPTION BASE 1
140 SHORT Tg(234),Tw(234),X(234),Qa(234),Uo(234),Ui(234),Hi(234),Ho(234),Mo(23
4),Wi(234),T1(234),T2(234),Re(45),Super(45),Mdot(45),Zero(45),One(45)
150 DIM M$(12),Tube(3),Fin(9),Seg(9),Pin(7)
160 !
170 ! *****
180 ! *
190 ! * THE FOLLOWING IS A DESCRIPTIVE LISTING OF ARRAYS:
200 ! *
210 ! * Tg ..... GAS BULK TEMPERATURE
220 ! * T1 ..... GAS ENTRY TEMPERATURE TO A ROW OF TUBES
230 ! * T2 ..... GAS EXIT TEMPERATURE FROM A ROW OF TUBES
240 ! * Tw ..... WATER BULK TEMPERATURE
250 ! * Wo ..... OUTSIDE TUBE-WALL TEMPERATURE
260 ! * Wi ..... INSIDE TUBE-WALL TEMPERATURE
270 ! * Qa ..... INSIDE SURFACE HEAT FLUX
280 ! * Hi ..... WATER-SIDE HEAT TRANSFER COEFFICIENT
290 ! * Ho ..... GAS-SIDE HEAT TRANSFER COEFFICIENT
300 ! * Uo ..... OVERALL HEAT TRANSFER COEFFICIENT BASED
    UPON THE OUTSIDE AREA
310 ! * Ui ..... OVERALL HEAT TRANSFER COEFFICIENT BASED
    UPON THE INSIDE AREA
320 ! *
330 ! * X ..... STEAM QUALITY
340 ! *
350 ! *
360 ! *****

```

```

370 M$(1)="TUBE"
380 M$(2)="FIN"
390 !
400 ! INPUT TUBE DIMENSIONS AND PROPERTIES
410 !
420 PRINT "TUBE DIMENSIONS REQUIRED ARE IN INCHES"
430 ASSIGN #1 TO "TUBE:F8,0"
440 MAT READ #1,1;Tube
450 PRINT "1> TUBE OUTSIDE DIAMETER";TAB(50),Tube(1)
460 PRINT "2> TUBE INSIDE DIAMETER";TAB(50),Tube(2)
470 PRINT "3> TUBE LENGTH";TAB(50),Tube(3)
480 Tube: Do=Tube(1)/12
490 Di=Tube(2)/12
500 Lt=Tube(3)/12
510 CALL Metals(1,Ktube,M$(1))
520 F$="0"
530 Fin$="SEGMENTED-FIN"
540 !
550 ! INPUT SEGMENTED FIN DIMENSIONS AND PROPERTIES
560 !
570 PRINT "ALL SEGMENTED FIN VARIABLES ARE IN INCHES "
580 ASSIGN #1 TO "SEG:F8,0"
590 MAT READ #1,1;Seg
600 MAT Fin=Seg
610 Ps=9
620 Display: PRINT ""
630 PRINT ""
640 PRINT ""
650 IF Ps=9 THEN PRINT TAB(1),"(1)";TAB(5),"(2)";TAB(18),"(3)";TAB(27),"(4)";
660 IF Ps=9 THEN PRINT TAB(36),"(5)";TAB(45),"(6)";TAB(54),"(7)";TAB(63),"(8)";
;TAB(72),"(9)"
670 PRINT ""
680 IF Ps=9 THEN PRINT TAB(2),"NF";TAB(10),"NS";TAB(19),"L";TAB(28),"TF";TAB(3
7),"SN";TAB(46),"SP";TAB(55),"DF";TAB(64),"WS";TAB(73),"LC"
690 PRINT ""
700 IF Ps=9 THEN PRINT TAB(1),Fin(1);TAB(9),Fin(2);TAB(18),Fin(3);TAB(27),Fin(
4);TAB(36),Fin(5);TAB(45),Fin(6);TAB(54),Fin(7);TAB(63),Fin(8);TAB(72),Fin(9)
710 Fin: Nf=Fin(1)
720 Nfin=INT(Lt*Nf*12+1)

```



```

730 Lt=PROUND(Nfin/Nf,-3)
740 Lt=Lt/12
750 Ns=Fin(2)
760 L=Fin(3)/12
770 Tf=Fin(4)/12
780 Sn=Fin(5)/12
790 Sp=Fin(6)/12
800 Df=Fin(7)/12
810 Ws=Fin(8)/12
820 Lc=Fin(9)/12
830 PRINTER IS 0
840 PRINT ""
850 PRINT ""
860 PRINT "THE SELECTED FIN PROFILE IS THE";TAB(33),Fin$
870 PRINT ""
880 Abto=PROUND(PI*Do+Lt,-5)
890 Abti=PROUND(PI*Di+Lt,-5)
900 Dr=Do
910 PRINT "THE OUTSIDE TUBE DIAMETER IS";TAB(43),Tube(1);TAB(55),"INCHES"
920 PRINT "THE INSIDE TUBE DIAMETER IS";TAB(43),Tube(2);TAB(55),"INCHES"
930 PRINT "THE TUBE LENGTH IS";TAB(42),Tube(3);TAB(55),"INCHES"
940 PRINT "THE TOTAL OUTSIDE TUBE AREA IS";TAB(43),Abto;TAB(55),"SQUARE FEET"
950 PRINT "THE TOTAL INSIDE TUBE IS";TAB(43),Abti;TAB(55),"SQUARE FEET"
960 PRINT "THE FIN ROOT DIAMETER IS";TAB(43),Tube(1);TAB(55),"INCHES"
970 PRINT "THE NUMBER OF 'FINS' PER INCH IS";TAB(43),Fin(1)
980 PRINT "THE NUMBER OF 'SEGMENTS' PER FIN IS";TAB(42),Fin(2)
990 PRINT "THE FIN HEIGHT IS";TAB(43),Fir(3);TAB(55),"INCHES"
1000 PRINT "THE FIN THICKNESS IS";TAB(44),Fin(4);TAB(55),"INCHES"
1010 PRINT "THE TRANSVERSE TUBE PITCH IS";TAB(43),Fin(5);TAB(55),"INCHES"
1020 PRINT "THE LONGITUDINAL TUBE PITCH IS";TAB(43),Fin(6);TAB(55),"INCHES"
1030 PRINT "THE FIN OUTSIDE DIAMETER IS";TAB(43),Fin(7);TAB(55),"INCHES"
1040 PRINT "THE FIN SEGMENT WIDTH IS";TAB(44),Fin(8);TAB(55),"INCHES"
1050 PRINT "THE LENGTH OF CUT FROM FIN TIF IS";TAB(44),Fin(9);TAB(55),"INCHES"
1060 PRINT "THE TOTAL INTEGER NUMBER OF FINS IS";TAB(41),Nfin;TAB(55),"FINS"
1070 PRINT "ACTUAL TUBE LENGTH WILL BE";TFB(42),Lt*12;TAB(55),"INCHES"
1080 PRINTER IS 16
1090 Ntrmax=12/Sn
1100 Ntr=Ntrmax
1110 PRINT "THE MAXIMUM NUMBER OF TUBES ALLOWED IN ANY ROW IS",Ntrmax

```

```

1120 CALL Metals(2,Kfin,M$(2))
1130 PRINTER IS 0
1140 PRINT "THE FIN THERMAL CONDUCTIVITY IS";TAB(41),Kfin;TAB(55),"BTU/Hr.Ft./F
"
1150 PRINT "THE TUBE THERMAL CONDUCTIVITY IS";TAB(42),Ktube;TAB(55),"BTU/Hr.Ft.
/F"
1160 PRINT ""
1170 !
1180 ! CALCULATE HEAT TRANSFER AREAS
1190 !
1200 Afint=PROUND(Nfin*(Ns*(2*Lc*Ws+2*Tf*Lc+Tf*Ws)+PI/2*((Df-2*Lc)^2-Do^2)), -6)
1210 Abt=PROUND(ABto-Nfin*PI*Do*Tf, -6)
1220 Afin=PROUND(Afint/Nfin, -6)
1230 Ato=PROUND(Afint+Abt, -6)
1240 Aso=PROUND(Ato/Nfin, -6)
1250 Asi=PROUND(Asi/Nfin, -6)
1260 Afhe=PROUND(Lt*Sn+Ntr, -6)
1270 Af=PROUND(Afhe/(Ntr*Nfin), -6)
1280 PRINT ""
1290 PRINT "CALCULATED HEAT TRANSFER AREAS IN SQUARE FEET:"
1300 PRINT ""
1310 PRINT TAB(10),"TOTAL HEAT EXCHANGER FRONTAL AREA";TAB(50),Afhe
1320 PRINT TAB(10),"TOTAL FIN AREA IS";TAB(50),Afint
1330 PRINT TAB(10),"TOTAL BARE TUBE AREA IS";TAB(51),Abt
1340 PRINT TAB(10),"TOTAL OUTSIDE TUBE AREA IS";TAB(50),Ato
1350 PRINT TAB(10),"SINGLE FIN AREA IS";TAB(52),Afin
1360 PRINT TAB(10),"OUTSIDE 'ELEMENTAL' AREA IS";TAB(52),Aso
1370 PRINT TAB(10),"INSIDE 'ELEMENTAL' AREA IS";TAB(52),Asi
1380 PRINT TAB(10),"ELEMENTAL' FRONTAL AREA IS";TAB(52),Af
1390 Ab=PROUND((Do*Lt+2*Nfin*L*Tf)/Nfin, -6)
1400 Amin=PROUND(Af-Ab, -6)
1410 PRINT TAB(10),"ELEMENTAL' BLOCKED AREA IS";TAB(52),Ab
1420 PRINT TAB(10),"ELEMENTAL' MINIMUM GFS-FLOW AREA IS";TAB(52),Amin
1430 PRINT ""
1440 PRINT ""
1450 PRINTER IS 16
1460 Agibt: INPUT "ENTER: AVERAGE GAS INLET BULK TEMPERATURE",Spec(1)
1470 Gsmfr: INPUT "ENTER: GAS-SIDE MASS FLOW RATE ( LBM/SEC )",Spec(2)
1480 Gsp: INPUT "ENTER: GAS-SIDE PRESSURE ( PSIA )",Spec(3)

```

```

1490 WSP: INPUT "ENTER WATER-SIDE PRESSURE ( PSIA )",Spec(4)
1500 Tsc=0
1510 PRINT "POSSIBLE WATER INLET CONDITIONS"
1520 PRINT "      0=SUBCOOLED"
1530 PRINT "      1=SATURATED"
1540 INPUT "ENTER INLET CONDITION",Inlet$
1550 IF Inlet$="0" THEN INPUT "ENTER AMOUNT OF INLET SUBCOOLING (°F)",Spec(6)
1560 !
1570 !      GIVEN AN EFFECTIVENESS, E, THE CHANGE IN FLUID BULK TEMPERATURES CAN
      BE FOUND
1580 !
1590 INPUT "ENTER AN ASSUMED INITIAL HEAT EXCHANGER EFFECTIVENESS",Spec(7)
1600 PRINT "DUE TO DISK STORAGE LIMITATIONS THE MAXIMUM NUMBER OF DIFFERENT REY
      NOLDS WHICH CAN BE INVESTIGATED AT ONE TIME IS 45"
1610 INPUT "HOW MANY DIFFERENT REYNOLDS ARE TO BE INVESTIGATED",Reyno
1620 FOR Run=1 TO Reyno
1630 INPUT "ENTER THE VALUE FOR THE REYNOLDS NUMBER",Spec(5)
1640 IF Run>1 THEN Cal
1650 Listing: PRINT "VALUES OF THE SPECIFIED DESIGN PARAMETERS:"
1660 PRINT ""
1670 PRINT TAB(10),"1) GAS INLET TEMPERATURE TO HEAT EXCHANGER IS";TAB(55),Spec
      (1);TAB(60),"°F."
1680 Tsat=PROUND(FNSattemp((Spec(4))),-2)
1690 PRINT TAB(10),"2) GAS-SIDE TOTAL MASS FLOWRATE IS";TAB(44),Spec(2);TAB(49)
      ,"Lbm/Sec."
1700 PRINT TAB(10),"3) GAS-SIDE PRESSURE IS";TAB(33),Spec(3);TAB(41),"psia."
1710 PRINT TAB(10),"4) WATER-SIDE PRESSURE IS";TAB(35),Spec(4);TAB(40),"psia."
1720 PRINT TAB(10),"      THE CORRESPONDING SATURATION TEMPERATURE IS";TAB(56),PRO
      UND(Tsat,-2);TAB(64),"°F."
1730 IF Inlet$="0" THEN PRINT TAB(10),"5) THE WATER ENTERS SUBCOOLED AN AMOUNT
      OF ";TAB(53),Spec(6);TAB(57),"°F."
1740 IF Inlet$="1" THEN PRINT TAB(10),"5) THE WATER ENTERS AT THE SATURATION TE
      MPERATURE"
1750 PRINT TAB(10),"6) THE ASSUMED HEAT EXCHANGER EFFECTIVENESS IS";TAB(56),Spe
      c(7);TAB(61),"."
1760 IF Count>0 THEN PRINT ""
1770 IF Count>0 THEN PRINT ""
1780 IF Count>0 THEN Cal
1790 Cor$="NULL"

```

```

1800 Hardcopy: Count=1
1810 PRINTER IS 0
1820 GOTO Listing
1830 Cal: PRINTER IS 16
1840 Tgi=Spec(1)
1850 Tgin=Tgi
1860 Tgf=Tgi
1870 Tgb=Tgi
1880 MAT T1=(Tgi)
1890 Mfrgin=3600*Spec(2)
1900 Mdotg=Mfrgin/(Ntr+Nfin)
1910 Cpg=FNAirpc((Tgf))
1920 Pg=Spec(3)
1930 Pw=Spec(4)
1940 CALL Combstm((Pw),(Tsat),(Istm,Sstm,Rpostm)
1950 Iw=FNHsl((Tsat))
1960 Ifg=Istm-Iw
1970 Tsc=Spec(6)
1980 Twi=PROUND(Tsat-Tsc,-2)
1990 IF Inlet$="0" THEN CALL Entcw((Pw),(Twi),Iwi)
2000 IF Inlet$="1" THEN Iwi=FNHsl((Tsat))
2010 Iwin=Iwi
2020 Iwout=Iwi
2030 Twin=Iwi
2040 Twout=Iwin
2050 Diff=Tsat-Twout
2060 Twb=Iwi
2070 IF Inlet$="0" THEN CALL Viscw((Pw),(Twb),Vw)
2080 IF Inlet$="1" THEN Vw=FNSatwvisc((Tsat))
2090 Rewin=Spec(5)
2100 Mdotw=PI*Di*Rewin+Vw/4
2110 Rew=Rewin
2120 Caprtg=Mdotgo*FNAirpc((Tgf))
2130 IF Inlet$="0" THEN CALL Sphcw((Pw),(Twb),Cpw)
2140 IF Inlet$="0" THEN Caprtw=Mdotw*Cpw
2150 IF Inlet$="1" THEN Caprtw=Mdotw*FNSprsatw((Tsat))
2160 Tto=Tgin-1
2170 Tti=Tto-1.5
2180 !

```

```

2190 ! MAIN PROGRAM
2200 !
2210 Iteration: FOR Axial=1 TO Nfin
2220 PRINT "SEGMENT";TAB(15.00);Axial
2230 Tgin=Tl(Axial)
2240 Ttmax=PROUND(Tgin-Twin,-2)
2250 Effectiveness: Eo=Eff
2260 Caprtg=Mdotg*Cpg
2270 Cminandouttemp: CALL Caprate(Twin,Twb,Twout,(Pw),(Xt),(Tsat),(Mdotw),Caprt
w,Type$)
2280 IF Type$="SUPERHEAT" THEN B$="NULL"
2290 IF Type$<>"SATURATED" THEN Mincapacity
2300 C$="CMAX-UNMIXED"
2310 Cmin=Caprtg
2320 Qs=Cmin*Dtmax+Eo
2330 Tgout=PROUND(Tgin-Qs/Caprtg,-2)
2340 GOTO Quality
2350 Mincapacity: Cmin=MIN(Caprtg,Caprtw)
2360 Cmax=MAX(Caprtg,Caprtw)
2370 IF Cmax=Caprtg THEN C$="CMAX-MIXED"
2380 IF Cmax=Caprtw THEN C$="CMAX-UNMIXED"
2390 Qs=Cmin*Dtmax+Eo
2400 Tgout=PROUND(Tgin-Qs/Caprtg,-2)
2410 Quality: Twout=Twint+Qs/Mdotw
2420 Tw=FNHsl((Tsat))
2430 CALL Combstm((Pw),(Tsat),Ismt,Sstm,Rhostm)
2440 Ifg=Istm-Tw
2450 IF Tsat-Twb>=20.00 THEN True
2460 IF Twb>Tsat THEN True
2470 Cpw=FNSphsatu((Tsat))
2480 Xd=PROUND((-Cpw*(Tsat-Twb)/Ifg,-4)
2490 Xe=PROUND((Twout-Tw)/Ifg,-4)
2500 Xt=PROUND(Xe-Xd*EXP(Xe/Xd-1),-4)
2510 Qv=Qs*(1-EXP(Xt/Xd-1))
2520 Qc=Qs-Qv
2530 GOTO Bulktemps
2540 True: Xt=PROUND((Twout-Tw)/Ifg,-4)
2550 Bulktemps: IF Type$="SUPERHEAT" THEN Twout=Twint+Qs/Caprtw
2560 IF (Type$="SUBCOOLED") AND (A$="SAT") THEN Twout=Twint+Qc/Caprtw

```

```

2570 IF (Type$="SUBCOOLED") AND (Twout>Tsats) THEN Twout=Tsats
2580 Twb=PRUND((Twout+Twint)/2,-2)
2590 Tgb=PRUND((Tgout+Tgin)/2,-2)
2600 Tuf=PRUND((Tub+Tti)/2,-2)
2610 Tgf=PRUND((Tgb+Tto)/2,-2)
2620 Airproperties: Cpg=FNAircp(Tgf)
2630 Kg=FNAirtc(Tgf)
2640 Prg=FNAirprandtl(Tgf)
2650 Visc=FNAirvisc(Tgf)
2660 Rhog=FNRhoair(Tgf),(Pg)
2670 Prgw=FNAirprandtl(Tto)
2680 Waterproperties: IF (Type$="SATURATED") OR (B$="BOILING") THEN Saturation
2690 IF (Xt)=1) AND (Rew>2200) THEN Stmdb
2700 IF (Xt)=1) AND (Rew)=2000) AND (Rew<=2200) THEN Stmlam
2710 IF (Xt)=1) AND (Rew<2000) THEN Stmcol
2720 IF Rew>2200 THEN Dittusboelter
2730 IF (Rew)=2000) AND (Rew<=2200) THEN Laminar
2740 IF Rew<2000 THEN Collier
2750 Saturation: A$="SAT"
2760 Row=FNSatwvisc(Tsats)
2770 Rhow=1/FNVolcw(Pu),(Tsats)
2780 CALL Combstm(Pu),(Tsats),Istm,Sstm,Rhostm)
2790 Rcpw=FNSphsatu(Tsats)
2800 Rprw=FNSatwprno(Tsats)
2810 Iw=FNHsl(Tsats)
2820 Ifg=Istm-Iw
2830 Sigma=5.8E-3*(1-.000142*Tsats)
2840 IF Rew>10000 THEN Satst
2850 IF (Rew>2200) AND (Rew<=10000) THEN Satdb
2860 IF (Rew)=2000) AND (Rew<=2200) THEN Satlam
2870 IF Rew<2000 THEN Satcol
2880 Dittusboelter: A$="D-B"
2890 CALL Viscw(Pu),(Twb),Vwb)
2900 CALL Tccw(Pu),(Twb),Kw)
2910 CALL Sphcw(Pu),(Twb),Cpw)
2920 GOTO Dbpr
2930 Satdb: Vwb=FNSatwvisc(Tsats)
2940 Kw=FNSatwtc(Tsats)
2950 Cpw=FNSphsatu(Tsats)

```

```

2960      GOTO Dbpr
2970 Stmdb: A$="D-B:STM"
2980      Vwb=FNViscs((Pw),(Twb),(Twb))
2990      CALL Sphs((Pw),(Twb),(Twb),Cpw)
3000      CALL Tcs((Pw),(Twb),(Twb),Kw)
3010 Dbpr: Prwb=Vwb*Cpw/Kw
3020      Rew=4*Mdotw/(PI*Di*Vwb)
3030      IF Rew<2200 THEN Waterproperties
3040      GOTO Airfactors
3050 Laminar: A$="LAM"
3060      CALL Viscw((Pw),(Twb),(Twb),Vwb)
3070      CALL Tccw((Pw),(Twb),(Twb),Kw)
3080      CALL Sphcw((Pw),(Twb),(Twb),Cpw)
3090      CALL Viscw((Pw),(Tti),(Tti),Vww)
3100      GOTO Lampr
3110 Satlam: Vwb=FNSatwisc((Tsat))
3120      Kw=FNSatwtc((Tsat))
3130      Cpw=FNSphsatu((Tsat))
3140      Vww=FNSatwisc((Tti))
3150      GOTO Lampr
3160 Stmlam: A$="LAM:STN"
3170      Vwb=FNViscs((Pw),(Twb),(Twb))
3180      Vww=FNViscs((Pw),(Twb),(Twb))
3190      CALL Sphs((Pw),(Twb),(Twb),Cpw)
3200      CALL Tcs((Pw),(Twb),(Twb),Kw)
3210 Lampr: Prwb=Vwb*Cpw/Kw
3220      Rew=4*Mdotw/(PI*Di*Vwb)
3230      IF Rew>2200 THEN Waterproperties
3240      GOTO Airfactors
3250 Collier: A$="COLL"
3260      CALL Viscw((Pw),(Twb),(Twb),Vwb)
3270      CALL Viscw((Pw),(Tti),(Tti),Vww)
3280      CALL Tccw((Pw),(Twb),(Twb),Kw)
3290      CALL Tccw((Pw),(Tti),(Tti),Kww)
3300      CALL Sphcw((Pw),(Twb),(Twb),Cpw)
3310      CALL Sphcw((Pw),(Tti),(Tti),Cpww)
3320      GOTO Dummy
3330 Satcoll: Kw=FNSatwtc((Twb))
3340      Kww=FNSatwtc((Tti))

```

```

3350 Cpwf=FNSphsatw<<(Twf)>>
3360 Cpwu=FNSphsatw<<(Tti)>>
3370 Vwu=FNSatwvisc<<(Tti)>>
3380 Vwf=FNSatwvisc<<(Twf)>>
3390 GOTO Dummy
3400 Stmcol1: A$="COLL:STM"
3410 CALL Tcs<<(Pw),<(Twf),<(Kuf)>>
3420 CALL Tcs<<(Pw),<(Tti),<(Kwu)>>
3430 CALL Sphs<<(Pw),<(Twf),<(Cpwf)>>
3440 CALL Sphs<<(Pw),<(Tti),<(Cpwu)>>
3450 Vwu=FNViscs<<(Pw),<(Tti)>>
3460 Vwf=FNViscs<<(Pw),<(Twf)>>
3470 Dummy: Dummy=FNVolcw<<(Pw),<(Twf+1)>>
3480 Rhofw=1/FNVolcw<<(Pw),<(Twf)>>
3490 Beta=LOG(Rhofw*Dummy)
3500 Prwu=Vwu*Cpwu/Kwu
3510 Prwf=Vwf*Cpwf/Kwf
3520 Rew=4*Mdotw/(PI*Di*Vwf)
3530 IF Rew>=2000 THEN Waterproperties
3540 Airfactors: Reg=Mdotg/Amin*Do/Visg
3550 J=FNCjseg<<(Reg)>>
3560 F=FNCfseg<<(Reg)>>
3570 Airheatxfcoef: Hout=Kg*J*Reg*Prw^(1/3)/Do
3580 H2Oheatxfcoef: IF Rew>2200 THEN Hc=FNDh<<(Vub,Ku,Di,Prub,Rew)>>
3590 IF <Rew>=2000: AND <Rew>=2200 THEN Hc=FNLam<<(Vub,Vwu,Ku,Di,Prub,Rew,Lt
)>>
3600 Dt=Tti-Twb
3610 IF Rew<2000 THEN Hc=FNColl<<(Kuf,Di,Rew,Prwf,Prwu,Rhofw,Gc,Beta,Vwf,Di)>>
3620 IF A$<>"SAT" THEN Hin=Hc
3630 IF A$<>"SAT" THEN Finefficiency
3640 Hb=Rwu*SQR<<(Rrho-Rhoatm)/Sigma)>>*(Rcpw/(.005*Rprw)))/3*(Tti-Tsat)/Ifg)
^2
3650 Q=Hc*(Tti-Twb)+Hb*(Tti-Tsat)
3660 Hin=Q/(Tti-Twb)
3670 Finefficiency: M1=(Df-Do)/2*SQR(2*(Ns+Tf)*Ifg/(Ws*Tf*Kfin))
3680 Etaf=FNTanh<<(M1)>>/M1
3690 Surfaceeffect: Etas=1-(1-Etaf)*Afin/Fso
3700 Overallxfcoef: Uco=1/(Aso/Aai*1/Hin+Aso*LOG(Do/Di)/(2*PI*Ktube*Lt/Nfin)+1
)>>/(Hout*Etas)

```



```

3710      Uoi=1/(1/Hin+Rsi*LOG(Do/Di)/(2*PI*Ktube*Lt/Nfin)+Rsi/Rso*1/(Hout*Eta))
3720      Numberxferunits: Ntu=.5*1/Cmin*(Uoo*Fso+Uoi*Rsi)
3730      Segeffectiveness: IF Type$="SATURATED" THEN Phasechange
3740      C=Cmin/Cmax
3750      IF C$="CMAX-MIXED" THEN Eff=1/C*(1-EXP(-C*(1-EXP(-Ntu))))
3760      IF C$="CMAX-UNMIXED" THEN Eff=1-EXP(-1/C*(1-EXP(-C*Ntu)))
3770      GOTO Resistance
3780      Phasechange: Eff=1-EXP(-Ntu)
3790      Resistance:      Ro=1/(Eta*Hout*Rso)
3800      Ri=1/(Hin*Rsi)
3810      Rth=1/(Uoi*Rsi)
3820      Rtube=LOG(Do/Di)/(2*PI*Ktube*Lt/Nfin)
3830      Qai=Qs/Rsi
3840      Walltemps: Tt=FNBoiltest((Pw),(Tsat),(Qai))
3850      IF (Tti)=Tt) AND ((Tsat-Twb)=0) FND (Tsat-Twb<20.00) THEN B$="BOILING
"
3860      IF (Tsat-Twb)>=0) AND (Tsat-Twb<20.00) AND (A$<>"SAT") THEN Waterproper
ties
3870      IF A$<>"SAT" THEN Tto=Tgb-Ro/Rth*(Tgb-Twb)
3880      IF A$<>"SAT" THEN Tti=Twb+Ri/Rth*(Tgb-Twb)
3890      IF A$="SAT" THEN Tti=FNBoiltest((Pw),(Tsat),(Qai)
3900      IF A$="SAT" THEN Tto=Tti+Rtube/Rth*(Tgb-Twb)
3910      Convergence: IF Type$="SUBCOOLED" THEN Delta=.00005
3920      IF (Type$="SUBCOOLED") AND (A$="SAT") THEN Delta=.00005
3930      IF Type$="SATURATED" THEN Delta=.000001
3940      IF Type$="SUPERHEAT" THEN Delta=.0000625
3950      IF ABS(Eo-Eff)>Delta THEN Effectiveness
3960      Qtotal=Qtotal+Qs
3970      Twin=Twout
3980      Twin=Twout
3990      T2(Axial)=PROUND(Tgout,-2)
4000      Tw(Axial)=PROUND(Twb,-2)
4010      X(Axial)=PROUND(Xt,-4)
4020      Uo(Axial)=PROUND(Uoo,-4)
4030      Ui(Axial)=PROUND(Uoi,-4)
4040      Ho(Axial)=PROUND(Hout,-4)
4050      Hi(Axial)=PROUND(Hin,-4)
4060      Qa(Axial)=PROUND(Qs/Rsi,-4)

```

```

4070 Wo(Axial)=PROUND(Tto,-2)
4080 Wi(Axial)=PROUND(Tti,-2)
4090 Nextsegment: NEXT Axiat
4100 Overallheatbal: IF Inlet$="1" THEN Vis
4110 CALL Viscw((Pw),(Twi),Vw)
4120 CALL Entcw((Pw),(Twi),Iw)
4130 GOTO Calling
4140 Vis: Vw=FNSatwvisc((Tsat))
4150 Iw=FNHsl((Tsat))
4160 Calling: IF Xt>1 THEN CALL Combstm((Pw),(Twtout),Istm,Satm,Rhostm)
4170 IF Xt=1 THEN CALL Combstm((Pw),(Tsat),Istm,Satm,Rhostm)
4180 IF Xt<1 THEN Istm=Iwtout
4190 Mdotwb=Qtotat/(Istm-Iw)
4200 Check=ABS((Mdotwb-Mdotw)/Mdotwb)
4210 IF Check<.05 THEN Printout
4220 Mdotw=.5*(Mdotu+Mdotwb)
4230 Rewin=4*Mdotw/(PI*Di*Vw)
4240 Twin=Twl
4250 Iwin=Iwl
4260 Twout=Twl
4270 Twb=Twl
4280 Xt=-1
4290 Qtotat=0
4300 GOTO Iteration
4310 Printout: Re(Run)=Rewin
4320 PRINTER IS 0
4330 PRINT ""
4340 PRINT ""
4350 PRINT "RECORD NUMBER IS",Run
4360 PRINT "-----"
4370 PRINT ""
4380 PRINT ""
4390 PRINT "ASSUMED INLET WATER-SIDE REYNOLDS NUMBER",PROUND(Spec(5),-3)
4400 PRINT ""
4410 PRINT "ACTUGL INLET WATER-SIDE REYNOLDS NUMBER",PROUND(Rewin,-3)
4420 PRINT ""
4430 PRINT "OUTLET WATER-SIDE REYNOLDS NUMBER",PROUND(Rew,-3)
4440 Re(Run)=Rewin
4450 PRINT ""

```

```

4460 PRINT "OVERALL WATER MASS FLOW RATE=", PROUND(Mdotwb, -6)
4470 Mdot(Run)=Mdotwb
4480 PRINT ""
4490 PRINT "TOTAL OVERALL HEAT ADDITION RATE=", PROUND(Qtotal, -3)
4500 PRINT ""
4510 PRINT "THE INLET WATER TEMPERATURE IS", Twi
4520 PRINT ""
4530 PRINT "THE SATURATION TEMPERATURE IS", PROUND(Tsat, -2)
4540 PRINT ""
4550 IF X(Nfin)<1 THEN PRINT "THE OUTLET WATER TEMPERATURE IS", PROUND(Twout
, -2)
4560 IF X(Nfin)>=1 THEN PRINT "THE OUTLET STEAM TEMPERATURE IS ", PROUND(Two
ut, -2)
4570 PRINT ""
4580 PRINT "THE AMOUNT OF SUPERHEAT IS", PROUND(Twout-Tsat, -2)
4590 Super(Run)=PROUND(Twout-Tsat, -2)
4600 PRINT ""
4610 PRINT ""
4620 PRINTER IS 16
4630 Recordresults: PRINT "RECORDING RESULTS ON DISK"
4640 FOR I=1 TO Nfin
4650   Tg(I)=PROUND(.5*(T1(I)+T2(I)), -2)
4660   NEXT I
4670   ASSIGN #1 TO "TG:F8,1"
4680   ASSIGN #2 TO "TW:F8,1"
4690   ASSIGN #3 TO "WO:F8,1"
4700   ASSIGN #4 TO "WI:F8,1"
4710   ASSIGN #5 TO "QA:F8,1"
4720   ASSIGN #6 TO "HI:F8,1"
4730   ASSIGN #7 TO "HO:F8,1"
4740   ASSIGN #8 TO "UO:F8,1"
4750   ASSIGN #9 TO "UI:F8,1"
4760   ASSIGN #10 TO "X:F8,1"
4770   MAT PRINT #1, Run; Tg
4780   MAT PRINT #2, Run; Tw
4790   MAT PRINT #3, Run; Wo
4800   MAT PRINT #4, Run; Wi
4810   MAT PRINT #5, Run; Qa
4820   MAT PRINT #6, Run; Hi

```

```

4830 MAT PRINT #7,Run;Ho
4840 MAT PRINT #8,Run;Uo
4850 MAT PRINT #9,Run;Ui
4860 MAT PRINT #10,Run;X
4870 Mdotw=0
4880 Qtotal=0
4890 FOR I=1 TO Nfin
4900 IF I=Nfin THEN 4970
4910 IF (SGN(X(I))<0) AND SGN(X(I+1))>0 THEN Loczer=Lt*12/Nfin*(I+(0-X(I)))/(X(I
+1)-X(I))
4920 IF X(Nfin)<1 THEN 4950
4930 IF (X(I)<=1) AND (X(I+1)>1) THEN Locone=Lt*12/Nfin*(I+(1-X(I)))/(X(I+1)-X(I
)))
4940 One(Run)=Locone
4950 Zero(Run)=Loczer
4960 NEXT I
4970 NEXT Run
4980 ASSIGN #1 TO "RE:F8,1"
4990 ASSIGN #2 TO "MDOT:F8,1"
5000 ASSIGN #3 TO "SUPER:F8,1"
5010 ASSIGN #4 TO "ZERO:F8,1"
5020 ASSIGN #5 TO "ONE:F8,1"
5030 MAT PRINT #1,1;Re
5040 MAT PRINT #2,1;Mdot
5050 MAT PRINT #3,1;Super
5060 MAT PRINT #4,1;Zero
5070 MAT PRINT #5,1;One
5080 Omega: END
5090 !
5100 ! THIS SET OF SUB-PROGRAMS CALCULATES THE THERMODYNAMIC AND TRANSPORT PR
OPERITIES OF AIR, GIVEN TEMPERATURE IN DEGREES FAHRENHEIT
5110 !
5120 DEF FNAirtc(T)
5130 !
5140 ! Airtc CALCULATES THE THERMAL CONDUCTIVITY FOR AIR ( BTU/FT.HR./F )
5150 !
5160 Kair=0
5170 A=.012999832
5180 B=2.71167E-5

```

```

5190      C=-1.2811E-8
5200      D=2.0152E-11
5210      E=-3.7245E-14
5220      F=3.5377E-17
5230      G=-1.27737E-20
5240      Kair=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6
5250      RETURN Kair
5260  FNEND
5270  !
5280  DEF FNAirprandt1(T)
5290  !
5300  !   Airprandt1 CALCULATES THE PRANDTL NUMBER OF AIR
5310  !
5320      Prair=0
5330      A=.71905671
5340      B=-1.35162E-4
5350      C=-9.1192E-8
5360      D=9.51125E-10
5370      E=-1.56672E-12
5380      F=1.11772E-15
5390      G=-3.0463E-19
5400      Prair=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6
5410      RETURN Prair
5420  FNEND
5430  !
5440  DEF FNAirvisc(T)
5450  !
5460  !   CALCULATE THE VISCOSITY OF AIR ( LBM/FT.HR. )
5470  !
5480      Vis=0
5490      Ta=T+459.69
5500      A=-32.2839
5510      B=.478845
5520      C=5.21402E-4
5530      D=3.96954E-7
5540      E=-1.52477E-10
5550      F=2.27201E-14
5560      Vis=A+B*Ta+C*Ta^2+D*Ta^3+E*Ta^4+F*Ta^5
5570      Muair=3.6E-4*Vis

```

```

5580      RETURN Muair
5590  FEND
5600  !
5610  DEF FNaircp(T)
5620  !
5630  !   CALCULATE THE SPECIFIC HEAT FOR FIR ( BTU/ LBM °F )
5640  !
5650  Cpair=0
5660  Ta=T+459.69
5670  A=.2446604
5680  B=-1.7494E-5
5690  C=-4.632E-9
5700  D=5.5502E-11
5710  E=-3.6663E-14
5720  F=7.1728E-18
5730  Cpair=A+B*Ta+C*Ta^2+D*Ta^3+E*Ta^4+F*Ta^5
5740  RETURN Cpair
5750  FEND
5760  !
5770  !   THE NEXT TWO SUB-PROGRAMS DETERMINE SATURATION TEMPERATURE AND PRESSUR
5780  !   E FOR WATER
5790  DEF FNSattemp(P)
5800  !
5810  !   CALCULATE THE SATURATION TEMPERATURE (°F) FOR A GIVEN PRESSURE ( psia
5820  !
5830  Tsat=0
5840  IF P<=450.0 THEN 5940
5850  V=LOG(P)
5860  A=11545.164
5870  B=-8386.0182
5880  C=2477.7661
5890  D=-363.44271
5900  E=26.690978
5910  F=-.78073813
5920  Tsat=A+B*V+C*V^2+D*V^3+E*V^4+F*V^5
5930  GOTO 6050
5940  V=LOG(10+P)

```

```

5950      A=35.15789
5960      B=24.592588
5970      C=2.1182069
5980      D=-.3414474
5990      E=.15741642
6000      F=-.031329585
6010      G=3.8658282E-3
6020      H=-2.4901784E-4
6030      I=6.8401559E-6
6040      Tsat=A+B*V+C*V^2+D*V^3+E*V^4+F*V^5+G*V^6+H*V^7+I*V^8
6050      RETURN Tsat
6060  FNEND
6070  !
6080  DEF FNSatpres(T)
6090  !
6100  !      CALCULATE THE SATURATION PRESSURE ( psia ) FOR A GIVEN TEMPERATURE ( °F
        )
6110  !
6120      Psat=0
6130      Tk=(T-32.2)*(5.0/9.0)+273.16
6140      Tc=647.27
6150      Pc=218.167
6160      Pa=14.696
6170      X=Tc-Tk
6180      IF T>=200.0 THEN 6260
6190          A=3.2437814
6200          B=5.86826E-3
6210          C=1.1702379E-8
6220          D=2.1878462E-3
6230          E=(A+B*X+C*X^3)*(1.0/(1.0+D*X))*(X/Tk)
6240          Psat=Pa*Pc/10^E
6250      GOTO 6330
6260          A=3.3463130
6270          B=4.14113E-2
6280          C=7.515484E-9
6290          D=1.3794481E-2
6300          E=6.56444E-11
6310          F=(A+B*X+C*X^3+E*X^4)*(1.0/(1.0+D*X))*(X/Tk)
6320          Psat=Pa*Pc/10^F

```

```

6330      RETURN Psat
6340 FNEND
6350 !
6360 ! THIS SET OF SUB-PROGRAMS CALCULATES THE THERMODYNAMIC AND TRANSPORT PR
6370 ! OPERIES OF WATER AND STEAM ( SUBCOOLED, SFTURATED, AND SUPERHEATED )
6380 ! GIVEN TEMPERATURE IN DEGREEE FAHRENHEIT AND PRESSURE IN psia
6390 DEF FNVolcw(P,T)
6400 !
6410 ! CALCULATE THE SPECIFIC VOLUME OF WATER ( CU.FT./LBM )
6420 !
6430      Spvolw=0
6440      IF P>40.0 THEN 6530
6450          A=.016055142
6460          B=-2.5908E-6
6470          C=4.3087E-8
6480          D=-1.2311E-10
6490          E=2.0737E-13
6500          F=-2.424E-16
6510          Spvolw=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5
6520          GOTO 6790
6530      IF P>250.0 THEN 6620
6540          A=.01604542
6550          B=-2.4005E-6
6560          C=4.0334E-8
6570          D=-1.0967E-10
6580          E=2.843E-13
6590          F=-4.747E-16
6600          G=4.132E-19
6610          GOTO 6780
6620      IF P>500.0 THEN 6710
6630          A=.01599807
6640          B=-1.0895E-6
6650          C=2.3031E-8
6660          D=3.35E-12
6670          E=-1.217E-13
6680          F=2.933E-16
6690          G=-1.748E-19
6700          GOTO 6780

```



```

6710      A=.01600488
6720      B=-2.0146E-6
6730      C=3.6511E-8
6740      D=-8.142E-11
6750      E=1.4081E-13
6760      F=-1.148E-16
6770      G=8.034E-20
6780      Spvolw=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6
6790      RETURN Spvolw
6800  FEND
6810  !
6820  DEF FNHs1(T)
6830  !
6840  ! CALCULATE THE ENTHALPY OF SATURATED WATER ( BTU/LBM )
6850  Isatw=0
6860  IF T<360.0 THEN 6940
6870      A=-9.0411706E2
6880      B=10.673802
6890      C=-4.2753836E-2
6900      D=9.41244E-5
6910      E=-1.0315357E-7
6920      F=4.560246E-11
6930      GOTO 7000
6940      A=-32.179105
6950      B=1.0088084
6960      C=-1.151699E-4
6970      D=4.8553836E-7
6980      E=-7.3618778E-10
6990      F=9.6350315E-13
7000      Isatw=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5
7010      RETURN Isatw
7020  FEND
7030  !
7040  DEF FNs1(T)
7050  !
7060  ! CALCULATE THE ENTROPY OF SATURATED WATER ( BTU/LBM*F )
7070  !
7080      Ssatw=0
7090      IF T<450.0 THEN 7210

```

```

7100 M=-560.0
7110 N=110.0
7120 A=.76209767
7130 B=.13690825
7140 C=7.5137702E-3
7150 D=5.7828937E-3
7160 E=-1.6168801E-3
7170 F=-2.1403201E-3
7180 G=3.9726934E-3
7190 H=3.4265601E-3
7200 GOTO 7310
7210 M=-360.0
7220 N=310.0
7230 A=.51575516
7240 B=.39679646
7250 C=-4.5979941E-2
7260 D=3.4251697E-2
7270 E=-6.072333E-3
7280 F=-3.670358E-3
7290 G=1.2035893E-2
7300 H=1.234655E-2
7310 Tb=(T+M)/N
7320 Ssatw=A+B*Tb+C*Tb^2+D*Tb^3+E*Tb^4+F*Tb^5+G*Tb^6+H*Tb^7
7330 RETURN Ssatw
7340 FEND
7350 !
7360 DEF FNSphsatu(T)
7370 !
7380 ! CALCULATE THE SPECIFIC HEAT FOR SATURATED WATER ( BTU/LBM/F )
7390 !
7400 Cpsatu=0
7410 A=.784791
7420 B=.00525143
7430 C=-4.8694E-5
7440 D=2.198212E-7
7450 E=-5.26892E-10
7460 F=6.35459E-13
7470 G=-3.078013E-16
7480 Invcpw=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6

```

```

7490 Cpsatw=1.0/Invcpw
7500 RETURN Cpsatw
7510 FNEND
7520 |
7530 DEF FNSatwprno(T)
7540 |
7550 | CALCULATE THE PRANDTL NUMBER FOR SATURATED WATER
7560 |
7570 Prsatw=0
7580 A=-.0490197
7590 B=.005501673
7600 C=-.0000632881
7610 D=.000000514648
7620 E=-1.912988E-9
7630 F=3.600413E-12
7640 G=-3.357675E-15
7650 H=1.213506E-18
7660 Invprw=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6+H*T^7
7670 Prsatw=1.0/Invprw
7680 RETURN Prsatw
7690 FNEND
7700 |
7710 DEF FNSatwtc(T)
7720 |
7730 | CALCULATE THE THERMAL CONDUCTIVITY FOR SATURATED WATER ( BTU/HR.FT.^F )
7740 |
7750 Ksatw=0
7760 A=294.48611
7770 B=1.000526
7780 C=-5.52837E-3
7790 D=2.533937E-5
7800 E=-7.28329E-8
7810 F=1.01215E-10
7820 G=-5.366486E-14
7830 Kw1000=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6
7840 Ksatw=Kw1000/1000.00
7850 RETURN Ksatw
7860 FNEND
7870 |

```

```

7880 DEF FNSatwvisc(T)
7890 !
7900 ! CALCULATE THE VISCOSITY OF SATURATED WATER ( LBM/HR.FT. )
7910 !
7920 IF T>705 THEN T=700
7930 Vis=0
7940 IF T>290.0 THEN 8050
7950 A=72.75867
7960 B=-1.6378164
7970 C=.02140938
7980 D=-1.7733537E-4
7990 E=9.51008E-7
8000 F=-3.19775E-9
8010 G=6.07367E-12
8020 H=-4.9235E-15
8030 Vis=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6+H*T^7
8040 GOTO 8220
8050 IF T>600.0 THEN 8130
8060 A=17.78575
8070 B=-.0963629
8080 C=2.380479E-4
8090 D=-2.779399E-7
8100 E=1.238119E-10
8110 Vis=A+B*T+C*T^2+D*T^3+E*T^4
8120 GOTO 8220
8130 IF T>695.0 THEN 8190
8140 A=-3.35537
8150 B=.02046975
8160 C=-2.02311E-5
8170 Vis=A+B*T+C*T^2
8180 GOTO 8220
8190 A=240.5726596
8200 B=-36.56075447
8210 Vis=A+B*LOG(T)
8220 Musatw=.1158264+Vis
8230 RETURN Musatw
8240 FNEED
8250 !

```

```

8260 DEF FNSatsvisc(T)
8270 !
8280 ! CALCULATE THE VISCOSITY OF SATURATED STEAM ( LBM/HR.FT. )
8290 !
8300     Vis=0
8310     IF T>400.0 THEN 8380
8320     A=.1826053825
8330     B=2.91414757E-4
8340     C=3.4626801E-7
8350     D=-3.2018417E-10
8360     Vis=A+B*T+C*T^2+D*T^3
8370     GOTO 8560
8380     IF T>645.0 THEN 8460
8390     A=.418496
8400     B=-2.0573E-3
8410     C=9.04919E-6
8420     D=-1.470579E-8
8430     E=8.98275E-12
8440     Vis=A+B*T+C*T^2+D*T^3+E*T^4
8450     GOTO 8560
8460     IF T>700.0 THEN 8530
8470     A=-59.868
8480     B=.288498
8490     C=-4.61343E-4
8500     D=2.46671E-7
8510     Vis=A+B*T+C*T^2+D*T^3
8520     GOTO 8560
8530     A=-155.190422
8540     B=23.78556532
8550     Vis=A+B*LOG(T)
8560     Musats=.1158264*Vis
8570     RETURN Musats
8580 FNEND
8590 !
8600 DEF FNSatsprno(T)
8610 !
8620 ! CALCULATES THE PRANDTL NUMBER OF SFATURATED STEAM
8630 !
8640     Prsats=0

```

```

8650      A=1.216696
8660      B=-8.6038E-4
8670      C=-2.7844E-6
8680      D=2.86414E-8
8690      E=-1.15555E-10
8700      F=2.01177E-13
8710      G=-1.28362E-16
8720      Invpr=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6
8730      Prsats=1.00/Invpr
8740      RETURN Prsats
8750      FNEND
8760      !
8770      DEF FNSphsats(T)
8780      !
8790      ! CALCULATE THE SPECIFIC HEAT FOR SATURATED STEAM - BTU LBN F
8800      !
8810      Cpsats=0
8820      A=2.3118805
8830      B=-.001870675
8840      C=1.965058E-5
8850      D=-1.284045E-7
8860      E=3.013665E-10
8870      F=-3.231449E-13
8880      G=1.310507E-16
8890      Invcp=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6
8900      Cpsats=1.00/Invcp
8910      RETURN Cpsats
8920      FNEND
8930      !
8940      DEF FNSatstc(T)
8950      !
8960      ! CALCULATED THE THERMAL CONDUCTIVITY FOR SATURATED STEAM ( BTU/HR.FT. °F )
8970      !
8980      Ksats=0
8990      IF T>400.0 THEN 9070
9000      A=14.270371366
9010      B=-7.611543425E-2
9020      C=.0006749682
9030      D=-1.8003646E-6

```

```

9040      E=1.7900443E-9
9050      Ks1000=A+B*T+C*T^2+D*T^3+E*T^4
9060      GOTO 9250
9070      IF T>600.0 THEN 9150
9080          A=429.014
9090          B=-3.70237
9100          C=.01233493
9110          D=-1.809064E-5
9120          E=1.008864E-8
9130      Ks1000=A+B*T+C*T^2+D*T^3+E*T^4
9140      GOTO 9250
9150      IF T>700.0 THEN 9220
9160          A=-16674.5
9170          B=79.4598
9180          C=-.1263192
9190          D=6.72313E-5
9200      Ks1000=A+B*T+C*T^2+D*T^3
9210      GOTO 9250
9220          A=-40486.22807
9230          B=6197.073611
9240      Ks1000=A+B*LOG(T)
9250      Ksats=Ks1000/1000.00
9260      RETURN Ksats
9270      FNEED
9280      !
9290      DEF FNViscs(P,T)
9300      !
9310      ! CALCULATE THE VISCOSITY OF STEAM ( LBM/HR.FT. )
9320      !
9330      Vis=0
9340      IF P>=50.0 THEN 9440
9350          A=1.926629
9360          B=.0002555
9370          C=.0000208279
9380          D=-.0000000049502
9390          E=6.3081E-11
9400          F=-4.0799E-14
9410          G=1.05411E-17
9420      Vis=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5+G*T^6

```

```

9430      GOTO 9510
9440      A=5.72541
9450      B=-.0332628
9460      C=.0001287352
9470      D=-2.088647E-7
9480      E=1.636259E-10
9490      F=-4.96576E-14
9500      Vis=A+B*T+C*T^2+D*T^3+E*T^4+F*T^5
9510      Mustm=.01158264+Vis
9520      RETURN Mustm
9530      FEND
9540      !
9550      SUB Entcw(P,T,Icompw)
9560      !
9570      ! CALCULATE THE ENTHALPY OF SUBCOOLED WATER ( BTU/LBM )
9580      !
9590      OPTION BASE 1
9600      DIM A(5),B(5,S)
9610      MAT A=ZER
9620      Icompw=0
9630      IF P<250.0 THEN 9900
9640          B(1,1)=-3.1883166908E1
9650          B(1,2)=2.98504393234E-3
9660          B(1,3)=1.33348288125E-7
9670          B(1,4)=9.70260583567E-10
9680          B(1,5)=-1.10362284847E-12
9690          B(2,1)=1.00048960506
9700          B(2,2)=-1.05314335283E-5
9710          B(2,3)=1.4746250309E-8
9720          B(2,4)=-3.4879367820E-11
9730          B(2,5)=2.62881336815E-14
9740          B(3,1)=2.82721817375E-5
9750          B(3,2)=-3.12450383809E-7
9760          B(3,3)=9.3331884114E-10
9770          B(3,4)=-1.04460627415E-12
9780          B(3,5)=3.9935288388E-16
9790          B(4,1)=-1.41016204839E-6
9800          B(4,2)=1.11163180927E-8
9810          B(4,3)=-3.0615771954E-11

```



```

9820      B(4,4)=3.50394655357E-14
9830      B(4,5)=-1.43655502814E-17
9840      B(5,1)=4.0766436036E-10
9850      B(5,2)=-1.87878835824E-13
9860      B(5,3)=1.1016365709E-15
9870      B(5,4)=-2.06875806005E-18
9880      B(5,5)=1.2174855867E-21
9890      GOTO 10420
9900      IF P<15.0 THEN 10170
9910      B(1,1)=-32.298005582
9920      B(1,2)=1.27073877487E-2
9930      B(1,3)=-1.24633564596E-4
9940      B(1,4)=7.14487908312E-7
9950      B(1,5)=-1.36503536452E-9
9960      B(2,1)=1.01381573376
9970      B(2,2)=-2.93828430308E-4
9980      B(2,3)=2.86589395496E-6
9990      B(2,4)=-1.30522857424E-8
10000     B(2,5)=2.11847605407E-11
10010     B(3,1)=-1.91102040795E-4
10020     B(3,2)=4.08786757295E-6
10030     B(3,3)=-4.09161725681E-8
10040     B(3,4)=1.82954852791E-10
10050     B(3,5)=-2.91997554328E-13
10060     B(4,1)=9.31823679019E-7
10070     B(4,2)=-2.39081198404E-8
10080     B(4,3)=2.47927446956E-10
10090     B(4,4)=-1.11965391764E-12
10100     B(4,5)=1.79677751792E-15
10110     B(5,1)=-1.37661172896E-9
10120     B(5,2)=4.6882864067E-11
10130     B(5,3)=-4.84079843213E-13
10140     B(5,4)=2.1188231596E-15
10150     B(5,5)=-3.28078007138E-18
10160     GOTO 10420
10170     B(1,1)=-33.9774136563
10180     B(1,2)=1.42585787825
10190     B(1,3)=-.329355699335
10200     B(1,4)=2.87673452024E-2

```

```

10210 B(1,5)=-8.42437941683E-4
10220 B(2,1)=1.12118345966
10230 B(2,2)=-8.72001344198E-2
10240 B(2,3)=1.99827532858E-2
10250 B(2,4)=-1.73328589779E-3
10260 B(2,5)=5.05202831066E-5
10270 B(3,1)=-2.65590705018E-3
10280 B(3,2)=1.96097311421E-3
10290 B(3,3)=-4.4506321979E-4
10300 B(3,4)=3.83467251626E-5
10310 B(3,5)=-1.11243809796E-6
10320 B(4,1)=2.55004247051E-5
10330 B(4,2)=-1.92085012998E-5
10340 B(4,3)=4.32399525838E-6
10350 B(4,4)=-3.70393732743E-7
10360 B(4,5)=1.07027718423E-8
10370 B(5,1)=-9.12566489903E-8
10380 B(5,2)=6.92372113929E-8
10390 B(5,3)=-1.5478901162E-8
10400 B(5,4)=1.31989972084E-9
10410 B(5,5)=-3.80217009719E-11
      FOR I=1 TO 5
      FOR J=1 TO 5
        K=J-1
        A(I)=A(I)+B(I,J)*P^K
      NEXT J
    NEXT I
  FOR I=1 TO 5
    K=I-1
    Icompw=Icompw+A(I)*T^K
  NEXT I
10520 SUBEND
10530 !
10540 SUB Tccw(P,T,Kcompw)
10550 !
10560 ! CALCULATED THE THERMAL CONDUCTIVITY FOR SUBCOOLED WATER ( BTU/HR.FT. F )
10570 !
10580 ! OPTION BASE 1
10590 DIM A(5),B(5,4)

```

```

10600 MAT A=ZER
10610 K1000=0
10620 IF P>10.0 THEN 10720
10630 A(1)=307.7700899
10640 A(2)=.696656122
10650 A(3)=-.00141211951
10660 FOR I=1 TO 3
10670 K=I-1
10680 K1000=K1000+A(I)*I^K
10690 NEXT I
10700 Kcompw=K1000/1000.0
10710 SUBEXIT
10720 B(1,1)=307.0877221
10730 B(1,2)=.007133552
10740 B(1,3)=-.00001948973
10750 B(1,4)=1.5643034E-8
10760 B(2,1)=.7234487569
10770 B(2,2)=-.000112715317
10780 B(2,3)=6.3925874E-7
10790 B(2,4)=-5.0782358E-10
10800 B(3,1)=-.001706410367
10810 B(3,2)=4.163327E-7
10820 B(3,3)=-3.73672272E-9
10830 B(3,4)=3.09641147E-12
10840 B(4,1)=1.008384811E-6
10850 B(4,2)=1.80385129E-9
10860 B(4,3)=1.4699925E-12
10870 B(4,4)=-2.36900954E-15
10880 B(5,1)=-1.286417756E-10
10890 B(5,2)=-6.66766057E-12
10900 B(5,3)=1.273196646E-14
10910 B(5,4)=-7.32465883E-18
10920 FOR I=1 TO 5
10930 FOR J=1 TO 4
10940 K=J-1
10950 A(I)=A(I)+B(I,J)*P^K
10960 NEXT J
10970 NEXT I
10980 FOR I=1 TO 5

```

```

10990      K=I-1
11000      K1000=K1000+A(I)*T^K
11010      NEXT I
11020      Kcompw=K1000/1000.0
11030      SUBEND
11040      !
11050      SUB Sphcw(P,T,Cpcomw)
11060      !
11070      ! CALCULATE THE SPECIFIC HEAT FOR SUPERHEATED WATER < BTU/LEW/F >
11080      !
11090      OPTION BASE 1
11100      Cpcomw=0
11110      DIM A(7)
11120      MAT A=ZER
11130      IF P>60.0 THEN 11250
11140      A(1)=1.0287136
11150      A(2)=-.001013384
11160      A(3)=.00001238154
11170      A(4)=-7.22385E-8
11180      A(5)=2.09487E-10
11190      A(6)=-2.29792E-13
11200      FOR I=1 TO 6
11210      K=I-1
11220      Cpcomw=Cpcomw+A(I)*T^K
11230      NEXT I
11240      SUBEXIT
11250      A(1)=1.014979
11260      A(2)=-.000548746
11270      A(3)=.0000058493
11280      A(4)=-3.07961E-8
11290      A(5)=9.5209E-11
11300      A(6)=-1.48161E-13
11310      A(7)=9.692E-17
11320      FOR I=1 TO 7
11330      K=I-1
11340      Cpcomw=Cpcomw+A(I)*T^K
11350      NEXT I
11360      SUBEND
11370      !

```

```

11390 SUB Tcs(P,T,Kstm)
11390 I
11400 I CALCULATE THE THERMAL CONDUCTIVITY FOR STEAM ( BTU/HR.FT.2F )
11410 I
11420 OPTION BASE 1
11430 DIM A(7),B(5,4)
11440 MAT A=ZER
11450 Ks1000=0
11460 IF P>=50.0 THEN 11600
11470 A(1)=9.90499
11480 A(2)=.0139388
11490 A(3)=.000038914
11500 A(4)=-.0000000589
11510 A(5)=7.615E-11
11520 A(6)=-5.164E-14
11530 A(7)=1.3371E-17
11540 FOR I=1 TO 7
11550 K=I-1
11560 Ks1000=Ks1000+A(I)*T1/4K
11570 NEXT I
11580 Kstm=Ks1000/1000.0
11590 SUBEXIT
11600 B(1,1)=8.7550405
11610 B(1,2)=-.096375699
11620 B(1,3)=-.000054876232
11630 B(1,4)=4.1416405E-7
11640 B(2,1)=-.014332668
11650 B(2,2)=-.00042096669
11660 B(2,3)=2.221582E-7
11670 B(2,4)=-1.92572826E-9
11680 B(3,1)=-.000043096178
11690 B(3,2)=6.4811772E-7
11700 B(3,3)=-1.5156235E-10
11710 B(3,4)=3.25662448E-12
11720 B(4,1)=-4.2130659E-8
11730 B(4,2)=-3.7618844E-10
11740 B(4,3)=-2.1559946E-13
11750 B(4,4)=-2.35229691E-15
11760 B(5,1)=1.77924019E-11

```

```

11770      B(5,2)=5.4324874E-14
11780      B(5,3)=2.0421744E-16
11790      B(5,4)=6.0458155E-19
11800      FOR I=1 TO 5
11810          FOR J=1 TO 4
11820              K=J-1
11830              A(I)=A(I)+B(I,J)*P^K
11840          NEXT J
11850      NEXT I
11860      FOR I=1 TO 5
11870          K=I-1
11880          Ks1000=Ks1000+A(I)*T^K
11890      NEXT I
11900      Kstm=Ks1000/1000.0
11910      SUBEND
11920 !
11930 SUB Sphz(P,T,Cpstm)
11940 !
11950 ! CALCULATE THE SPECIFIC HEAT FOR STEAM ( BTU/LEM/F )
11960 !
11970      OPTION BASE 1
11980      DIM A(7),B(7,5)
11990      MAT A=ZER
12000      MAT B=ZER
12010      Cpstm=0
12020      IF P>=10.0 THEN 12490
12030          B(1,1)=.422296265
12040          B(1,2)=.030268522
12050          B(1,3)=-.004854928
12060          B(1,4)=-.0000059748
12070          B(1,5)=.000045136
12080          B(2,1)=.000181043581
12090          B(2,2)=-.000170325517
12100          B(2,3)=-.000013866942
12110          B(2,4)=1.37436147E-5
12120          B(2,5)=-1.38328347E-6
12130          B(3,1)=-1.6226512E-7
12140          B(3,2)=-1.3626817E-7
12150          B(3,3)=4.8500908E-7

```

```

12160 B(3,4)=-1.4264727E-7
12170 B(3,5)=1.12507264E-8
12180 B(4,1)=-5.6930996E-10
12190 B(4,2)=2.50520512E-9
12200 B(4,3)=-2.19632537E-9
12210 B(4,4)=5.31864156E-10
12220 B(4,5)=-3.83612442E-11
12230 B(5,1)=1.9550162513E-12
12240 B(5,2)=-5.8231567039E-12
12250 B(5,3)=4.10144879154E-12
12260 B(5,4)=-9.18383604222E-13
12270 B(5,5)=6.33208744846E-14
12280 B(6,1)=-2.01261424352E-15
12290 B(6,2)=5.38727678341E-15
12300 B(6,3)=-3.47742978501E-15
12310 B(6,4)=7.47260528987E-16
12320 B(6,5)=-5.01661911137E-17
12330 B(7,1)=7.02997694396E-19
12340 B(7,2)=-1.79132736742E-18
12350 B(7,3)=1.10536956813E-18
12360 B(7,4)=-2.31734765803E-19
12370 B(7,5)=1.52893617959E-20
12380 FOR I=1 TO 7
12390   FOR J=1 TO 5
12400     K=J-1
12410     A(I)=A(I)+B(I,J)*P^K
12420   NEXT J
12430 NEXT I
12440 FOR I=1 TO 5
12450   K=I-1
12460   Cpsm=Cpsm+A(I)*T^K
12470 NEXT I
12480 SUBEXIT
12490 MAT B=ZER(6,4)
12500 IF P>150.0 THEN 12860
12510   B(1,1)=.471051822
12520   B(1,2)=.0071901422
12530   B(1,3)=.00002902186
12540   B(1,4)=-1.0947953E-8

```

```

12550 B(2,1)=-.00030842028
12560 B(2,2)=-3.36841469E-5
12570 B(2,3)=-2.56142116E-7
12580 B(2,4)=4.0736494E-10
12590 B(3,1)=1.40514276E-6
12600 B(3,2)=5.510352E-8
12610 B(3,3)=9.0367755E-10
12620 B(3,4)=-2.1368295E-12
12630 B(4,1)=-2.3995704E-9
12640 B(4,2)=-3.3266941E-11
12650 B(4,3)=-1.54501998E-12
12660 B(4,4)=4.3756116E-15
12670 B(5,1)=1.95901818E-12
12680 B(5,2)=-2.753866E-15
12690 B(5,3)=1.26930177E-15
12700 B(5,4)=-3.9664668E-18
12710 B(6,1)=-6.16157702E-16
12720 B(6,2)=7.0953059E-18
12730 B(6,3)=-4.0450706E-19
12740 B(6,4)=1.34272907E-21
12750 FOR I=1 TO 6
12760 FOR J=1 TO 4
12770 K=J-1
12780 A(I)=A(I)+B(I,J)*P^K
12790 NEXT J
12800 NEXT I
12810 FOR I=1 TO 6
12820 K=I-1
12830 Cpstm=Cpstm+A(I)*T^K
12840 NEXT I
12850 SUBEXIT
12860 MAT B=ZER(5,5)
12870 B(1,1)=-3.1654004
12880 B(1,2)=-.050468168
12890 B(1,3)=-.000157021974
12900 B(1,4)=2.3189283E-7
12910 B(1,5)=-9.7309759E-11
12920 B(2,1)=-.01818816
12930 B(2,2)=-.00025378215

```



```

12940      B(2,3)=8.1211789E-7
12950      B(2,4)=-1.19184066E-9
12960      B(2,5)=5.0417466E-13
12970      B(3,1)=-.008033784538
12980      B(3,2)=4.7562105E-7
12990      B(3,3)=-1.55257254E-9
13000      B(3,4)=2.27809037E-12
13010      B(3,5)=-9.6702875E-16
13020      B(4,1)=2.7766181E-8
13030      B(4,2)=-3.9361743E-10
13040      B(4,3)=1.30491831E-12
13050      B(4,4)=-1.9840844E-15
13060      B(4,5)=8.1631412E-19
13070      B(5,1)=-8.4927264E-12
13080      B(5,2)=1.21404264E-13
13090      B(5,3)=-4.0761977E-16
13100      B(5,4)=5.9420773E-19
13110      B(5,5)=-2.5627204E-22
13120      FOR I=1 TO 5
13130      FOR J=1 TO 5
13140      K=J-1
13150      A(I)=A(I)+B(I,J)*P^K
13160      NEXT J
13170      NEXT I
13180      FOR I=1 TO 5
13190      K=I-1
13200      Cpstm=Cpstm+A(I)*T^K
13210      NEXT I
13220      SUBEND
13230      SUB Combstm(Pa,Tfs,Istm,Sstm,Rhostm)
13240      !
13250      !
13260      ! CALCULATE ENTHALPY, ENTROPY, AND DENSITY FOR STEAM ( BTU/LBM ); ( BTU/LB
M'F ); ( LBM/CU.FT.)
13270      !
13280      OPTION BASE 1
13290      T=Tfs/1.8+255.38
13300      P=Pa/14.6959
13310      B1=2641.62/T*10.0^(80870.0/T^2)

```

```

13320 B2=82.546
13330 B3=162460.0/T
13340 B4=.21828*T
13350 B5=126970.0/T
13360 Bo=1.89-B1
13370 Ba=Bo*P/T^2
13380 Bb=Bo/2*(P/T)^2
13390 Fo=1.89-B1*(372-20.0/T^2+2)
13400 F=775.596+.63296*T+.000162467*T^2+47.3635*LGT(T)
13410 B6=Bo*B3-2*Fo*(B2-B3)
13420 B7=2*Fo*(B4-B5)-Bo*B5
13430 B=Bo*(1.0+Ba*(B2-B3+Bb*(B4-B5)*Bo*F))
13440 Bet=1.0/T*((Bo-Fo)*P+Bb*(B6+Bb*Bo*(Bo*(B4-B5)-2*B7)))
13450 Vol=.0160185*(4.55504*T/P+B)
13460 RhoStm=1.0/Vol
13470 Istm=F+.043557*(Fo*P+Bb*(-B6+Bb*(B2-B3+2*B7*Bb)))
13480 Sstm=.809691*LGT(T)-.253801*LGT(P)+.00018052*T-11.4276/T-.355579-.024198
3*Bet
13490 SUBEND
13500 I
13510 SUB Viscw(Pres,Temp,U)
13520 I
13530 I CALCULATE THE VISCOSITY OF SUB-COOLED WATER ( LBM/HR.FT.)
13540 I
13550 OPTION BASE 0
13560 DIM A(4),B(5,5)
13570 Sum1=0
13580 Sum2=0
13590 A(0)=.0181583
13600 A(1)=.0177624
13610 A(2)=.0105287
13620 A(3)=-.0036744
13630 B(0,0)=.501938
13640 B(0,1)=.235622
13650 B(0,2)=-.274637
13660 B(0,3)=.145831
13670 B(0,4)=-.0270448
13680 B(1,0)=.162888
13690 B(1,1)=.789393

```

```

13700 B(1,2)=-.743539
13710 B(1,3)=-.263129
13720 B(1,4)=-.0253093
13730 B(2,0)=-.130356
13740 B(2,1)=-.673665
13750 B(2,2)=-.959456
13760 B(2,3)=-.347247
13770 B(2,4)=-.0267758
13780 B(3,0)=-.907919
13790 B(3,1)=1.207552
13800 B(3,2)=-.687343
13810 B(3,3)=-.213486
13820 B(3,4)=-.0822904
13830 B(4,0)=-.551119
13840 B(4,1)=-.0670665
13850 B(4,2)=-.497089
13860 B(4,3)=-.100754
13870 B(4,4)=-.0602253
13880 B(5,0)=-.146543
13890 B(5,1)=-.0843370
13900 B(5,2)=-.195286
13910 B(5,3)=-.032932
13920 B(5,4)=-.0202595
13930 T=(Temp-32)/1.8+273.16
13940 Tc=647.27
13950 Rc=317.763
13960 Dummy=FNVolcw(Pres,Temp)
13970 Rho=1/Dummy
13980 R=Rho/2.2046*3.2808^3
13990 FOR K=0 TO 3
14000     Sum1=Sum1+R(K)*(Tc/T)^K
14010 NEXT K
14020 Uo=SQR(T/Tc)/Sum1
14030 FOR I=0 TO 5
14040     FOR J=0 TO 4
14050         Sum2=Sum2+B(I,J)*(Tc/T-1)^I*(R/Rc-1)^J
14060     NEXT J
14070 NEXT I
14080 U=Uo*EXP(R/Rc*Sum2)/1000000*2.2046/3.2808*3600

```

```

14090 SUBEND
14100 !
14110 SUB Caprate(Twin,Twb,Twout,Pu,Xt,Isat,Mdotw,Caprtw,Type$)
14120 !
14130 ! CALCULATE WATER-SIDE HEAT CAPACITY RATE ( BTU/HR./F )
14140 !
14150 H20dif=Isat-Twout
14160 IF H20dif>0 THEN 14210
14170 IF Xt>1.0 THEN 14250
14180 Type$="SATURATED"
14190 Twout=Isat
14200 SUBEXIT
14210 CALL Sphcw((Pw),(Twb),Cpw)
14220 Caprtw=Mdotw*Cpw
14230 Type$="SUBCOOLED"
14240 SUBEXIT
14250 CALL Sphs((Pw),(Twb),Cps)
14260 Caprtw=Mdotw*Cps
14270 Type$="SUPERHEAT"
14280 SUBEND
14290 !
14300 SUB Metals(T,Km,M$)
14310 !
14320 ! TABULAR LISTING OF SELECTED MATERIAL THERMAL CONDUCTIVITIES
14330 !
14340 PRINT ""
14350 PRINT ""
14360 PRINT ""
14370 PRINT ""
14380 PRINT ""
14390 PRINT ""
14400 PRINT "*****"
14410 PRINT TAB(10),"K, THERMAL CONDUCTIVITY (BTU/HR.FT./F) OF VARIOUS METALS
"
14420 PRINT ""
14430 PRINT TAB(14),"TABLE #";TAB(23),T;": K FOR SOME SELECTED";TAB(49),M$;" M
ATERIALS"

```

```

14440 PRINT "*****"
*****
14450 WAIT 500
14460 PRINT TAB(5), "METAL"; TAB(34), "68°F"; TAB(40), "212°F"; TAB(47), "392°F"; TAB(
54), "572°F"; TAB(61), "752°F"; TAB(68), "1112°F"; TAB(75), "1472°F"
14470 IF T>1 THEN 14690
14480 PRINT TAB(1), "STEEL ( C MAX.=1.5 % )"
14490 PRINT TAB(3), "CARBON STEEL C=.5 %"; TAB(34), "31"; TAB(40), "30"; TAB(47), "28
"; TAB(54), "26"; TAB(61), "24"; TAB(68), "20"; TAB(75), "18"
14500 PRINT TAB(5), "1.0 %"; TAB(34), "25"; TAB(40), "25"; TAB(47), "24"; TAB(54), "23"
; TAB(61), "21"; TAB(68), "19"; TAB(75), "17"
14510 PRINT TAB(5), "1.5 %"; TAB(34), "21"; TAB(40), "21"; TAB(47), "21"; TAB(54), "20"
; TAB(61), "19"; TAB(68), "18"; TAB(75), "16"
14520 PRINT TAB(3), "NICKEL STEEL NI=0 %"; TAB(34), "42"
14530 PRINT TAB(5), "20 %"; TAB(34), "11"
14540 PRINT TAB(5), "40 %"; TAB(34), "6"
14550 PRINT TAB(5), "80 %"; TAB(34), "20"
14560 PRINT TAB(3), "INVAR ; NI=36 %"; TAB(34), "6.2"
14570 PRINT TAB(3), "CHROME STEEL CR=0 %"; TAB(34), "42"; TAB(40), "39"; TAB(47), "36
"; TAB(54), "32"; TAB(61), "28"; TAB(68), "23"; TAB(75), "21"
14580 PRINT TAB(5), "1 %"; TAB(34), "35"; TAB(40), "32"; TAB(47), "30"; TAB(54), "27"; T
AB(61), "24"; TAB(68), "21"; TAB(75), "19"
14590 PRINT TAB(5), "2 %"; TAB(34), "30"; TAB(40), "28"; TAB(47), "26"; TAB(54), "24"; T
AB(61), "22"; TAB(68), "19"; TAB(75), "18"
14600 PRINT TAB(5), "5 %"; TAB(34), "23"; TAB(40), "22"; TAB(47), "21"; TAB(54), "21"; T
AB(61), "19"; TAB(68), "17"; TAB(75), "17"
14610 PRINT TAB(5), "20 %"; TAB(34), "13"; TAB(40), "13"; TAB(47), "13"; TAB(54), "13";
TAB(61), "14"; TAB(68), "14"; TAB(75), "14"
14620 PRINT TAB(3), "CF-NI ( CHROME-NICKEL ):"
14630 PRINT TAB(5), "15 CR. 10 NI"; TAB(34), "11"
14640 PRINT TAB(5), "18 CR. 8 NI ( V2A )"; TAB(34), "9.4"; TAB(40), "10"; TAB(47), "1
0"; TAB(54), "11"; TAB(61), "11"; TAB(68), "13"; TAB(75), "15"
14650 PRINT TAB(5), "20 CR. 15 NI"; TAB(34), "8.7"
14660 PRINT TAB(5), "25 CR. 20 NI"; TAB(34), "7.4"
14670 INPUT "ENTER A VALUE FOR THE TUBE THERMAL CONDUCTIVITY", Km
14680 SUBEXIT
14690 PRINT TAB(1), "ALUMINUM:"
14700 PRINT TAB(3), "PURE"; TAB(34), "118"; TAB(40), "119"; TAB(47), "124"; TAB(54), "1
24"; TAB(61), "132"; TAB(68), "144"

```

```

14710 PRINT TAB(3), "AL-CU < DURALUMIN > 54-96 AL,"
14720 PRINT TAB(5), "3-5 CU, TRACE MG"; TAB(34), "95"; TAB(40), "105"; TAB(47), "112"
14730 PRINT TAB(3), "AL-MG < HYDRONALIUM >"
14740 PRINT TAB(5), "91-95 AL, 5-9 MG"; TAB(34), "65"; TAB(40), "73"; TAB(47), "82"
14750 PRINT TAB(3), "AL-SI < SILUMIN > 87 AL,"
14760 PRINT TAB(5), "13 SI"; TAB(34), "95"; TAB(40), "101"; TAB(47), "107"
14770 PRINT TAB(3), "AL-SI < ALUSIL > 78-80 AL,"
14780 PRINT TAB(5), "20-22 SI"; TAB(34), "93"; TAB(40), "97"; TAB(47), "101"; TAB(54),
"103"
14790 PRINT TAB(3), "AL-MG-SI 97 AL, 1 MG,"
14800 PRINT TAB(5), "1 SI, 1 MN"; TAB(34), "102"; TAB(40), "109"; TAB(47), "118"
14810 PRINT TAB(1), "CUPPER:"
14820 PRINT TAB(3), "PURE"; TAB(34), "223"; TAB(40), "219"; TAB(47), "216"; TAB(54), "2
13"; TAB(61), "210"; TAB(68), "204"
14830 INPUT "ENTER A VALUE FOR THE FIN THERMAL CONDUCTIVITY", Km
14840 SUBEND

```

LIST OF REFERENCES

1. Babcock and Wilcox Co., Steam, Its Generation and Use, Babcock and Wilcox Co., New York, 1963.
2. Shields, Carl D., Boilers: Types, Characteristics, and Functions, F.W. Dodge Corporation, New York, 1961.
3. Latham, Robert F., Introduction to Marine Engineering, U.S. Naval Institute, Annapolis, Maryland, 1955.
4. Croft, Terrel, Steam Boilers, McGraw-Hill Book Co., Inc. New York, 1937.
5. Fryling, Glenn R., Combustion Engineering, Combustion Engineering Co., Inc. New York, 1966.
6. Principles of Naval Engineering, 3rd ed., NAVPERS 10788-B, p. 255, Training Publications Division, Naval Personnel Program Support Activity, Washinton, DC, 1970.
7. Combs, R.M., LCDR, U.S.N., Waste Heat Recovery Unit Design for Gas Turbine Propulsion Systems, M.S. Thesis, Naval Postgraduate School, Monterey, California, 1979.
8. Egusa, Tatsuo, Short Straight Tube Boiler - S.S.T., Lectures presented at Naval Postgraduate School, Monterey, California, 23-27 June 1980.
9. Holland, F.A., Moores, R.M., Watson, F.A., and Wilkinson, J.K., Heat Transfer, American Elsevier Publishing Co., Inc., New York, 1970.
10. Holman, J.P., Heat Transfer, 4th ed., McGraw-Hill Book Co., Inc., New York, 1976.
11. Kays, W.M. and London, A.L., Compact Heat Exchangers, McGraw-Hill Book Co., Inc., New York, 1964.
12. Weierman, C., Taborek, J., and Marner, W.J., Comparison of In-Line and Staggered Banks of Tubes with Segmented Fins, paper presented at the 15th National Heat Transfer Conference, AIChE-ASME, San Francisco, California, 1975.
13. Eckert, E.R.G., and Drake, R.M., Analysis of Heat and Mass Transfer, McGraw-Hill Book Co., New York, 1972

14. Jakob, M., Heat Transfer and Flow Resistance in Cross Flow of Gases over Tube Banks, Trans. ASMR, vol. 60, p. 384, 1938.
15. Collier, J.G., Convective Boiling and Condensation, McGraw-Hill Book Co., New York, 1972.
16. Sieder, E.N., and Tate, C.E., Heat Transfer and Pressure Drop of Liquids in Tubes, Inc. Eng. Chem., vol. 28, p. 1429, 1936.
17. Dittus, F.W., and Boelter, L.N.K., Heat Transfer in Automobile Radiators of Tubular Type, Publications in Engineering, University of California, p. 443, 1930.
18. Bergles, A.E., and Rohsenow, W.M., The Determination of Forced Convection Surface-Boiling Heat Transfer, J. Heat Trans. vol. 86, pp. 365-372, 1964.
19. Hsu, Y.Y., On the Size Range of Active Nucleation Cavities on a Heating Surface, J. Heat Trans., 843(3), pp. 207-216, 1962.
20. Han, C.Y., and Griffith, P., The Mechanism of Heat Transfer in Nucleate Pool Boiling, Part I, Bubble Initiation Growth and Departure, Int. J. Heat Mass Trans. 8(6), pp. 887-904, 1965.
21. Rohsenow, W.M., A Method of Correlating Heat Transfer Data for Surface Boiling of Liquids, Trans., ASME, 74, p. 969, 1952.
22. Rohsenow, W.M., Heat Transfer with Evaporation, University of Michigan Press, p. 101-150, 1953.
23. Sucec, J., Heat Transfer, Simon and Schuster Technical Outline, Simon and Schuster, Inc., New York, 1975.
24. Hsu, Y.Y., and Graham, R.W., Transport Processes in Boiling and Two-Phase Systems, McGraw-Hill Book Co., New York, 1976.
25. Rohsenow, W.M., and Harnett, J/P., Editors, Handbook of Heat Transfer, McGraw-Hill Book Co., New York, 1973.
26. Levy, S., Forced Convection Subcooled Boiling-Prediction of Vapor Volumetric Fraction, Int. J. Heat Mass Trans., 10, pp. 951-965, 1967.
27. Tong, L.S., Boiling Heat Transfer and Two-Phase Flow, John Wiley and Sons, Inc., New York, 1965.

28. Chen, J., A Correlation for Boiling Heat Transfer to Saturated Fluids in Convective Flow, ASME, 63-HT-34, 1963.
29. Afimiwala, K.A., Interactive Computer Methods for Design Optimization, Ph.D. Thesis. State University of New York, Buffalo, New York, 1976.

INITIAL DISTRIBUTION LIST

	No. Copies
1. Defense Technical Information Center Cameron Station Alexandria, Virginia 22314	2
2. Library, Code 0142 Naval Postgraduate School Monterey, California 93940	2
3. Department Chairman, Code 69 Department of Mechanical Engineering Naval Postgraduate School Monterey, California 39340	2
4. Professor Paul F. Pucci, Code 69Pc Department of Mechanical Engineering Naval Postgraduate School Monterey, California 93940	3
5. Professor Jack Stodghill Dept. of Mathematics Dickenson College Carlisle, Pennsylvania 17013	1
6. Lt. Leo W. Vollmer, Jr. Rural Route #4 Vincennes, Indiana 47591	1

12-81