


AD-A111 191

CONSTRUCTION ENGINEERING RESEARCH LAB (ARMY) CHAMPAIGN IL F/O 13/2
A PROCEDURE FOR EVALUATING SUBPOTABLE WATER REUSE POTENTIAL AT --ETC(U)
NOV 81 J T BANDY, M MESSENGER, E D SMITH
CERL-TR-N-109

UNCLASSIFIED

NL

1 of 2
4/11/91



construction
engineering
research
laboratory




United States Army
Corps of Engineers
... Serving the Army
... Serving the Nation

Technical Report N-109
November 1981

A PROCEDURE FOR EVALUATING SUBPOTABLE
WATER REUSE POTENTIAL AT ARMY FIXED FACILITIES

AD A111191

by
J. T. Bandy
M. Messenger
E. D. Smith



FILE COPY



82 02 22 100

Approved for public release; distribution unlimited.

The contents of this report are not to be used for advertising, publication, or promotional purposes. Citation of trade names does not constitute an official indorsement or approval of the use of such commercial products. The findings of this report are not to be construed as an official Department of the Army position, unless so designated by other authorized documents.

***DESTROY THIS REPORT WHEN IT IS NO LONGER NEEDED
DO NOT RETURN IT TO THE ORIGINATOR***

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER CERL-TR-N-109	2. GOVT ACCESSION NO. AD-A111 191	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) A PROCEDURE FOR EVALUATING SUBPOTABLE WATER REUSE POTENTIAL AT ARMY FIXED FACILITIES		5. TYPE OF REPORT & PERIOD COVERED FINAL
		6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) J.T. Bandy M. Messenger E.D. Smith		8. CONTRACT OR GRANT NUMBER(s)
9. PERFORMING ORGANIZATION NAME AND ADDRESS U.S. ARMY CONSTRUCTION ENGINEERING RESEARCH LABORATORY P.O. Box 4005, Champaign, IL 61820		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 4A762720A896-B-008
11. CONTROLLING OFFICE NAME AND ADDRESS		12. REPORT DATE November 1981
		13. NUMBER OF PAGES 102
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		15. SECURITY CLASS. (of this report) UNCLASSIFIED
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES Copies are obtainable from the National Technical Information Service Springfield, VA 22151		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) water reclamation		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) The amendments to the Clean Water Act of 1977 require Army installations to consider wastewater reuse when planning new water or wastewater treatment works. This has created a need for a method that can be used (1) to assess quickly the opportunities for reuse at Army fixed facilities, and (2) to identify the most cost-effective reuse option available. To address this need, U.S. Army Construction Engineering Research Laboratory (CERL) researchers have developed the Wastewater Reuse component of the Pollution Abatement Management.		

DD FORM 1 JAN 73 1473 EDITION OF 1 NOV 65 IS OBSOLETE

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

Block 20 continued.

Systems (PAMS). This will help the Army Facilities Engineers, major commands, and Environmental Offices meet Federal environmental requirements by allowing a quick, accurate assessment of reuse potential, and providing a basis for economic comparison of reuse systems.

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

FOREWORD

This study was performed by the Environmental Division (EN) of the U.S. Army Construction Engineering Research Laboratory (CERL) for the Directorate of Military Programs, Office of the Chief of Engineers (OCE), under Project 4A762720A896, "Environmental Quality for Construction and Operation of Military Facilities"; Task B, "Pollution Control Technology"; Work Unit 008, "Pollution Abatement Management System." The QCR number is 3.01.004. LTC D. Gilson, DAEN-ZCE, is the OCE Technical Monitor.

This research was made possible through the efforts of U.S. Army Medical Bioengineering Research and Development Laboratory (USAMBRDL), consultants from SCS Engineers, and Dr. Yeun-Ci Wu, University of Pittsburgh. Field tests were performed in conjunction with MAJ Roy Miller and LT Clyde Yount, U.S. Army Environmental Hygiene Agency. Administrative support and counsel were provided by Dr. R. K. Jain, Chief of EN.

COL L. J. Circeo is Commander and Director of CERL, and Dr. L. R. Shaffer is Technical Director.

A-

CONTENTS

DD FORM 1473	1
FOREWORD	3
LIST OF TABLES AND FIGURES	5
1 INTRODUCTION.....	9
Background	
Objective	
Approach	
Scope	
Mode of Technology Transfer	
Use of the Model	
2 STAGE 1 -- ASSESSMENT OF REUSE POTENTIAL AND FEASIBILITY.....	11
Part 1: General Information About the Installation	
Part 2: Information About Major Activities	
3 STAGE 2: CASCADE REUSE NETWORKS.....	24
4 STAGE 2: PRELIMINARY COST ESTIMATES.....	33
Piping Costs	
Storage	
Treatment	
Pumping	
Total Costs	
5 STAGE 3: WASTEWATER SURVEYS.....	41
6 THE COMPUTER SYSTEM.....	42
7 CONCLUSION.....	44
REFERENCES	45
APPENDIX A: White Sands Missile Range Field Test	47
APPENDIX B: Water and Effluent Quality	73
DISTRIBUTION	

TABLES

<u>Number</u>		<u>Page</u>
1	Army Activities With Greatest Potential as Sources of Reclaimed Water	23
2	Army Activities With Greatest Potential as Users of Reclaimed Water	23
3	Army Activities With Greatest Potential for Internal Recycling	23
4	Reuse System Sample Water Balance	32
A1	Chemical Analyses of Composite Samples of Post Water Supply	50
A2	Tolerable Water Quality According to Various References	58
A3	Costs of the Reuse Network	67
A4	Sewage Treatment Plant Influent	69
A5	Sewage Treatment Plant Effluent	70
A6	Photo Lab Data Comparison	71
B1	Tolerable Water Supply Quality -- Aircraft Wash Racks	74
B2	Typical Effluent Quality -- Aircraft Wash Racks	74
B3	Tolerable Water Supply Quality -- Air Pollution Wet Scrubbers	75
B4	Air Pollution Wet Scrubbers -- Typical Effluent Quality	75
B5	Base Housing Water Supply Quality	76
B6	Typical Base Housing Sewage	76
B7	Low Pressure Boilers -- Tolerable Water Supply Quality	77
B8	Low Pressure Boilers -- Typical Effluent Quality	78
B9	Cooling Water (Recirculating Systems) -- Tolerable Water Supply Quality (Also Dynamometers)	79

TABLES (Cont'd)

<u>Number</u>		<u>Page</u>
B10	Cooling Waters (Once-Through) -- Tolerable Water Quality (Also Dynamometers)	80
B11	Typical Effluent Quality -- Cooling Tower Blowdown (Also Dynamometers)	81
B12	Fire Protection/Spill Washdown Reservoirs -- Tolerable Water Supply Quality	82
B13	Hospitals -- Typical Effluent Quality	82
B14	Irrigation -- Tolerable Water Supply Quality	83
B15	Laundries -- Tolerable Water Quality	84
B16	Industrial Laundries -- Typical Effluent Quality	85
B17	Laundromat -- Effluent Quality	86
B18	Metal Cleaning -- Typical Effluent Quality	86
B19	Metal Electroplating and Finishing Rinse Waters -- Tolerable Water Supply Quality, Also Metal Cleaning	87
B20	Paint Booth Water Walls -- Tolerable Water Supply Quality	87
B21	Paint Booth Water Walls -- Typical Effluent Quality	88
B22	Photographic Laboratories -- Tolerable Water Supply Quality	88
B23	Photographic Laboratories -- Typical Effluent Quality	89
B24	Recreational Lakes (Limited Body Contact) -- Tolerable Water Supply Quality	90
B25	Steam Cleaning -- Typical Effluent Quality	91
B26	Vehicle Wash Racks -- Tolerable Water Supply Quality Using Sewage Treatment Plant Effluent	91
B27	Vehicle Wash Racks -- Tolerable Water Supply Quality Using Internally Recycled Water	91
B28	Vehicle Wash Racks -- Typical Effluent Quality	92

TABLES (Cont'd)

<u>Number</u>		<u>Page</u>
B29	Summary of Tolerable Water Supply Quality and Typical Effluent Wastewater Quality	93
B30	Final Lagoon Effluent Quality at Lake City Ammunition Plant and Its Possible Uses	97

FIGURES

1	Basic Types of Reuse Schemes	25
2	Reuse of Reclaimed Sewage Treatment Plant Effluent	26
3	Direct Cascade Reuse of Reclaimed Water	27
4	Cascade Reuse With Pretreatment	28
5	Internal Treatment and Recycling	28
6	Sample Reuse Network Diagram -- Simple Scheme	29
7	Sample Reuse Network Diagram -- Complex Scheme	30
8	Sample Water Balance Diagram for Conceptual Reuse Systems Showing Flow Rates (Cubic Meters, Maximum and Minimum), Requirements for Storage and Additional Fresh Water	31
9	Raw Sewage Pumping (Constant Speed)	37
10	Raw Sewage Pumping (Variable Speed, Curve 1)	38
11	Raw Sewage Pumping (Variable Speed, Curve 2)	39
12	Curve for Estimating Maintenance Hours	40
A1	Cross Section Through Well Field	48
A2	Monthly and Yearly Pumpage in the Post Headquarters Well Field	51
A3	WSMR Facilities	52
A4	WSMR Wastewater Treatment Plant	53
A5	Comparison of Mean/Average Daily Flows	55
A6	Hourly kVA Demand	57

FIGURES (Cont'd)

<u>Number</u>		<u>Page</u>
A7	Schematic of Reuse Network	63
A8	Total Head Developed by Pumping System	66
A9	Average Flow	72

A PROCEDURE FOR EVALUATING SUBPOTABLE WATER REUSE POTENTIAL AT ARMY FIXED FACILITIES

1 INTRODUCTION

Background

The Department of the Army (DA) has many installations in regions where sources of inexpensive, good quality water are limited. In some areas of the western and southwestern United States, surface water is scarce and groundwater is either extremely high in dissolved solids, or so deep underground that pumping is costly. Wastewater reuse can benefit installations by reducing their requirements for potable water. In certain situations, reuse of wastewater can prove an economical solution to both water supply and wastewater disposal problems.

Army Regulation (AR) 200-1 and amendments to the Clean Water Act of 1977 require Army installations to consider wastewater reuse when new water or wastewater treatment works are planned.¹

A model -- a system of manual and automated procedures -- is needed to help Army planners choose installations where wastewater reuse would be most economical and beneficial, and to identify which of the many possible reuse networks would be most cost-effective.

Such a model has been developed by the U.S. Army Construction Engineering Research Laboratory (CERL) as a component of the Water Pollution Abatement Subsystem (WPAS) of the Pollution Abatement Management System (PAMS).²

Objective

The objective of this study was to develop a wastewater reuse model which will allow the Army (1) to assess the potential for wastewater reuse at fixed facilities, and (2) to identify the most cost-effective reuse networks which can be implemented at an installation.

Approach

1. A protocol was developed to quickly assess an installation's potential for wastewater reuse in the course of a 1-day site visit (Chapter 2).

2. Guidelines for developing networks that cascade water among an installation's water-using activities were formulated (Chapter 3).

¹ Environmental Protection and Enhancement, Army Regulation (AR) 200-1 (Headquarters [HQ], Department of the Army [DA], 20 January 1980).

² R. D. Webster, E. D. Smith, and V. Kothandaraman, Pollution Abatement Management System -- Concept Definition, Technical Report N-42/ADA055565 (U.S. Army Construction Engineering Research Laboratory [CERL], May 1978).

3. A method for making rough cost estimates for the proposed networks was devised (Chapter 4).

4. A computer system that validates and compares the cost of the wastewater reuse networks proposed for an installation was developed (Chapter 6).

5. The reuse model was field tested at White Sands Missile Range (WSMR) in conjunction with the Army Environmental Hygiene Agency (AEHA). (An account of the WSMR field test is presented in Appendix A.)

Scope

The reuse model is applicable to installations that produce wastewater similar to typical domestic sewage. It is not concerned with heavily industrial operations such as munitions manufacture.

Mode of Technology Transfer

The information in this report will be used to document AR 18-1 requirements. This information will specifically form a basis for the General Functional System Requirements and for development of the Project Master Plan for PAMS. In addition, this information will serve as a basis for an Engineer Technical Note (ETN), which will be prepared after field testing of the approach.

Use of the Model

To use the model, the installation must first identify facilities that have potential for subpotable water reuse (Stage 1). Then schematic diagrams of networks that cascade water among an installation's water-using activities are developed; the costs of the networks are estimated so those that are not economical can be eliminated (Stage 2). Finally, actual water quality and flow data must be gathered on post (Stage 3) for input to a computer system that evaluates the feasibility of each wastewater reuse system being considered.

2 STAGE 1 -- ASSESSMENT OF REUSE POTENTIAL AND FEASIBILITY

In Stage 1 of the wastewater reuse model, efficient, straightforward methods are used to identify facilities that have potential for subpotable water reuse. The techniques have been designed so that a knowledgeable person can complete them during a 1- to 2-day site visit.

Completion of Stage 1 requires a sound general knowledge of five major areas of the installation: water supply, wastewater treatment/disposal, institutional aspects of the water and wastewater systems, environmental factors, and energy. The evaluators responsible for completing Stage 1 need not be sanitary engineers; however, they should be familiar with Army installations, should be completely briefed on the purpose of the Stage 1 model, and should have enough technical background to discuss water supply systems, wastewater treatment, and Army activities.

Most important, at each post the evaluators must locate key persons who have or know where to obtain the information needed for Stage 1. The Chief of Utilities or another member of the Facilities Engineering Office can furnish much of the information. The Master Planning Office will know about future events that may change the water/wastewater scenario or the activities of the installation.

Part 1: General Information About the Installation

Answers to the following questions must be obtained as the first step in completing Stage 1:

1. Water Supply

A key to wastewater reuse potential is the availability and cost of the installation water supply, both now and in the future. Water shortages, potential water supply problems, and high water usage are all factors that make reuse attractive.

a. Is the installation water supply available from a reliable source for the next 20 years?

(1) What is the source?

(2) Where is it?

Remarks: a negative response indicates possible long-range supply problems, making reuse advantageous.

b. Is there possible significant depletion of the water supply within the next 10 years?

(1) If so, what is the cause?

(2) What alternative sources of supply exist?

(3) What planning has been done to meet this contingency?

Remarks: a positive response means there will be future planning and possible design of new water supply facilities -- a good time to evaluate reuse.

c. Is there a problem anticipated with the water supply within 5 years?

(1) What is the problem?

(2) What are the possible solutions?

Remarks: positive response -- high rating for reuse as evaluation and planning for new or additional water supplies should include reuse possibilities.

d. Is there a foreseeable event that could markedly increase water costs in the next 10 years?

(1) What?

(2) How much?

Remarks: although costs may be reasonable now, many areas are realizing increased costs as water sources are depleted and quality degrades. Future cost increases benefit reuse economics.

e. List average water use in million gallons per day (mgd) for each month of the last year (see water treatment plant [WTP] records).

f. Check type of testing done on influent and effluent of WTP. (This information is available from the plant superintendent.)

	<u>Influent</u>	<u>Effluent</u>
Total dissolved solids (TDS)		
Suspended solids (SS)		
Coliforms		
Biochemical oxygen demand (BOD)		
Total organic carbon (TOC)		
Chemical oxygen demand (COD)		
Nitrogen		
Other (specify)		

g. What is the present cost of water procurement and treatment per 1000 gal (3790 L)? (This information is available on FORSCOM Form 243-2-R, 1 July 1977.)

Remarks: high water costs are a driving force for reuse as the economics of reuse become more attractive.

h. Is expansion or upgrading of the water supply/treatment system planned in the next 10 years?

Remarks: reuse can provide savings in reduced plant capacity. Planning should include reuse feasibility.

i. What is the effective population on the installation? Is this going to increase or decrease greatly in the future?

j. What changes in activities are planned for the next 10 years?

(1) Are more industrial activities planned?

(2) What will be the water use requirements of planned changes?

2. Wastewater

Wastewater management is an important consideration for reuse: treatment facilities, effluent quality, discharge requirements, costs, and volumes are important factors. In general, installations with high-volume treatment facilities discharging high-quality effluent have good reuse potential; this is also true of installations at the other extreme -- with outdated or overloaded treatment facilities that are unable to meet discharge requirements.

a. Does the installation treat wastewater for direct discharge to surface water or land?

(1) What is the name of the receiving body of water?

(2) If land discharge, describe system.

(3) If not, how and where is sewage discharged?

Remarks: direct discharging installations have more reuse potential because of the problems associated with meeting increasingly stringent discharge requirements. Reuse is one answer for reducing plant loadings, or for eliminating discharges altogether.

b. Does the installation treatment plant presently meet discharge requirements?

(1) Describe noncompliance (sewage treatment plant [STP] records).

(2) Provide National Pollutant Discharge Elimination System (NPDES) permit information.

Remarks: a negative response indicates a wastewater management problem for which reuse may be part of the solution.

c. Are there plans to upgrade or add to the existing treatment facilities within the next 5 years?

Remarks: a positive response indicates planning, design, and construction of new facilities. Reuse could have positive impact, or could conceivably alleviate the problem so that new facilities would not be necessary.

- d. Are there plans to hook into a regional or municipal sewage system?
- e. Are there plans to accept wastewater from surrounding communities for treatment?
- f. Draw a simple process train for the installation STP; include design capacity.
- g. List average flow in mgd for each month of the last year (STP records).

Remarks: as plants near design capacity, decisions about expansion or reuse have to be made. Problems with overloading may be solved by reuse. Economies of scale favor reuse at installations with large volumes of wastewater.

- h. Fill in the minimum and maximum monthly averages for the parameters listed below for the past year. (This information is available on the form filled out for the NPDES discharge monitoring report: OMB #158-r00.)

	<u>Minimum and</u> <u>Month of Occurrence</u>	<u>Maximum and</u> <u>Month of Occurrence</u>
mg/L BOD		
mg/L Total N		
mg/L SS		

Remarks: good quality effluent is a bonus for reuse because little extra treatment is required, making it more economical.

- i. Does an industrial wastewater treatment plant (IWTP) exist on post?
 - (1) Does it meet discharge requirements?
 - (2) What quality is plant effluent with respect to COD?
 - (3) Are discharge limits set for specific contaminants? Which ones?

Remarks: industrial waste treatment plants with specific contaminant limits are likely to have a higher quality effluent (better for reuse). They may also have problems meeting these discharge standards, in which case reuse may help.

- (4) What is average monthly flowrate in mgd for the last year for the IWTP?
- (5) Has the IWTP effluent ever caused problems at STP?

(6) List average monthly IWTP flows for the past year.

j. If municipal or regional sewer system is used,

(1) What is the discharge fee and rate structure?

(2) Are future changes likely that would markedly increase the discharge fee?

Remarks: high discharge fees have a positive effect on reuse economics.

2. Institutional Factors

a. Do any long-term agreements for water purchase prohibit the installation from reducing water use?

Remarks: constraints on the ability to reduce water usage are obviously detrimental to reuse programs.

b. Do any water laws or agreements prohibit the installation from reducing the volume of effluent discharged?

Remarks: constraints on the ability to reduce wastewater discharge volumes are detrimental to reuse programs.

c. Is any type of wastewater reuse or water recycle occurring on post?

(1) What percentage of the wastewater is being reused? Where? How?

(2) What percentage of the water is being recycled? Where?

Remarks: installations already reusing a portion of their wastewater are obvious candidates for a more comprehensive reuse plan.

d. Are key installation personnel interested in using reclaimed water?
Name point of contact (POC).

e. Are key installation personnel opposed to using reclaimed water?
Name POC.

Remarks: the attitudes of key personnel toward wastewater reuse are prime factors in the success of a program.

4. Environmental Factor

Another area of interest is meteorological and hydrogeological data. Because of the value of irrigation as a major sink for reclaimed water, installations in arid or semi-arid areas may have more reuse applications than installations in areas of adequate rainfall. Although not always the case, installations in dry areas tend to have more serious water supply problems than those in more temperate zones.

a. What is the average monthly rainfall on post? (This information can be obtained from the local weather forecaster, a nearby university department of atmospheric sciences, or a meteorological monitoring station.)

b. What is the monthly average reservoir evaporation on the installation?

c. At what average depth is the water table located? (The U.S. Geological Survey [USGS] may be able to supply this information.)

d. Is the aquifer from which the installation draws its supply the sole source available?

(1) What is its estimated life?

(2) Is there a salt water intrusion problem?

(3) Is groundwater recharge being practiced?

e. Are there any natural or artificially filled lakes on installation?

(1) Current use

(2) Acres and depth

(3) Sources of water

(4) Any quality data available?

f. Are any reports available on these topics from USGS, AEHA, or contractor studies?

g. What groundwater protection laws apply to this region?

5. *Energy*

Energy usage is an ever-increasing concern; water supply and disposal systems often use large amounts of electrical energy. If the total head and/or distance over which the water supply must be pumped is great, the potential for reuse increases. If power costs for wastewater treatment and disposal are high, irrigation or another consumptive use before treatment may save power costs by reducing the plant load.

a. Obtain copies of rate calculations for both water and sewage disposal service for as many years past as available.

b. What is the current charge for electricity in cents per kilowatt-hour (kWh)? Describe the rate structure.

c. What is the projected cost of electricity for water and sewage treatment over the next 20 years?

- d. Is any electricity produced on post?
 - (1) What is the cost of production in cents per kWh?
 - (2) What fuel is used?
- e. Are there plans to produce electricity on post?
- f. How is the 20 percent reduction in energy use mandated by DA for 1985 going to be achieved?
- g. What plans have been made for energy conservation?

Data Analysis

Based on the information obtained, a decision must be made about whether the installation could benefit from wastewater reuse. This requires a great deal of judgment. Several factors contribute to a decision to proceed, but no attempt should be made to use a cookbook formula to reach a conclusion:

- 1. If the water supply is not available from a reliable, adequate, and inexpensive source currently or in the near future, reuse should be examined further.
- 2. If additional water treatment works are going to be necessary, reuse may be more economical.
- 3. A high volume of wastewater and a good quality effluent contribute to the cost-effectiveness of reuse.
- 4. Noncompliance with NPDES permit requirements may make reuse beneficial if consumptive uses for the wastewater can be found (e.g., irrigation), or if the total volume of wastewater can be reduced to alleviate STP overloading.

However, if the installation is committed by prior agreements or laws to stated volumes of water use and wastewater discharge, reuse may not be possible. If a high percentage of water or wastewater is already being reused, most of the opportunities for reuse may have been exploited.

- 5. In many places, reclaimed water is used for irrigation, which tends to be a large percentage of total water use in climates experiencing low rainfall or high evaporation. Lakes can serve as sinks or storage areas for reclaimed water and can provide recreation.

- 6. High power costs for water supply or disposal contribute to the cost effectiveness of reuse.

Part 2: Information About Major Activities

In Part 2, information is sought on the spatial relationships and estimated water use/wastewater discharge of the major activities on post.

To determine spatial relationships, a base map showing elevations and having a scale of at least 1 in. = 500 ft should be obtained. The individual(s) who seemed most knowledgeable about the water systems in Part 1 should be asked to point out the major water-using activities. These locations should be circled and labeled on the map.

High volume is essential to cost-effective reuse networks. Unfortunately, water is rarely metered on Army posts, and accurate estimates of the water use by individual activity are often not available from either the Facility Engineer's (FE's) office or the activities themselves. Every effort should be made to develop accurate usage and discharge estimates as well as daily, weekly, and monthly usage patterns for each activity. If the FE's office cannot provide this information, a point of contact at the activity in question should be found.

Appendix B presents data on tolerable water quality and typical effluent quality for 13 common Army activities.³ The following information should be obtained on post, if possible; the data in Appendix B should be used only after all avenues of inquiry have been exhausted.

1. Golf course(s)
 - a. Number of acres.
 - b. Number of acres irrigated.
 - c. Is potable water used?
 - d. Describe existing irrigation system (automatic, manual, etc.).
 - e. During which months is watering necessary?
 - f. Is any other source of irrigation water available (such as a lake or quarry) close to the course?
 - g. Daily, weekly, monthly usage patterns.
 - h. Usage estimates.
2. Large cooling towers (water type) > 50 tons
 - a. Number.
 - b. Number of tons capacity at each location (refrigeration shop records).
 - c. Blowdown rate (gallons/ton/hour).

³ As the tables indicate, some of the information is from SCS Engineers. For a more detailed explanation of the tables, see Curtis J. Schmidt, Ernest V. Clements III, and Leanne Hammer, Subpotable Water Reuse at Army Fixed Installations: A Systems Approach, Volume I, ADA075159 (SCS Engineers, supported by U.S. Army Medical Research and Development Command, August 1979).

- d. Evaporation rate (gallons/ton/hour).
- e. Chemicals used.
- f. Months of usage.
- 3. Landscape, athletic fields, parade grounds
 - a. Acreage presently irrigated.
 - b. Additional acreage that could be irrigated if reclaimed water were available.
 - c. Daily, weekly, monthly usage patterns.
 - d. Usage estimates.
- 4. Vehicle and aircraft washracks
 - a. Number of washracks.
 - b. Number of vehicles.
 - c. Number of washings/month/vehicle.
 - d. Daily, weekly, monthly usage patterns.
 - e. Usage estimates.
- 5. Steam cleaners
 - a. Number.
 - b. Hours per week in use.
 - c. Daily, weekly, monthly usage patterns.
 - d. Usage estimates.
- 6. Metal plating and finishing
 - a. Daily, weekly, monthly usage patterns.
 - b. Usage estimates.
 - c. Pretreatment provided before discharge.
- 7. Boilers
 - a. Btu capacity.
 - b. Months in use.
 - c. Blowdown rate.

8. Autoclaves

- a. Number and size.
- b. Hours per week usage.
- c. Daily, weekly, monthly usage patterns.
- d. Usage estimates.

9. Paint booth water walls

- a. Number.
- b. Daily, weekly, monthly usage patterns.
- c. Usage estimates.

10. Air pollution wet scrubbers

- a. Type: spray, towers, cyclones, venturis, packed or floating beds.
- b. Daily, weekly, monthly usage patterns.
- c. Usage estimates.

11. Dynamometers

- a. Number.
- b. Daily, weekly, monthly usage patterns.
- c. Usage estimates.

12. Industrial laundries

- a. Number and capacity of washers.
- b. Daily, weekly, monthly usage patterns.
- c. Usage estimates.

13. Photo processing facility

- a. Daily, weekly, monthly usage patterns.
- b. Usage estimates.
- c. Pretreatment provided.

14. Civilian water users close to post

- a. Golf course.

- b. Power plant.
- c. Agriculture.
- d. Others.

Remarks: large civilian water users near the installation can offer a sink for reclaimed water if the quality is acceptable and the economics of transport are feasible.

15. Describe reuse projects planned or existing in surrounding communities.

16. Other installation water-using activities

- a. Description.
- b. Daily, weekly, monthly usage patterns.
- c. Usage estimates.

The decision to be made at this point, based on the data obtained above, is whether reuse is economically feasible.

Rough daily water balances for the installation as a whole should be calculated to reflect both summer and winter usage patterns as well as any other unique seasonal patterns that may exist.

High volume of water usage is essential both for potential sources and users of reclaimed water. A good source produces enough wastewater for reuse to be economical due to freshwater savings and/or wastewater discharge reduction. Good potential users of reclaimed water take significant volumes on a regular basis -- for example, industrial cooling towers. Irrigation can use tremendous volumes of reclaimed water; however, good estimates of the water volume for irrigation are rarely available on post.

A rough estimate of irrigation usage can be obtained by looking at the average daily water production for each month during the irrigation season and subtracting from each the volume of wastewater treated at the STP that month plus the volume of water for other consumptive purposes. Other consumptive uses frequently encountered include evaporative air conditioning, aircraft and vehicle washracks that drain to the storm sewers, and steam production.

Reliable flow is another important attribute of good sources and (to a lesser extent) good users of reclaimed water. The source flow should be predictable so that storage needs can be determined and a reliable supply provided to user activities. User demands should be consistent so that accurate estimates of costs and savings can be determined.

Finally, a good source of reclaimed water should not be so highly contaminated that prohibitively expensive treatment would be needed before reuse.

Some industrial wastewaters -- e.g., steam cleaning and metal cleaning wastes -- require extensive waste treatment before reuse to remove or

neutralize such diverse contaminants as oils, grease, cyanides, phenols, heavy metals, phosphates, acids, and caustics, and therefore have very low reuse potential. However, other industrial effluents -- e.g., some plating shop rinse waters and cooling system blowdowns -- meet the above criteria and are good candidates for reuse.

Sanitary and domestic-type wastewaters from housing, community, protective, administrative/institutional, and commercial activities also have excellent reuse potential. At most Army posts, these wastewaters are collected by the sanitary sewer system into a single sewage flow which can often be reused after secondary or tertiary treatment in a sewage treatment plant. A post STP which works well improves the economics of reuse considerably. IWTP effluents can also be reused if the treatment is complete and effective. IWTP effluent is advantageous because both bacterial and viral contamination can be very low. However, before these waters can be reused, oils and dissolved metals and salts must often be removed.

The best users of reclaimed water are those that can handle good secondary effluent because it is usually available and not expensive to produce. Activities that can use filtered secondary effluent also have good potential because most secondary plants can be readily upgraded with filtration, although this is more expensive. Activities that require very high water quality (e.g., boilers) are generally poor users because the technology to purify wastewater is too expensive in most cases. Although only nonpotable reuse is considered in this report, bacteria and viruses in the reclaimed water can be a hazard in those activities that include human contact with water sprays and aerosols. Such activities include wash and steam racks, paint water walls, and, to a lesser extent, spray irrigation of golf courses and landscapes. Typical Army activities with the greatest potential as sources of reclaimed water are listed in Table 1, as users of reclaimed water in Table 2, and as users of internal recycle in Table 3.

If promising sources and sinks for reclaimed water are present on post, networks should be developed that route the water from activity to activity. Many small, scattered sources and users make reuse harder to implement economically. However, with very high water-supply or wastewater-treatment costs, or an inadequate or unreliable supply, reuse networks for these unpromising activities also should be drawn and considered, as described in Chapter 3.

Table 1

Army Activities With Greatest Potential as Sources of Reclaimed Water

Housing, Community, Protective,
Administrative/Institutional,
and Commercial*

Industrial

Vehicle wash racks

Aircraft wash racks

Wastewater ManagementSewage treatment plant
effluentIndustrial waste treatment
plantMetal plating and finish-
ing effluent

Cooling towers

Dynamometers

Industrial laundries

Boilers

*The total sewage flow from these activities should be considered as one
wastewater source.

Table 2

Army Activities With Greatest Potential as Users of Reclaimed Water

Community

Golf course irrigation

Landscape irrigation

Athletic field, playground,
park irrigationRecreational lakes and
pondsCommercial

Laundry

Industrial

Cooling towers

Paint booth water walls

Air pollution wet scrubbers

Autoclaves

Dynamometers

Vehicle wash racks

Aircraft wash racks

Steam cleaning

Ash handling system water

Maintenance wash downs

Table 3

Army Activities With Greatest Potential for Internal Recycling

Industrial Activities

Metal plating and finishing

Vehicle wash racks

Aircraft wash racks

Dynamometers

Large industrial autoclaves

Cooling towers

Paint booth water walls

Air pollution wet scrubbers

3 STAGE 2: CASCADE REUSE NETWORKS

The second stage of the model requires 2 days of office work. Conceptual reuse systems are developed for the installation. All the data gathered on activities and spatial relationships are used to develop feasible reuse networks. These networks are essentially schematic diagrams showing the distribution of fresh and reclaimed water throughout the base, as well as the collection, treatment, reuse and disposal of wastewaters.

Several basic types of water reuse are practical for Army installations, depending on the performance of treatment facilities, major industrial or irrigation activities, and other factors (Figure 1).

1. Treated effluent reuse: the direct reuse of secondary or tertiary effluent from an STP or IWTP by an activity -- e.g., irrigation and cooling towers. Figure 2 lists other activities that can use effluent.
2. Direct cascade reuse: the direct reuse, without treatment, of the discharge from one activity as the water supply for another activity. The donor activity usually has a fairly clean discharge, and the user activity can tolerate low quality water. Feasible pairings are shown in Figure 3.
3. Cascade reuse with pretreatment: the same as direct cascade reuse with an intervening treatment step to bring the donor's wastewater up to the recipient's quality requirements. These pairings are generally practical only when simple treatment can do the job (Figure 4).
4. Internal recycling: the reuse of wastewater as new source water for the same activity. For instance, recirculating water can be used in paint shop water walls and air pollution scrubbers. The water can be continuously bled off and made up, or periodically dumped and refilled. Other activities can be altered to internal recycling systems by treating the wastewater and mixing it in with a freshwater supply. Candidate activities are shown in Figure 5.

Some installations may be able to incorporate more than one of the basic reuse systems in a total reuse scheme. The evaluator must compare actual installation activities and existing treatment facilities, and plan possible reuse networks. The most efficient way to lay out these networks is to look first at large sources and users and develop a basic system around them. Smaller users can be added when it appears they would not add significantly to the total cost -- if, for example, they are close to the source, will not require further treatment of the source water before reuse, and will not need excessive amounts of plumbing or storage. The treatment processes required between different activities can be selected by referring to Figures 2 through 5. All feasible networks should be drawn for consideration. This part of the model requires the highest level of engineering judgment to complete. Figure 6 depicts a simple reuse network that involves STP effluent reuse to irrigate a golf course. Figure 7 shows a more complex reuse scheme that includes multiple STP effluent uses, plating wastewater reuse, and internal reuse at a tank washrack.




Figure 1. Basic types of reuse schemes.




Figure 2. Reuse of reclaimed sewage treatment plant effluent.




Figure 3. Direct cascade reuse of reclaimed water.




Figure 4. Cascade reuse with pretreatment.




Figure 5. Internal treatment and recycling.




Figure 6. Sample reuse network diagram -- simple scheme.

At this point, a general water balance for each network should be developed to help calculate required storage capacities and ensure that water supply requirements are met.

Where seasonal variations are large, it is often valuable to develop water balances on a monthly as well as a daily basis. It is important to obtain data for maximum and minimum days and months. Such variations may be due to seasonal effects (e.g., irrigation) or changes in staffing levels (training, maneuvers, etc.). Storage requirements will depend on the differences between source and user activities during both minimum and maximum flow. The storage required and the flows encountered can then be transferred to the reuse network diagrams as demonstrated in Figure 8. Table 4 shows a completed sample balance.




Figure 7. Sample reuse network diagram -- complex scheme.




Figure 8. Sample water balance diagram for conceptual reuse systems showing flow rates (cubic meters, maximum and minimum), requirements for storage and additional fresh water.

Table 4
Reuse System Sample Water Balance

Conceptual Reuse System No. From Figure 8	Source Activity	Wastewater Sources		Reclaimed Water Users		Flow, gpd (L) or gal/mo (L)	
		Flow, gpd (L) or gal/mo (L)	Min.	Treatment Required	User Activities	Max.	Min.
1.	Sewage treatment plant effluent	1,000,000 (3,790,000)	750,000 (2,847,500)	Secondary treatment plus sand filtration	Cooling towers	200,000 (758,000)	150,000 (568,500)
					Wash racks	30,000 (113,700)	10,000 (37,900)
					Steam cleaning	10,000 (37,900)	5,000 (18,950)
					Dynamo- meters	30,000 (113,700)	20,000 (75,800)
					Golf course and other area irrigation	2,000,000 (7,580,000)	0
2.	Metal plating rinses	50,000 (189,500)	50,000 (189,500)	Sand filtration plus ion* exchange	Metal plating rinses	52,000 (197,080)	52,000 (197,080)
					Plating shop fume scrubbers	5,000 (18,950)	5,000 (18,950)
					Plating solution makeup water	1,000 (3790)	1,000 (3790)

*Already existing.

4 STAGE 2: PRELIMINARY COST ESTIMATES

Evaluating a network using the computer system (Chapter 6) is expensive because actual water quality parameters and flow patterns for each activity's influent and effluent must be determined. This requires that a wastewater survey be done on post. Preliminary cost estimates are needed so that networks that are clearly not cost-effective can be eliminated before the survey.

The amounts and costs of materials, labor, and energy needed to implement a reuse network must be calculated. The first step is to establish, using the water and sewage costs obtained in Stage 1, the water and sewage treatment savings realized by each network (in gallons per year and dollars per year). These potential savings will be compared to the costs of the networks.

Next, both capital and operations and maintenance (O&M) costs must be estimated for each network. The major expenses are those for piping, pumping, storage, and additional treatment.

Piping Costs

The length of pipe needed for each network is obtained by measuring distances between activities on the map and converting to feet. The necessary pipe diameters can be calculated using the relationship

$$\text{Area, sq ft} = \frac{\text{flow, cu ft/sec}}{\text{velocity, ft/sec}}$$

$$\frac{\pi d^2}{4} = \frac{Q, \text{ cu ft/sec}}{V, \text{ ft/sec}} \quad [\text{Eq 1}]$$

$$d = \frac{4Q}{\pi V^{1/2}} \text{ feet}$$

where: Q = flow, cu ft/sec
V = velocity, ft/sec
d = pipe diameter, ft.

The maximum flow to be carried should be used to decide the proper size for the pipe. A typical flow velocity of 5 ft/sec can be used for this rough costing.

The appropriate type and diameter of pipe can be quickly costed by referring to the current Means Building Construction Cost Data or Dodge Guide to Public Works and Heavy Construction Costs.⁴

O&M costs on the pipe network are negligible.

⁴ Dodge Guide to Public Works and Heavy Construction, Annual Edition No. 12 (McGraw-Hill Information Systems Co., 1980); Building Construction Cost Data, 38th Annual Edition (Robert Snow Means Co., Inc., 1980).

Storage

Storage volume must be calculated for the period that shows the greatest difference between user demand and source supply. If this difference is going to be great for an extended time each year, it might be more economical to switch to potable water for that time rather than to store large volumes of reclaimed water. Both options should be checked.

Large volumes of reclaimed water can be stored in man-made lakes, which also can be used to provide recreation if O&M funds are available. A cheaper form of storage is an earthen or lined lagoon. Concrete tankage can be used to store smaller volumes.

Capital costs of storage lagoons can be estimated by calculating (in cubic yards) the amount of earthwork necessary, and referring to the Means or Dodge Guides. Concrete tankage costs can be estimated as the sum of earthwork needed, plus the volume of concrete slab and concrete wall, in place. These figures are also available in the Means and Dodge Guides. In addition, these references provide information about other forms of storage -- such as steel and plastic tanks and elevated storage -- if special applications require them.

O&M costs on storage are negligible.

Treatment

Treatments that can be used between activities to remove specific pollutants include ion exchange, filtration, chemical coagulation, and chlorination. Capital costs for these processes vary widely depending on the flow rate to be treated, whether a package plant will suffice, how much site preparation must be done, and many other factors. Cost algorithms presented by the U.S. Environmental Protection Agency (USEPA) for treatment works generally do not include flows less than 1 mgd (3790 m³) and cannot be extrapolated to lower ranges. A detailed description and cost analysis of the many options available to treat these types of flows is outside the scope of this work. Manufacturers should be contacted for rough cost estimates of treatment units needed for each specific application.

Estimates of labor and energy needed for operation of these treatment processes can be obtained from:

1. Estimating Staffing for Municipal Wastewater Treatment Facilities (USEPA, Office of Water Program Operations, 1973).
2. Energy Conservation in Municipal Wastewater Treatment, EPA 430/9-77-011 (USEPA, Office of Water Program Operations, March 1978).

Pumping

Pumping costs depend on both the capacity of the pump and the total head that must be developed. The head can be calculated using the energy equation which states that the head produced by the pump is proportional to the differences in pressure, velocity, and elevation between inlet and outlet, plus the frictional and other energy losses throughout the system:

$$h_p = \frac{P_2 - P_1}{\delta} + \frac{V_2^2 - V_1^2}{2g} + (Z_2 - Z_1) + h_L \quad [\text{Eq 2}]$$

where:

- h_p = head produced by pump, ft
- P_2, P_1 = pressures, lbs/sq ft
- δ = specific weight of fluid pumped = 62.4 lbs/cu ft for water at 60°F
- V_1, V_2 = velocity of fluid in pipes = Q/A
- Z_1, Z_2 = elevation, available from base map
- h_L = head losses in the system due to friction, entrances, exits, etc.
- g = gravitational constant.

Once the head that must be developed has been estimated by this method, a manufacturer can be called for a rough estimate of the capital cost. The maximum and minimum flows that the pump must handle, as well as the head it must develop, are all factors that influence the type of pump chosen.

The manufacturer can supply information about the efficiency of the specific pump recommended at the various flow rates it will handle. This information can be used to calculate power consumption using the following equation:

$$HP = \frac{Q \delta H}{550e} \quad [\text{Eq 3}]$$

where:

- HP = horsepower required
- Q = flow rate, cu ft/sec
- δ = specific weight, lbs/cu ft
- H = head produced, ft
- e = efficiency of pump

This can be converted to kWh per year:

$$\text{kWh/yr} = \left(\frac{\text{HP}}{0.75 \text{ HP/kW}} \right) \left(\frac{\text{hrs pumping}}{\text{year}} \right) \quad [\text{Eq 4}]$$


An alternative to these calculations is to use the curves presented by the USEPA for electrical consumption of raw sewage pumping. These are illustrated in Figures 9 through 11.⁵ An estimate of maintenance hours required can be extrapolated from Figure 12.

Total Costs

The capital costs and O&M costs should be totaled for the whole network. The total yearly cost can be found by dividing the capital costs, including interest of the components, by their expected lifetimes to get dollars per year, and adding that to the annual O&M cost.

This total yearly cost can be compared to the annual water and sewage dollar savings of the reuse network. Networks that have a total yearly cost equal to or less than the yearly savings anticipated should be pursued under Stage 3 of the model, as described in Chapter 5.

⁵ These figures are from Energy Conservation in Municipal Wastewater Treatment, EPA 430/9-77-011 (USEPA, Office of Water Program Operations, March 1978).




RAW SEWAGE PUMPING (CONSTANT SPEED)

Design Assumptions:

- Efficiencies for typical centrifugal pumps (varies with flow)
- Variable level wet well
- TDH is total dynamic head

Type of Energy Required: Electrical

Figure 9. Raw sewage pumping (constant speed).
(From Energy Conservation in Municipal Wastewater Treatment, EPA 430/9-77-011 [USEPA, Office of Water Program Operation, March 1978].)



RAW SEWAGE PUMPING (VARIABLE SPEED)


(Curve 1 of 2)

Design Assumptions:

- Efficiencies for typical centrifugal pumps (varies with flow)
- Wound Rotor variable speed
- Variable level wet well

Type of Energy Required: Electrical

Figure 10. Raw sewage pumping (variable speed, curve 1).
(From Energy Conservation in Municipal Wastewater
Treatment, EPA 430/97-77-011 [USEPA, Office of Water
Program Operations, March 1978].)



RAW SEWAGE PUMPING (VARIABLE SPEED)

(Curve 2 of 2)

Design Assumptions:

- Efficiencies for typical centrifugal pumps (varies with flow)
- Wound rotor variable speed
- Variable level wet well

Type of Energy Required: Electrical

Figure 11. Raw sewage pumping (variable speed, curve 2).
(From Energy Conservation in Municipal Wastewater Treatment, EPA 430/97-77-011 [USEPA, Office of Water Program Operations, March 1978].)




Figure 12. Curve for estimating maintenance hours.
(From Estimating Staffing for Municipal
Wastewater Treatment Facilities [USEPA,
Office of Water Program Operations, 1973].)

5 STAGE 3: WASTEWATER SURVEYS

So that the output from the computer system (Chapter 6) can be used as a basis for preliminary design, actual water quality and flow data must be input for each activity under consideration. Therefore, a wastewater survey must be done on post -- unless data are available from very recent and very complete testing. Because of the great expense of this type of testing, Stage 3 analysis should be done only for the most promising networks.

Detailed descriptions of wastewater surveying protocols are available in the professional literature.⁶

The following general survey tasks are completed during an in-depth base visit (20 to 30 man-days):

1. Interviews with base personnel to expand Stage 2 data.
2. Composite and grab sampling of all activities without good existing data. This, along with interviews, should yield complete activity descriptions.
3. Survey of the base for location of possible new treatment, storage, or pumping facilities, and best location for reclaimed water pipelines.

⁶ An excellent reference on this subject is Modern Pollution Control Technology, Volume 2 (Water Pollution Control and Solid Waste Disposal Research and Education Association, 1978). Chapter 1 of this publication contains sampling and flow measuring data.

6 THE COMPUTER SYSTEM

After the wastewater survey has been completed, a computer program can be used to compare reuse networks. The program is divided into two separate phases. Output from Phase I (Activity Description) is intended to help the evaluator select feasible activity cascade networks from those that remain after Stage 2 analysis. Phase I assimilates installation activity data supplied by the user and prints out several forms for each activity showing flow patterns, effluent quality after various levels of treatment, the effects of recommended pretreatment units, and cascade potential.

Phase II (Network Feasibility) evaluates the networks selected. Output provides a comprehensive network description including the requirements for piping, pumping, storage, and treatment facilities, and finally the total cost of the entire cascade system. Continued modification of the most cost-effective cascade networks should lead to an optimum reuse system for an installation.

Use of the computer program requires the following tasks:

1. Complete all input data for the computer program (Phase I).
2. Run Phase I of the computer program.
3. Complete conceptual networks and other Phase II computer program input.
4. Run Phase II of the computer program.
5. Complete evaluation and make conclusions and recommendations.

The computer program is not to be used for final design and costing, but rather as a tool to efficiently compare the overall estimated costs of selected reuse schemes. The computer program is based on work performed by SCS Engineers for the Air Force.⁷

The computer system does not require the services of a programmer, but it does require an environmental engineer to evaluate interim computer output and to make decisions as to appropriate reuse networks for testing. The engineer must also evaluate final cost figures, adjust for existing equipment, and make other engineering judgments. The computer program does not provide accurate cost data; rather it is a means of comparing various networks.

All program documentation can be found in the users' manual published by SCS Engineers.⁸ This reference includes a complete description of and layout for the Stage 3 computer program data and a copy of the reuse computer program.

⁷ SCS Engineers, Cascade System for Water Reuse at Air Force Installations, CEEDO-TR-77-19 (U.S. Air Force, October 1976).

⁸ Curtis J. Schmidt, Ernest V. Clements, and Leanne Hammer, Subpotable Water Reuse at Army Fixed Installations: A Systems Approach, Volume II (SCS Engineers, August 1979).

The computer model requires input from the evaluator in two areas. Initially, activity data as well as treatment efficiencies must be provided for all treatment processes to be considered. After the first phase of the program is complete, the evaluator must input various reuse systems that he/she wishes to test. The evaluator must have access to a computer that can accept the program's language and that has enough memory storage. The program is written in American Standard Fortran IV, and was originally tested on a CDC 6500 computer. The program is large and requires about 260,000 bytes of computer core.

7 CONCLUSION

The wastewater reuse model component will allow the Army (1) to assess quickly an installation's potential for water reuse and (2) to identify the most cost-effective reuse networks for an installation.

REFERENCES

- Analysis of Water System, U.S. Army WSMR, New Mexico (prepared by Higginbotham and Associates, and Gilbert, Meyer, & Sams, both of Colorado Springs, CO, August 1979).
- Annual Water-Resources Review (U.S. Department of the Interior Geological Survey, open file 79-985, 1978).
- Building Construction Cost Data, 38th Annual Edition (Robert Snow Means Co., Inc., 1980).
- Dodge Guide to Public Works and Heavy Construction, Annual Edition No. 12 (McGraw-Hill Information Systems Co., 1980).
- Eckenfelder, W. W., Principles of Water Quality Management (CBI Publishing Co., 1980), p 11.
- Energy Conservation in Municipal Wastewater Treatment, EPA 430/9-77-011 (USEPA, Office of Water Program Operations, March 1978).
- Environmental Protection and Enhancement, Army Regulation (AR) 200-1 (Headquarters [HQ], Department of the Army [DA], 20 January 1980).
- Estimating Staffing for Municipal Wastewater Treatment Facilities (USEPA, Office of Water Program Operations, 1973).
- Everest, William R., and Robert A. Paul, "Reclaimed Wastewater as a Feasible Water Resource for Landscape and Orchard Irrigation," in Water Reuse Symposium Proceedings, Vol III (AWWA Research Foundation, March 1979), pp 2098-2099.
- Innovative and Alternative Technology Assessment Manual, EPA 430/9-78-009 (USEPA Office of Water Programs Operation, 1978).
- Installation Environmental Impact Assessment (DA, USAWSMR, March 1976, revised May 1978).
- Modern Pollution Control Technology, Volume 2 (Water Pollution Control and Solid Waste Disposal Research and Education Association, 1978).
- Municipal Wastewater Reuse News, American Water Works Association (AWWA) Research Foundation, No. 29 (February 1980), p 13.
- New Mexico Water Quality Act (Chapter 326, Laws of 1973, as amended).
- Restoration and Repair of Nine-Hole Golf Course, Document #W5 50-79 (Facilities Engineering Directorate, WSMR, February 1979).
- SCS Engineers, Cascade System for Water Reuse at Air Force Installations, CEEDO-TR-77-19 (U.S. Air Force, October 1976).

Schmidt, Curtis J., Ernest V. Clements, and Leanne Hammer, Subpotable Water Reuse at Army Fixed Installations: A Systems Approach, Volume II, (SCS Engineers, August 1979).

Schmidt, Curtis J., Ernest V. Clements III, and Stephen P. Shelton, "A Survey of Practices and Regulations for Reuse of Water by Groundwater Recharge," AWWA Journal (JAWWA) (March 1978), p 146.

Todd, David Keith, ed., The Water Encyclopedia (Port Washington, NY: Water Information Center, 1970).

Wastewater System Analysis, U.S. Army WSMR (prepared by Higginbotham & Associates, and Gilbert, Meyer, and Sams, both of Colorado Springs, CO, August 1979).

Water Resources Development, Analytical Report (AR) 210-20 (Director of Facilities Engineering, WSMR, December 1978).

Webster, R. D., E. D. Smith, and V. Kothandaraman, Pollution Abatement Management System -- Concept Definition, Technical Report N-42/ADA055565 (U.S. Army Construction Engineering Research Laboratory [CERL], May 1978).

APPENDIX A:

WHITE SANDS MISSILE RANGE FIELD TEST

Stage 1, Part 1

In February 1980, White Sands Missile Range (WSMR) was initially considered as a possible site to field test the wastewater reuse model. AEHA Regional Division North determined through preliminary telephone conversations with WSMR environmental personnel that the groundwater supply was being withdrawn at a faster rate than it was recharging, and that a large volume of water was being used for landscape irrigation. In March 1980, the site was visited by personnel from CERL, AEHA-Aberdeen, and AEHA-North. For information about WSMR, the reuse team had to rely on published reports, and on conversations with the personnel involved in various activities. The following references were used; these gave detailed information on the water supply, water and wastewater treatment plants, environmental factors, energy costs of water production, and the golf course.

1. Annual Water-Resources Review (U.S. Department of the Interior Geological Survey, open file 78-985, 1978).
2. Water Resources Development, Analytical Report (AR) 210-20 (Director of Facilities Engineering, WSMR, December 1978).
3. Analysis of Water System, U.S. Army WSMR, New Mexico (prepared by Higginbotham and Associates, and Gilbert, Meyer, & Sams, both of Colorado Springs, CO, August 1979).
4. Wastewater System Analysis, U.S. Army WSMR (prepared by Higginbotham & Associates, and Gilbert, Meyer, and Sams, both of Colorado Springs, CO, August 1979).
5. Restoration and Repair of Nine-Hole Golf Course, Document #WS-50-79 (Facilities Engineering Directorate, WSMR, February 1979).
6. Installation Environmental Impact Assessment (DA, USAWSMR, March 1976, revised May 1978).

The information for Stage 1 comes from these references, except where noted.

1. Water Supply and Treatment

The base's water supply is being mined from an aquifer 400 ft (122 m) below the surface. The aquifer is potable to a depth of 2500 ft (762 m) at the west boundary of the post, the Organ Mountain Range. It decreases in thickness as it extends to the east; 4 mi (6.4 km) east of the post area, the aquifer becomes totally saline alluvial fill (Figure A1).

The estimated lifetime of the potable aquifer is 25 to 100 years. Natural recharge of the potable aquifer has been estimated at 825 acre-feet (10^6 m^3) per year. This is about one third of the current annual withdrawal.




Figure A1. Cross section through well field.
(From Water Resource Development,
Analytical Report [AR] 210-20
[Director of Facilities Engineering,
WSMR, December 1978].)

The lifetime of the aquifer can be extended if the water is mined evenly instead of from one area; this will lessen saltwater intrusion due to excessive drawdown in one small portion of the aquifer. Adjacent watersheds also have potential for development; this would contribute to lengthening the life of the current supply.

Routine testing of the water supply is not done at the WTP; however, the quality of both the potable water and the water supply is well documented by special studies performed because of continuing concern over the future availability of usable water (Table A1). Average monthly usage is 3.3 mgd (12 500 m³) with a peak usage in June and July of 4.9 mgd (18 600 m³). Monthly and yearly pumpage from the 11 wells north of the post from 1964 through 1978 is presented in Figure A2. These bar graphs show that 70 percent of the total annual usage occurs between April and August. This consumption pattern is due mainly to heavy irrigation demands during the summer months.

Since the water supply is of such good quality, sedimentation followed by chlorination is the only treatment provided. From the WTP, the water is pumped to two 400,000 gal (1.52 x 10⁶ L) ground-level storage tanks. Additional storage is provided by two 1 MG (3.79 x 10⁶ L) and one 0.2 MG (758 000 L) elevated storage tanks (see Figure A3).

Costs of water production are currently \$1.17/1000 gal (\$0.31/1000 L); most of this amount is spent for electricity to pump the groundwater from an average depth of 450 ft (137 m). Capital and administrative costs are not included in this figure.

No expansion or upgrading of the water supply system is planned. The sedimentation process at the plant has a capacity of 6000 gpm (22 740 L/min). This is well above the 4.9 mgd (18 600 m³) peak demand. In 1974, water conservation measures were enforced to reduce peak electrical demand: no landscape irrigation is permitted between 10 a.m. and 4 p.m. Monday through Friday. This restriction extends to the golf course. In addition, a computer-controlled sprinkler system was installed at the golf course to allow control and measurement of the water usage. As a result of these measures, annual water usage for 1977 was the lowest since 1963, while the population on the post remained fairly constant (about 4600).

There are no plans that would cause WSMR's mission, activities, or effective population to change greatly in the future. However, since the major cost of the water supply is pumping, future costs are sure to increase as electrical costs rise, and as water must be drawn from greater depths.

2. Wastewater

The wastewater treatment facility servicing the Main Post area is a trickling filter plant 1.5 mi (2.4 km) southeast of Post Headquarters (HQ). This facility was built in 1958 with a design capacity of 1 mgd (3790 m³). The process train is presented in Figure A4. The wastewater flows by gravity through the plant to an open channel where it percolates into the soil mantle.

The plant does not have an NPDES permit due to the conditions to which it discharges. No particular discharge quality has been specified by either the New Mexico EPA or the USEPA. The performance of the plant is very good. It

Table A1

Chemical Analyses of Composite Samples of Post Water Supply
 (From Water Resources Development, Analytical Report
 [AR] 210-20 (Director of Facilities Engineering WSMR.
 December 1978.)

<u>Date of Collection</u>		(ppm) <u>Jul 1955</u>	(ppm) <u>Jul 1964*</u>	(ppm) <u>Aug 1976**</u>
Silica	(SiO ₂)	40.	41.	28.1
Iron	(Fe)	0.04	0.04	0.06
Manganese	(Mn)	-	-	0.02
Calcium	(Ca)	35.	35.	39.3
Magnesium	(Mg)	9.1	7.5	7.6
Sodium	(Na)	21.	29.	28.7
Potassium	(K)			2.4
Bicarbonate	(HCO ₃)	128.	130.	-
Carbonate	(CO ₃)	0	0	-
Sulfate	(SO ₄)	44.	50.	65
Chloride	(Cl)	10.	11.	19.7
Fluoride	(F)	0.4	0.4	0.4
Nitrate	(NO ₃)	3.3	3.2	1.35 ⁺
Dissolved Solids, Calculated		225.	241.	264.
Hardness as CaCO ₃		121.	115.	134.
Noncarbonate hardness, CaCO ₃		15.	15.	-
Alkalinity as CaCO ₃		-	106.	106.
Specific Conductance (micromhos at 25°C)		330.	358.	430.
pH		7.5	7.4	7.93

*Analyses by USGS, Water Resources Division, Albuquerque, NM.

**Analysis by AEHA, Fitzsimmons Army Medical Center, Denver, CO.

⁺Nitrates, as nitrogen.




Figure A2. Monthly and yearly pumpage in the post headquarters well field. (From Annual Water-Resources Review [U.S. Department of the Interior Geological Survey, open file 78-985, 1978].)




Figure A3. WSMR facilities.




Figure A4. WSMR wastewater treatment plant. (From Wastewater System Analysis, U.S. Army, WSMR [prepared by Higgenbotham & Associates, and Gilbert, Meyer, and Sams, both of Colorado Springs, CO., August 1979].)

averages 85 percent BOD removal; the mean effluent quality is 20 mg/L BOD. A mean solids removal of 90 percent provides an average effluent quality of 12.6 mg/L SS. Nitrogen compounds are not measured.

The average flow through the plant is about 0.58 mgd (2200 m³). The range of average daily flows and their mean for the period 1971-1978 are shown in Figure A5.

Expanding or upgrading the plant, discharging to a regional sewage system, and accepting wastewater from surrounding communities are not planned.

There is no industrial waste treatment plant on post; however, there are a number of laboratories and operations that discharge industrial-type wastes to the trickling filter system. A description of these facilities and their wastes is presented in Stage 1, Part 2 (p 60). According to one report, "Normal operations of these technical activities do not pose a serious threat to reasonable performance of the treatment works. Accidental discharge of large quantities of a variety of chemicals could cause complete plant upset and failure; however, it appears that adequate housekeeping, training, and professional conduct on the part of the staff has served to minimize this potential."⁶

3. Institutional Factors

No laws or agreements regulate withdrawal of groundwater or volume of wastewater discharge.

Internal recycle is being practiced at the large photo lab. This will be described in greater detail in Stage 1, Part 2.

The base commander is interested in using reclaimed water if it will lead to a reduction in energy consumption.

4. Environmental Factors

The average monthly precipitation* in Albuquerque, NM (200 mi [320 km] north of WSMR main post area) is as follows:

J	F	M	A	M	J	J	A	S	O	N	D
0.4	0.4	0.5	0.5	0.8	0.6	1.2	1.3	1.0	0.8	0.4	0.5
(10.2)	(10.2)	(12.7)	(12.7)	(20.3)	(15.2)	(30.5)	(33)	(25.4)	(20.3)	(10.2)	(12.7)

The values are in inches (millimeters) and are based on 30 years of records.

The average monthly reservoir evaporation in Roswell, NM (100 mi [160 km] east of WSMR), computed in inches (millimeters), is:

⁶ Wastewater System Analysis, U.S. Army WSMR (prepared by Higginbotham & Associates, and Gilbert, Meyer, and Sams, both of Colorado Springs, CO, August 1979).

* Precipitation and evaporation data were taken from David Keith Todd, ed., The Water Encyclopedia (Port Washington, NY: Water Information Center, 1970).




Figure A5. Comparison of mean/average daily flows (from Wastewater System Analysis, U.S. WSMR [prepared by Higginbotham & Associates, and Gilbert, Meyer, and Sams, both of Colorado Springs, CO, August 1979].)

J	F	M	A	M	J	J	A	S	O	N	D
2.1	3.2	4.9	6.8	8.3	9.8	9.4	8.3	6.9	5.5	3.5	2.5
(53.3)	(81.3)	(124.5)	(172.7)	(210.8)	(248.9)	(238.8)	(210.8)	(175.3)	(139.7)	(88.9)	(63.5)

The State of New Mexico has groundwater protection regulations that provide standards for irrigation water.¹⁰

8. Energy

WSMR is a U.S. Army Test and Evaluation Command (TECOM) installation; breakdowns of water and sewage treatment costs were not available. An experiment done 25 June 1975 showed that the WSMR facility used 1500 kVA over an 8-hour period to produce and store 5.34 MG (20.2 ML) of potable water (Figure A6).¹¹

El Paso Electric Company provided the WSMR conversion factor between kVA and kW. Electricity needed for water production was calculated as:

$$[(1500 \text{ kVA})(0.998 \text{ kW/kVA})(8 \text{ hours})]/5.34 \text{ MG} \\ = 2.243 \text{ kWh/1000 gal (0.59 kWh/1000 L)}$$

As water must be pumped from greater and greater depths, electricity usage will increase. Electricity is not produced on post, and there are no plans to do so.

WSMR has taken steps to cut electricity costs without cutting overall usage by reducing use during peak hours (8 a.m. to 4 p.m.). No lawn sprinkling is allowed, the golf course is watered at night, and the wells and the central booster pump at the WTP are not operated between these hours.

Data Analysis

The present aquifer will be adequate in the near future, and other watersheds are available for development. However, the available supplies, while containing enough water, are all expensive to produce due to their depth.


The WTP, STP, and well field are operated at about half of their capacities. The effective population of the post is not expected to change. Therefore, barring failure, no new supply or treatment works will be necessary.

A literature search was done to identify tolerable water quality for landscape irrigation (see Table A2). The STP effluent will have to be better characterized than it is presently; however, it meets even the most stringent BOD and SS requirements. Obviously, chlorination will be necessary.

The volume of wastewater is low; it averages 0.58 mgd (2200 m³) and shows very little seasonal fluctuation. Water is supplied to the post at an average rate of 1 mgd (3790 m³) from October through March and 2.9 mgd from April through September. Therefore, 58 percent of the potable water produced is

¹⁰New Mexico Water Quality Act (Chapter 326, Laws of 1973, as amended).

¹¹Water Resources Development, Analytical Report (AR) 210-20 (Director of Facilities Engineering, WSMR, December 1978).



HOURLY kVA DEMAND: PEAK--10,805; HOUR--1100

LOCATION: POST AREA

DATE: 25 JUNE 1975, WEDNESDAY

Figure A6. Hourly kVA demand.

Table A2
Tolerable Water Quality According
to Various References

Constituent	Tolerable Concentration, mg/L, by Source, for Irrigation						
	(Numbered headings refer to references listed following table.)						
	1	2	3	4	5	6	7
BOD ₅	30	--	--	20	--	30	--
COD	60	--	--	--	--	--	--
TOC	--	--	--	--	--	--	--
phenols	0.5	--	--	50	--	0.5	--
SS	50	--	--	15	--	15	--
TDS	2000	--	500	--	1600	750	500
O and G	30	--	--	nil	--	10	--
Cl	350	--	100	100-200	200	175	250
NO ₃	10	--	--	--	--	30	--
NH ₄	20	--	--	--	--	--	--
PO ₄	N.S.	--	--	--	--	--	--
Na	350	--	--	--	--	--	--
Ca	--	--	--	--	--	--	--
CaCO ₃	N.S.	--	--	--	--	--	--
B	3.0	--	0.5	--	0.75	1.5	--
CN	0.01	--	--	--	--	.1	--
Fe	10	5.0	--	5.0	5.0	--	--
pH	4.5-9.0	4.5-9.0	7-8.5	6-9	--	--	--
Coliform	23/100 ml	--	1000/100 ml	2.2/100 ml	--	200/100 ml	--
Al	--	5.0	--	5.0	5.0	--	--
Cd	--	0.01	--	0.01	0.01	--	--
Cr	--	0.1	--	0.1	0.1	0.005	--
Co	--	0.05	--	0.05	0.05	--	--
Cu	--	0.2	0.1	0.2	0.2	.2	--
Pb	--	5.0	--	5.0	5.0	--	--
Zn	--	2.0	--	2.0	2.0	.3	--
SAR	--	--	6.0	8-18	6-8	--	--
umhos/cm	--	--	750	--	2500	--	--
RSC*	--	--	1.25	--	--	--	--
As	--	--	1.0	0.1	0.1	0.01	--
SO ₄ ⁻²	--	--	200	200-400	--	250	250
F	--	--	--	2.0	1.0	--	--
Li	--	--	--	2.5	.075	--	--
Mn	--	--	--	0.2	0.2	--	--
Mo	--	--	--	0.01	0.01	--	--
Ni	--	--	--	0.2	0.2	0.1	--
Se	--	--	--	0.02	0.02	--	--
V	--	--	--	0.1	0.1	--	--
Be	--	--	--	--	0.1	--	--

*Residual sodium carbonate

Table A2 (Cont'd)

References

1. Curtis J. Schmidt, Ernest V. Clements, Leanne Hammer, Subpotable Water Reuse at Army Fixed Installations: A Systems Approach, Volume I, ADA075159 (SCS Engineers, supported by U.S. Army Medical Research and Development Command, August 1979).
2. W. W. Eckenfelder, Principles of Water Quality Management (CBI Publishing Co., 1980), p 11.
3. David K. Todd, ed., The Water Encyclopedia, Sec. E, "Irrigation Quality," (Port Washington, NY: Water Information Center, 1970), pp 331-4.
4. Municipal Wastewater Reuse News, American Water Works Association (AWWA) Research Foundation, No. 29 (February 1980), p 13.
5. William R. Everest and Robert A Paul, "Reclaimed Wastewater as a Feasible Water Resource for Landscape and Orchard Irrigation," in Water Reuse Symposium Proceedings, Vol III (AWWA Research Foundation, March 1979), pp 2098-2099.
6. California Regional Water Quality Control Board Standards, from Curtis J. Schmidt, Ernest V. Clements III, and Stephen P. Shelton, "A Survey of Practices and Regulations for Reuse of Water by Groundwater Recharge," AWWA Journal (JAWWA) (March 1978), p 145.
7. California State Health Department Standards, in Schmidt, et al., "Survey," p 146.

returned as sewage from October through March; only 20 percent is returned from April through September. These figures reflect the tremendous volumes of water being used for irrigation in the spring and summer.

High consumptive use of expensive water is the main reason to proceed to Part 2 of Stage 1.

Stage 1, Part 2

The following information was obtained by interviews with base personnel. See Figure A3 for the location of activities.

Bus Washrack

WSMR has 37 buses, but only 17 are in constant use for the commuter runs to El Paso. These 17 are washed once every 2 weeks on the average, depending on the weather. The other 20 buses are rarely washed. The post motor pool could not estimate the amount of water use.

Information obtained at Fort Campbell indicates that it takes 450 gal (1706 L) of water when a troop carrier helicopter is washed, inside and out with a garden hose. Obviously, this equipment is not comparable to the bus washrack at WSMR, which has spray nozzles on three sides. (Flow estimation with a bucket and stopwatch was not possible on this apparatus due to its structure.) But the amount of water needed to wash a bus and a helicopter should be roughly comparable. Using a conservative estimate of 1000 gal (3790 L) to wash one bus (more than twice that needed for one helicopter), WSMR could save 17,000 gal (64 430 L) every 2 weeks. At \$1.17 for 1000 gal (\$0.31/1000 L), the savings would amount to \$20 every 2 weeks, or \$500 a year. For this reason, and because of the washrack's isolated location, it was discounted as either a source or sink of reclaimed water.

Boiler Plant in Tech Area

Building 1544 contains three small boilers that produce steam to provide heat and hot water for eight or nine buildings in the tech area. There is no operator for this very small facility. The plant capacity is 15×10^6 Btu. According to Utilities personnel, blowdown is not constant. When solids increase to a predetermined level, the boilers are completely dumped and refilled. This occurs about once a month. Personnel did not know the capacity of the boilers.

The only water-using activity near the boiler plant is the photo processing facility. Both the boiler plant and the photographic laboratories need an extremely high-quality influent, and both produce a highly contaminated effluent. There are no irrigated areas near either facility. For these reasons, and because of the extremely erratic nature of the effluent flow, the boiler plant will not be considered in any reuse networks.

Photographic Facilities

Photographic processing is a major technical activity, performed mostly in Buildings 1512 and 1621. The motion-picture processing laboratories in Building 1512 produce both color and black and white finished film work. Maximum production runs may last as long as 8 hours per day, with one of the seven processing machines having been operated for 16 hours per day in the past. All processing machines have continuous wash water discharges. When all machines are operating simultaneously, it is possible that a maximum discharge rate of 400 gpm (1516 L/min) could occur.

A complete still photofinishing laboratory is in Building 1621, and can use five different photofinishing processes, three of which are automated. Peak production runs in this facility may reach 6 hours per day, though not on a daily basis. A total wash water flow rate of approximately 50 gpm (190 L/min) may occur.¹²

Personnel at the laboratory in Building 1512 reported that it is extremely rare for all processes to run simultaneously and that actual water usage is a fraction of values cited above and highly variable. Film is processed from 3 p.m. to midnight. Water usage data are not available; however, a log of the processes run versus time is kept, and water usage can be calculated from this.

Tap water filtered to 40 μ m is used for all processes. Hardness must be added to the process water to avoid emulsion problems. Water conservation measures have been instituted at the facility. All developing solutions are reused throughout a shift, being continually refreshed when the concentration of developer falls beneath a certain level. A Kodak cascade process for reuse of rinse waters was installed in 1977. But at intervals, emulsion swelling occurred that could be attributed to nothing other than the cascade process; use of the system was discontinued in 1979. Ferricyanide bleaches are held and not discharged with the process effluents. There is some retention of cyanide in the washwater; however, the concentration is extremely small and not cause for concern in the waste treatment process. The silver is recovered by an electrolysis process and returned to a central reclamation facility in New Jersey.¹³

Golf Course

The golf course must be irrigated 4 months per year. 350,000 gpd (1300 m³) are used every other day to water the whole course; 40,000 gpd (151 000 L/day) are used on the off-days to water greens and tees during July and August. During May and June, the whole course is watered every day. Water savings would amount to 34 MG (129 ML) a year or \$39,000 a year. The maximum rate of use is 750 gpm (2843 L/min). The course is 3.5 mi (5.6 km) from the STP and 225 ft (69 m) above it.

¹²Wastewater System Analysis, U.S. Army WSMR (prepared by Higginbotham & Associates, and Gilbert, Meyer, and Sams, both of Colorado Springs, CO, August 1979).

¹³Wastewater System Analysis, U.S. Army WSMR (prepared by Higginbotham & Associates, and Gilbert, Meyer, and Sams, both of Colorado Springs, CO, August 1979).

The course superintendent said that the soil does not have a high clay content and displays adequate percolation rates. On the other hand, the greens were specially built with sludge and Milorganite (Milwaukee's processed sludge) and percolate very little. The superintendent emphasized that the course needs soil tests and groundwater tests for existing quality.

An underground irrigation system and pump already exist. Application is controlled by a computer. The whole course is watered in 8 hours during the night to reduce peak electrical demand, and to avoid lowering the pressure in the family housing area, which is served by the same line.

Stage 2, Data Analysis

Only two activities are potential users of large volumes of reclaimed water: the photo lab and the golf course. The photo lab's needs are not as well defined and they vary from day to day as different processes are used. In addition, photoprocessing requires extremely high-quality water. Therefore, the photo lab may have potential for internal recycling.

Only one source of reclaimed water exists that is large, reliable, and fairly clean: the STP effluent. Electrical costs for pumping would be a large percentage of the total operating costs for a reuse network that provides STP effluent for golf course irrigation: the STP is 3.5 mi (5.6 km) east of and 225 ft (69 m) lower than the golf course. The potable water supply currently serving the course also requires a great deal of pumping: it is drawn from an average depth of 450 ft (137 m) through treatment and about 1 mi (1.6 km) of pipe to elevated storage 100 ft (30.5 m) above the ground. It is not obvious which system will have higher costs.

In addition, water can be provided not only to the golf course, but also to several areas along the pipeline that are not currently irrigated -- such as the teenclub ball fields, just north of the golf course, and the driving range at the course.

A schematic of the network is shown in Figure A7. To grow grass in New Mexico, 6.2 in. (157.5 mm) of water per month is needed.¹⁴ This is equivalent to 0.2 in./day (5 mm/day). The volumes of water needed to irrigate areas other than the golf course have been calculated using this value.

The water savings at the golf course are:

$(350,000 \text{ gpd})(92 \text{ days} \text{ -- May, June, half of July, August}) + (40,000 \text{ gpd}) \times (31 \text{ days} \text{ -- half of July, August}) =$

$34 \times 10^6 \text{ gal per year potable water saved.}$

$(34 \times 10^6 \text{ gal } [128.9 \times 10^6 \text{ L}] \text{ per year}) (\$1.17 \text{ for } 1000 \text{ gal}) = \$39,000 \text{ per year}$

¹⁴David Keith Todd, ed., The Water Encyclopedia (Port Washington, NY: Water Information Center, 1970).




Figure A7. Schematic of reuse network.

The additional benefit of 9.4×10^6 gal (35.6×10^6 L) per year results from this reuse scheme for irrigating other areas. Since these areas are not currently watered, no dollar savings result. No savings in sewage treatment would occur.

The physical facilities required to implement this network must be more thoroughly defined before rough costing can be done. Since the pipe and pump sizes needed vary proportionately with the flow rate, the most economical way to build the system is to pump at a constant rate throughout the day. A total volume of 426,200 gpd (1.6×10^6 L/day) is needed for all areas to be irrigated. Storage of 500,000 gal (1.9×10^6 L/day) capacity will be provided in a lined earthen lagoon. The surface area of this lagoon should be minimized to reduce evaporation and algal growths. Design values of 10 ft (3 m) deep, 6700 sq ft (622 m²) surface will be used. This lagoon can be built to provide a water hazard on the golf course if space is available. The maximum evaporation rate, experienced in June, is 9.8 in. (250 mm) per month. This is equivalent to 0.32 in. per day (.8 mm). Therefore, the maximum rate of evaporation from this lagoon would be about 1400 gpd (5306 L/day).

Assuming no other losses in the system, about 428,000 gpd (1.6×10^6 L/day) should be pumped to storage. This represents virtually all of the STP effluent available during the summer months (approximately 450,000 gpd [1.7×10^6 L/day]).

A constant volume will not be available at the STP, and the system must be sized to carry the peak flow coming from the STP or flow equalization must be built. Data on diurnal variations are not available from WSMR.

Pipe Costs

The pipe size needed to carry this flow is given by:

$$d^2 = \frac{4(1.0 \text{ cu ft/sec})}{\pi(5 \text{ ft/sec})}$$
$$d = 0.51 \text{ ft} = 6.12 \text{ in. (0.16 m)}$$

Since piping is widely available in even diameters only, 8-in. (203-mm) pipe is needed: 200-psi asbestos cement pipe costs \$9.43 per linear foot including the contractor's overhead and profit. PVC class 160 SDR-26 costs \$8.60 per linear foot. PVC class 150 SDR-18 costs \$12.20 per linear foot.¹⁵

Asbestos cement pipe is commonly used for this type of application. Total costs for such pipe would be.

$$(5280 \text{ ft/mi})(3.5 \text{ mi})(\$9.43/\text{ft}) = \$174,266$$

This does not include any valves that might be necessary. The pipeline can probably be placed on top of the ground over the open desert, very little excavation will be necessary.

Storage

A 10-ft-deep (3-m), 6670-sq-ft (622-m²) lagoon will provide 1.5 ft (0.45 m) of sidewall above the water surface when the lagoon is full. This should be adequate. Approximately 2500 cu yd (1911 m³) of earthwork are needed, this can be done with a crawler-mounted hydraulic backhoe.

A hoe with 3.5 cu yd (2.7 m³) capacity can remove about 150 cu yd/hr (115 m³) at a cost of \$1.16/cu yd (\$1.52/m³). The earth can be dumped in the desert south of the course. A 20-cu-yd (15.3-m³) dump trailer can haul 2.5 loads per hour over a 1-mi (1.6-km) round trip; three trailers, at an average cost of \$1.04/cu yd (\$1.36/m³) per trailer, would be needed to keep up with the hoe. Therefore, total costs for digging the lagoon are about \$5500. The lagoon must be lined to prevent percolation of the stored water. A 1/16-in.-thick (1.6-mm), nylon-reinforced neoprene sheet costs \$1.80/sq ft (\$19.38/m²). Lining the whole lagoon would cost about \$18,000. Lining just the bottom and 1 ft (0.3 m) up on the sides would cost about \$13,000.¹⁶

Total storage costs for a fully lined lagoon would be about \$23,500.

Treatment

At a minimum, chlorination will have to be provided. This can be put in at the STP and used all year, or just during the irrigation season.

¹⁵Figures are from Building Construction Cost Data, 38th Annual Edition (Robert Snow Means Co., Inc., 1980).

¹⁶Figures are from Building Construction Cost Data, 38th Annual Edition (Robert Snow Means Co., Inc., 1980).

Construction costs for a 0.5-mgd (1900 m³) chlorination system are \$35,000.¹⁷ Also necessary are 15,000 kWh/yr, 400 hours of labor for operation and maintenance, and 22 tons (20,000 kg) of chlorine per year.¹⁸ If the system is only used 4 months per year, the figures are reduced to 5000 kWh, 133 hours of labor, and 7 tons (6364 kg) of chlorine.

Pumping

At this point, there is not enough data on hourly flows at the STP outfall to allow a pumping system to be designed. However, the friction losses throughout the pipe network can be estimated, which will lead to an estimate of the power required.

The head loss due to friction in a pipe flowing full is expressed by:

$$h_L = (f) \left(\frac{L}{D} \right) \left(\frac{V^2}{2g} \right)$$

where: h_L = frictional head loss, feet

f = friction factor

L = length of pipe, feet

D = diameter of pipe, feet

V = velocity in pipe, feet/sec

g = gravitational constant = 3.2 ft/sec².

Assume flow equalization is built at the STP outfall, so a constant pumping rate can be maintained. An equalization basin could perhaps double as part of the chlorination system. Pumping would be done from 4 p.m. to 8 a.m. only. The pumping rate required would be 26,625 gph (100 000 L/hr). The velocity of this flow in an 8-in. (203-mm) pipe is 2.9 ft/sec (0.88 m/sec).

The friction factor varies with the flow velocity, the diameter, material and condition of the pipe and the viscosity of the reclaimed water, but can be approximated at 0.02. Minor losses, such as those on entrance and exit, are insignificant compared to the frictional losses ($L > 1000 D$). The frictional head loss calculated using the values above is 72 ft (22 m).

The energy equation can now be used to determine the total head that must be developed by the pumping system (see Figure A8). The pressure at points 1 and 2 in Figure A8 is atmospheric, and the velocities are essentially zero. Therefore, these items can be ignored and the equation reduces to:

¹⁷Figures are from Building Construction Cost Data, 38th Annual Edition (Robert Snow Means Co., Inc., 1980).

¹⁸Innovative and Alternative Technology Assessment Manual, EPA 430/9-78-009 (USEPA Office of Water Program Operations, 1978).




Figure A8. Total head developed by pumping system.

$$h_p = h_L + (Z_2 - Z_1)$$

$$h_p = 297\text{ ft (90.5 m)}$$

where h_p is the head that the pump must produce. Assuming pump efficiency is 60 percent, and that the flow is fairly constant, 56 horsepower (HP) is needed. The system would be running 16 hours per day for 93 days a year, and about 2 hours per day for 31 days a year. This is 1550 hours of operation per year. The annual kilowatt-hour requirement would be approximately 65,000. Using wind power to pump this flow is an alternative to consider.

The existing booster pump at the golf course pumps from elevated storage and is not powerful enough to deliver water at the desired pressure and rate from ground-level storage. The golf course superintendent prefers that the pump not be used in the reclaimed water system at any rate, so that he still has the option of switching to potable water if problems with the reclaimed system arise. The extra power that would be needed due to the 100 ft (30.5 m) loss of head to supply reclaimed irrigation water at a maximum rate of 750 gpm (2843 L/mm) is 32 HP.

The total power needed is 72 HP, assuming the existing pump was sized correctly to provide 40 HP. The whole course is watered in 8 hours; the greens only are watered in 1 hour. The total use is 775 hours for the season, and the electrical usage would be 42,000 kWh/yr. Total electrical use of the reclaimed water system would be 107,000 kWh/yr, of which 88,000 kWh/yr would go for the golf course alone. WSMR is currently paying \$0.045/kWh; electrical cost at this rate comes to \$4815 a year (\$3960 a year for the golf course alone).

Current electrical costs to water the course are 2.243 kWh/1000 gal (0.59 kWh/1000 L) for the potable water supply, plus the cost of running the 40-HP booster pump. This is about 76,000 kWh/yr (\$3240 per year).

Labor needed for maintenance of the pumps can be extrapolated from Figure 12 to be 53 hours per year for the system at the STP. The cost of maintaining a booster pump at the golf course is already being borne. Capital costs of \$35,000 for both pumping systems are from the 1980 Means Guide.¹⁹

Total Costs

The total costs of the network are summarized in Table A3.

Estimating labor costs at \$10 an hour, electricity at 4.5 cents per kilowatt-hour, and chlorine at \$200 a ton, total yearly costs are about \$35,000. This compares favorably with the \$39,000 per year that WSMR is currently paying to water the golf course with potable water. This network was pursued under Stage 3 of the model.

Table A3
Costs of the Reuse Network

	Construction			O&M/Year	
	Total Costs (\$)	Total Yearly Costs* (\$)	Labor	Materials	Electricity
Pipeline	174,000	17,700	--	--	--
Lined Storage					
Lagoon	23,500	2,400	--	--	--
Chlorination	35,000	3,600	133 hrs	7 tons (64 MT) Cl ₂	5000 kWh
Pumping	35,000	3,600	53 hrs	--	88,000
Total	267,500	27,300	186 hrs	7 tons (64 MT) Cl ₂	93,000

*Total yearly costs are calculated assuming a 20-year lifetime at 8 percent interest.

¹⁹Building Construction Cost Data, 38th Annual Edition (Robert Snow Means Co., Inc., 1980).

Stage 3: Field Test at WSMR

Two wastewater streams at WSMR were sampled on April 7-18, 1980. Three samplers were set up; an automatic flow compositor on the influent to the STP, a 24-hour compositor on the STP effluent, and a 24-hour compositor on the photo lab sump. A flow recorder was put on the STP influent. A voltage recorder was connected to both photo lab sump pumps to determine how often they operated. The photo lab was tested because it is the largest industrial water user on post, and it discharges throughout the evening and late night -- when flow to the STP is otherwise low.

On April 9, 10, 11, 14, 15, samples were collected from 8 a.m. to 8 a.m. the following morning. Flow recorders were left running April 12 and 13, but no samples were taken.

Samples were iced down, preserved with acid, and shipped to AEHA's chemists at Fort Meade. They analyzed for BOD, TOC, metals, hardness, boron, sodium, total Kjeldahl nitrogen (TKN), ammonia (NH_3), nitrite/nitrate, phenols, suspended solids, total dissolved solids (TDS), oil and grease, chloride, phosphate, cyanide, iron, coliforms, pH, and flow rate. The results are presented in Tables A4 through A6 and Figure A9.

Samples were also taken from six monitoring wells close to STP outfall to determine both the groundwater quality in the area and any effect the effluent discharge might have. Soil samples were taken from the golf course greens, fairways, and driving range, and from the ball fields near the course, and shipped back to AEHA for characterization. Permeability tests were done on site with an experimental device called an infiltrometer.

A comparison of the STP effluent quality with the water quality tolerable for irrigation shows that the effluent is entirely suitable, except for its high cyanide concentrations. The STP effluent contained an average cyanide concentration of 0.29 mg/L, which is almost three times the highest standard for irrigation water found in the literature. A cyanide mass balance shows that the photo lab is a significant source of cyanide in the STP influent, but probably not the only one. Complete removal of cyanide only from the photo lab waste stream probably would not result in suitable cyanide concentrations in the STP effluent. Alkaline chlorination is the most common method of removing cyanide; all of the STP effluent will have to be chlorinated to the breakpoint level during the irrigation season.

The flow and water quality data obtained at WSMR were used as inputs to both the yearly and daily cascade computer programs to consider irrigation of the golf course, driving range, and athletic fields with the STP effluent. The costs calculated by the program were considerably higher than the rough costs obtained using Mean's Building Construction Cost Data. The greatest discrepancies occurred in the pipe and pump figures. These differences are to be resolved in future runs.

Table A4

Sewage Treatment Plant Influent

Parameter	Date of Sample Collection -- April 1980					Average
	9th	10th	11th	15th	16th	
pH	7.0	7.3		7.4		NA
Conductivity (mhos)	880	750		810		813
BOD ₅ (mg/L)	139	122		162		141
Total organic carbon (mg/L)	85	68		149		101
Phenol (mg/L)	<0.05	<0.05		0.02		<0.04
Cyanide (mg/L)	0.76*	0.34*		0.54		0.55
Total suspended solids (mg/L)	153	78		202		144
Total dissolved solids (mg/L)	472	418		462		451
NO ₂ NO ₃ /N (mg/L)	<0.01	0.04		0.02		0.02
NH ₃ N (mg/L)	21	17		26		21.3
Total Kjeldahl nitrogen (mg/L)	9.3	8.4		12		9.9
Total phosphates (mg/L)	28	23		38		29.7
Fluoride ion (mg/L)	0.42	0.40		0.45		0.42
Chloride ion (mg/L)	46	43		46		45
Oil and grease (mg/L)**		40		35	24	33

*Unpreserved sample -- actual values may have been higher.

**Oil and grease analyses conducted on a grab sample; all other analyses conducted on 24-hour flow -- composited sample.

Table A5
Sewage Treatment Plant Effluent

Parameter	Date of Sample Collection -- April 1980					Average
	9th	10th	11th	15th	16th	
pH	7.4	7.4	7.7	7.5		7.4
Conductivity (mhos)	720	700	740	710	760	726
BOD ₅	12	12	6	13	9	10.4
Total organic carbon (mg/L)	29	23	24	22	23	24.2
Phenol (mg/L)	<0.05	<0.05	<0.05	<0.1	<0.1	<0.07
Cyanide (mg/L)	0.32*	0.33*	0.31*	0.22	0.28	0.29
Total suspended solids (mg/L)	14	4	7	7	1	6.6
Total dissolved solids (mg/L)	489	464	466	434	458	462
NO ₂ NO ₃ /N (mg/L)	3.3	4.0	4.8	4.9	6.6	4.1
NH ₃ /N (mg/L)	8.4	6.8	10	9	7.6	8.4
Total Kjeldahl nitrogen (mg/L)	11	8.1	13	9.3	8.4	10.0
Total phosphates (mg/L)	7.5	7.2	7.7	7.6	8.0	7.6
Fluoride ion (mg/L)	0.44	0.55	0.45	0.40	0.51	0.47
Chloride ion (mg/L)	48	44	45	49	51	47.4
Oil and grease (mg/L)**	--	6	--	10	4	6.7

*Unpreserved sample -- actual values may have been higher.

**Oil and grease analyses conducted on a grab sample; all other analyses were performed on 24-hour flow -- composited samples.

Table A6
Photo Lab Data Comparison

	14 April 1030 - 1530	14 April 1730 - 1930	15 April 1200 - 2100	16 April 1145 - 2145	
Processor					
		<u>Runtimes (minutes)</u>			
P-003 (B&W)			31	52	
P-004 (B&W)				90	
P-005 (B&W)			84	76	
P-006 (Color)	95	100	245	100	
P-009 (Color)	30	120	140	275	
P-010 (B&W)			52	42	
Parameters					
		<u>Concentration (mg/L)</u>			<u>Average*</u>
TOC	340	357	245	283	281
CN	38	12	7.5	11	11.4
NO ₂ /NO ₃ /N	1.6	1.9	2.9	2.2	2.38
NH ₃ /N	100	23	22	95	62.5
TP ₀₄ /P	0.68	14	3.6	13	9.16
F	0.54	0.41	0.54	0.84	0.67
Cl	214	39	269	255	235
Hardness/CaCO ₃	259	241	274	238	252
Metals					
Na	212	250	268	525	390
Ba	--	--	--	--	--
Fe	18	5.7	4.1	5.5	5.7
Pb	--	--	--	--	--
As	--	--	--	--	--
Cd	--	--	--	--	--
Hg	0.0002	--	0.0002	--	--
Se	--	--	--	--	--
Ag	2.93	0.58	1.63	3.24	2.39
C	0.44	0.30	0.043	0.73	0.43
Ca	35	35	41	37	38
Mg	34	35	40	33	36
Cr	0.025	0.025	0.025	0.025	0.025

*Flow weighted average based on total flow of 31,430 gal (122,910 L).




Figure A9. Average flow.

APPENDIX B:

WATER AND EFFLUENT QUALITY

The tables in this appendix provide information on tolerable water quality and typical effluent quality for common Army activities. The references mentioned in the tables are listed on pp 98 through 102.

Table B1
Tolerable Water Supply Quality -- Aircraft Wash Racks

Constituent	Concentration, mg/L
	SCS Report*
BOD ₅	10
COD	25
Phenol	2.0
SS	10
TDS	2000
O&G	5.0
Cl	600
NO ₃	NS
NH ₄	5.0
PO ₄	NS
Na	600
CaCO ₃	500
B	NS
CN	0.5
Fe	40
MPN (total coliform)	<2.2/100 ml

*Curtis J. Schmidt, Ernest V. Clements, Leanne Hammer, Subpotable Water Reuse at Army Fixed Installations: A Systems Approach, Volume 1, ADA075159 (SCS Engineers, supported by U.S. Army Medical Research Development Command, August 1979). All report values are SCS estimates. NS indicates not significant.

Table B2
Typical Effluent Quality -- Aircraft Wash Racks

Constituent	Concentration, mg/L	
	SCS	Ref. 15*
BOD ₅	5700	270
COD	8400	976
Phenol	8.5	
SS	470	164
TDS	SD**	
O&G	280	305
Cl	SD	
NO ₃	0.8	1.7
NH ₄	(0.1)+	
PO ₄	80	1.6
Na	SD	
CaCO ₃	SD	
B	(0.1)+	
CN	(0.005)+	
Fe	1.1	

*Samples of wastewater from aircraft washing.

**SD indicates dependent on source quality.

+Values in parentheses are SCS estimates, other values in that column are based on Reference 1.

Table B3
Tolerable Water Supply Quality --
Air Pollution Wet Scrubbers

Constituent	Concentration, mg/L	
	SCS Report*	Ref. 2**
BOD ₅	100	
COD	200	
Phenol	2.0	
SS	100	14
TDS	2000	900
O&G	50	
Cl	600	100
NO ₃	50	22.0
NH ₄	20	2.0
PO ₄	NS	14.0
Na	600	
CaCO ₃	300	
B	NS	
CN	0.5	
Fe	20	
Mg	200	

*All values are SCS estimates. NS indicates concentration is not significant.
**Sewage effluent used as make-up to gas-cleaning system.

Table B4
Air Pollution Wet Scrubbers --
Typical Effluent Quality

Constituent	Concentration, mg/L		
	SCS Report*	Ref. 3**	Ref. 4+
BOD	10	180+	
COD	720	350	1-390
Phenol	(0.001)		
SS	3270	150	
TDS	(5000)		2800-92,500
O&G	0.3	150	
Cl	(400)		420-33,000
NO ₃	(28)		
NH ₄	(0.1)		
PO ₄	5.4	250	
Na	(72)		10-29,000
CaCO ₃	(200)	250	
B	(0.1)		
CN	(.005)		
Fe	5.3		

*Values in parentheses are SCS estimates; other report values are from Reference 1.
**Values are characteristic of phosphate waste waters from fume scrubbers.
+Flue gas desulfurization sludge liquors.

Table B5

Base Housing Water Supply Quality
(Also Included Are Unclassified Office Space,
Hospitals, and Commercial Services)

Constituent	Concentration, mg/L
	SCS Report*
Phenol	0.001
CN	0.2
Cd	0.01
TDS	500
Cl	250
SO ₄	250
Cr total	0.05
Cu	1.0
Fe	0.3
Pb	0.05
Mn	0.05
NO ₃ as N	10
NH ₃	5
As	0.05
Ba	1.0
Hg	0.002
Se	0.01
Ag	0.05
Chlorinated hydrocarbons	0.0002
Lindane	0.004
Methoxychlor	0.1
Toxaphene	0.005
2,4D	0.1
Silvex	0.01

*National Interim Primary Drinking Water
Regulations, maximum limit based on Reference 58.

Table B6

Typical Base Housing Sewage
(Also Includes Commercial and Unclassified Office Space)

Constituent	Concentration, mg/L
	SCS Report*
BOD	200
COD	300
Phenol	0.15
SS	300
TDS	300+
O&G	50-100
Cl	100+
NH ₄	30
PO ₄	10
Na	50+
CaCO ₃	80+
B	1.0+
CN	0.01
Fe	1.0+
Alk (as CaCO ₃)	50-100
Total coliform	1X10 ⁶ - 4.6X10 ⁷ /100 ml

*Plus indicates source water concentration.

Table B7

Low Pressure Boilers -- Tolerable Water Supply Quality

Constituent	Concentration, mg/L					
	SCS Report(a)	Ref. 37(b)	Ref. 37(c)	Ref. 44(d)	Ref. 45	Ref. 5(e)
BOD ₅	(1.0)					
COD	(3.0)	100		5		
Phenol	(0.1)					
SS	(10)	15,000	10	10	300-600	
TDS	2000	35,000	700	700	500-3000	3000-500
Hardness (CaCO ₃)	10	5000	350	20	80	80
Oil	(0.0)				1.0	
Cl	(200)	19,000				
NO ₃	NS					
NH ₄	(2.5)		.1			
PO ₄	(0.3)					
H ₂ S	(0.0)					5
Na	(200)					
CO ₃	40				200	200
B	(2.0)					
CN	(0.5)					
Fe	(0.5)	80	1.0	1.0		
Mn	(0.5)	10	.3	.3		
Si as SiO ₂	(50)	150	30	30	40	40
Alk (as CaCO ₃)	(100)	500	350	140		
pH	79.0		7-10	8-10	8.0	8.0 min.

(a) Values in parentheses are estimates; others are from Reference 5. NS indicates not significant.

(b) Pp 370, 377.

(c) For steam generation (maximum values); same as Reference 61.

(d) From Federal Water Pollution Control Administration (FMPCA) Water Quality Criteria, 1968.

(e) Appears that Reference 44 was based on Reference 5.

Note: for heat exchangers, need better water quality listed in Reference 61.

Table B8
Low Pressure Boilers -- Typical Effluent Quality

Constituent	Concentration, mg/L	
	SCS Report	Ref. 46**
BOD	5.0	
COD	15.0	
Phenol	0.5	
SS	50	
TDS	3500	
O&G	0.5	
Hardness (CaCO ₃)	50	10
Cl	1000	
NO ₃	150	
NH ₄	2.0	
PO ₄	60	
Na	1000	
CO ₃	200	
B	10	
CN	2.5	
Fe	2.5	1.4
Mn	2.5	
Zn	1.0	0.01
Si	2.5	
Ni	0-.1	0.05
Cu	3.0	0.05
Alk (as CaCO ₃)	500	
Cr	.005	<.005
pH	10.0	

*Values are five times source water except PO₄, Cu, Cr, Zn, Ni: see Table B7.

**Examples of boiler blowdown.

Table B9
Cooling Water (Recirculating Systems) -- Tolerable Water
Supply Quality (Also Dynamometers)

Constituent	SCS Report(a)	Ref. 37(b)	Concentration, mg/L			
			Ref. 40(c)	Ref. 41(d)	Ref. 42	Ref. 43
BOD ₅	10		10	5		
COD	75	100	--			75
Turb.	50				2	
SS	100	15,000	10	200-400		100
TDS	500-1500	1000	--	3000	500	
Hardness (CaCO ₃)	50	850	--	1200		130
Fe	0.5	80	--		0.3	0.5
Mn	0.5	10			0.3	0.5
Si as SiO ₂	50	150	10	175	50	
Al	0.1	3				0.1
Ca	50	500	28			50
HCO ₃	24	600				
SO ₄	200	680	200			200
Cl	500	500	--	2000	200	500
Alk as CaCO ₃	350	500	--			20
MBAS	1.0	1.3				1.0
Total P	0.3	4.0	.5	.4		

(a) Values are from References 5 and 37.

(b) Values are maximums on p 370. Reported values from Reference 37 are for steam generation purposes; also values same as Reference 61. References 38 and 39 agree with SCS Report values.

(c) Desired quality for Arizona nuclear project based on previous experience with freshwater sources. Dash indicates "not important."

(d) Recommended control limits.

Table B10
Cooling Waters (Once-Through) -- Tolerable Water Quality
(Also Dynamometers)

<u>Constituent</u>	<u>SCS Report*</u>	<u>Concentration, mg/L</u>		
		<u>Ref. 37**</u>	<u>Ref. 37+</u>	<u>Ref. 61</u>
SS	100	5000	5000	5000
Total P	1.0	4		4
Hardness (CaCO ₃)	650	850	850	850
Fe	0.5	14		14
Mn	0.5	2.5		2.5

*Values are SCS estimates; other constituents are not critical.

**Maximum values, p 370.

+P 377, steam generation plants using freshwater.

Table B11

Typical Effluent Quality -- Cooling Tower Blowdown
(Also Dynamometers)

Constituent	SCS Report(a)	Ref. 32(b)	Concentration, mg/L			
			Ref. 33(c)	Ref. 34(d)	Ref. 35	Ref. 36
Alkalinity (CaCO ₃)	SD					
BOD ₅	7.0					
COD	35					
Phenol	0-0.1					
SS	30					
TDS	SD		2680		856	4910
Cl	SD		631	135.3	32	130
P(total)	2.1	23.9		91.5	1.4	
Hardness (CaCO ₃)	SD					
Fe	0.6			7.8	0.74	
SO ₄	SD	340	758	1200	386	3200
Ca	0-2.0				0.23	
Cr	0.05				5.7	
Mn	0.1				0.12	
Zn	3.0	1.63		2.08	2.2	
Ni	1.0				0.005	
pH	7.4		6.85			

(a) Used References 6 and 7. SD -- indicates dependent of source quality, number of cycles and blowdown volume, typically five times source.

(b) Blowdown of cooling tower -- simulated blowdown.

(c) Cooling tower blowdown.

(d) Blowdown characteristics, mean concentration.

(e) Median concentration of blowdown in power plants.

Table B12

Fire Protection/Spill Washdown Reservoirs --
Tolerable Water Supply Quality

Constituent	Concentration, mg/L	
	SCS Report*	Ref. 59**
BOD	10	85 percent reduction
COD	22	
Phenol	0.01	
SS	10	95 percent reduction
TDS	NS	
O&G	1.0	
Cl	NS	
NO ₃	5.0	
NH ₄	10	
PO ₄	1	
Na	NS	
CaCO ₃	NS	
B	0.1	
CN	0.1	
Fe	5.0	
pH	5.0-9.0	

*NS indicates not significant. All values are estimates by SCS.

**Should also be stable and disinfected, treatment plant effluent.

Table B13

Hospitals -- Typical Effluent Quality

Constituent	Concentration, mg/L	
	SCS Report*	Ref. 23**
BOD	250	135
COD	850	
SS	200	
TDS	1400	1200
O&G	45	
PO ₄ as P	170	
SO ₄	35	98
Turb. JTU	50	
Alk (CaCO ₃)	125	
ABS	75	
Cd	0.02	
Ca	15	
Cr	1.1	
Fe	0.3	
Pb	0.3	
Mg	16	
K	34	
Na	360	
Ag	0.3	
pH	7.6	

*Values are from Reference 6.

**Values are for Army mobile hospital "Must" waste.

Table B14

Irrigation -- Tolerable Water Supply Quality

Constituent	SCS Report (a)	Ref. 47 (b)	Concentration, mg/L					Ref. 51 (f)	Ref. 52 (g)	Ref. 53 (h)
			Ref. 48 (c)	Ref. 49 (d)	Ref. 50 (e)					
BOD	30	76-204	12		D		2 ⁰ Eff.			
COD	60	140-509	24		I				<30	
Phenol	0.5	-			S					
SS	50	54-450	19		I					
TDS	2000	765-1053	654	468	F		<2000			2000
0&G	30	-	13		E					
Cl	350	212-319	85	118	C					
NO ₃	10	6-2.5	1.86	19	T					
NH ₃	20	16.5-55	3.19	13.2	O					
PO ₄	NS	.7-6.9	2.75	19	M			F 2 ⁰		
Na ₂	350	185-300	64		90					
CaCO ₃	NS	-			O					
B	3.0	-		0.53	L T					
				O E	L R					
				M A						
CN	.01	-			I T					
F	10	trace			O E					
pH	4.5-9.0	7.8-8.1	0.4							
Coliform		-	700	G E						
Agriculture	2.2/100 ml	-		T	T			<500 ml	<1000	<1000
Landscape 23/100 ml										

(a) All values are SCS estimates. NS -- indicates constituent not significant.

(b) Used 1⁰ effluent, no health problems, farm in Hungary.

(c) Values of applied effluent in United States.

(d) 2⁰ effluent used for irrigation.(e) Thirty-seven states in United States require 2⁰ treatment and disinfection for landscape irrigation.

(f) Arizona state regulations.

(g) Australian reuse for landscape irrigation.

(h) For golf course irrigation.

Table B15
Laundries -- Tolerable Water Quality

<u>Constituent</u>	<u>Concentration, mg/L</u>		
	<u>SCS Report*</u>	<u>Ref. 22⁺</u>	<u>Ref. 5</u>
BOD	45		
COD	500		
Phenol	0.05		
O+G	10		
SS	30		
TDS	3300	<1500	
NH ₃ -N	1.5		
Hardness (CaCO ₃)	50		50
Alk (CaCO ₃)	60		60
Fe	1.0		1.0
Mn	1.0		0.2
Zn	0.5		
Cr	0.5		
Cu	(1.0)**		
CN	(0.2)**		
As	(0.5)**		
Pb	.5		
MPN	(2.2/100 ml)**	10	
pH	6.0-6.8	5-7.5	6.0-6.8

*Used References 5, 19, 23, 16.

**Values in parentheses estimated by SCS.

*Numbers are for tentative National Aeronautics and Space Administration (NASA) standards.

Table B16
Industrial Laundries -- Typical Effluent Quality

Constituent	SCS Report (a)	Concentration, mg/L					Ref. 63 (f)
		Ref. 22 (b)	Ref. 23 (c)	Ref. 23A (d)	Ref. 13 (e)	Ref. 31	
BOD	450	435	4930	256	370-635	152	1600
COD ⁵	2000	1853	20,200	3820			2700
SS	1000	167	4020	290	210-540	116	250-500
2000	3912	8013		3268	800-2100		
TDS	211	3900		341	170-550		
O+G	848				-511		
Alk (CaCO ₃)	500					0.71	
Fe	1.0	0.75					
Si	130	310					
Ca	740	23					
Mg	6.4	1.5					
Cu	0.3	0.43	3.0			0.16	
Pb	0.7	0.32	20.0			0.16	
Cd	0.04	0.03	0.4			0.406	
Zn	0.5	0.14	10.			0.10	
Cr	0.06	0.09	2.0			0.05	
Ni	2.1	0.11				0.00013	
Hg	0.001-0.007	0.001		11.1	9.0-10.3	10.3	8-9
pH	11.2	11.2	-				

(a) Values from References 6, 7, 19, 20 16, 21.

(b) Dirty sample at a commercial laundry.

(c), (d) Two industrial laundries.

(e) Studies based on V. L. Snoyink et al., USAF Mobility Program Wastewater Treatment System, Technical Report AFM-TR-71-169 (Air Force Weapons Laboratory, April 1972).

(f) P 446, uses as source H. E. Painter, in Water and Pollution Handbook, L. E. Ciaccio, ed., Vol 1 (Marcel Dekker, 1971), p 350.

Table B17
Laundromat -- Effluent Quality

Constituent	Concentration, mg/L			
	SCS Report*	Ref. 17**	Ref. 18	Ref. 30
BOD ₅	200		243	118-284
COD	400	447	572	562-662
SS	130	173		100-127
TDS	360	812	1270	975-1140-275
O&G	750			
PO ₄	220	148	267	140-275
NH ₃ -N	3.0	3.0		
NO ₃	1.0	4.0		
CaCO ₃	250			
ABS	60	44	63	39-80
Turbidity	250			
pH	8.2	-		6.9-7.0
Alkalinity	182	182		

*References are 6 and 16.

**Average values for typical launderette waste.

Table B18
Metal Cleaning -- Typical Effluent Quality

Constituent	Concentration, mg/L		
	SCS Report*	Ref. 26**	Ref. 27*
COD	3000	1,167,500	10,100
SS	300	1210	550
O&G	350	962	1050
Phenol	70	3.24	3000
PO ₄	40	2.0	
CN	0.6		
Pb	0.4	0.26	
Zn	6.0	1.5	
Cr	25	31.3	100
Cd	0.5	0.2	
pH	9.0		8.3
Alk (CaCO ₃)	400		
MBAS	3.0		

*Values from References 24 and 25.

**Analysis of paint stripping waste from holding pit.
Average values.

*Characteristics of phenolic paint stripping wastewater.

Table B19

Metal Electroplating and Finishing Rinse Waters --
Tolerable Water Supply Quality, Also Metal Cleaning

<u>Concentration, mg/L</u>	
<u>Constituent</u>	<u>SCS Report*</u>
BOD	1.0
COD	3.0
TDS	500
SS	1.0
Phenol	0.001
Hardness (CaCO ₃)	10
As	0.05
B	1.0
Cd	0.01
Cr	0.05
Cu	1.0
CN	0.2
Fe	0.3
Mn	0.05
NH ₄	0.5
NO ₃	10
Pb	0.05
SO ₄	5.0
HCO ₃	5.0
Zn	5.0

*All values estimated by SCS.

Table B20

Paint Booth Water Walls --
Tolerable Water Supply Quality

<u>Concentration, mg/L</u>	
<u>Constituent</u>	<u>SCS Report*</u>
BOD ₅	30
COD	60
Phenol	NS
SS	60
TDS	NS
O+G	30
Cl	NS
NO ₃	NS
NH ₄	15
PO ₄	NS
Na	NS
CaCO ₃	NS
B	NS
CN	0.5
Fe	NS

*NS indicates concentration not significant;
all values are estimates by SCS.

Table B21
Paint Booth Water Walls --
Typical Effluent Quality

Constituent	Concentration, mg/L
	SCS Report*
BOD ₅	8100
COD	13,600
Phenol	1.2
SS	2800
TDS	SD
O+G	280
Cl ⁻	SD
NO ₃	(28)
NH ₄	(0.1)
PO ₄	(3.0)
Na	SD
CaCO ₃	SD
B	(0.1)
CN	(.005)
Fe	3.2
Cu (Total)	13
Cu	(0.005)
MBAS	4900

*Values in parentheses are estimates by SCS, other values from Reference 1. SD indicates source-dependent.

Table B22
Photographic Laboratories --
Tolerable Water Supply Quality

Constituent	Concentration, mg/L		
	SCS Report*	Ref. 5**	Ref. 62 [†]
BOD	0.1		
COD	1.0		
Phenol	0.001		
SS	1.0		
TDS	700		<200
O+G	0.2		
Cl ⁻	200	<25	
NO ₃	20		
NH ₄	0.1		
PO ₄	3.0		
Na	100		
CaCO ₃	400	100	100
B	0.1		
CN	0.01		
Fe	0.3	<0.1	0.02 together
Mn	0.5		
Cu	0.5	.5	

*Values are estimates by SCS.

**Fe >0.1 may cause staining; need good water for mixing developers of Cl⁻ <25 mg, although salt water can be used for washing.

[†]Used for source: Report of the U.S. Study Commission-Texas (March 1962), p 299.

Table B23

Photographic Laboratories --
Typical Effluent Quality

Constituent	Concentration, mg/L		
	SCS Report*	Ref. 8**	Ref. 9+
BOD ₅	300	225	
COD	500	752	500
Phenol	(0.001)		
SS	225		150
TDS	2900		2000-4000
O+G	(4.0)		
Cl ⁻	SD		250
NO ₃	(8.8)		
NH ₄	(16)		
PO ₄	(9.3)		
Na	SD		750
CaCO ₃	SD		
B	18		
CN	(4.8)	0.57	5.0
Fe	2.0		5.0
Ag	.5	0.45	
pH	7.8		7.5-8.3

*Values in parentheses are estimates from SCS; other values in SCS Report are from 6 and 7. SD indicates dependent on source water quality.

**Only items of concern.

+Also has values for additional characteristics, such as SO₄⁻, SO₂⁻, alkalinity, hardness, Si, HCO₃⁻, MG, turbidity.

Table B24

Recreational Lakes (Limited Body Contact) --
Tolerable Water Supply Quality

Constituent	SCS Report (a)	Concentration, mg/L				
		Ref. 45(b)	Ref. 56(c)	Ref. 5(d)	Ref. 3/4	Ref 57(f)
BOD	10					
COD	60					
Phenol	(0.01)					
SS	10				0.1	
TDS	(2000)*				25	
U+G	(5.0)	3000				
Cl	300					
NO ₃	2.5					
NH ₄	0.1			1.5	0.02	
PO ₄	0.3				0.2	
Na	250					
CaCO ₃	NS					
B	0.1					
CN	(0.1)					
F ₂	(5.0)		0.05		0.005	
pH	5.0-9.0					
MPN	<2.2/100 ml	240-2400		6.7-8.6	5.0-9.0	0.0-8.5
Temp. (max.)	86°F			<2000 avg.	1000/100 ml	50-100
					93°F.	1000-10,000 fish

(a) NS indicates not significant, values in parentheses are SCS estimates.

(b) Values tolerated by most freshwater fish.

(c) Toxic to some fish.

(d) Recreational lakes.

(e) For freshwater fish.

(f) Values varied between states.

(g) Bathing, fish life, p 254.

Table B25

Steam Cleaning -- Typical Effluent Quality

Constituent	Concentration, mg/L
	SCS Report*
BOD	1300
COD	2800
Phenol	3.0
SS	1000
TDS	-
O+G	245
Cl ⁻	-
NO ₃	30
NH ₄	0.1
PO ₄	65
Na	70
CaCO ₃	-
B	0.1
CN	<0.01
Fe	3.6
Cd	0.5
Cr+6	0.3
Cu	0.2
Pb	0.6
Ni	<0.05
Zn	2.0
pH	9.7

*Values from Reference 54.

Table B26

Vehicle Wash Racks --
Tolerable Water Supply Quality
Using Sewage Treatment Plant Effluent

Constituent	Concentration, mg/L
	SCS Report*
BOD	10
COD	25
Phenol	2.0
SS	10
TDS	2000
O+G	5.0
Cl ⁻	600
NO ₃	NS
NH ₄	5.0
PO ₄	NS
Na	600
CaCO ₃	500
B	NS
CN	0.5
Fe	40
Pb	1.0
Median Coliform #	<2.2/100 ml

*All values estimates by SCS.

Table B27

Vehicle Wash Racks --
Tolerable Water Supply Quality
Using Internally Recycled Water

Constituent	Concentration, mg/L
	SCS Report**
BOD ₅	20
COD	100
Phenol	3.0
SS	60
TDS	2000
O+G	5.0
Cl ⁻	600
NO ₃	NS
NH ₄	15
PO ₄	NS
Na	600
CaCO ₃	500
B	NS
CN	0.5
Fe	40

*All values are SCS estimates; values labeled NS are not significant.

Table B28
Vehicle Wash Racks -- Typical Effluent Quality

Constituent	SCS Report(a)	Concentration, mg/L					
		Ref. 11(b)	Ref. 12(c)	Ref. 13(d)	Ref. 14(e)	Ref. 28(f)	Ref. 29(g)
BOD	60			135-300		80	272
COD	900	336		420-916	64-3400		
Phenol	(0.01)			0.02-6.7			
SS	2000	2864		27-60		310	
TDS	SD	175		500-580	570-12,900		500
O+G	60	14.7	100	4-50	19-1050	225	333
Alk (CaCO ₃)	115	131					
Cl-	SD						
NO ₃	(3.3)			1-7			
NH ₄	(0.01)						
P (total)	33						
PO ₄	(12)						
Na	SD		15	18-105	2-580		
CaCO ₃	SD		150				
B	(0.01)						
CN	(0.005)						
Fe	4.7	31.3	1	0.1-0.7			
Zn	2.9		1	0.1-0.8			
Pb	2.5		1	0.1-0.2			
Mg	15						
Ca	31						
LAS			1		0-530		

- (a) Values in parentheses are SCS estimates; other values from References 10 and 6, SD: dependent on source water.
 (b) Values from rough wash facility, dirt removal from water impact forces only.
 (c) Values are for dilute synthetic waste, based on composite samples.
 (d) Washrack waste water.
 (e) For a particular wash site, values were either all high or all low.
 (f) Waste water design average.
 (g) Effluent from maintenance area.

Table B29

Summary of Tolerable Water Supply Quality and Typical Effluent Wastewater Quality

Activities	Turb.	BOD ₅	COD	Phenol	SS	TDS	Oil	Cl-1	NO ₃	NH ₄	PO ₄	Na	CaCO ₃	B	CN	Fe	MPN* (Total Coli.)	Mg*
1. Aircraft wash racks																		
TWQ	X	10	25	2	10	2000	5	600	NS	5	NS	600	500	NS	0.5	40	<2.2	
TEWQ	X	2985	4688	8.5	317	SD	293	SD	1.3	0.1	41	SD	SD	0.1	0.005	1.1		
2. Air pollution wet scrubbers																		
TWQ	X	100	200	2.0	100	2000	50	600	50	20	NS	600	300	NS	0.5	20		200
TEWQ	X	95	720	0.001	3270	26,000	75	5000	28	0.1	128	4870	225	0.1	0.005	5.3		
3. Base housing, hospital and commercial services																		
TWQ	X	200	300	0.001	300	500	75	100	10	30	10	50	80	1.0	0.01	0.2	2.35x	
TEWQ	X			0.15		300										1.0	10 ⁷	
4. Low pressure boilers																		
TWQ	X	10	36	0.1	120	200	0.5	200	NS	2.5	30	200		2.0	0.5	0.8		
TEWQ	X	5	15	0.5	50	3500	0.5	1000	150	2.0	60	1000		10	2.5	2.5		
5. Cooling water with recirculating																		
TWQ	50	10	75			128		740								0.5		
Once-through type																		
TWQ	X				3780											9.5		
6. Cooling tower blowdown																		
TEWQ	X	7	35	0.05	30	SD		SD			91					0.7		
7. Fire protection																		
TWQ		10	20	0.01	10	NS	1.0	NS	5.0	10.0	1.0	NS	NS	0.1	0.1	5.0		
8. Hospital																		
TEWQ	75	250	850		200	1400	45				170		360			0.3		16
9. Irrigation																		
TWQ	X	30	60	0.5	50	2000	30	350	15	20	NS	350	NS	3.0	0.01	10.0		70

TWQ = Tolerable water quality
 NS = Not significant
 TEWQ = Typical effluent water quality
 SD = Source dependent
 *Per 100 ml

Table B29 (cont'd)

Activities	Turb.	BOD ₅	COD	Phenol	SS	TDS	ORP	Cl-1	NO ₃	NH ₄	PO ₄	Na	CaCO ₃	B	CN	Fe	Mg*
10. Laundries																	
TWQ	X	45	500	0.05	30	2300	10			1.5						0.2	1.0
TEWQ	X	560	2590			1.00	2660	300								1.0	6
11. Laundromat																	
TEWQ		250	215	473	139	910	750		3.0	3.0	220		250				
12. Metal cleaning																	
TEWQ				6550	70	425	790				40					0.6	
13. Electroplating																	
TWQ			1.0	3.0	0.001	1.0	500		10	0.5					1.0	0.2	0.3
14. Paint booth water walls																	
TWQ		30	60	NS	60	NS	30	NS	NS	15.0	NS	NS	NS	NS	NS	0.5	NS
TEWQ		8100	13,600	1.0	2800	SD	280	SD	SD	28	0.1	3.0	SD	SD	0.1	0.005	
15. Photographic lab.																	
TWQ	X	0.1	1.0	0.001	1.0	700	0.2	200	0.1	0.1	3.0	100	400	0.1	0.1	0.01	0.3
TEWQ	X	300	584	0.001	225	2900	4.0	SD	8.8	16	9.3	SD	SD	18	4.8	3.5	
16. Recreational Lakes																	
TWQ	X	10	60	0.10	25	2500	5.0	300	2.5	0.1	0.3	250	NS	0.1	0.1	5.0	1000
17. Steam cleaning																	
TEWQ	X	1300	2800	8.0	1000		245		30	0.1	65	70		0.1	0.01	3.6	
18. Vehicle wash racks using sewage treatment plant effluent																	
TWQ	X	10	25	2.0	10	2000	5.0	600	NS	5.0	NS	600	500	NS	0.5	40	2.2
19. Vehicle wash racks using internally recycled water																	
TWQ	X	20	100	3.0	60	2000	5.0	600	NS	15.0	NS	600	500	NS	0.5	40	
20. Vehicle wash racks																	
TEWQ	X	158	900	1.7	2000	SD	127	SD	3.3	0.01	30	SD	SD	0.01	0.005	4.7	

TWQ = Tolerable water quality
 TEWQ = Typical effluent water quality
 NS = Not significant
 SD = Source dependent
 *per 100 ml

AD-A111 191

CONSTRUCTION ENGINEERING RESEARCH LAB (ARMY) CHAMPAIGN IL F/S 13/2
A PROCEDURE FOR EVALUATING SUBPOTABLE WATER REUSE POTENTIAL AT --ETC(U)
NOV 81 J T SANDY, M MESSENGER, E D SMITH
CERL-TR-N-109

UNCLASSIFIED

NL

2 of 2
2011/11/11



END
DATE
FILMED



Table B29 (cont'd)

Activities	Turb.	800 ₅	COD	Phenol	SS	TDS	CaCl ₂	NO ₃	NH ₄	PO ₄	Na	CaCO ₃	B	CN	Fe	MPN* (Total Coli.)	Mg*
10. Laundries																	
TMQ	X	45	500	0.05	30	3300	10		1.5						0.2	1.0	6
TEWQ	X	560	2590			1.00	2660	300								1.0	
11. Laundromat																	
TEWQ	250	215	473		139	910	750	3.0	3.0	220	250						
12. Metal cleaning																	
TEWQ		6550		70	425		790			40					0.6		
13. Electroplating																	
TMQ		1.0	3.0	0.001	1.0	500		10	0.5					1.0	0.2	0.3	
14. Paint booth water walls																	
TMQ		30	60	NS	60	NS	30	NS	NS	15.0	NS	NS	NS	NS	0.5	NS	
TEWQ		8100	13,600	1.0	2800	SD	280	SD	28	0.1	3.0	SD	SD	0.1	0.005		
15. Photographic lab.																	
TMQ	X	0.1	1.0	0.001	1.0	700	0.2	200	0.2	0.1	3.0	100	400	0.1	0.01	0.3	
TEWQ	X	300	584	0.001	225	2900	4.0	SD	8.8	16	9.3	SD	SD	18	4.8	3.5	
16. Recreational Lakes																	
TMQ	X	10	60	0.10	25	2500	5.0	300	2.5	0.1	0.3	250	NS	0.1	0.1	5.0	1000
17. Steam cleaning																	
TEWQ	X	1300	2800	8.0	1000		245		30	0.1	65	70		0.1	0.01	3.6	
18. Vehicle wash racks using sewage treatment plant effluent																	
TMQ	X	10	25	2.0	10	2000	5.0	600	NS	5.0	NS	600	500	NS	0.5	40	2.2
19. Vehicle wash racks using internally recycled water																	
TMQ	X	20	100	3.0	60	2000	5.0	600	NS	15.0	NS	600	500	NS	0.5	40	
20. Vehicle wash racks																	
TEWQ	X	158	900	1.7	2000	SD	127	SD	3.3	0.01	30	SD	SD	0.01	0.005	4.7	

TMQ - Tolerable water quality
 NS = Not significant
 TEWQ = Typical effluent water quality
 SD = Source dependent
 *Per 100 ml

Table B29 (cont'd)

Activities	Cd	SO ₄	Cr	Cu	Pb	Zn	As	Ba	Hg	Se	Ag	Alk	Hard- ness CO ₃ -2	Mn	Si	pH	M1
1. Aircraft wash racks																	
TMQ																	
TEMQ																	
2. Air pollution wet scrubbers																	
TMQ																	
TEMQ																	
3. Base housing, hospital and commercial services																	
TMQ	0.01	250	0.05	1	0.05	5	0.05	1	2x 10 ⁻²	0.1	0.05	75					
TEMQ																	
4. Low pressure boilers																	
TMQ			5x 10 ⁻³	3		1						200	90	147	0.5	50	8.7
TEMQ												500	50	200	2.5	2.5	10
5. Cooling water with recirculating																	
TMQ				320								350	340	0.5	90		
Once-through type																	
TMQ													800	1.8			
6. Cooling tower blowdown																	
TEMQ		SD	0.05			3						SD	SD	0.1		7.4	1.0
7. Fire protection																	
TMQ																5-1	
8. Hospital																	
TEMQ	0.02	35	1.1		0.3						0.3	125				7.6	
9. Irrigation																	
TMQ																	

TMQ = Tolerable water quality TEMQ = Typical effluent water quality * Per 100 ml
 NS = Not significant SD = Source dependent

Table B29 (cont'd)

Activities	Cd	SO ₄	Cr	Cu	Pb	Zn	As	Ba	Hg	Se	Ag	Alk	Hard- ness	CO ₃ -2	Mn	Si	pH	Ni
10. Laundries																		
TWQ				0.5	1.0	0.5	0.5	0.5				60	50		1.0		5.0-	
TEWQ	0.04		0.08	0.3	0.7	0.5		4x10 ⁻³				500				220	7.5- 9-11	2.1
11. Laundromat																		
TEWQ												182					8.2	
12. Metal cleaning																		
TEWQ	0.5		28		0.4	1.0						400					9.0	
13. Electroplating																		
TWQ	0.01	5.0	0.05	1.0	0.05	5.0	5 x 10 ⁻²						10		0.05			
14. Paint booth water walls																		
TWQ																		
TEWQ																		
15. Photographic lab.																		
TWQ				0.5							0.5				0.5		7.5- 8.3	
TEWQ																		
16. Recreational lakes																		
TWQ																	5-9	
17. Steam cleaning																		
TEWQ	0.5		0.3	0.2	0.6	2.0											9.7	0.05
18. Vehicle wash racks using sewage treatment plant effluent																		
TWQ																		
19. Vehicle wash racks using internally recycled water																		
TWQ																		
20. Vehicle wash racks																		
TEWQ	15				2.5	2.9										123		

TWQ = Tolerable water quality
NS = Not significant

TEWQ = Typical effluent water quality
SD = Source dependent

* Per 100 ml

Table B30

**Final Lagoon Effluent Quality At Lake City
Ammunition Plant and Its Possible Uses**

Constituent	Possible Use										
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
pH	8.5		8.7 Y			5-9 Y	4.5-9 Y	5-7.5 Y			
Total suspended solids	9	100 Y	120 Y	128 Y	3780 Y	10 Y	50 Y	30 Y	1.0 N	60 Y	1.0 N
Total solids	970	2000 Y	2000 Y	1312 Y		NS Y	2000 Y	3300 Y	500 N	NS Y	700 N
COD	63	200 Y	36 N	75 Y		22 N	60 N	500 Y	3.0 N	60 N	1.0 N
TOC	23										
Oil & grease	29	50 Y	0.5 N			1.0 N	30 Y	10 N		30 Y	0.2 N
Sulfate	279			320 Y					5.0 N		
Iron	0.74	20 Y	08. Y	0.5 N	9.5 Y	5.0 Y	10 Y	10 Y	0.3 N	NS Y	0.3 N
Aluminum	<0.1										
Copper	0.262						1.0 Y		1.0 Y		0.5 Y
Lead	<0.1						0.5 Y		0.05 N		
Zinc	0.29						0.5 Y		5.0 Y		
Antimony	0.226										
Chromium	<0.025						0.5 Y		0.05 Y		
Mercury	0.0011										

Note: All values are in mg/l except pH

Y = yes
N = No

Answers whether effluent is permissible to use for that purpose

Note: (k) = Photographic laboratories
(i) = Recreational lakes
(m) = Vehicle washracks

NS = Not significant
(a) = Final lagoon effluent (median value)
(b) = Air pollution wet scrubber
(c) = Low pressure boilers
(d) = Cooling water recirculating
(e) = Cooling water once-through
(f) = Fire protection
(g) = Irrigation
(h) = Laundries
(i) = Plating rinsewater metal cleaning
(j) = Paint booth water wells

REFERENCES FOR TABLES B1 THROUGH B30

1. United States Air Force Environmental Health Laboratory Industrial Waste and Water Pollution Surveys (for various Air Force Bases) (U.S. Air Force Environmental Health Laboratory, Kelly Air Force Base, Texas).
2. Eden, G. E., D. A. Bailey, and K. Jones, "Water Reuse in the United Kingdom," in Water Renovation and Reuse, ed., H. I. Shuval (Academic Press, 1977), pp 397-428.
3. Matherly, J. E., R. J. Fileccia, and H. A. Porte, Industrial Wastewaters, Red River Army Depot, Texarkana, Texas, Technical Report E-24/AD#778162 (U.S. Army Construction Engineering Research Laboratory [CERL], April 1974), p 47.
4. CH2M Hill Canada Ltd., Water Intake, Wastewater Production and Treatment and Air Pollution Control Technology in Coal-Fired Steam-Electric Power Generating Stations, Report EPS-3-WP-80-1 (Environment Canada, 1980), p 84.
5. McKee, J. E. and H. W. Wolf, Water Quality Criteria, Second Edition (California State Water Resources Control Board, 1963), 548 pp.
6. Schanche, G. W., J. R. Cannon, L. R. Creep, and B. A. Donahue, Pollution Estimation Factors, Technical Report N-12/ADA033753 (CERL, November 1976).
7. USEPA, State and Local Pretreatment Programs, Vol III (1977).
8. Development Document for Interim Final Effluent Limitations Guidelines and Proposed New Source Performance Standards for Photographic Processing Subcategory (USEPA, July 1976), p 4.
9. Spicher, R. B., G. M. Idehara and J. G. Kautz, "Treatment of Photographic Waste at Beale AFB, California," Proc. 26th Purdue Conference (1971), pp 1008-1019.
10. Fileccia, R. J., L. J. Benson, K. A. Conley, and J. E. Matherly, Vehicle Washing Operations and Wastewater Discharges, Fort Drum, New York, Findings and Recommendations, Technical Report E-80/ADA026173 (CERL, June 1976), 47 pp.
11. Mikucki, W. J., R. J. Fileccia, J. E. Matherly, and A. P. Norwood, "Recycle of Vehicle Wash Water," 2nd National Conference on Complete Water Reuse Proc. (1975), pp 30-32.
12. Chian, E. S. K., "Renovation of Vehicle Washrack Wastewater for Reuse," American Institute of Chemical Engineers (AIChE) Symposium Series, Vol 71, No. 151 (1975), pp 87-92. 42. Kawabe, A., et al., "Wastewater Reclamation by the Reverse Osmosis Process at a Power Station," (AIChE, 2nd National Conference on Complete Water Reuse, 1976), pp 942-955.

13. Wang, L. K., R. G. Ross, and J. G. Michalovic, "Sources, Quantities and Characteristics of Military Wastewaters," Proc. 30th Purdue Conference 1975 (1977), pp 727-740.
14. Chian, E. S. K. and A. Gupta, "Recycle of Wastewater from Vehicle Washracks," Proc. 29th Purdue Conference (1974), pp 9-20.
15. Clark, E. E. and J. L. Fink, "Major Airport Industrial Waste Pollution Abatement, A Comprehensive Program," Proc. 29th Purdue Conference (1974), pp 978-989.
16. Draft Development Document for Proposed Effluent Limitations Guidelines and New Source Performance Standards for the Auto and Other Laundries Point Source Category USEPA (Unpublished).
17. Flynn, J. M. and B. Andres, "Launderette Waste Treatment Process," Journal of the Water Pollution Control Federation (JWPCF), Vol 35 (1963), pp 783-798.
18. Eckenfelder, W. W., Jr., "Removal of ABS and Phosphate From Laundry Waste Waters," Proc. 19th Purdue Conference (1964), pp 467-478.
19. Redux Corporation, Redux Laundry Water Recycling System Saves Water, Money, and Energy; Stops Pollution (St. Louis, Missouri: Arundale, Inc., 1977).
20. Santo, J. E., J. H. Duncan, H. L. Liu, and N. I. Shapira, Regeneration of Wastewater for Reuse Through Hydroperm Microfiltration (Laurel, MD: Hydronautics, Inc., 1979).
21. Nemerow, N. L., Liquid Waste of Industry (Reading, MA: Addison-Wesley Publishing Co., 1971), 584 pp.
22. Claunch, R. W., "Redux Water Recycling System," Water Reuse Symposium, Vol 1 (1979), pp 433-447.
23. Santo, J. E., et al., "Regeneration of Wastewater for Reuse Through HydropermTM Microfiltration," Complete Water Reuse (1979), pp 1446-1486.
24. U.S. Army Environmental Hygiene Agency, Industrial Wastes, Corpus Christi Army Depot, Corpus Christi, Texas, 4-18 November 1977, 16-20 January, and 13-17 February 1978, Final Report, Water Quality Engineering Special Study No. 24-0068-78 (1978).
25. SCS Engineers, Cascade Water Reuse, CEEDU-TR-77-19 (Tyndall Air Force Base, 1977).
26. Mueller, J. A. and W. W. Melvin, Jr., "Biological Treatability of Various Air Force Industrial Wastes," Proc. 23rd Purdue Conference (1968), pp 398-427.
27. Kroop, R. A., "Treatment of Phenolic Aircraft Paint Stripping Wastewater," Proc. 28th Purdue Conference (1973), pp 1071-1087.

28. Furland, L. P. and W. E. Schley, "Characterization and Treatment of Wastewater From Army Vehicle Washracks," Proc. 34th Purdue Conference (1979), pp 643-654.
29. Lubieniecki, E., Jr., C. Watson, M. J. Staub, and J. E. Matherly, "Sand Filtration of Wastewater From Military Vehicle Washing Facilities," Proc. 34th Purdue Conference (1979), pp 655-663.
30. Aulenback, D. B., et al., "Treatment of Laundromat Wastes. I. Winfair Water Reclamation System," Proc. 25th Purdue Conference (1970), pp 36-53.
31. Lent, D. S., "Treatment of Power Laundry Wastewater Utilizing Powdered Activated Carbon and Cationic Polyelectrolyte," Proc. 30th Purdue Conference (1975), pp 751-759.
32. Garton, R. B., "Biological Effects of Cooling Tower Blowdown," AICHE Symposium Series 129, Vol 69 (1973), pp 284-292.
33. Fosberg, T. M., "Industrial Wastewater Reclamation," AICHE Symposium Series 136, Vol 70 (1974), pp 534-538.
34. Chian, E. S. K. and H. H. P. Fang, "RO Treatment of Power Plant Cooling Tower Blowdown for Reuse," AICHE Symposium Series 151, Vol 71 (1975), pp 82-86.
35. Lee, G. F., "Chemical Characteristics of Cooling Tower Blowdown Relative to EPA Proposed Water Quality Criteria," AICHE Symposium Series 151, Vol 71 (1975), pp 338-348.
36. Awerbuch, L., A. N. Rogers, and S. May, "Evaporation of Blowdown Water in Power Plants," AICHE Symposium Series 166, Vol 73, pp 312-322.
37. USEPA, Water Quality Criteria 1972, EPA-R3-73-033 (National Academy of Science, National Academy of Engineers, March 1973), pp 370-377.
38. DeCook, K. J., "Sources and Potential Uses of Salvageable Waters in Arizona Urban Regions" (AICHE, 3rd National Conference on Complete Water Reuse, AICHE & EPA, 1976), pp 310-319.
39. Williams, S. L., "Processing of Cooling Tower Blowdown for Reuse Without the Production of a Liquid Waste Stream" (AICHE, 3rd National Conference on Complete Water Reuse, 1976), pp 407-416.
40. Weddle, C. L. and A. C. Rogers, "Water Reclamation Process Evaluation for the Arizona Nuclear Power Project" (AICHE, 2nd National Conference on Complete Water Reuse, 1975), pp 163-171.
41. Fleischman, M., "Reuse of Wastewater Effluent as Cooling Tower Makeup Water" (AICHE, 2nd National Conference on Complete Water Reuse, 1975), pp 501-514.

42. Kawabe, A., et al., "Wastewater Reclamation by the Reverse Osmosis Process at a Power Station," (AIChE, 2nd National Conference on Complete Water Reuse, 1976), pp 942-955.
43. Linstedt, K. D., E. R. Bennett, and S. W. Work, "Quality Considerations in Successive Water Use," JWPCF, Vol 43 (1971), pp 1681-1694.
44. Esvelt, L. A., et al., "Reuse of Reclaimed Fruit Processing Wastewater," Water Reuse Symposium 1979, Vol 1 (1979), pp 336-370. Uses Federal Water Pollution Control Administration (FWPCA) Water Quality Criteria Table V, 1968.
45. Camp, T. R. and R. L. Meserve, Water and Its Impurities (Dowden, Hutchinson and Ross, Inc., 1974), p 158.
46. Allison, R. C., C. B. Cobb, and H. M. McCastlain, "Optimization of Water Use in Plywood Manufacturing," (AIChE, 2nd National Conference on Complete Water Reuse, 1976), pp 1176-1180.
47. Vermes, L., The Debrecen Sewage Research Farm Project in Wastewater Renovation and Reuse (Marcel Dekker, 1977), pp 183-203.
48. Wenck, N. C., M. C. Hannaman, and R. F. Roskopf, "Irrigation of Leased Farmland With Treated Wastewater," (AIChE, 3rd National Conference on Complete Water Reuse, 1976), pp 578-593.
49. Stenquist, R. J., et al., "Three California Water Reclamation Case Histories," Proc. Water Reuse Symposium, Vol 3 (March 1979), pp 1693-1736.
50. Deb, A. K., "Water Reuse Management Using Dual Water Supply," Water Reuse Symposium (1979), pp 1800-1815.
51. Bourver, H., "Reuse of Sewage Effluent in Urbanizing Irrigated Valleys -- Arizona's Salt River Valley," Water Reuse Symposium, Vol 3 (1979), pp 2026-2037.
52. Smith, M. A., "Reuse of Water in Australia," Water Reuse Symposium, Vol 1 (1979), pp 925-936.
53. Hart, O. O. and L. R. J. van Vuusen, "Water Reuse in South Africa," in Water Renovation and Reuse, ed., H. I. Shuval (Academic Press, 1977), pp 355-396.
54. U.S. Army Environmental Hygiene Agency, Industrial Wastewater Treatment, Anniston Army Depot, Anniston, Alabama, 16 October-1 November, 1976, Water Quality Engineering Special Study No. 24-0656-77 (1977).
55. Schmidt, C. J. and E. V. Clements, Demonstrated Technology and Research Needs for Reuse of Municipal Wastewater, EPA-670/2-75-038 (USEPA, 1975), 339 pp.
56. Cheremisinoff, P. N., et al., "Treating Metal Finishing Wastes," Industrial Wastes (November/December 1976), pp 31-34.

57. American Public Health Association, Water Quality Standards of the U.S. Territories and District of Columbia (1969).
58. National Interim Primary Drinking Water Regulations, EPA-570/9-76-003 (USEPA, 1976), 159 pp.
59. Kalinske, A. A., et al., "Reclamation of Wastewater Treatment Plant Effluent for High Quality Industrial Reuse in Saudi Arabia," Water Resource Symposium, Vol 2 (1979), pp 958-992.
60. Sussman, S., "Treatment of Water for Cooling, Heating and Steam Generation," Water Quality and Treatment, Third Edition (American Water Works Assoc., McGraw Hill Book Co., 1971), 654 pp.
61. Water Quality Criteria (National Technical Advisory Committee, FWPCA, 1968), 234 pp.
62. Chemical Rubber Company (CRC), Handbook of Environmental Control; Vol III, Water Supply and Treatment (CRC Press, 1973), 835 pp.
63. United States Army Environmental Hygiene Agency, Lake City Army Ammunition Plant, Water Quality Engineering Special Study No. 32-24-0126-79 (1978).

CERL DISTRIBUTION

Chief of Engineers
ATTN: Tech Monitor
ATTN: DAEN-ASI-L (2)
ATTN: DAEN-CCP
ATTN: DAEN-CW
ATTN: DAEN-CWE
ATTN: DAEN-CWM-R
ATTN: DAEN-CWO
ATTN: DAEN-CWP
ATTN: DAEN-MP
ATTN: DAEN-MPC
ATTN: DAEN-MPE
ATTN: DAEN-MPO
ATTN: DAEN-MPR-A
ATTN: DAEN-RD
ATTN: DAEN-RDC
ATTN: DAEN-RDM
ATTN: DAEN-RM
ATTN: DAEN-ZC
ATTN: DAEN-ZCE
ATTN: DAEN-ZCI
ATTN: DAEN-ZCM

US Army Engineer Districts

ATTN: Library
Alaska
Al Batín
Albuquerque
Baltimore
Buffalo
Charleston
Chicago
Detroit
Far East
Fort Worth
Galveston
Huntington
Jacksonville
Japan
Kansas City
Little Rock
Los Angeles
Louisville
Memphis
Mobile
Nashville
New Orleans
New York
Norfolk
Omaha
Philadelphia
Pittsburgh
Portland
Riyadh
Rock Island
Sacramento
San Francisco
Savannah
Seattle
St. Louis
St. Paul
Tulsa
Yicksburg
Walla Walla
Wilmington

US Army Engineer Divisions

ATTN: Library
Europe
Huntsville
Lower Mississippi Valley
Middle East
Middle East (Rear)
Missouri River
New England
North Atlantic
North Central
North Pacific
Ohio River
Pacific Ocean
South Atlantic
South Pacific
Southwestern

Waterways Experiment Station

ATTN: Library

Cold Regions Research Engineering Lab

ATTN: Library

US Government Printing Office

Receiving Section/Depository Copies (2)

Defense Technical Information Center

ATTN: DDA (12)

Engineering Societies Library

New York, NY

FESA, ATTN: Library

ETL, ATTN: Library

Engr. Studies Center, ATTN: Library

Inst. for Water Res., ATTN: Library

SHAPE

ATTN: Survivability Section, CCB-OPS
Infrastructure Branch, LANDA

HQ USEUCOM

ATTN: ECJ 4/7-LOE

Army Instl. and Major Activities (CONUS)

DARCOM - Dir., Inst., & Svcs.

ATTN: Facilities Engineer

ARRADCOM

Aberdeen Proving Ground
Army Matls. and Mechanics Res. Ctr.
Corpus Christi Army Depot
Harry Diamond Laboratories
Dugway Proving Ground
Jefferson Proving Ground
Fort Monmouth
Letterkenny Army Depot
Natick Research and Dev. Ctr.
New Cumberland Army Depot
Pueblo Army Depot
Red River Army Depot
Redstone Arsenal
Rock Island Arsenal
Savanna Army Depot
Sharpe Army Depot
Seneca Army Depot
Tobyhanna Army Depot
Tooele Army Depot
Watervliet Arsenal
Yuma Proving Ground
White Sands Missile Range

FORSCOM

FORSCOM Engineer, ATTN: AFEN-FE

ATTN: Facilities Engineers

Fort Buchanan
Fort Bragg
Fort Campbell
Fort Carson
Fort Devens
Fort Drum
Fort Hood
Fort Indiantown Gap
Fort Irwin
Fort Sam Houston
Fort Lewis
Fort McCoy
Fort McPherson
Fort George G. Meade
Fort Ord
Fort Polk
Fort Richardson
Fort Riley
Presidio of San Francisco
Fort Sheridan
Fort Stewart
Fort Wainwright
Vancouver Bks.

TRADOC

HQ, TRADOC, ATTN: ATEN-FE

ATTN: Facilities Engineer

Fort Belvoir
Fort Benning
Fort Bliss
Carlisle Barracks
Fort Chaffee
Fort Dix
Fort Eustis
Fort Gordon
Fort Hamilton
Fort Benjamin Harrison
Fort Jackson
Fort Knox
Fort Leavenworth
Fort Lee
Fort McClellan
Fort Monroe
Fort Rucker
Fort Sill
Fort Leonard Wood

INSCOM - Ch, Instl. Div.

ATTN: Facilities Engineer

Vint Hill Farms Station
Arlington Hall Station

WESTCOM

ATTN: Facilities Engineer

Fort Shafter

MDW

ATTN: Facilities Engineer

Cameron Station

Fort Lesley J. McNair

Fort Myer

HSC

HQ USAHSC, ATTN: HSLD-F
ATTN: Facilities Engineer
Fitzsimons Army Medical Center
Walter Reed Army Medical Center

USACC

ATTN: Facilities Engineer
Fort Huachuca
Fort Ritchie

MTMC

HQ, ATTN: MTMC-SA
ATTN: Facilities Engineer
Oakland Army Base
Bayonne MOT
Sunny Point MOT

US Military Academy

ATTN: Facilities Engineer
ATTN: Dept of Geography &
Computer Science
ATTN: DSCPER/MAEN-A

USAES, Fort Belvoir, VA

ATTN: ATZA-DTE-IM
ATTN: ATZA-DTE-SW
ATTN: ATZA-FE
ATTN: Engr. Library

Chief Inst. Div., ISA, Rock Island, IL

USA ARRCOM, ATTN: Dir., Instl & Svc

TARCOM, Fac. Div.

TECOM, ATTN: DRSTE-LG-F

TSARCOM, ATTN: STSAS-F

NARAD COM, ATTN: DRDNA-F

AMMRC, ATTN: DRXMR-WE

HQ, XVIII Airborne Corps and

Ft. Bragg

ATTN: AFZA-FE-EE

HQ, 7th Army Training Command

ATTN: AETTIG-DEH (5)

HQ USAREUR and 7th Army

ODCS/Engineer

ATTN: AEAEN-EH (4)

V Corps

ATTN: AETVDEH (5)

VII Corps

ATTN: AETSDEH (5)

21st Support Command

ATTN: AEREN (5)

US Army Berlin

ATTN: AEBA-EN (2)

US Army Southern European Task Force

ATTN: AESE-ENG (5)

US Army Installation Support Activity,

Europe

ATTN: AEUES-RP

8th USA, Korea

ATTN: EAPE

Cdr, Fac Engr Act (R)

AFE, Yongsan Area

AFE, 2D Inf Div

AFE, Area II Spt Det

AFE, Cp Humphreys

AFE, Pusan

AFE, Taegu

OLA ATTN: OLA-WI

USA Japan (USARJ)

Ch, FE Div, AJEN-FE

Fac Engr (Honshu)

Fac Engr (Okinawa)

ROK/US Combined Forces Command

ATTN: EUSA-HHC-CFC/Engr

416th Engineer Command

ATTN: Facilities Engineering

Norton AFB

ATTN: AFRCE-MX/DEE

Port Hueneme, CA 93043

ATTN: Library (Code L08A)

AFESC/Engineering & Service Lab

Tyndall AFB, FL 32403

Chanute AFB, IL 61868

3345 CES/DE, Stop 27

National Guard Bureau

Installation Division

WASH DC 20310

ENS Team Distribution

USA ARRAO (M)
ATTN: DRJAR-LCA-OK

1st. Bayton, Canal Zone 34004
ATTN: DIAF

West Point, NY 10996
ATTN: Dept of Mechanics
ATTN: Library

HQDA (SGRD-EDE)

Chief of Engineers
ATTN: DAEN-MPC-B
ATTN: DAEN-MPR
ATTN: DAEN-MPO-U
ATTN: DAEN-MPZ-A
ATTN: DAEN-RDL

National Defense Headquarters
Director General of Construction
Ottawa, Ontario, Canada K1A 0K2

Airports and Const. Services Dir.
Technical Info. Reference Centre
Ottawa, Ontario, Canada K1A 0N8

Aberdeen Proving Ground, MD 21005
ATTN: AMXHE

Ft. Belvoir, VA 22060
ATTN: Learning Resources Center
ATTN: ATSE-TO-TL (2)
ATTN: British Liaison Officer (2)

Ft. Leavenworth, KS 66027
ATTN: ATZLCA-SA

Ft. Monroe, VA 23651
ATTN: ATEN-AD (3)
ATTN: ATEN-FE-E

Ft. Lee, VA 23801
ATTN: DRXMC-D (2)

Ft. McPherson, GA 30330
ATTN: AFEN-CD

5th US Army
ATTN: AKFB-LG-E

6th US Army
ATTN: AFKC-EN

7th US Army
ATTN: AETIM-HRD-EHD

US Army Engineer District
New York
ATTN: Chief, NANEN-F
ATTN: Chief, Design Br.
Pittsburgh
ATTN: Chief, Engr Div
Philadelphia
ATTN: Chief, NAPEN-E
Baltimore
ATTN: Chief, Engr Div
Norfolk
ATTN: Chief, NAOEN-R
Huntington
ATTN: Chief, ORHED-P
Wilmington
ATTN: Chief, SAWEN-PP
ATTN: Chief, SAWEN-PM
ATTN: Chief, SAWEN-E
Charleston
ATTN: Chief, Engr Div
Savannah
ATTN: Chief, SASAS-L

US Army Engineer District
Jacksonville
ATTN: Inv. Res. Br.
Nashville
ATTN: Chief, ORND-P
Memphis
ATTN: Chief, LMED-PR
Vicksburg
ATTN: Chief, Engr Div
Louisville
ATTN: Chief, Engr Div
St. Paul
ATTN: Chief, ED-ER
Chicago
ATTN: Chief, NCCPD-ER
ATTN: Chief, NCCPE-PES
St. Louis
ATTN: Chief, ED-B
Kansas City
ATTN: Chief, Engr Div
Omaha
ATTN: Chief, Engr Div
Little Rock
ATTN: Chief, Engr Div
Tulsa
ATTN: Chief, Engr Div
Fort Worth
ATTN: Chief, SWFED-PR
ATTN: Chief, SWFED-F
Galveston
ATTN: Chief, SWGAS-L
ATTN: Chief, SWGCO-M
Albuquerque
ATTN: Chief, Engr Div
Los Angeles
ATTN: Chief, SPLED-E
San Francisco
ATTN: Chief, Engr Div
Sacramento
ATTN: Chief, SPKED-D
Far East
ATTN: Chief, Engr Div
Seattle
ATTN: Chief, NPSEN-PL-WC
ATTN: Chief, NPSEN-PL-ER
ATTN: Chief, NPSEN-PL-BP
Walla Walla
ATTN: Chief, Engr Div
Alaska
ATTN: Chief, NPASA-R

US Army Engineer Division
New England
ATTN: Laboratory
ATTN: Chief, NEDED-E
South Atlantic
ATTN: Chief, SADEN-E
Huntsville
ATTN: Chief, HNDED-CS
ATTN: Chief, HNDED-M
Lower Mississippi Valley
ATTN: Chief, PD-R
Ohio River
ATTN: Chief, Engr Div
North Central
ATTN: Chief, Engr. Planning Br.
Southwestern
ATTN: Chief, SWOCO-O
South Pacific
ATTN: Laboratory
Pacific Ocean
ATTN: Chief, Engr Div
ATTN: Chief, PODED-P
North Pacific
ATTN: Laboratory
ATTN: Chief, Engr Div

Tinker AFB, OK 73145
2854 ABG/DEEE

Patrick AFB, FL 32925
ATTN: XRO

AF/RDXT
WASH DC 20330

AFISC/PPT
Lyndall AFB, FL 32404

Little Rock AFB
ATTN: 314/DIII

Kirtland AFB, NM 87117
ATTN: DEP

US Naval Oceanographic Office
ATTN: Library
Bay St. Louis, MS 39522

Naval Facilities Engr Command
ATTN: Code 04
Alexandria, VA 22332

Port Hueneme, CA 93043
ATTN: Merrill Library

Washington, DC
ATTN: Building Research Advisory Board
ATTN: Transportation Research Board
ATTN: Dept. of Transportation Library

Dept. of Transportation
Tallahassee, FL 32304

Bandy, John T.

A procedure for evaluating subpotable water reuse potential at Army fixed facilities / by J. T. Bandy, M. Messenger, E.D. Smith. - Champaign, IL : Construction Engineering Research Laboratory ; Springfield, VA : available from NTIS, 1982.

102 p. (Technical report ; N-109)

I. Water reuse. I. Messenger, Manette. II. Smith, Edgar D. III. Title. IV. Series : U.S. Army. Construction Engineering Research Laboratory. Technical report ; N-109.

FILMED
8