

DRXTH-TE-CR-82128

6

ECONOMIC EVALUATION OF MUNITIONS
MANUFACTURING PINK WASTEWATER
TREATMENT ALTERNATIVES USING A
PRESENT VALUE-UNIT COST METHODOLOGY

CONTRACT NO. DAAK70-80-C-0101

BY

V. J. CICCONE & ASSOCIATES, INC.
14045 JEFF DAVIS HIGHWAY
WOODBIDGE, VA. 22191

FEBRUARY 1982

APPROVED FOR PUBLIC RELEASE;
DISTRIBUTION UNLIMITED

SDTIC
ELECTED
JUN 7 1982
H

DISTRIBUTION STATEMENT A
Approved for public release
Distribution Unlimited

PREPARED FOR

U. S. ARMY TOXIC AND HAZARDOUS MATERIALS AGENCY
ABERDEEN PROVING GROUND, MD. 21010

AND

U. S. ARMY MOBILITY EQUIPMENT RESEARCH AND DEVELOPMENT COMMAND
FORT BELVOIR, VA. 22060



AD A 115218

DTC FILE COPY

82 05 25 026

6

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER DRXTH-TE-CR-82126	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) Economic Evaluation of Munitions Manufacturing Pink Wastewater Treatment Alternatives Using a Present Value- Unit Cost Methodology		5. TYPE OF REPORT & PERIOD COVERED Final Report Jun 1980-31 Nov 1981
		6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) Dr. Vincent J. Ciccone Mr. Richard P. Schmitt Dr. James M. Morgan, Jr. Dr. George A. Garrigan		8. CONTRACT OR GRANT NUMBER(s) DAAK70-80-C-0101
9. PERFORMING ORGANIZATION NAME AND ADDRESS V. J. Ciccone & Associates, Inc. 14045 Jefferson Davis Hwy. Woodbridge, VA 22191		PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 62720A, 1L162720D048, EW, W-47
11. CONTROLLING OFFICE NAME AND ADDRESS US Army Toxic and Hazardous Materials Agency, Aberdeen Proving Grd, MD 21010		12. REPORT DATE February 1982
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office) US Army Mobility Equipment Research and Development Command Ft Belvoir, VA 22060		13. NUMBER OF PAGES
		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE

16. DISTRIBUTION STATEMENT (of this Report)
Approved for public release; distribution unlimited,

DTIC
ELECTE
JUN 7 1982
S D
H

17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)

18. SUPPLEMENTARY NOTES
This project was accomplished as part of the US Army's pollution abatement program D048. The primary objective of this program is to provide through R&D efforts cost-effective techniques, processes and systems to aid in achievement of the Army's goal in environmental protection and enhancement.

19. KEY WORDS (Continue on reverse side if necessary and identify by block number)

Economic Analysis	Activated Carbon	Surfactant Com-
Present Value-Unit Cost	UV-Ozone	plexing
Pink Water	Ultrafiltration	Water Reuse
Munitions Manufacturing Wastewaters	Liquid/Liquid Extraction	TNT/RDX Wastes
Economic Models	Powdered Carbon	Munitions

20. ABSTRACT (Continue on reverse side if necessary and identify by block number)

This economic evaluation studies munitions manufacturing wastewater (pink water) treatment alternatives using computer simulations based on a present value-unit cost (PVUC) methodology and compares seven state-of-the-art processes: activated granular carbon adsorption with and without carbon regeneration; ultraviolet-ozone; ultrafiltration; liquid/liquid extraction; powdered carbon adsorption; and surfactant complexing. Preliminary designs for 100,000 gallons per day and 1,000,000 gallons per day treatment facilities were prepared, based on pilot- and laboratory-scale data available; cost,

cont.

19. KEY WORDS

Capital Costs
O&M Costs

Water Reclamation
Pink Water Pollution Abatement Technology
Pollution Abatement

20. ABSTRACT

cont

estimates were developed for the full-scale facilities and the resulting unit treatment costs for a 30-year time frame. Cost sensitivity analyses were made of selected significant factors, e.g., carbon regeneration vs no regeneration; density of ultraviolet lamps; surfactant dosages; and, powdered carbon vs the exchange rate of carbon. The several advanced wastewater treatment methods are listed in order of preference based on the PVUC treatment cost per 1,000 gallons of pink water treated. The single most cost effective alternative is activated granular carbon adsorption technique with on-site thermal regeneration of the carbon. A glossary of selected terms is provided.

Accession For	
NTIS GRA&I	
DTIC TAB	
Unannounced	
Justification <i>see form</i>	
<i>file 182 or</i>	
<i>file re. pp. 138-</i>	
By <i>155</i>	
Distribution/	
Availability Codes	
Dist	Special
A	

DTIC
COPY
INSPECTED

DRXTH-TE-CR-82126

ECONOMIC EVALUATION OF MUNITIONS
MANUFACTURING PINK WASTEWATER TREATMENT
ALTERNATIVES USING A PRESENT VALUE-UNIT
COST METHODOLOGY

CONTRACT NO. DAAK70-80-C-0101

BY

V. J. CICCONE & ASSOCIATES, INC.
14045 JEFF DAVIS HIGHWAY
WOODBIDGE, VA 22191

FEBRUARY 1982

Approved for public release;
Distribution unlimited

PREPARED FOR

U.S. ARMY TOXIC AND HAZARDOUS MATERIALS AGENCY
ABERDEEN PROVING GROUND, MD 21010

and

U.S. ARMY MOBILITY EQUIPMENT RESEARCH & DEVELOPMENT COMMAND
FORT BELVOIR, VA 22060



THE VIEWS, OPINIONS AND/OR FINDINGS CONTAINED
IN THIS REPORT ARE THOSE OF THE AUTHOR(S) AND
SHOULD NOT BE CONSTRUED AS AN OFFICIAL DEPARTMENT
OF THE ARMY POSITION, POLICY, OR DECISION, UNLESS
SO DESIGNATED BY OTHER DOCUMENTS.



EXECUTIVE SUMMARY

Seven feasible alternative Pink Water treatment systems were evaluated economically using the Present Value-Unit Cost (PVUC) methodology. This methodology allows treatment unit costs to be calculated on a "systems" basis thereby accounting for all of the major system unit processes and components. Preliminary designs for daily flows of 10^5 and 10^6 gallons per day (GPD) were prepared to include flow diagrams and data sheets for each alternative treatment system. The design basis provides that the plant effluent would contain less than 1 mg/l TNT.

Capital and operating costs were obtained from published and unpublished sources (e.g., from an equipment manufacturer or supplier), adjusted if necessary to reflect 1980 dollars, and converted to functions suitable for use in the computerized PVUC model.

Computer simulations which compared the seven alternatives in various combinations with each other were conducted. The results were tabulated to yield a relative ranking of the feasible alternatives on the basis of the PVUC values. The following ranking was obtained:

- a) granular carbon with thermal regeneration;
- b) granular carbon with no regeneration;
- c) surfactant complexing; powdered carbon with atomized suspension technique (AST) regeneration;
- d) ultraviolet-ozone;
- e) liquid/liquid extraction;
- f) ultrafiltration.

Analytical (i.e., mathematical) experiments were conducted which examined the "sensitivity" of the PVUC model decision parameters to variations in selected significant factors, such as the adsorption rate for carbon (lbs of TNT/lb of carbon). The graphs show the calculated model response due to the variations.



The major conclusions reached in this study are:

- a) the most promising of the seven alternatives studied is Granular Carbon with Thermal Regeneration;
- b) the least promising is Ultrafiltration;
- c) the best documented alternative is Granular Carbon;
- d) one of the least documented is Surfactant Complexing.

Recommendations are to:

- a) concentrate research efforts on improving the efficiency of those unit processes identified in the Granular Carbon with Thermal Regeneration alternative;
- b) focus these efforts on those processes concerned with regeneration of the carbon;
- c) continue research on the Surfactant Complexing alternative to identify a more efficient complexing agent free of either mutagenic or carcinogenic characteristics;
- d) conduct research to document the performance characteristics of surfactant complexed sludge concentration dewatering and ultimate disposal.

The authors wish to express their sincerest thanks by acknowledging the valuable and timely comments, guidance and contributions made by Mr. J. Klein (USATHAMA), Mrs. E. Radoski (USAMERADCOM), Mr. B. Jackson (LCWSL), and the engineers and scientists from numerous other Army agencies who provided technical inputs and information. Special thanks are also given to the many members of the VJCA staff who were all instrumental in the performance of this study and the preparation of this report.

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
1.0	INTRODUCTION	1
1.1	BACKGROUND	1
1.2	TECHNICAL APPROACH	3
1.3	OBJECTIVES	3
2.0	INVESTIGATION	5
2.1	LITERATURE SEARCH	5
2.2	SITE VISITS	6
2.3	PINK WATER SOURCES AND CHARACTERISTICS	7
2.4	PINK WATER TREATMENT METHODS	11
2.5	PRELIMINARY DESIGN CONSIDERATIONS	14
2.6	FULL-SCALE PLANT PRELIMINARY DESIGNS AND PROCESS DESCRIPTIONS	16
2.7	INTERACTIVE PVUC COMPUTER MODEL	23
2.8	COST DATA ADJUSTMENT FOR PRICE LEVEL CHANGES	25
3.0	FINDINGS & DISCUSSION	29
3.1	COMPUTER SIMULATIONS OUTPUTS	29
3.1.3.1a	GRANULAR CARBON WITHOUT	31
3.1.3.1b	REGENERATION VS. GRANULAR CARBON WITH THERMAL REGENERATION	67
3.1.3.2a	GRANULAR CARBON WITH THERMAL	37
3.1.3.2b	REGENERATION VS. SURFACTANT COMPLEXING	73
3.1.3.3a	GRANULAR CARBON WITH THERMAL	43
3.1.3.3b	REGENERATION VS. POWDERED CARBON	79
3.1.3.4a	GRANULAR CARBON WITH THERMAL	49
3.1.3.4b	REGENERATION VS. UV-OZONE	85



TABLE OF CONTENTS (CON'T)

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
3.1.3.5a	GRANULAR CARBON WITH THERMAL	55
3.1.3.5b	REGENERATION VS. SOLVENT EXTRACTION	91
3.1.3.6a	GRANULAR CARBON WITH THERMAL	61
3.1.3.6b	REGENERATION VS. ULTRAFILTRATION	97
3.2	SENSITIVITY ANALYSIS	114
3.2.1	GRANULAR CARBON WITHOUT REGENERATION VS. INCREASED THERMAL REGENERATION COSTS	115
3.2.2	GRANULAR CARBON WITH THERMAL REGENERATION VS. NUMBER OF UV LAMPS	117
3.2.3	GRANULAR CARBON WITH THERMAL REGENERATION VS. SURFACTANT COMPLEXING (DOSAGES AND PRICE)	119
3.2.4	GRANULAR CARBON WITH THERMAL REGENERATION VS. ADSORPTION RATE FOR POWDERED CARBON ADSORPTION	122
4.0	CONCLUSIONS	125
5.0	RECOMMENDATIONS	127
6.0	REFERENCES	128
7.0	GLOSSARY OF SELECTED TERMS	133

TABLE OF CONTENTS (CON'T)

<u>APPENDIX</u>	<u>TOPIC</u>	<u>PAGE</u>
A	FLOW DIAGRAMS AND DESIGN DATA SHEETS	137
B	DATA SET USED FOR PVUC ANALYSES INVOLVING FLOW RATES OF 100 000 GPD	156
C	DATA SET USED FOR PVUC ANALYSES INVOLVING FLOW RATES OF 1 000 000 GPD	160



TABLE OF CONTENTS (CON'T)

<u>TABLES</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
1.1.1	U.S. Army & Navy Ammunition Facilities Capable of Generating Pink Wastewater	2
2.1.1	Munitions Operations Producing Pink Wastewaters	8
2.1.2	Compounds Identified in Synthetic "Pink Water"	10
2.1.3	Pink Water Treatment Methods	12
2.1.4	Full-Scale 10 ⁵ and 10 ⁶ GPD Plant Designs	13
3.1	Matrix of Pink Water Treatment Systems Compared on a PVUC Basis	28
3.2	Calculated Capital & Annual Operating Costs for Each Alternative Considered	104
3.3	Calculated PVUC (\$/K-GAL) for Each Alternative - 100,000 GPD - 30 Year Planning Horizon	105
3.4	Calculated PVUC (\$/K-GAL) for Each Alternative - 1,000,000 GPD - 30 Year Planning Horizon	106
3.5	Calculated PVUC (\$/K-GAL) for Each Alternative - 100,000 GPD - 5 Year Planning Horizon	109
3.6	Calculated PVUC (\$/K-GAL) for Each Alternative - 1,000,000 GPD - 5 Year Planning Horizon	110
3.7	Calculated Annual Savings By Using Granular Carbon with Thermal Regeneration - 100,000 GPD	111
3.8	Calculated Annual Savings By Using Granular Carbon with Thermal Regeneration - 1,000,000 GPD	112



TABLE OF CONTENTS (CON'T)

<u>FIGURE</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
3.1	Calculated PVUC (\$/K-GAL) for Each Alternative vs. Planning Horizons, 100,000 GPD	107
3.2	Calculated PVUC (\$/K-GAL) for Each Alternative vs. Planning Horizons, 1,000,000 GPD	108
3.2.1	Sensitivity of the Granular Carbon Alternative to the Adsorption Rate of Carbon	116
3.2.2	Sensitivity of the UV-Ozone Alternative to the Number of UV Lamps Used	118
3.2.3	Sensitivity of the Surfactant Complexing Alternative to the Required Dosage and Price	120
3.2.4	Sensitivity of the Powdered Carbon Alternative to the Adsorption Rate of the Carbon	123
3.2.5	Sensitivity of the Powdered Carbon Alternative to Reduced AST Carbon Regeneration Costs	124



COMPUTER OUTPUTS

<u>NO.</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
3.1.3.1a	Carbon No Regeneration vs. Carbon With Thermal Regeneration, 100,000 GPD	31
3.1.3.1b	Carbon No Regeneration vs. Carbon With Thermal Regeneration, 1,000,000 GPD	67
3.1.3.2a	Carbon With Thermal Regeneration vs. Surfactant Complexing, 100,000 GPD	37
3.1.3.2b	Carbon With Thermal Regeneration vs. Surfactant Complexing, 1,000,000 GPD	73
3.1.3.3a	Carbon With Thermal Regeneration vs. Powdered Carbon Adsorption, 100,000 GPD	43
3.1.3.3b	Carbon With Thermal Regeneration vs. Powdered Carbon Adsorption, 1,000,000 GPD	79
3.1.3.4a	Carbon With Thermal Regeneration vs. Ultraviolet-Ozone, 100,000 GPD	49
3.1.3.4b	Carbon With Thermal Regeneration vs. Ultraviolet-Ozone, 1,000,000 GPD	85
3.1.3.5a	Carbon with Thermal Regeneration vs. Liquid/Liquid Extraction, 100,000 GPD	55
3.1.3.5b	Carbon With Thermal Regeneration vs. Liquid/Liquid Extraction, 1,000,000 GPD	91
3.1.3.6a	Carbon With Thermal Regeneration vs. Ultrafiltration, 100,000 GPD	61
3.1.3.6b	Carbon With Thermal Regeneration vs. Ultrafiltration, 1,000,000 GPD	97



1.0 INTRODUCTION

1.1 BACKGROUND

1.1.1 The Department of Defense is responsible for a number of operations engaged in the manufacture and loading of explosives and/or propellants. The ammunition manufacturing and loading facilities are mostly Government-Owned, Contractor Operated (GOCO). The prime contractor for each facility is usually a major U.S. corporation retained for a specific number of years, and the contractor is responsible for all business and industrial operations, to include environmental pollution abatement activities. This study deals with the evaluation of seven alternative treatment systems designed to control pink wastewater discharges from such ammunition manufacturing and loading plants.

1.1.2 The United States Army controls seventeen Army Ammunition Plants (AAP) engaged in explosive or propellant manufacture. Seven AAP's engage only in manufacturing activities, eight are involved only in Load, Assemble and Pack (LAP) activities and two engage both in manufacture and LAP activities. The Army manufactures all explosives (except nitroglycerin) employed by the United States Air Force and the Army LAP facilities process Air Force munitions. The Air Force controls only one munition manufacturing plant but it is not concerned with pink wastewater problems at this time. The United States Navy controls and operates six munition manufacturing installations, four of which have pink wastewater effluent discharges. The service installations with potential pink wastewater problems are shown in Table 1.1.1.

1.1.3 Some of the mentioned munition facilities are relatively modern while others are of older vintage. A comprehensive effort has been underway in the Department of Defense to modernize munition production and loading plants. The modernization effort includes the abatement of pollution discharges which have an adverse impact on the environment and on local or regional streams and rivers. Stringent federal and state regulations require that munition facility discharges meet exacting requirements. As treatment of wastewaters from such military explosive and propellant production facilities is complex and expensive, efficient management of in-plant production methods and industrial



Table 1.1.1

U.S. Army and U.S. Navy Ammunition
Facilities Capable of Generating
Pink Wastewater

<u>Army Ammunition Plants (AAP)</u>	<u>Navy Ammunition Depots (NAD) or Navy Weapons Stations (NWS)</u>
Hawthorne - Hawthorne, NV*	Crane - Crane, IN
Holston - Kingsport, TN	Yorktown - Yorktown, VA
Iowa - Burlington, IA	
Joliet - Joliet, IL	
Kansas - Parsons, KS	
Lone Star - Texarkana, TX	
Louisiana - Shreveport, LA	
McAlester - McAlester, OK*	
Milan - Milan, TN	
Newport - Newport, IN	
Radford - Radford, VA	
Volunteer - Chattanooga, TN	

*Navy Plants now operated by the U.S. Army.

housekeeping require increasingly efficient pollution control methods. Advanced wastewater treatment technology is being planned and, in certain locations, already employed in the military explosive and propellant industry to assure that the wastewater treatment plant effluents and the discharged pollutants will meet strict effluent controls.

1.1.4 The abatement of pollution is one of the major and integral parts of the munitions industry modernization program. Implementation of the program is being aggressively pursued and has gone beyond the initial stages at selected installations. Extensive research and development studies have already been undertaken throughout the munition industry to insure reduction in the discharge of key pollution components in the various waste streams. Industry-wide effects are now being felt in a continuing pollution abatement program, in the promise



of new advanced wastewater treatment technologies, and in the implementation phase which promises efficient and economically operated wastewater treatment facilities.

1.1.5 Pollution abatement of one such wastewater, known throughout the industry as "pink water", is the specific subject of this study. The pink wastewater effluent contains trinitrotoluene (TNT) nitro bodies in suspension and solution at varying concentration levels.

1.2 TECHNICAL APPROACH

1.2.1 By applying the Present Value-Unit Cost (PVUC) method, this study evaluates the relative economic advantages of seven different protocols used to remove TNT constituents from wastewaters of the explosive manufacturing and certain LAP operations. The evaluation focuses upon a comparison of the calculated costs of the alternative treatment methods in proposed full-scale treatment facilities with capabilities of 10^5 gallons per day (GPD) and 10^6 GPD.

1.2.2 The PVUC methodology, ⁽⁷⁾ a computerized mathematical model approach, evaluates the cost differentials of the seven alternative pink wastewater treatment system designs. The calculated outputs, presented in both the tabulated and graphical formats, provide military planners, engineers and decision-makers with information for making effective and economically efficient wastewater treatment decisions.

1.3 OBJECTIVES

1.3.1 The objectives of this study were to:

- a) Review pink wastewater pilot and laboratory operational data.
- b) Establish an a priori order of advanced wastewater treatment preferences based upon previous pink wastewater treatment efforts.
- c) Obtain capital and operation and maintenance cost data for the proposed full-scale unit processes involved.



- d) Analyze cost functions and transform to PVUC format.
- e) Conduct in-depth PVUC comparative cost simulations for seven advanced pink wastewater treatment alternatives.
- f) Compile cost simulations in both tabular and graphical form.
- g) Conduct sensitivity analyses of selected alternatives.
- h) Submit monthly reports.
- i) Submit a draft report for review and a final report with conclusions and recommendations.

2.0 INVESTIGATION

2.1 LITERATURE SEARCH

2.1.1 An extensive on-line computer literature search focusing on the treatment of pink water was conducted to insure the appropriateness of the techniques to be followed. Descriptive item key-words used in the search were: TNT, trinitrotoluene, pink water, red water, industrial wastes, munitions wastes, munition waste pollution abatement, costs, present value unit costs, and risks. On-line requests were made of (a) Defense Technical Information Center, Cameron Station, Virginia and (b) Dialog Information Retrieval Service, Palo Alto, California. The information retrieval service of the U.S. Army Environmental Hygiene Agency, Aberdeen Proving Ground, Maryland, was queried to seek file information topics and microfiche cards related to TNT, pink water (and red water) as far back as 1950. In addition, copies of pertinent documents were obtained from the U.S. Army Toxic and Hazardous Materials Agency (USATHAMA), Aberdeen Proving Ground, Maryland, and from the Large Caliber Weapon Systems Laboratory, U.S. Army Armament Research and Development Command (ARRADCOM), Dover, New Jersey.

2.1.2 Laboratory-scale and pilot-plant scale wastewater treatment experimental data provided by staff and other subordinate elements of ARRADCOM were reviewed.

2.1.3 Munition plants were visited and laboratory-scale and pilot-plant scale treatment processes were observed. Industrial wastewater treatment equipment manufacturer data and a variety of construction data concerning unit processes were compiled to provide capital, operating and other necessary cost information. Full-scale plant-size units to treat 10^5 GPD and 10^6 GPD were designed and plant flow patterns were selected. The PVUC model was written in micro-BASIC language (see Section 2.7) as a convenient method to compare the several treatment alternatives. By employing the foregoing approach, the ability of the PVUC model to analyze waste treatment alternatives was demonstrated and the calculated results obtained were used for sensitivity analyses of selected parameters.



2.1.4 The advantages of the approach selected and followed allowed a logical solution to the problem. The literature search, data review, plant visits, cost data collection, full-scale plant design and PVUC model use were approached on a systematic basis. The main emphasis involved the translation of the experimental data to plant design and thence to PVUC analysis. The PVUC method is simple to use and understand. The entire cost functions across time horizons* can be fully comprehended as the micropricing concept is employed and at the same time the model examines a comparison of alternatives in a macrosense. Conversely, micropricing assists in decision-making in a macrosense, since the PVUC model provides the decision-maker with an overview of the whole system being investigated. When the model is understood and correctly interpreted, results can be easily developed to permit the user to make an immediate decision, to postpone a decision over a planning horizon, or to adjust constantly fluctuating factors.

2.1.5 The main disadvantage is that an assumption must be made that the user, or the decision-maker, is knowledgeable with the concepts of systems analysis and is conversant with interactive modes, in this case micro-computers.

2.2 SITE VISITS

2.2.1 Site visits were made as indicated to the following installations:

- a) Iowa Army Ammunition Plant, Burlington, Iowa: December 10-11, 1980.
- b) Large Caliber Weapon Systems Laboratory,, U.S. Army Armament Research and Development Command, Dover, New Jersey: October 22, 1980 and January 12, 1981.
- c) U.S. Army Environmental Hygiene Agency, Aberdeen Proving Ground, Maryland: July 30, 1980.
- d) U.S. Army Natick Research and Development Command, Natick, Massachusetts: February 9, 1981.
- e) U.S. Army Toxic and Hazardous Materials Agency, Aberdeen Proving Ground, Maryland: July 30, 1980, March 10, 1981 and July 16, 1981.

*Time horizons are periods of one to five years, six to ten years, etc., for a thirty-year period.



2.2.2 On each visit, personnel involved in pink wastewater treatment processes or research activities were interviewed, pilot- and laboratory-scale facilities were visited where appropriate and pertinent data and references were obtained. Site visits were supplemented by correspondence and discussions with knowledgeable personnel at the several installations listed, or at other installations.

2.3 PINK WATER SOURCES AND CHARACTERISTICS

2.3.1 Pink Water Sources

2.3.1.1 The munitions industry as a pink wastewater producer may be characterized by two major activities. First, manufacturing involves the production of an explosive or a propellant or an intermediate product from raw materials; the manufacture of TNT is an example. The second major activity, Load, Assemble and Pack (LAP), involves the loading of an explosive product into a munition and may also involve the blending of various munitions products in the loading process.

2.3.1.2 Pink water is the common name given to the aqueous colored waste which is generated at all (a) trinitrotoluene (TNT) manufacturing plants, (b) at all LAP operations where propellants and explosives are transformed into live munitions, or (c) where TNT-loaded munitions are demilitarized or unloaded. The colored wastewater is a principal effluent from munitions spills and from building and equipment washdown operations. In brief, it is a solution of TNT in water which appears everywhere TNT is made, processed, loaded or unloaded, containing TNT and other nitro bodies.

2.3.1.3 Pink wastewater from manufacturing operations may originate from fog filter effluents such as spent acid recovery (SAR) units; nitration fume scrubber discharges; "red water" distillates*; finishing building hood scrubber

*The TNT purification process involves the use of sellite, a concentrated solution (16 percent) of sodium sulfite (Na_2SO_3). Crude TNT is washed with sellite and the unwanted isomers of TNT react with sunlight or ultraviolet light leaving alpha-TNT. The sellite solution, together with the rinse waters, constitutes the red water.



and washdown effluents; and, possibly, spent acid recovery wastes. The first two types of pink wastewater may contain trinitrotoluene isomers and all three may contain dinitrotoluenes. At LAP installations the pink water generally results from actual unloading operations of defective munitions, demilitarization of munitions, the steaming out of rejected projectiles as well as facility washdown and clean-up activities. Table 2.1.1 summarizes pink water sources.

Table 2.1.1

Munitions Operations Producing Pink Wastewaters

<u>Manufacturing Operations</u>	<u>Load, Assemble, Pack Operations</u>
Stack fog filters	Loading and unloading munitions
Nitration fume scrubbers	Demilitarization of munitions
Red water concentration distillates	Steam out of rejected projectiles
Finishing building hood scrubbers and washdowns	Facility washdown and clean-up
Spent acid recovery operations (SAR)	

2.3.1.4 The characteristic pink color persists throughout dilution practices or treatment until the complex TNT compound is reduced to a concentration of relatively few milligrams per liter. "Pink water" should be differentiated from "red water" which is a highly concentrated sulfonated nitrobody in wastewater that results from purification of TNT.

2.3.2 Pink Water Characteristics

2.3.2.1 Pink wastewaters contain mostly trinitrotoluene, and lesser amounts of other nitro compounds (nitrobodies) such as dinitrotoluene (DNT) and isomers of TNT which may be toxic and hazardous.⁽³⁷⁾ The term "nitrobodies" include alpha-TNT, other isomers, other sellite process products and by-products from the munitions production process.



2.3.2.2 Large quantities of various wastewaters are generated daily at a number of the production and loading sites. Relatively small quantities of TNT, DNT, cyclotrimethylene-trinitramine (RDX), cyclotetramethylene-tetranitramine (HMX), and other nitro bodies are in the contaminated waste streams. The concentrations of TNT, RDX, and HMX have been identified by both laboratory and field experience as being toxic. Even though DNT has been identified as a potential carcinogen, absolute concentrations of DNT that cause harmful effects have not yet been conclusively identified.

2.3.2.3 TNT is toxic below the levels of visibility of the characteristic pink color in wastewater. While fresh solutions of TNT in water are practically colorless, when TNT dissolves in wastewater and undergoes photolysis by exposure to ultraviolet light, there are formed highly colored, poorly identified chemical compounds which are similar to dyes.

2.3.2.4 The pink color in TNT solutions also may be caused by making the solutions alkaline without exposure to ultraviolet light. Concrete tanks may cause this phenomenon until residual alkaline components have been leached from the tank surfaces. Earthen dikes, or lagoon walls and bottom surfaces, may also contribute alkaline products. The alkaline-imposed color may be reversed by acidification, a phenomenon not noted in the sunlight-induced coloration. Exposure of the TNT solutions simultaneously to both alkaline and sunlight conditions causes the nitro bodies to become highly complex. The complexity and large number of compounds identified in a typical synthetic pink water are listed in Table 2.1.2.

2.3.2.5 TNT exists as 2,4,6-trinitrotoluene (alpha-TNT) $[(NO_2)_3C_6H_2CH_3]$, an aromatic ring compound. Solid TNT exists as pale yellow crystals and has a reported specific gravity of 1.3 to 1.6. It is soluble in water and the extent of the solubility is strongly temperature dependent. At $20^{\circ}C$ the solubility is 160 mg/l. At lower temperatures it is less soluble. A saturated TNT solution cooled below $20^{\circ}C$ will crystallize. When warmed, the crystals will slowly return to solution. As TNT is soluble in water to the extent greater than 100 mg/l at ambient conditions, the exact value depends strongly upon temperature and the presence or absence of other solutes.



Table 2.1.2
Compounds Identified in Synthetic "Pic Water"

Compound	Estimated percentage*	Compound	Estimated percentage*
alpha-TNT	(45%)	2-amino-4,6-dinitrobenzoic acid	5-6%
Trinitrobenzene	0.5-1.0%	2,2'-dicarboxy-3,3',5,5'-tetranitro- azoxybenzene (white compound")	Trace
4,6-dinitroisoanthranil	1.0%	2,2'-dicarboxy-3,3',5,5'-tetranitro- azobenzene ("desoxy white compound")	7%
4,6-dinitroanthranil	3-4%	2-carboxy-3,3',5,5'-tetranitroazoxy- benzene (not confirmed)	- 2%
2,4-trinitrobenzaldehyde (photo sensitive)	8-10%	2-carboxy-3,3',5,5'-tetranitroazo- benzene	- 2.3%
2,4,6-trinitrobenzotrile	3-4%	2-amino-4,6-dinitrobenzoic acid	- 4-5%
Unknown II (unstable)	< 1%	Origin material	- 1.2%
2,4,6-trinitrobenzylalcohol*	- 1%	High molecular weight insoluble condensates	- 60%
3,5-dinitrophenol	< 1%		
Unknown III			

*Estimated the percent of total TNT photoproduct

Note: Analysis is based on work performed by the Chemistry Research Department of the Naval Weapons Center, Silver Springs, MD. (2,3)

Source: Tatyrek (36)

2.3.2.6 Concentrations of TNT in untreated munition plant or washdown wastewaters generally fall in the 100-200 mg/l range. The concentrations would consist of TNT nitro bodies in both solution and suspension. RDX concentrations in untreated wastewaters generally range from 10-30 mg/l. These concentrations, plus HMX, are reduced in certain wastewater treatment processes which are hereinafter described. In general, reducing pink water concentrations from approximately 120 mg/l to 10 mg/l presents no major difficulty in envisioned full-scale treatment facilities. Reducing the discharge concentrations under full-scale conditions to 1 mg/l can be done with careful control and treatment. Reducing plant effluents to extremely low concentrations may not be met in any single treatment system herein described. It may be possible to meet this lower limit by additional units or by combining treatment methods in systems collectively using the best available technology. The Hazardous Waste and Consolidated Permit Regulations which appeared in the Federal Register, 45 FR 33123, Monday, 19 May 1980,⁽³⁸⁾ 40 CFR Part 261, as amended by 46 FR 56582-56589,⁽³⁹⁾ Tuesday, November 17, 1981, listed hazardous waste from specific sources. One of the specific sources was Explosives. The U.S. Environmental Protection Agency (EPA) hazardous waste number K045 was indicated as "spent carbon from treatment of wastewater containing explosives" and K047 as "pink/red water from TNT operations." According to the Hazards Code both the K045 and the K047 waste was classified as reactive waste. No concentration discharge limit was placed on either reactive waste.

2.3.2.7 Other major pollutants from TNT production include nitrates, sulfates, sodium sulfite, sodium nitrate, sodium bisulfite, sodium sulfide, sodium thiosulfate and sodium trinitromethane sulfonate but were not the subjects of this study.

2.4 PINK WATER TREATMENT METHODS

2.4.1 The disposal of TNT in an environmentally acceptable manner poses serious difficulties. To do so effectively requires employment of advanced wastewater treatment methods to remove both suspended and dissolved concentrations.



2.4.2 The treatment goal for pink water includes the most reliable and economical concentration process or destruction method capable of treating relatively large quantities of wastewaters with relatively low or no concentrations of pollutants observed in plant effluents. Concentration of the pink water contaminants to a form which may be totally destroyed is the ultimate goal. This goal may ultimately be reached by employing advanced wastewater treatment processes singly or in combination. To reach anticipated low effluent values will require some refinements in the current state-of-the-art treatment processes and a combination of alternative systems may be necessary to accomplish these goals economically.

2.4.3 Tatyrek⁽³⁶⁾ described the current state-of-the-art for the then (1976) promising treatment methods for TNT munitions wastewaters. The report detailed the work accomplished under the technical direction of the Modernization and Special Technology Division of the Manufacturing Technology Directorate of Picatinny Arsenal, the predecessor of Large Caliber Weapon Systems Laboratory. The report also included work on pink water studies which had previously been initiated by other government and private organizations. The fourteen methods of pink water treatment which had been studied by 1976 were classified under the general headings of (a) concentration methods and (b) destruction methods. These are listed in Table 2.1.3.

Table 2.1.3

Pink Water Treatment Methods

<u>Concentration Methods</u>	<u>Destruction Methods</u>
1. Distillation	9. Ozonolysis
2. Reverse osmosis	10. Ozonolysis/ultraviolet
3. Carbon adsorption & regeneration	11. Gamma radiation
4. Polymeric adsorption & regeneration	12. Incineration
5. Liquid membrane separation	13. Aqueous phase-catalytic oxide
6. Foam separation	14. Composting and soil disposal
7. Solvent extraction	
8. Water recycle (a conservation method)	

Source: Tatyrek⁽³⁶⁾



2.4.4 Some promising methods of treating pink waters have received more attention than others. This study has investigated cost comparisons by the alternative selection scheme made possible by applying the Present Value-Unit Cost Methodology to those promising methods identified by USATHAMA (including two not listed in Table 2.1.3, i.e., surfactant complexing and ultrafiltration). Design criteria for the major treatment components for full-scale plants were determined based on laboratory and pilot-plant data when available. Otherwise conventional design criteria obtained from established sources were used. The first facility size envisions a treatment plant of 10^5 GPD capacity and the second is a treatment plant of 10^6 GPD capacity. Preliminary designs for full-scale plants of both capacities for the treatment methods selected for comparison are listed in Table 2.1.4.

Table 2.1.4

Full-Scale
 10^5 and 10^6 GPD Plant Designs

<u>Concentration Methods</u>	<u>Destruction Method</u>
1. Granular carbon adsorption with/without thermal regeneration	6. Ultraviolet - Ozone
2. Powdered carbon with Atomized Suspension Technique carbon regeneration	
3. Ultrafiltration	
4. Liquid/liquid extraction	
5. Surfactant complexing	

2.4.5 The full-scale designs were based on the most complete and comprehensive data available from laboratory-scale and pilot-plant scale studies. Data from some studies were not as complete as originally intended at the beginning of this investigation; this turn of events was caused by the unavailability of data not yet collected or collated and by the fact that research projects underway were delayed. The available specific research data were analyzed to obtain mean values of pink water concentrations prior to and following treatment.



2.4.6 The feasible alternative treatment methods listed in Table 2.1.4 were selected for analysis for the following reasons: granular carbon adsorption is already being employed on a 10^4 GPD pilot-scale and it is a proven TNT concentration method. The pilot-scale results are available only for a non-regeneration process. An on-site pilot-plant AST program for powdered carbon regeneration is currently underway. The powdered carbon adsorption technique, although not yet on a pilot-plant scale basis, appears to have good adaptability to pink water treatment. Ultrafiltration treatment is undergoing laboratory investigation and, although the low molecular weight of the TNT waste product may be difficult to reject with ultrafiltration membranes, an economic comparison appears warranted. Liquid/liquid extraction, listed in Table 2.1.3 as solvent extraction, employs toluene countercurrent with the pink wastewaters followed by white-oil countercurrent with the toluene/TNT and has been found to be a practical and efficient method for treatment on a laboratory-scale experimentation and therefore should be compared economically with the other methods. Surfactant complexing, originally conceived and listed in Table 2.1.3 as a foam separation method, appears to enhance the rate of decomposition of the TNT product. The enhanced decomposition process takes place in the presence of surfactants and alkali, rather than in the presence of alkali alone. Ozonolysis alone does not completely destroy the pink water pollutant contaminants; however, ozonolysis in combination with ultraviolet irradiation appears to have excellent potential as a method for destroying the pink water nitroaromatics.

2.5 PRELIMINARY DESIGN CONSIDERATIONS

2.5.1 When this study was originally conceived, it was contemplated that the on-going pink water treatment technology research phase schedules would provide completed design criteria and performance characteristics of the treatment methods to be analyzed (except for ultrafiltration). For various reasons, several of the research and development program reports were not completed. Hence it was necessary to prepare preliminary designs of full-scale (10^5 GPD and 10^6 GPD) plants on the basis of preliminary data as it became available. The decision to proceed in this mode was obtained from the Contracting Officer's Technical Representative.



2.5.2 In preparing the preliminary designs, best available technology methods were incorporated. Manufacturers of specialized equipment furnished cost and operational data. For standardized equipment, operational data were obtained from conventional sources and cost information was sought from sources explained in Section 2.8, Cost Adjusting Data for Price Level Changes.

2.5.3 In the design, the following assumptions were made based upon extensive review of the literature shown in Section 6.0.

- a) The average dissolved TNT in water concentration would vary between 100 and 150 mg/l (design of specific units were calculated on the basis of a TNT concentration in the range of 100 mg/l to 120 mg/l).
- b) The average suspended TNT concentrations would be approximately 80 mg/l.
- c) The ratio of TNT to RDX would be 70 percent to 30 percent.
- d) The solubilities of chemical constituents at ambient temperatures would be:

130 mg/l for TNT
50 mg/l for RDX
5 mg/l for HMX

(actual dissolved concentrations may be quite different from these limits due to the presence of other organics, alcohols and acids in the constantly varying wastewater streams).

- e) Each designed wastewater treatment alternative would receive raw wastewater and reduce same to a finished treatment product as follows:

	<u>Raw</u>	<u>Finished</u>
<u>TNT:</u>	100-120 mg/l	< 1.0 mg/l
<u>RDX:</u>	30-40 mg/l	< 1.0 mg/l
<u>DNT:</u>	Unknown	< 1.0 mg/l



2.5.4 It was not assumed that the treatment alternatives would be sufficiently effective to reduce the wastewater treatment plant effluents to the extremely low concentrations mentioned in Section 2.3.2.6.

2.5.5 The following standardized units were used for design flow:

$$10^5 \text{ GPD} = 0.1 \text{ MGD} = 69.4 \text{ gpm (70.0 gpm)}$$

$$10^6 \text{ GPD} = 1.0 \text{ MGD} = 694 \text{ gpm (700 gpm)}$$

$$1,000 \text{ gal} = \text{K-GAL}$$

2.6 FULL-SCALE PLANT PRELIMINARY DESIGNS AND PROCESS DESCRIPTIONS

2.6.1 On the basis of the available published research, pilot-scale and other data, treatment unit processes were selected and a preliminary full-scale design for each pink water treatment system was made. System flow diagrams are shown for the seven treatment methods on Figures A-1 through A-6 in Appendix A (the flow diagrams for granular carbon with and without regeneration are both shown on Figure A-1). Design data sheets with PVUC catalog numbers, major treatment components and pertinent design data for the 10^5 GPD systems will be found on Tables A-1a through A-6a and for the 10^6 GPD systems, on Tables 1b through 6b, also in Appendix A. Therefore, by jointly considering the flow diagrams (Figures A-1 through A-6), PVUC Catalog Numbers, and Tables A-1a, 1b through A-6a, 6b with Computer Output Sheets, it is possible to study each treatment system in specific detail. To arrive at the system of analysis it was necessary to accept the most up-to-date available research and equipment data for the preliminary design criteria. Otherwise conventional design criteria obtained from established sources were used. From the data search the Granular Carbon Adsorption without Regeneration treatment method appeared to be the best documented and the Surfactant Complexing treatment method the least documented.

2.6.2 In all of the descriptions which follow, the 10^5 GPD plant size is described. The flows can be followed on the appropriate figures and detailed dimensions can be found on the accompanying tables. Flow patterns for the 10^6 GPD plant size are similar to the 10^5 GPD descriptions and, of course,



dimensions and the number of individual units may change because of the order of magnitude increase. For each of the alternatives considered the design basis provides that the plant effluents would contain less than 1 mg/l TNT. In addition, wherever possible, "standardized" units such as tanks or pumps were used throughout the designs and subsequent economic evaluations.

2.6.2.1 GRANULAR CARBON WITH AND WITHOUT REGENERATION: Of all the processes employed for the removal of organic materials from wastewater, activated carbon has the longest history and is the best developed method in use today. Therefore, the process is well documented throughout the industrial and municipal wastewater treatment literature. Activated carbon is also effective in removing some inorganics from wastewater, particularly at the trace levels of certain metals. The process proceeds by adsorption or the attraction and accumulation of one substance on the surface of another. The decision whether to regenerate and reuse granular carbon or to use granular carbon without regeneration is based upon cost incentive. The granular carbon treatment techniques have been designed in this study both with and without thermal regeneration. During the study, a visit was made to the Iowa Army Ammunition Plant, Burlington, Iowa,⁽¹⁹⁾ to observe the operation of a granular carbon treatment process without regeneration. As the granular carbon with thermal regeneration process has been determined to be the most economical of all treatment systems studied, the design of that system will be discussed.

In the design for the 10^5 GPD granular carbon with thermal regeneration process, the assumptions were that influents to the pink water treatment plant would be collected in a subsurface sump. Intermittently, contents of the sump are pumped to a one-day retention equalization tank. Constant flow from the equalization tank would be pumped to a diatomaceous earth filter and from there to a bank of three carbon columns in series, each with a detention time of 35 minutes. As the adsorption capacity of the carbon in a column is exhausted the carbon would be discharged and held in carbon waste tanks, each with a capacity of one carbon column. The liquid discharge, always from the third column operating in series (accomplished by appropriate piping arrangement), would flow to a 25,000 gallon holding tank. If appropriate the liquid plant discharge could be effected at this point and discharged as plant effluent. Some of the



liquid waste could be used again at the diatomaceous earth filter units for backwash operations. Any excess liquid accumulating in the waste carbon tanks could likewise be returned to the equalization tank. The plant has the capability for virgin carbon storage of a minimum of two carbon column capacity. The virgin carbon for make-up purposes is fed, as needed, into the carbon columns through a pipe mixer with water pumped from the holding tank.

In the thermal regeneration scheme, the spent granular material from the carbon waste tanks is conveyed into a multi-hearth furnace, part of the regeneration system, with a thirty-minute retention time. Off-gases would be scrubbed as shown as a part of the regeneration scheme. Regenerated carbon enters a quench tank as part of the cooling process and is stored in a carbon de-fine tank. The regenerated carbon is reintroduced hydraulically into the three carbon column series bank as required. For a non-regenerative granular carbon treatment process, the regeneration scheme would be omitted and the remaining liquid flow patterns would be the same. Spent, unregenerated carbon, used on a once-through basis, must be ultimately disposed of by some acceptable technique. In this study the disposal method considered was "open burning". (See Appendix C, where the O&M cost function for carbon column-granular includes the cost of open burning).

2.6.2.2 UV-OZONE: Oxidation has long been used as a common method of chemically treating water and wastewater. Ozone has likewise been recognized as a powerful chemical oxidant. An oxidizer combined with short wavelength ultraviolet (UV) light has been shown by Farrell et al.⁽¹⁰⁾ and others^(1,3,6) to be a promising pink water abatement process. The Farrell process, herein referred to as UV-Ozone, employs banks of ultraviolet lamps around which ozonated pink wastewaters are channeled to flow. Critical design considerations for proper performance include lamp spacing and ozone concentrations.

In the design for the 10^5 GPD UV-Ozone plant, which mainly follows the Farrell et al.⁽¹⁰⁾ investigation, the assumptions were that the pink wastewater treatment plant influent would enter through a sump into a one-day retention equalization tank and then through a diatomaceous earth pressure filter. The filter effluent would enter an ozone precontactor, a counter current flow tank similar to a bubble-cap plate tower, and subsequently to the ozone reactor. The



reactor is a specially designed tank, composed of a number of stages to assure maximum contact of the UV light and ozonated wastewater. The contact time-intensity is dependent upon the flow-through rate and the number of UV lamps per square foot of ozone reactor surface area. The reactor envisioned is similar to that of an enclosed baffled flocculation tank and has a detention time of two and one-half hours. Any resulting off-gas is re-routed to the precontactor for organic oxidation and then to an ozone destroyer tank or water gas separator, if required.

The ozone reactor may be constructed in units or as a single entity. The total number of required 65-watt ultraviolet lamps, each about 5 feet in length and slightly over 1 inch in diameter, would be 2,304. To provide cool dry air to the ozone generator would necessitate installation of an air chiller. Ozone produced in the generator would flow directly to the ozone reactor where it would mix with the pink water and the mixture subjected to UV light from the banked lamps. Treated pink water effluent from the ozone reactor would flow to a 25,000 gallon detention holding tank, which has a return capability to the diatomaceous earth filter for backwash, or to the plant discharge line.

2.6.2.3 SURFACTANT COMPLEXING: The proposed surfactant treatment process for pink waters was initially conceived as a foam separation technique. Foam separation as a method was abandoned when it was discovered that certain surfactants reacted with TNT to form an insoluble compound which would be more easily removed by filtration than by foaming. The surfactant process has been described by Roth⁽⁶⁾ and Okamoto, et al.^(28,29). More detailed research on the use of surfactants is currently underway at the Louisiana Army Ammunition Plant. The objective of the bench-scale investigation is to evaluate the process for fixation and removal of explosives and LAP residues from pink waters using a quaternary surfactant. The surfactant is expected to react under alkaline conditions to form and remove by filtration an insoluble complex. The surfactant is likewise expected to remove the colored products from the pink waters.

In the design for the 10^5 GPD surfactant complexing process, the assumptions were that the pink water treatment plant influent would enter through a sump into a one-day retention equalization tank. The surfactant is



first introduced upstream of a mixing pipe which is followed by the introduction of sodium hydroxide in solution directly with the surfactant into primary surfactant mixing tanks in series with a secondary reaction tank. Retention time in the surfactant mixing tanks is one-half to one hour. The liquid overflow from the second surfactant mixing tank is directed to a sulfuric acid neutralization tank with a one hour detention.

Resulting sludge is withdrawn from the bottom of the second surfactant mixing tank and directed to a vacuum filter the size of which has been estimated since it is not exactly known at this time what daily volume of liquid/sludge must be filtered. The filtered liquid phase may be returned to the second surfactant mixing tank or to the sulfuric acid neutralization tank as appropriate. In this design, the ultimate disposal of the resulting sludge has not been specifically determined (or costed) and no dedicated sludge disposal method has been estimated. The ultimate sludge disposal method is therefore shown as a phantom incinerator.

2.6.2.4 LIQUID/LIQUID EXTRACTION: Liquid/liquid countercurrent extraction is a method of transferring a solute from one solvent stream to another. This process, as described by Brown and Jackson,⁽⁴⁾ is a two-phase system of mutually immiscible solvents. Initially the solute is associated with only one solvent. On the addition of the second solvent with thorough mixing, an equilibrium is achieved in which the solute is distributed between the two solvents in proportions defined by the respective solubility product constants of each solvent-solute phase. Tash, Layne and Goodfellow⁽³⁵⁾ have found liquid/liquid extraction of pink water to be a feasible and practical process using toluene as the extractant. The laboratory-scale experimentation permitted reduction of TNT concentration to below 1 mg/l. Based on laboratory analysis and a computer program, the extractor column equipment for a pilot-plant extraction system was made. The full-scale design for 10⁵ GPD was developed from the Tash, Layne and Goodfellow work. It is anticipated that any small quantities of toluene remaining in the pink water effluent may be removed by extracting with "white oil" which was the original extractant to be considered but later found to be impractical due to the quantities required to effect significant separation of initial TNT concentrations.



The assumptions for liquid/liquid extraction were that following flow through a sump and a one-day retention in an equalization tank, pink water waste would pass through a diatomaceous earth filter and then in series through two solvent extractor columns each 8 feet in diameter by 15 feet in height with detention time of 85 minutes. The toluene solvent is to be introduced at the column bottom from 500-gallon solvent mix tanks. The toluene/TNT effluent is directed to a distillation unit which also receives the white oil/toluene effluent from the second extractor column. By fractional distillation the toluene and white oil are recovered for recycling. The TNT laden sludge from the distillation process must be disposed of by such methods as incineration. The system allows for the effluent from the second solvent extractor to be collected in a 25,000 gallon holding tank, and then returned to the diatomaceous earth filter for backwash operation. A phantom incinerator is indicated for incineration of sludge following distillation (not costed in this study).

2.6.2.5 ULTRAFILTRATION: Ultrafiltration of liquids is an attractive alternative to the usual chemical or other treatment methods, especially for the removal of suspended materials in aqueous waste streams. Through new membrane technology, it offers the advantages of being a simple hydraulic system without certain inherent operator problems with water chemistry and separation schemes, although system problems can develop. Ultrafiltration is a pressure active physical separation process in which a porous membrane is used to restrict the passage of unwanted material while allowing water and some dissolved matter to pass. Generally tubular or hollow filter modules are employed by banks in equipment connected in series. One type of module is a bundle of hollow polymeric fibers encased in a plastic shell held in place at each end of the element by various epoxy or other compounds. The concept has been to provide maximum membrane area under conditions of minimum space, flow and pressure requirements, while maintaining above average permeation rates. The normal molecular range for ultrafiltration cartridges is from less than 2,000 to more than 80,000 M.W. The molecular weight of TNT, the principal constituent in pink water, is approximately 227. In the design of the proposed 10^5 GPD plant two alternatives were investigated; the batch treatment method and the feed and bleed method of operation. The latter method is herein presented for a flow



rate of 70 gallons per minute, a TNT concentration of 118 mg/l and each ultrafiltration module was assumed to have a membrane area of 26.5 square feet.

The assumptions for ultrafiltration were that following the flow-through sump and a one-day retention equalization tank, the pink waters would pass through a diatomaceous earth filter and thence to a 25,000 gallon holding tank. From the holding tank, the filtered wastewater would pass through a total of ten stages of ultrafiltration modules, each equipped with high capacity recirculation pumps. At each stage there is to be a one percent bleed of concentrated TNT effluent to disposal. It is assumed there will be a constant 10 percent TNT removal per stage with a 25 gallons per square foot per day permeate rate at a constant 30 psig. The recirculation rate per module was estimated to be 20 gallons per minute with a resulting 0.46 gallons of permeate per minute per module. It was estimated 1450 modules would be required with a total pump horsepower requirement of 840 horsepower. Even with the 10 stages it was not likely that the 1 mg/l TNT effluent could be obtained. In addition, the final TNT laden ultrafiltration brine effluent would have to be disposed of by incineration or some other suitable method. Such disposal methods costs were not examined in this study.

2.6.2.6 POWDERED CARBON: Powdered carbon is used in many water and wastewater treatment plants. It has been widely used in industry to remove objectionable organic constituents from liquid wastes. The resulting residues separated from the liquids have been discharged by ponding, by incineration or by burial. The powdered carbon treatment process becomes more attractive where reactivation of the carbon can be successfully implemented; therefore, regeneration of the carbon becomes an important factor in the powdered carbon technique studied. The powdered carbon adsorption technique has been described by Jackson⁽⁶⁾ on a pilot-plant experimentation which involves regeneration of the carbon by AST. The AST regeneration process as installed at Iowa Army Ammunition Plant was observed in December 1980.⁽¹⁸⁾

In the calculations for the 10^5 GPD powdered carbon adsorption technique, a standard industrial treatment design was adopted and the assumptions were that the pink wastewater treatment plant influent would enter through a sump into a one-day retention equalization tank. A polymer and a coagulant would both be

introduced to a flash mix tank with overflow to one of two powdered carbon upflow clarifiers in series, each with a fifty minute detention period. Partially exhausted carbon slurry separated in the second clarifier would be returned as influent to the first clarifier. Solids collected in the first clarifier would be directed to a gravity thickener with a two-hour detention capability. Liquid overflow from the second clarifier would be pumped to a diatomaceous earth filter with the effluent flowing to a 25,000 gallon holding tank. As required, the holding tank contents may be used for filter backwash operations or discharged to the receiving stream. Piping arrangements have been shown to permit thickener effluent returned to the clarifier system with sludge withdrawal directly entering the vacuum filtration process; the vacuum filtered sludge would be trucked to ultimate sludge disposal. In this study, no dedicated sludge disposal system or procedure has been included in the cost estimations.

Should the AST regeneration scheme be feasible, resulting filtered sludge would be transported by screw conveyor to the AST furnace where it would be appropriately heat-treated in a 200-pound per day furnace. The off-gases would be scrubbed and the solids residue directed by screw conveyor to a quench tank for cooling. The regenerated carbon would be reintroduced to the system upstream of the second clarifier at approximately the same point where virgin carbon would be introduced into the system as makeup carbon.

2.7 INTERACTIVE PVUC COMPUTER MODEL

2.7.1 The existing computer model for the PVUC method of evaluating wastewater facilities has evolved from earlier versions by Ciccone⁽⁷⁾ and Morgan.⁽¹⁴⁾ As was the case in Morgan, this program is in an interactive format in Micropolis Extended BASIC (Micro-BASIC) and is run on a Vector Graphics Micronet II system.

2.7.2 The program is subdivided into five programs identified as PVUC-PART1, PVUC-PART2, PVUC-PART3, PVUC-PART4, and PVUC-PART5 respectively. Briefly, these programs perform the following functions.



2.7.2.1 PVUC-PART1: Through an interactive mode, PART1 gathers necessary preliminaries, such as operator name, date, titles of both systems associated with the present analysis, interest rate, inflation rate, and projected operational days per year. The title page to the output then is printed and the program automatically chains to PART2.

2.7.2.2 PVUC-PART2: This part of the program is used to introduce the actual design of any two alternative wastewater treatment systems under study. There is an option at the beginning of PART2 for the user to obtain a printout, if desired, of the catalog of units available in memory from which the two alternative treatment systems are to be compared. The user begins by designing the first system. An option exists either to call units from the PVUC equipment catalog by specific number and use the values for each unit stored in memory or to call a unit and modify values (costs, sizes, numbers, etc.) according to the needs of the treatment system being designed. The user may alternate between the above options during the design process.

Once the design for a treatment system is complete, it may be displayed or a hard copy printout may be prepared for examination and revision. Once the first treatment system design is satisfactory the program moves directly into the design of the second treatment system. The procedures and options for designing the second system are identical to those for the first system. On completion of the treatment system design phase, the user may chain to either PART3 or PART4. Once this option is taken, the chaining automatically occurs.

2.7.2.3 PVUC-PART3: If PART3 is selected, the Micronet will automatically provide a printout of the complete design specified by the operator of both wastewater treatment systems to be compared. The printout will include a listing of all pertinent data for each treatment unit as determined previously by the operator. If the hard copy is determined by the computer to be too extensive for one page, a special pagination mode will be automatically activated, and printout will be delayed at the end of each page to allow for readjustments of the paper positioning. At the termination of printing there is an automatic chaining to PART4.



2.7.2.4 PVUC-PART4: Upon entering PART4 the program will designate the flow (GPD) for both alternative treatment systems. The operator chooses which flow is to be designated by selecting the appropriate version of PVUC program entered into the computer. Either program permits the options for a hard copy printout of calculations pertaining to the analysis or a direct advancement to a graphical printout, PART5. Given either option, all pertinent calculations are accomplished at this point before execution of the option. Calculated values are stored in an array with six columns (one for each of six five-year horizons) and twenty horizontal lines (one for each variable type under study). If the printout of the result of the calculations is requested, it is executed in tabular format, on one page, with the option for the operator to interject comments about the study which are felt to be pertinent. Once the table is complete there is an automatic chain to PART5.

2.7.2.5 PVUC-PART5: PART5 automatically adjusts the size of the graph to be produced to fit the the maximum space selected, and then prints the Discriminant (i.e, the normalized difference between the PVUC for "A" and PVUC for "B") curve before the printout of the PVUC curves for each alternative wastewater treatment system. Both curves are printed on one graph. The vertical heights of each graph, with appropriate axis labels and captions are set to display attractively on standard sized (8 1/2 inch by 11 inch) paper.

2.8 COST ADJUSTMENT DATA FOR PRICE LEVEL CHANGES

2.8.1 Capital and Operating Cost Function Adjustments

2.8.1.1 Capital cost data for components (unit processes), were extracted from several sources which had different dollar value bases. In order to adjust all data to a current dollar value base (December 1980), each unit process was reviewed for the nature of its construction and the type of materials used both in construction and operation. Then, an appropriate Producer Price Index (PPI) (formerly the Wholesale Price Index) fitting the nature and type of construction and operation of this process, was used to adjust each point estimate of costs (at different flow rates) for the price changes that occurred between the date of the specific price level of the source data and December 1980. For example,



the data retrieved from an EPA publication had costs as of 1974. Updating these costs necessitated a 66.6 percent upward change in each point estimate to bring values into line with December 1980 price levels. In another case, cost estimates gleaned from an EPA document had been set at January 1977 levels. In this instance, the cost data were adjusted by applying the "PPI by Stage of Processing for Materials and Components for Manufacturing" rather than the PPI for all commodities. This cost adjustment resulted in a 49.2 percent increase in the January 1977 data to bring it to December 1980 levels. Another source had data set at the second quarter 1977 PPI dollar values; each point estimate taken from this set was adjusted by a 41.9 percent increase.

2.8.1.2 In instances where the process involved construction-type activity (e.g., concrete or earthen basins for flow equalization tanks), the PPI for "materials and components for construction" was used.

2.8.1.3 After adjusting Cost data to December 1980 levels, cost functions were calculated for each unit process. Thus, all cost functions have a common dollar valid base of December 1980. A similar procedure for O&M Costs, (labor, power, supplies and chemicals), Construction Costs and Capital Cost Recovery Rates, using appropriate indices was followed in this study.

2.8.2 Cost Adjustment Data

2.8.2.1 The interest rate used in this analysis was selected after considering several different measurements of rates of interest and bond yields in the economy as of mid-year 1981. For example, in July 1981, the Council of Economic Advisor's publication of Economic Indicators shows U.S. security yields ranging from 14.699 percent to 15.15 percent, high-grade municipal bonds at 11.03 percent, corporate AAA bonds at 14.38 percent, prime 6-month commercial paper at 16.09 percent, prime rate charged by banks at 20.5 percent and new home mortgage yields at 14.72 percent. The average rate for these measurements led us to the 15.0 percent interest rate used in these calculations.



2.8.2.2 For the rate of inflation the Council of Economic Advisors' Economic Indicators shows a 1.2 percent change in the consumer price index in July 1981 over the preceding month for all items, a 1.6 percent change in housing, and a relatively small 0.4 percent change in energy. After taking into account these and other price changes, including the Producer Price Index, these figures were annualized over a July to July basis resulting in a general inflation rate for computation purposes of 13.0 percent annually.



TABLE 3.1
MATRIX OF PINK WATER TREATMENT SYSTEMS COMPARED ON A PVUC BASIS

	Alternative "A"							
	Granular Carbon w/ Thermal Regen.	Granular Carbon w/ Thermal Regen.	Granular Carbon w/ No Regen.	Surfactant Complexing	Powdered Carbon w/ AST Regen.	UV-Ozone	Liquid/Liquid Extraction	Ultrafiltration
1	Granular Carbon w/ Thermal Regen.		●	●	●	●	●	●
2	Granular Carbon w/ No Regen.	●		●	●	●	●	●
3	Surfactant Complexing	●	●		●	●	●	●
4	Powdered Carbon w/ AST Regen.	●	●	●		●	●	●
5	UV-Ozone	●	●	●	●		●	●
6	Liquid/Liquid Extraction	●	●	●	●	●		●
7	Ultrafiltration	●	●	●	●	●	●	

3.0 FINDINGS AND DISCUSSION

3.1 COMPUTER SIMULATION/OUTPUTS

3.1.1 Table 3.1 presents a convenient comparison of pink water treatment alternatives considered in this study. It shows those combinations of systems that were compared on the PVUC basis. The titles are the same for each of the flows examined, however, the computer outputs are identified as "a" for the 10^5 GPD series and "b" for the 10^6 GPD set.

3.1.2 The full-scale plant designs, the specific individual treatment units of varying sizes and modes and the corresponding capital and O&M costs were used as inputs to the Interactive PVUC Computer Model by means of the Micronet systems to make simulation runs as explained in Section 2.7. The carbon with regeneration alternative was compared with each of the other six pink water treatment methods because this system consistently was shown to be the most economical in terms of unit cost of treatment for flows of both 10^5 and 10^6 GPD. Each comparison consists of two tables and two graphical presentations. The first table lists the alternative treatment system PVUC catalog numbers, the number of units in each system, the capital costs, the O&M costs, unit capacities in gallons, the daily rates of flow through each unit and the estimated life of the unit in years. The second table presents the PVUC analysis and includes specific data, such as total capital costs for each alternative, the ratio of capital costs, interest and inflation rates over the period under consideration, salvage values, and daily flows, and summarizes the Discriminant and the unit treatment costs in \$/K-GAL over the entire time horizon. The first graphical presentation is the Discriminant plot versus time horizon and the second graphical presentation is a dual plot of both alternatives considered and represents unit treatment costs in \$/K-GAL or \$/M-GAL over the time horizons.

3.1.3 By coordinating the full-scale plant designs, the cost data and typical computer simulations/outputs (similar to those which follow in an ascending order of unit treatment costs for daily flows of 10^5 and 10^6 GPD), it has been possible to produce findings upon which this section is based.



<u>Computer*</u> <u>Outputs</u>	<u>Title</u>
3.1.3.1a	Granular Carbon Without Regeneration vs. Granular Carbon With Thermal Regeneration
3.1.3.1b	
3.1.3.2a	Granular Carbon With Thermal Regeneration vs. Surfactant Complexing
3.1.3.2b	
3.1.3.3a	Granular Carbon With Thermal Regeneration vs. Powdered Carbon
3.1.3.3b	
3.1.3.4a	Granular Carbon With Thermal Regeneration vs. UV-Ozone
3.1.3.4b	
3.1.3.5a	Granular Carbon With Thermal Regeneration vs. Liquid/Liquid Extraction
3.1.3.5b	
3.1.3.6a	Granular Carbon With Thermal Regeneration vs. Ultrafiltration
3.1.3.6b	

* a = For 10^5 GPD
b = For 10^6 GPD



COMPUTER OUTPUT 3.1.3.1a
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: NO REGENERATION (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)
FOR FLOW RATE OF 100 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 9, 1981



COMPUTER OUTPUT 3.1.3.1a
 LISTING OF ALL COMPONENTS FOR PVOC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF TABLE. FLOW IS
 100 000 GPD.

ALTERNATIVE (A)						ALTERNATIVE (B)								
CARBON: NO REGENERATION (0.652 LBS TNT/LB C)						CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)								
NAME OF UNIT UNDERWRITTEN BY:						NAME OF UNIT UNDERWRITTEN BY:								
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT LIFE	CAT NOS.	UNIT	UNIT CAPACITY	UNIT LIFE	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT LIFE			
*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS	*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS	*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS
SUMP-STL OR MI						SUMP-STL OR MI								
9028	1	\$ 6900	\$ 0	20000	100000	30		9028	1	\$ 6900	\$ 0	20000	100000	30
PUMP-PRESS. SUMP						PUMP-PRESS. SUMP								
9007	2	\$ 1786	\$ 3326	7.58 ^a	100000	30		9007	2	\$ 1786	\$ 3326	7.58 ^a	100000	30
EQUALIZATION/SEDIMENTATION TAN						EQUALIZATION/SEDIMENTATION TAN								
9018	1	\$ 18777	\$ 0	100000	25000	30		9018	1	\$ 18777	\$ 0	100000	25000	30
PUMP-PRESS. EQUALIZATION						PUMP-PRESS. EQUALIZATION								
9006	2	\$ 1047	\$ 1737	2.66 ^a	100000	30		9006	2	\$ 1047	\$ 1737	2.66 ^a	100000	30
FILTER-PRESSURE-DE						FILTER-PRESSURE-DE								
9015	2	\$ 43865	\$ 896	200	50000	30		9015	2	\$ 43865	\$ 896	200	50000	30
CARBON COLUMN-GRANULAR						CARBON COLUMN WITH THERMAL REG								
9013	1	\$ 151367	\$ 80829	2000	100000	30		9019	1	\$ 151367	\$ 7227	2000	100000	30
WASTE CARBON TNK-STL OR MI						WASTE CARBON TNK-STL OR MI								
9014	3	\$ 5511	\$ 0	12000	1000	30		9014	3	\$ 5511	\$ 0	12000	1000	30
VIRGIN CARBON STORAGE TANK						VIRGIN CARBON STORAGE TANK								
9008	1	\$ 7709	\$ 0	24000	24000	30		9008	1	\$ 7709	\$ 0	24000	24000	30
PUMP-PRESS. BACKWASH-D.E.						PUMP-PRESS. BACKWASH-D.E.								
9004	1	\$ 879	\$ 4	1.89 ^a	10000	30		9004	1	\$ 879	\$ 4	1.89 ^a	10000	30
CONVEYOR SCREW						CONVEYOR SCREW								
9031	1	\$ 4566	\$ 1000	1 ^b	25 ^c	30		9031	1	\$ 4566	\$ 1000	1 ^b	25 ^c	30
HOLDING TANK						CARBON DE-FINE TANK								
9023	1	\$ 7612	\$ 0	25000	100000	30		9040	1	\$ 137843	\$ 1000	2500	2500	30

--CONTINUED

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet



```

!HOLDING TANK
! 9023 1 $ 7612 $ 0      25000 100000 30
!
!CARBON REGEN FURNACE
! 9011 1 $ 5284875 28449 1b 30d 30
!

```

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 9 1981

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



COMPUTER OUTPUT 3.1.3.1a
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: NO REGENERATION (0.652 LBS TNT/LB C))
 WITH TREATMENT B (CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 307750 AND FOR ALTERNATIVE B = \$ 974080;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = 3.16, INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 100000 GALLONS; SYSTEM B 100000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	444000	1297000	2522000	4090000	5971000	8139000
TOT. OP. COSTS FOR ALTERN. B \$	235000	686000	1334000	2164000	3159000	4306000
CURRENT SALVAGE VALUE FOR A \$	256000	205000	153000	102000	51000	0
CURRENT SALVAGE VALUE FOR B \$	811000	649000	487000	324000	162000	0
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	1.31137	.52158	.19449	.06446	.01602	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	175	350	525	700	875	1050
TOT. FLOW (MGAL) FOR ALTERN B	175	350	525	700	875	1050
RSUM FOR ALTERNATIVE A	2.67500	6.30247	9.15230	11.04570	12.20407	12.87883
RSUM FOR ALTERNATIVE B	1.41526	3.33444	4.84220	5.84394	6.45680	6.81379
* THE DISCRIMINANT IS	-.0083	1.1596	2.2779	3.0806	3.5930	3.8998
PVUC (\$/MGAL PROCESSED): A \$	21000	27000	26000	25000	24000	23000
PVUC (\$/MGAL PROCESSED): B \$	22000	22000	21000	21000	20000	20000

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 9 1981.

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: NO REGENERATION (0.652 LBS TNT/LB C) AND SYSTEM (B):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 9 1981





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: NO REGENERATION (0.652 LBS TNT/LB C) AND SYSTEM (B):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 9 1981



COMPUTER OUTPUT 3.1.3.2a
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): SURFACTANT COMPLEXING
FOR FLOW RATE OF 100 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 10, 1981



COMPUTER OUTPUT 3.1.3.2a
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY. FLOW IS
 100 000 GPD.

ALTERNATIVE (A) CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)						ALTERNATIVE (B) SURFACTANT COMPLEXING							
*CAT NOS.	UNIT	UNIT CAP	COST	UNIT CAPACITY	UNIT LIFE	*CAT NOS.	UNIT	UNIT CAP	COST	UNIT CAPACITY	UNIT LIFE		
*NO.	UNIT CAP	COST	O&M COST	(GAL)	GPD	NO.	UNIT CAP	COST	O&M COST	(GAL)	GPD		
SUMP-STL OR MI						SUMP-STL OR MI							
9028	1	\$ 6900	\$ 0	20000	100000	30	9028	1	\$ 6900	\$ 0	20000	100000	30
PUMP-PRESS. SUMP						PUMP-PRESS. SUMP							
9007	2	\$ 1786	\$ 3326	7.58 ^a	100000	30	9007	2	\$ 1786	\$ 3326	7.58 ^a	100000	30
EQUALIZATION/SEDIMENTATION TAN						EQUALIZATION/SEDIMENTATION TAN							
9018	1	\$ 18777	\$ 0	100000	25000	30	9018	1	\$ 18777	\$ 0	100000	25000	30
PUMP-PRESS. EQUALIZATION						PUMP-PRESS. EQUALIZATION							
9006	2	\$ 1047	\$ 1737	2.66 ^a	100000	30	9006	5	\$ 1047	\$ 1737	2.66 ^a	100000	30
FILTER-PRESSURE-DE						SURF. STR/MIX/BODY FEED TNK							
9015	2	\$ 43865	\$ 896	200	50000	30	9024	1	\$ 1361	\$ 0	500	0 ^b	30
CARBON COLUMN WITH THERMAL REG						CHEMICAL FEEDER							
9019	1	\$ 151367	\$ 7227	2000	100000	30	9025	1	\$ 3000	\$ 1000	1 ^b	1 ^b	30
WASTE CARBON TNK-STL OR MI						SURF. STR/MIX/BODY FEED TNK							
9014	3	\$ 5511	\$ 0	12000	1000	30	9024	1	\$ 1361	\$ 0	500	0 ^b	30
VIRGIN CARBON STORAGE TANK						CHEMICAL FEEDER							
9008	1	\$ 7709	\$ 0	24000	24000	30	9025	1	\$ 3000	\$ 1000	1 ^b	1 ^b	30
PUMP-PRESS. BACKWASH-D.E.						SURFACT REACT TANK							
9004	1	\$ 879	\$ 4	1.89 ^a	10000	30	9035	2	\$ 5749	\$ 23000	5000	100000	30
CONVEYOR SCREW						VACUUM FILTER POWDERED CARB.							
9031	1	\$ 4566	\$ 1000	1 ^b	25 ^c	30	9034	1	\$ 73622	\$ 1855	1 ^b	20 ^d	30
CARBON DE-FINE TANK						SURF. STR/MIX/BODY FEED TNK							
9040	1	\$ 137843	\$ 1000	2500	2500	30	9024	1	\$ 1361	\$ 0	500	0 ^b	30

--CONTINUED

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



HOLDING TANK				CHEMICAL FEEDER									
9023	1	\$ 7612	\$ 0	25000	100000	30	9025	1	\$ 3000	\$ 1000	1 ^b	1 ^b	30
CARBON REGEN FURNACE				NEUTRALIZATION TANK									
9011	1	\$ 528487	\$ 28449	1 ^b	30 ^d	30	9022	1	\$ 3749	\$ 80750	5000	100000	30

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

NOTE: Not all values shown relate to column headings,
 a = hydraulic horsepower
 b = BASIC coding
 c = length in feet
 d = square feet



COMPUTER OUTPUT 3.1.3.2a
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C))
 WITH TREATMENT B (SURFACTANT COMPLEXING).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 974080 AND FOR ALTERNATIVE B = \$ 136445;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = .14 INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 100000 GALLONS; SYSTEM B 100000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	235000	686000	1334000	2164000	3159000	4306000
TOT. OP. COSTS FOR ALTERN. B \$	697000	2033000	3954000	6411000	9359000	12756000
CURRENT SALVAGE VALUE FOR A \$	811000	649000	487000	324000	162000	0
CURRENT SALVAGE VALUE FOR B \$	113000	90000	68000	45000	22000	0
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	.05803	.02308	.00860	.00285	.00070	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	175	350	525	700	875	1050
TOT. FLOW (MGAL) FOR ALTERN B	175	350	525	700	875	1050
RSUM FOR ALTERNATIVE A	0.44713	1.05348	1.52984	1.84633	2.03995	2.15274
RSUM FOR ALTERNATIVE B	1.32463	3.12091	4.53212	5.46972	6.04333	6.37746
*THE DISCRIMINANT IS	-.3738	-1.3492	-2.1952	-2.7809	-3.1478	-3.3647
PVUC (\$/MGAL PROCESSED): A \$	2200	2200	2100	2100	2000	2000
PVUC (\$/MGAL PROCESSED): B \$	4100	3900	3700	3600	3400	3300

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 SURFACTANT COMPLEXING
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 SURFACTANT COMPLEXING
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981



COMPUTER OUTPUT 3.1.3.3a
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGEN (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): POWDERED CARBON ADSORPTION
FOR FLOW RATE OF 100 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 10, 1981



COMPUTER OUTPUT 3.1.3.3a
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF TABLE. FLOW IS
 100 000 GPD.

ALTERNATIVE (A)						ALTERNATIVE (B)								
CARBON: THERMAL REGEN (0.652 LBS TNT/LB C)						POWDERED CARBON ADSORPTION								
* NAME OF UNIT UNDERWRITTEN BY:						* NAME OF UNIT UNDERWRITTEN BY:								
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT COST	UNIT CAPACITY	UNIT LIFE	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT COST	UNIT CAPACITY	UNIT LIFE			
*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS	NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS	NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS
SUMP-STL OR MI						SUMP-STL OR MI								
9028	1	\$ 6900	\$ 0	20000	100000 30	9028	1	\$ 6900	\$ 0	20000	100000		30	
PUMP-PRESS. SUMP						PUMP-PRESS. SUMP								
9007	2	\$ 1786	\$ 3326	7.58 ^a	100000 30	9007	2	\$ 1786	\$ 3326	7.58 ^a	100000		30	
EQUALIZATION/SEDIMENTATION TAN						EQUALIZATION/SEDIMENTATION TAN								
9018	1	\$ 18777	\$ 0	100000	25000 30	9018	1	\$ 18777	\$ 0	100000	25000		30	
PUMP-PRESS. EQUALIZATION						PUMP-PRESS. EQUALIZATION								
9006	2	\$ 1047	\$ 1737	2.66 ^a	100000 30	9006	3	\$ 1047	\$ 1737	2.66 ^a	100000		30	
FILTER-PRESSURE-DE						SURF. STR/MIX/BODY FEED TANK								
9015	2	\$ 43865	\$ 896	200	50000 30	9024	2	\$ 1361	\$ 0	500	0 ^b		30	
CARBON COLUMN WITH THERMAL REG						POWD. CARB. MIX TANK								
9019	1	\$ 151367	\$ 7227	2000	100000 30	9036	1	\$ 670	\$ 1000	100	100000		30	
WASTE CARBON TNK-STL OR MI						POWD. CARB. CLARIFIER								
9014	3	\$ 5511	\$ 0	12000	1000 30	9037	2	\$ 1209755	\$ 9956	5000	100000		30	
VIRGIN CARBON STORAGE TANK						THICKENER-GRAVITY								
9008	1	\$ 7709	\$ 0	24000	24000 30	9030	1	\$ 24204	\$ 3954	2000	10000		30	
PUMP-PRESS. BACKWASH-D.E.						POLYMER ADDITION								
9004	1	\$ 879	\$ 4	1.89 ^a	10000 30	9033	1	\$ 7515	\$ 7697	500	100000		30	
CONVEYOR SCREW						VACUUM FILTER: POWDERED CARB.								
9031	1	\$ 4566	\$ 1000	1 ^b	25 ^c 30	9034	1	\$ 73622	\$ 1855	1 ^b	20 ^d		30	
CARBON DE-FINE TANK						CONVEYOR SCREW								
9040	1	\$ 137843	\$ 1000	2500	2500 30	9031	2	\$ 4566	\$ 1000	1 ^b	25 ^c		30	

--CONTINUED

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



HOLDING TANK						FAST-FURNACE (250 LB/DAY)				
9023	1	\$ 7612	\$ 0	25000	100000	30	9032	1	\$ 134000	\$ 24000 1 ^b 100000 30
CARBON REGEN FURNACE							!FILTER-PRESSURE-DE			
9011	1	\$ 5284875	28449	1 ^b	30 ^c	30	9015	2	\$ 43865	\$ 896 2000 50000 30
							!PUMP-PRESS. BACKWASH-D.E.			
							9004	1	\$ 879	\$ 4 1.89 ^a 10000 30
							!DRY FEEDER			
							9044	2	\$ 23489	\$ 21000 100000 100000 30
							!HOLDING TANK			
							9023	1	\$ 7612	\$ 0 25000 100000 30

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



COMPUTER OUTPUT 3.1.3.3a
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGEN (0.652 LBS TNT/LB C))
 WITH TREATMENT B (POWDERED CARBON ADSORPTION).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 974000 AND FOR ALTERNATIVE B = \$ 669416;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = .68; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 100000 GALLONS; SYSTEM B = 100000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOT. YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	235000	686000	1334000	2164000	3159000	4306000
TOT. OP. COSTS FOR ALTERN. B \$	740000	2159000	4200000	6810000	9941000	13550000
CURRENT SALVAGE VALUE FOR A \$	811000	649000	487000	324000	162000	0
CURRENT SALVAGE VALUE FOR B \$	557000	446000	334000	223000	111000	0
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	.28472	.11324	.04222	.01399	.00347	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	175	350	525	700	875	1050
TOT. FLOW (MGAL) FOR ALTERN B	175	350	525	700	875	1050
RSUM FOR ALTERNATIVE A	0.44713	1.05348	1.52984	1.84633	2.03995	2.15274
RSUM FOR ALTERNATIVE B	1.40700	3.31498	4.81395	5.80984	6.41913	6.77403
* THE DISCRIMINANT IS	-.7766	-2.0002	-2.9905	-3.6571	-4.0679	-4.3085
PVUC (\$/MGAL PROCESSED): A \$	2200	2200	2100	2100	2000	2000
PVUC (\$/MGAL PROCESSED): B \$	4800	4600	4500	4300	4200	4000

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN (0.652 LBS TNT/LB C) AND SYSTEM (B):
 POWDERED CARBON ADSORPTION
 FC² FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981





PVC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN (0.652 LBS TNT/LB C) AND SYSTEM (B):
 POWDERED CARBON ADSORPTION
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981



COMPUTER OUTPUT 3.1.3.4a
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGENERATION (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): ULTRAVIOLET-OZONE
FOR FLOW RATE OF 100 000 GPD

BY
VINCENT J. CICCONE
SEPTEMBER 23, 1981



COMPUTER OUTPUT 3.1.3.4a
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF TABLE. FLOW IS
 100 000 GPD.

ALTERNATIVE (A)							ALTERNATIVE (B)							
CARBON: THERMAL REGENERATION (0.652 LBS TNT/L)							ULTRAVIOLET-OZONE							
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	LIF	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	LIF	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	LIF
*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS	*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS	*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	YRS
SUMP-STL OR MI							SUMP-STL OR MI							
9028	1	\$ 6900	\$ 0	20000	100000	30	9028	1	\$ 6900	\$ 0	20000	100000	30	
PUMP-PRESS. SUMP							PUMP-PRESS. SUMP							
9007	2	\$ 1786	\$ 3326	7.58 ^a	100000	30	9007	2	\$ 1786	\$ 3326	7.58 ^a	100000	30	
EQUALIZATION/SEDIMENTATION TAN							EQUALIZATION/SEDIMENTATION TAN							
9018	1	\$ 18777	\$ 0	100000	25000	30	9018	1	\$ 18777	\$ 0	100000	25000	30	
PUMP-PRESS. EQUALIZATION							PUMP-PRESS. EQUALIZATION							
9006	2	\$ 1047	\$ 1737	2.66 ^a	100000	30	9006	2	\$ 1047	\$ 1737	2.66 ^a	100000	30	
FILTER-PRESSURE-DE							FILTER-PRESSURE-DE							
9015	2	\$ 43865	\$ 896	200	50000	30	9015	2	\$ 43865	\$ 896	200	50000	30	
CARBON COLUMN WITH THERMAL REG							OZONE PRECONTACTOR							
9019	1	\$ 151367	\$ 7227	2000	100000	30	9041	1	\$ 1846	\$ 0	1000	100000	30	
WASTE CARBON TNK-STL OR MI							PUMP-PRESS. EQUALIZATION							
9014	3	\$ 5511	\$ 0	12000	1000	30	9006	1	\$ 1047	\$ 1737	2.66 ^a	100000	30	
VIRGIN CARBON STORAGE TANK							OZONE REACTOR							
9008	1	\$ 7709	\$ 0	24000	24000	30	9003	1	\$ 326000	\$ 0	10000	100000	30	
PUMP-PRESS. BACKWASH-D.E.							UV LAMPS							
9004	1	\$ 879	\$ 4	1.89 ^a	10000	30	9005	1	\$ 1 ^b	\$ 208350	2304 ^e	100000	30	
CONVEYOR SCREW							HOLDING TANK							
9031	1	\$ 4566	\$ 1000	1 ^b	25 ^c	30	9023	1	\$ 7612	\$ 0	25000	100000	30	
CARBON DE-FINE TANK							PUMP-PRESS. BACKWASH-D.E.							
9040	1	\$ 137843	\$ 1000	2500	2500	30	9004	1	\$ 879	\$ 4	1.89 ^a	10000	30	

--CONTINUED

NOTE: Not all values shown relate to column headings

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet
- e = number of UV lamps



HOLDING TANK				!PUMP-PRESS. SUMP			
9023	1	\$ 7612	\$ 0	25000	100000	30	! 9007 1 \$ 1786 \$ 3326 7.58 ^a 100000 30
CARBON REGEN FURNACE				!OZONE GENERATOR			
9011	1	\$ 528487	\$ 28449	1 ^b	30 ^d	30	! 9012 1 \$ 160127 \$ 98784 1 ^b 100000 30
				!COOLER-CHILLER			
				1 ^b	1 ^b	30	! 9021 1 \$ 5000 \$ 2000 1 ^b 1 ^b 30

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY VINCENT J. CICCONI

SEPTEMBER 23 1981

NOTE: Not all values shown relate to column headings,

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



COMPUTER OUTPUT 3.1.3.4a
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGENERATION (0.652 LBS TNT/L)
 WITH TREATMENT B (ULTRAVIOLET-OZONE).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 974080 AND FOR ALTERNATIVE B = \$ 623380;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = .63; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 100000 GALLONS; SYSTEM B = 100000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	235000	686000	1334000	2164000	3159000	4306000
TOT. OP. COSTS FOR ALTERN. B \$	1547000	4512000	8776000	14228000	20771000	28311000
CURRENT SALVAGE VALUE FOR A \$	811000	649000	487000	324000	162000	0
CURRENT SALVAGE VALUE FOR B \$	519000	415000	311000	207000	103000	0
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	.26514	.10546	.03932	.01303	.00324	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	175	350	525	700	875	1050
TOT. FLOW (MGAL) FOR ALTERN B	175	350	525	700	875	1050
RSUM FOR ALTERNATIVE A	0.44713	1.05348	1.52984	1.84633	2.03995	2.15274
RSUM FOR ALTERNATIVE B	2.93979	6.92634	10.05828	12.13910	13.41214	14.15369
*THE DISCRIMINANT IS	-2.2817	-5.5721	-8.1905	-9.9400	-11.0139	-11.6409
PVUC (\$/MGAL PROCESSED): A \$	2200	2200	2100	2100	2000	2000
PVUC (\$/MGAL PROCESSED): B \$	9400	9000	8700	8300	8000	7700

STUDY CONDUCTED BY VINCENT J CICCONE

SEPTEMBER 23 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGENERATION (0.652 LBS TNT/L AND SYSTEM (B):
 ULTRAVIOLET-OZONE
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY VINCENT J CICCONE

SEPTEMBER 23 1981





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGENERATION (0.652 LBS TNT/L AND SYSTEM (B):
 ULTRAVIOLET-OZONE
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY VINCENT J CICCONE

SEPTEMBER 23 1981



COMPUTER OUTPUT 3.1.3.5a
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CATION: THERMAL REGEN. (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): LIQUID-LIQUID EXTRACTION
FOR FLOW RATE OF 100 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 10, 1981



COMPUTER OUTPUT 3.1.3.5a
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF TABLE. FLOW IS
 100 000 GPD.

ALTERNATIVE (A) CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)						ALTERNATIVE (B) LIQUID-LIQUID EXTRACTION					
NAME OF UNIT UNDERWRITTEN BY:						NAME OF UNIT UNDERWRITTEN BY:					
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT LIF	UNIT CAP COST	O&M COST (GAL)	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT LIF	UNIT CAP COST	O&M COST (GAL)
*NO.			YRS			*NO.			YRS		
9028	1	20000	30	\$ 6900	\$ 0	9028	1	20000	30	\$ 6900	\$ 0
9007	2	100000	30	\$ 1786	\$ 3326	9007	2	100000	30	\$ 1786	\$ 3326
9018	1	100000	30	\$ 18777	\$ 0	9018	1	100000	30	\$ 18777	\$ 0
9006	2	100000	30	\$ 1047	\$ 1737	9006	3	100000	30	\$ 1047	\$ 1737
9015	2	50000	30	\$ 43865	\$ 896	9015	2	50000	30	\$ 43865	\$ 896
9019	1	100000	30	\$ 151367	\$ 7227	9045	2	6000	30	\$ 1062127	\$ 775931
9014	3	1000	30	\$ 5511	\$ 0	9028	1	20000	30	\$ 6900	\$ 0
9008	1	24000	30	\$ 7709	\$ 0	9046	1	1000000	30	\$ 4821705	\$ 92395
9004	1	10000	30	\$ 879	\$ 4	9024	1	500	30	\$ 1361	\$ 0
9031	1	25	30	\$ 4566	\$ 1000	9025	1	1	30	\$ 3000	\$ 1000
9040	1	2500	30	\$ 1378435	\$ 1000	9023	1	25000	30	\$ 7612	\$ 0

--CONTINUED

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- f = ten thousand pounds per day



HOLDING TANK				PUMP-PRESS. BACKWASH-D.E.			
9023	1	\$ 7612	\$ 0	25000	100000	30	9004 1 \$ 878 \$ 4 1.09 ^a 10000 30
CARBON REGEN FURNACE				SURF. STR/MIX/BODY FEED TR			
9011	1	\$ 528487	\$ 28449	1 ^d	30 ^d	30	9025 1 \$ 1361 \$ 0 500 0 ^b 30
				CHEMICAL FEEDER			
				9025 1 \$ 3000 \$ 1000 1 ^b 1 ^b 30			

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



COMPUTER OUTPUT 3.1.3.5a
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGEN. (0.052 LBS TNT/LB C))
 WITH TREATMENT B (LIQUID-LIQUID EXTRACTION).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 974000 AND FOR ALTERNATIVE B = \$ 2750668;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = 2.82; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 100000 GALLONS; SYSTEM B = 100000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	235000	686000	1334000	2164000	3159000	4306000
TOT. OP. COSTS FOR ALTERN. B \$	7876000	22967000	44668000	72423000	105723000	144103000
CURRENT SALVAGE VALUE FOR A \$	811000	649000	487000	324000	162000	0
CURRENT SALVAGE VALUE FOR B \$	2292000	1833000	1375000	916000	458000	-1000
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	1.16996	.46534	.17351	.05751	.01429	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	175	350	525	700	875	1050
TOT. FLOW (MGAL) FOR ALTERN B	175	350	525	700	875	1050
RSUM FOR ALTERNATIVE A	0.44713	1.05348	1.52984	1.84633	2.03995	2.15274
RSUM FOR ALTERNATIVE B	14.96308	35.25396	51.19501	61.78607	68.26564	72.03998
*THE DISCRIMINANT IS	-15.5841	-35.7237	-51.3769	-61.7264	-68.0403	-71.7110
PVUC (\$/MGAL PROCESSED): A \$	2200	2200	2100	2100	2000	2000
PVUC (\$/MGAL PROCESSED): B \$	47600	45700	43900	42200	40600	39100

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 LIQUID-LIQUID EXTRACTION
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1991





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 LIQUID-LIQUID EXTRACTION
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981



COMPUTER OUTPUT 3.1.3.6a
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGEN. (0.652 '9S TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): ULTRAFILTRATION
FOR FLOW RATE OF 100 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 10, 1981



COMPUTER OUTPUT 3.1.3.6a
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF TABLE. FLOW IS
 100 000 GPD.

ALTERNATIVE (A)					ALTERNATIVE (B)								
CARBON: THERMAL REGEN. (0.652 LBSTNT/LB C)					ULTRAFILTRATION								
* NAME OF UNIT UNDERWRITTEN BY:					* NAME OF UNIT UNDERWRITTEN BY:								
*CAT NOS.	UNIT	UNIT CAPACTY	UNIT	LIF	*CAT NOS.	UNIT	UNIT CAPACTY	UNIT	LIF				
*NO.	UNIT CAP	COST	O&M COST (GAL)	GPD	YRS	NO.	UNIT CAP	COST	O&M COST (GAL)	GPD	YRS		
*****					*****								
SUMP-STL OR MI					SUMP-STL OR MI								
9028	1	\$ 6900	\$ 0	20000	100000	30	9028	1	\$ 6900	\$ 0	20000	100000	30
PUMP-PRESS. SUMP					PUMP-PRESS. SUMP								
9007	2	\$ 1786	\$ 3326	7.58 ^a	100000	30	9007	2	\$ 1786	\$ 3326	7.58 ^a	100000	30
EQUALIZATION/SEDIMENTATION TAN					EQUALIZATION/SEDIMENTATION TAN								
9018	1	\$ 18777	\$ 0	100000	25000	30	9018	1	\$ 18777	\$ 0	100000	25000	30
PUMP-PRESS. EQUALIZATION					PUMP-PRESS. EQUALIZATION								
9006	2	\$ 1047	\$ 1737	2.66 ^a	100000	30	9006	2	\$ 1047	\$ 1737	2.66 ^a	100000	30
FILTER-PRESSURE-DE					FILTER-PRESSURE-DE								
9015	2	\$ 43865	\$ 896	200	50000	30	9015	2	\$ 43865	\$ 896	200	50000	30
CARBON COLUMN WITH THERMAL REG					UF MEMBRANE MODULE								
9019	1	\$ 151367	\$ 7227	2000	100000	30	9027	10	\$ 1513889	\$ 219239	.19 ^g	0 ^b	30
WASTE CARBON TNK-STL OR MI					UF-RECIRC. PUMP								
9014	3	\$ 5511	\$ 0	12000	1000	30	9026	10	\$ 5774	\$ 13844	75.6 ^a	4320000	30
VIRGIN CARBON STORAGE TANK					PUMP-PRESS. BACKWASH-D.E.								
9008	1	\$ 7709	\$ 0	24000	24000	30	9004	1	\$ 879	\$ 4	1.89 ^a	10000	30
PUMP-PRESS. BACKWASH-D.E.					HOLDING TANK								
9004	1	\$ 879	\$ 4	1.89 ^a	10000	30	9023	2	\$ 7612	\$ 0	25000	100000	30
CONVEYOR SCREW													
9031	1	\$ 4566	\$ 1000	1 ^b	25 ^c	30							
CARBON DE-FINE TANK													
9040	1	\$ 137843	\$ 1000	2500	2500	30							

--CONTINUED

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet
- g = million gallons per day



HOLDING TANK						
9023	1	\$ 7612	\$ 0	25000	100000	30
CARBON REGEN FURNACE						
9011	1	\$ 5284875	28449	1 ^b	30 ^d	30

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

NOTE: Not all values shown relate to column headings,
 a = hydraulic horsepower
 b = BASIC coding
 c = length in feet
 d = square feet



COMPUTER OUTPUT 3.1.3.6a
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGEN. (0.652 LBSTNT/LB C))
 WITH TREATMENT B (ULTRAFILTRATION).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 974080 AND FOR ALTERNATIVE B = \$15331815;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = 15.73; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 160000 GALLONS SYSTEM B = 100000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	235000	686000	1334000	2164000	3159000	4306000
TOT. OP. COSTS FOR ALTERN. B \$	11116000	32416000	63043000	102215000	149214000	203382000
CURRENT SALVAGE VALUE FOR A \$	811000	649000	487000	324000	162000	0
CURRENT SALVAGE VALUE FOR B \$	12776000	10221000	7665000	5110000	2555000	-1000
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	6.52120	2.59375	.96716	.32056	.07968	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	175	350	525	700	875	1050
TOT. FLOW (MGAL) FOR ALTERN B	175	350	525	700	875	1050
RSUM FOR ALTERNATIVE A	0.44713	1.05348	1.52984	1.84633	2.03995	2.15274
RSUM FOR ALTERNATIVE B	21.11845	49.75642	72.25516	87.20307	96.34814	????????
*THE DISCRIMINANT IS	-29.3042	-61.0137	-84.5593	-99.7963	????????	????????
PVUC (\$/MGAL PROCESSED): A \$	2200	2200	2100	2100	2000	2000
PVUC (\$/MGAL PROCESSED): B \$	78100	75400	72900	70500	68300	66100

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBSNT/LB C) AND SYSTEM (B):
 ULTRAFILTRATION
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBSNT/LB C) AND SYSTEM (B):
 ULTRAFILTRATION
 FOR FLOW OF 100 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981



COMPUTER OUTPUT 3.1.3.1b
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: NO REGENERATION (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)⁽⁶⁾
FOR FLOW RATE OF 1 000 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 9, 1981



COMPUTER OUTPUT 3.1,3.1b
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF THE TABLE. THE
 LIFE SPAN FOR ALL UNITS IS SET AT 30 YEARS AND THE
 FLOW IS 1 000 000 GPD.

ALTERNATIVE (A)					ALTERNATIVE (B)						
CARBON: NO REGENERATION (0.652 LBS TNT/LB C)					CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)						
*CAT NOS.	UNIT NO.	UNIT CAP COST	UNIT O&M COST	UNIT CAPACITY (GAL)	UNIT GPD	*CAT NOS.	UNIT NO.	UNIT CAP COST	UNIT O&M COST	UNIT CAPACITY (GAL)	UNIT GPD
SUMP-STL OR MI					SUMP-STL OR MI						
	9228 1	\$ 19006	\$ 0	200000	1000000		9228 1	\$ 19006	\$ 0	200000	1000000
PUMP-PRESS. SUMP					PUMP-PRESS. SUMP						
	9207 2	\$ 1786	\$ 3326	7.58 ^a	1000000		9207 2	\$ 1786	\$ 3326	7.58 ^a	1000000
EQUALIZATION/SEDIMENTATION TAN					EQUALIZATION/SEDIMENTATION TAN						
	9218 2	\$ 68176	\$ 0	1000000	1000000		9218 2	\$ 68176	\$ 0	1000000	1000000
PUMP-PRESS. EQUALIZATION					PUMP-PRESS. EQUALIZATION						
	9206 2	\$ 1047	\$ 1737	2.66 ^a	1000000		9206 2	\$ 1047	\$ 1737	2.66 ^a	1000000
MIXED MEDIA PRESS. FILT.					MIXED MEDIA PRESS. FILT.						
	9239 4	\$ 113523	\$ 460	5000	340000		9239 4	\$ 113523	\$ 460	5000	340000
CARBON COLUMN-GRANULAR					CARBON COLUMN WITH THERMAL REG						
	9213 1	\$ 359106	\$ 748216	21000	1000000		9219 1	\$ 359106	\$ 47821	21000	1000000
CONVEYOR SCREW					CONVEYOR SCREW						
	9231 3	\$ 4566	\$ 2000	1 ^b	25 ^c		9231 3	\$ 4566	\$ 2000	1 ^b	25 ^c
WASTE CARBON TNK-STL OR MI					WASTE CARBON TNK-STL OR MI						
	9214 3	\$ 7612	\$ 0	25000	10000		9214 3	\$ 7612	\$ 0	25000	10000
HOLDING TANK					CARBON REGEN FURNACE						
	9223 1	\$ 7612	\$ 0	25000	1000000		9211 1	\$ 1339783	\$ 147598	1 ^b	300 ^d
PUMP-PRESS. BACKWASH					CARBON DE-FINE TANK						
	9204 1	\$ 3700	\$ 83	31.6 ^a	100000		9240 1	\$ 1408525	2000	25000	25000
VIRGIN CARBON STORAGE TANK					HOLDING TANK						
	9208 1	\$ 7709	\$ 0	24000	24000		9223 1	\$ 7612	\$ 0	25000	1000000

NOTE: Not all values shown relate to colum headings.

--CONTINUED

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



!PUMP-PRESS. BACKWASH			
! 9204	1	\$ 3700	\$ 83
			31.6 ^a 100000
!			
!VIRGIN CARBON STORAGE TANK			
! 9208	1	\$ 7709	\$ 0
			24000 24000
!			

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN SEPTEMBER 9 1981

NOTE: Not all values shown relate to column headings.
a = hydraulic horsepower



COMPUTER OUTPUT 3.1.3.1b
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: NO REGENERATION (0.652 LBS TNT/LB C))
 WITH TREATMENT B (CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 1029786 AND FOR ALTERNATIVE B = \$ 2510422;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = 2.43; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA', = 1.0000
 DAILY FLOW IN SYSTEM A = 1000.00 GALLONS; SYSTEM B = 1000000 GALLONS


VALUES USED FOR DECISION PROCFS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	3636000	10602000	20620000	33432000	48805000	66522000
TOT. OP. COSTS FOR ALTERN. B \$	1022000	2981000	5798000	9401000	13723000	18705000
CURRENT SALVAGE VALUE FOR A \$	858000	686000	514000	343000	171000	-10000
CURRENT SALVAGE VALUE FOR B \$	2092000	1673000	1255000	836000	418000	-1000
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	1.01001	.40172	.14979	.04965	.01234	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	1750	3500	5250	7000	8750	10500
TOT. FLOW (MGAL) FOR ALTERN B	1750	3500	5250	7000	8750	10500
RSUM FOR ALTERNATIVE A	6.53375	15.39395	22.35475	26.97942	29.80878	31.45688
RSUM FOR ALTERNATIVE B	1.83728	4.32874	6.28611	7.58656	8.38217	8.84561
* THE DISCRIMINANT IS	3.8543	9.0643	14.7191	17.9843	19.9960	21.1734
PVUC (\$/MGAL PROCESSED): A \$	2100	2000	2000	1900	1800	1700
PVUC (\$/MGAL PROCESSED): B \$	820	790	770	750	730	710

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 9 1981.

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: NO REGENERATION (0.652 LBS TNT/LB C) AND SYSTEM (B):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 9 1981





PVUC \$/NGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: NO REGENERATION (0.652 LBS TNT/LB C) AND SYSTEM (B):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 9 1981



COMPUTER OUTPUT 3.1.3.2b
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): SURFACTANT COMPLEXING
FOR FLOW RATE OF 1 000 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 10, 1981



COMPUTER OUTPUT 3.1.3.2b
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF THE TABLE. THE
 LIFE SPAN FOR ALL UNITS IS SET AT 30 YEARS AND THE
 FLOW IS 1 000 000 GPD.

ALTERNATIVE (A) CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)					ALTERNATIVE (B) SURFACTANT COMPLEXING				
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT		*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	
*NO.	UNIT CAP COST	O&M COST (GAL)	GPD		NO.	UNIT CAP COST	O&M COST (GAL)	GPD	
SUMP-STL OR MI					SUMP-STL OR MI				
9228	1	\$ 19006 \$ 0	200000	1000000	9228	1	\$ 19006 \$ 0	200000	1000000
PUMP-PRESS. SUMP					PUMP-PRESS. SUMP				
9207	2	\$ 1786 \$ 3326	7.58 ^a	1000000	9207	2	\$ 1786 \$ 3326	7.58 ^a	1000000
EQUALIZATION/SEDIMENTATION TAN					EQUALIZATION/SEDIMENTATION TAN				
9218	2	\$ 68176 \$ 0	1000000	1000000	9218	2	\$ 68176 \$ 0	1000000	1000000
PUMP-PRESS. EQUALIZATION					PUMP-PRESS. EQUALIZATION				
9206	2	\$ 1047 \$ 1737	2.66 ^a	1000000	9206	5	\$ 1047 \$ 1737	2.66 ^a	1000000
MIXED MEDIA PRESS. FILT.					SURF. STR/MIX/BODY FEED TNK				
9239	4	\$ 113523 \$ 460	5000	340000	9224	3	\$ 1361 \$ 0	500	0 ^b
CARBON COLUMN WITH THERMAL REG					CHEMICAL FEEDER				
9219	1	\$ 359106 \$ 47821	21000	1000000	9225	3	\$ 3000 \$ 1000	1 ^b	1 ^b
CONVEYOR SCREW					SURFACT REACT TANK				
9231	3	\$ 4566 \$ 2000	1 ^b	25 ^c	9235	2	\$ 9612 \$ 264500	25000	1000000
WASTE CARBON TNK-STL OR MI					VACUUM FILTER POWDERED CARB.				
9217	3	\$ 7612 \$ 0	25000	10000	9234	1	\$ 282495 \$ 11829	1 ^b	200 ^d
CARBON REGEN FURNACE					NEUTRALIZATION TANK				
9211	1	\$ 1339783 \$ 147598	1 ^b	300 ^d	9222	1	\$ 9612 \$ 789500	25000	1000000
CARBON DE-FINE TANK									
9240	1	\$ 140852 \$ 2000	25000	25000					
HOLDING TANK									
9223	1	\$ 7612 \$ 0	25000	1000000					

--CONTINUED

NOTE: Not all values shown relate to column headings,

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



PUMP-PRESS. BACKWASH				
9204	1	\$ 3700	\$ 83	31.6 ^a 100000
VIRGIN CARBON STORAGE TANK				
9208	1	\$ 7709	\$ 0	24000 24000

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

NOTE: Not all values shown relate to column headings,
a = hydraulic horsepower



COMPUTER OUTPUT 3.1.3.2b
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C))
 WITH TREATMENT B (SURFACTANT COMPLEXING).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 2510422 AND FOR ALTERNATIVE B = \$ 489588;
 RATIO OF CAPITAL COSTS (B TO CAPITAL COSTS OF A = .19; INTEREST RATE = .15;
 INFLATION RATE = .13; NOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 100000 GALLONS; SYSTEM B - 100000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	1022000	2981000	5798000	9401000	13723000	18706000
TOT. OP. COSTS FOR ALTERN. B \$	6399000	18661000	36292000	58843000	85899000	117082000
CURRENT SALVAGE VALUE FOR A \$	2092000	1673000	1255000	836000	418000	-1000
CURRENT SALVAGE VALUE FOR B \$	407000	325000	244000	162000	81000	0
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	.08063	.03207	.01195	.00396	.00098	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	1750	3500	5250	7000	8750	10500
TOT. FLOW (MGAL) FOR ALTERN B	1750	3500	5250	7000	8750	10500
RSUM FOR ALTERNATIVE A	0.75366	1.77567	2.57859	3.11204	3.43841	3.62852
RSUM FOR ALTERNATIVE B	4.71723	11.11411	16.13966	19.47858	21.52131	22.71121
*THE DISCRIMINANT IS	-3.4918	-8.6657	-12.8051	-15.5775	-17.2816	-18.2773
PVUC (\$/MGAL PROCESSED): A \$	820	790	770	750	730	710
PVUC (\$/MGAL PROCESSED): B \$	3700	3500	3400	3200	3100	3000

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 SURFACTANT COMPLEXING
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 SURFACTANT COMPLEXING
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981



COMPUTER OUTPUT 3.1.3.3b
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGEN (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): POWDERED CARBON ADSORPTION
FOR FLOW RATE OF 1 000 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 10, 1981



COMPUTER OUTPUT 3.1.3.3b
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF THE TABLE. THE
 LIFE SPAN FOR ALL UNITS IS SET AT 30 YEARS AND THE
 FLOW IS 1 000 000 GPD.

ALTERNATIVE (A) CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)					ALTERNATIVE (B) POWDERED CARBON ADSORPTION						
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT COST	UNIT GPD	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT COST	UNIT GPD		
*NO.	UNIT CAP	O&M COST (GAL)			NO.	UNIT CAP	O&M COST (GAL)				
SUMP-STL OR MI					SUMP-STL OR MI						
9228	1	\$ 19006	\$ 0	200000	1000000	9228	1	\$ 19006	\$ 0	200000	1000000
PUMP-PRESS. SUMP					PUMP-PRESS. SUMP						
9207	2	\$ 1786	\$ 3326	7.58 ^a	1000000	9207	2	\$ 1786	\$ 3326	7.58 ^a	1000000
EQUALIZATION/SEDIMENTATION TAN					EQUALIZATION/SEDIMENTATION TAN						
9218	2	\$ 68176	\$ 0	1000000	1000000	9218	2	\$ 68176	\$ 0	1000000	1000000
PUMP-PRESS. EQUALIZATION					PUMP-PRESS. EQUALIZATION						
9206	2	\$ 1047	\$ 1737	2.66 ^a	1000000	9206	3	\$ 1047	\$ 1737	2.66 ^a	1000000
MIXED MEDIA PRESS. FILT.					SURF. STR/MIX/BODY FEED TNK						
9239	4	\$ 113523	\$ 460	5000	340000	9224	2	\$ 1361	\$ 0	500	0 ^b
CARBON COLUMN WITH THERMAL REG					POWD. CARB. MIX TANK						
9219	1	\$ 359106	\$ 47821	21000	1000000	9236	1	\$ 1846	\$ 3000	1000	1000000
CONVEYOR SCREW					POWD. CARB. CLARIFIER						
9231	3	\$ 4566	\$ 2000	1 ^b	25 ^c	9237	2	\$ 247000	\$ 221570	36000	1000000
WASTE CARBON TNK-STL OR MI					THICKNER-GRAVITY						
9214	3	\$ 7612	\$ 0	25000	10000	9230	1	\$ 24204	\$ 3954	2000	10000
CARBON REGEN FURNACE					POLYMER ADDITION						
9211	1	\$ 1339783	\$ 147598	1 ^b	300 ^d	9233	1	\$ 18482	\$ 18098	500	1000000
CARBON DE-FINE TANK					VACUUM FILTER POWDERED CARB.						
9240	1	\$ 140852	\$ 2000	25000	25000	9234	1	\$ 282495	\$ 11829	1 ^b	200 ^d
HOLDING TANK					CONVEYOR SCREW						
9223	1	\$ 7612	\$ 0	25000	1000000	9231	2	\$ 4566	\$ 2000	1 ^b	25 ^c

--CONTINUED

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet



PUMP-PRESS. BACKWASH					!AST-FURNACE (250 LB/DAY)					
9204	1	\$ 3700	\$ 83	31.6 ^a	100000	9232	1	\$ 1500000	\$ 238000 1 ^b	1000000
VIRGIN CARBON STORAGE TANK						!MIXED MEDIA PRESS. FILT.				
9208	1	\$ 7709	\$ 0	24000	24000	9239	4	\$ 1135235	460	5000 340000
						!PUMP-PRESS. BACKWASH				
						9204	1	\$ 3700	\$ 83	31.6 ^a 100000
						!DRY FEEDER				
						9244	2	\$ 36412	\$ 123000	1000000 1000000
						!HOLDING TANK				
						9223	1	\$ 7612	\$ 0	25000 1000000

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

NOTE: Not all values shown relate to column headings,
a = hydraulic horsepower
b = BASIC coding



COMPUTER OUTPUT 3.1.3.3b
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C))
 WITH TREATMENT B (POWDERED CARBON ADSORPTION).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 2510422 AND FOR ALTERNATIVE B = \$ 3033189;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = 1.20; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 1000000 GALLONS; SYSTEM B = 1000000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	1022000	2981000	5798000	9401000	13723000	18706000
TOT. OP. COSTS FOR ALTERN. B \$	4658000	13585000	26420000	42836000	62533000	85234000
CURRENT SALVAGE VALUE FOR A \$	2092000	1673000	1255000	836000	418000	-1000
CURRENT SALVAGE VALUE FOR B \$	2527000	2022000	1516300	1011000	505000	0
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	.50059	.19910	.07424	.02460	.00611	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	1750	3500	5250	7000	8750	10500
TOT. FLOW (MGAL) FOR ALTERN B	1750	3500	5250	7000	8750	10500
RSUM FOR ALTERNATIVE A	0.75366	1.77567	2.57859	3.11204	3.43841	3.62852
RSUM FOR ALTERNATIVE B	3.43408	8.09092	11.74945	14.18014	15.66722	16.53345
*THE DISCRIMINANT IS	-2.8023	-6.4891	-9.3663	-11.2720	-12.4359	-13.1131
PVUC (\$/MGAL PROCESSED): A \$	820	790	770	750	730	710
PVUC (\$/MGAL PROCESSED): B \$	2900	2600	2700	2600	2500	2400

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 POWDERED CARBON ADSORPTION
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 POWDERED CARBON ADSORPTION
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981



COMPUTER OUTPUT 3.1.3.4b
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGENERATION (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): ULTRAVIOLET-OZONE (8 LAMPS/SQ.FT.)
FOR FLOW RATE OF 1 000 000 GPD

BY
VINCENT J. CICCONE
SEPTEMBER 23, 1981



COMPUTER OUTPUT 3.1.3.4b
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF THE TABLE. THE
 LIFE SPAN FOR ALL UNITS IS SET AT 30 YEARS AND THE
 FLOW IS 1 000 000 GPD.

ALTERNATIVE (A) CARBON:THERMAL REGENERATION (0.652 LBS TNT/LB)					ALTERNATIVE (C) ULTRAVIOLET-OZONE (8 LAMPS/SQ.FT)				
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	UNIT	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	UNIT
*NO.	UNIT CAP COST	O&M COST (GAL)	GPD		NO.	UNIT CAP COST	O&M COST (GAL)	GPD	
SUMP-STL OR MI					SUMP-STL OR MI				
9228	1	\$ 19006	\$ 0	200000 1000000	9228	1	\$ 19006	\$ 0	200000 1000000
PUMP-PRESS. SUMP					PUMP-PRESS. SUMP				
9207	2	\$ 1786	\$ 3326	7.58 ^a 1000000	9207	2	\$ 1786	\$ 3326	7.58 ^a 1000000
EQUALIZATION/SEDIMENTATION TAN					EQUALIZATION/SEDIMENTATION TAN				
9218	2	\$ 68176	\$ 0	1000000 1000000	9218	2	\$ 68176	\$ 0	1000000 1000000
PUMP-PRESS. EQUALIZATION					PUMP-PRESS. EQUALIZATION				
9206	2	\$ 1047	\$ 1737	2.66 ^a 1000000	9206	2	\$ 1047	\$ 1737	2.66 ^a 1000000
MIXED MEDIA PRESS. FILT.					MIXED MEDIA PRESS. FILT.				
9239	4	\$ 1135235	\$ 460	5000 340000	9239	4	\$ 1135235	\$ 460	5000 340000
CARBON COLUMN WITH THERMAL REG					OZONE PRECONTACTOR				
9219	1	\$ 3591065	\$ 47821	21000 1000000	9241	1	\$ 5086	\$ 0	10000 1000000
CONVEYOR SCREW					PUMP-PRESS. EQUALIZATION				
9231	3	\$ 4566	\$ 2000	1 ^b 25 ^c	9206	1	\$ 1047	\$ 1737	2.66 ^a 1000000
WASTE CARBON TNK-STL OR MI					OZONE REACTOR				
9214	3	\$ 7612	\$ 0	25000 10000	9203	4	\$ 6520005	\$ 0	30000 1000000
CARBON REGEN FURNACE					UV LAMPS/REACTOR TANK				
9211	1	\$ 1339783	\$ 147598	1 ^b 300 ^d	9205	4	\$ 1 ^b	\$ 520875	5760 ^e 1000000
CARBON DE-FINE TANK					HOLDING TANK				
9240	1	\$ 1408525	\$ 2000	25000 25000	9223	1	\$ 7612	\$ 0	25000 1000000
HOLDING TANK					PUMP-PRESS. BACKWASH				
9223	1	\$ 7612	\$ 0	25000 1000000	9204	1	\$ 3700	\$ 83	31.6 ^a 100000

--CONTINUED

NOTE: Not all values shown relate to column headings,
 a = hydraulic horsepower
 b = BASIC coding
 c = length in feet
 d = square feet
 e = number of UV lamps



PUMP-PRESS. BACKWASH						!PUMP-PRESS. SUMP					
9204	1	\$ 3700	\$ 83	31.6 ^a	100000	9207	1	\$ 1786	\$ 3326	7.58 ^a	1000000
VIRGIN CARBON STORAGE TANK						!OZONE GENERATOR					
9208	1	\$ 7709	\$ 0	24000	24000	9212	1	\$ 323078	\$ 739410	1 ^b	1000000
						!COOLER-CHILLER					
						9221	1	\$ 5000	\$ 2000	1 ^b	1 ^b

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY VINCENT J CICCONE SEPTEMBER 23 1981

NOTE: Not all values shown relate to column headings.
a = hydraulic horsepower
b = BASIC coding



COMPUTER OUTPUT 3.1.3.4b
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON:THERMAL REGENERATION (0.652 LBS TNT/LB)
 WITH TREATMENT B (ULTRAVIOLET-OZONE (8 LAMPS/SQ.FT)).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 2510422 AND FOR ALTERNATIVE B = \$ 3570436;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = 1.42; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 1000000 GALLONS; SYSTEM B = 1000000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	1022000	2981000	5798000	9401000	13723000	18706000
TOT. OP. COSTS FOR ALTERN. B \$	13485000	39324000	76479000	123999000	181013000	246726000
CURRENT SALVAGE VALUE FOR A \$	2092000	1673000	1255000	836000	418000	-1000
CURRENT SALVAGE VALUE FOR B \$	2975000	2380000	1785000	1190000	595000	0
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	.58925	.23437	.08739	.02896	.00720	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	1750	3500	5250	7000	8750	10500
TOT. FLOW (MGAL) FOR ALTERN B	1750	3500	5250	7000	8750	10500
RSUM FOR ALTERNATIVE A	0.75366	1.77567	2.57859	3.11204	3.43241	3.62852
RSUM FOR ALTERNATIVE B	9.94056	23.42059	34.01086	41.04692	45.35155	47.85900
*THE DISCRIMINANT IS	-9.4342	-21.9975	-31.8285	-38.3485	-42.3332	-44.6527
PVUC (\$/MGAL PROCESSED): A \$	820	790	770	750	730	710
PVUC (\$/MGAL PROCESSED): B \$	8000	7700	7400	7100	6800	6500

STUDY CONDUCTED BY VINCENT J CICCONE

SEPTEMBER 23 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON:THERMAL REGENERATION (0.652 LBS TNT/LB AND SYSTEM (B):
 ULTRAVIOLET-OZONE (8 LAMPS/SQ.FT)
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY VINCENT J CICCONE

SEPTEMBER 23 1981





PVOC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGENERATION (0.652 LBS TNT/LB AND SYSTEM (B):
 ULTRAVIOLET-OZONE (8 LAMPS/SQ. FT)
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY VINCENT J CICCONE

SEPTEMBER 23 1981



COMPUTER OUTPUT 3.1.3.5b
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGEN. (0.652 LBS INT/LB C)⁽⁶⁾
WITH SYSTEM (B): LIQUID-LIQUID EXTRACTION
FOR FLOW RATE OF 1 000 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 10, 1981



COMPUTER OUTPUT 3.1.3.5b
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF THE TABLE. THE
 LIFE SPAN FOR ALL UNITS IS SET AT 30 YEARS AND THE
 FLOW IS 1 000 000 GPD.

ALTERNATIVE (A)					ALTERNATIVE (B)				
CARBON: THERMAL REGEN. (0.652 LBS INT/LB C)					LIQUID - LIQUID EXTRACTION				
NAME OF UNIT UNDERWRITTEN BY:					NAME OF UNIT UNDERWRITTEN BY:				
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	UNIT	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	UNIT
*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	GPD	*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	GPD
SUMP-STL OR MI					SUMP-STL OR MI				
9228	1	\$ 19006 \$ 0	200000	1000000	9228	1	\$ 19006 \$ 0	200000	1000000
PUMP-PRESS. SUMP					PUMP-PRESS. SUMP				
9207	2	\$ 1786 \$ 3326	7.58 ^b	1000000	9207	2	\$ 1786 \$ 3326	7.58 ^a	1000000
EQUALIZATION/SEDIMENTATION TAN					EQUALIZATION/SEDIMENTATION TAN				
9218	2	\$ 68176 \$ 0	1000000	1000000	9218	2	\$ 68176 \$ 0	1000000	1000000
PUMP-PRESS. EQUALIZATION					PUMP-PRESS. EQUALIZATION				
9206	2	\$ 1047 \$ 1737	2.66 ^a	1000000	9206	3	\$ 1047 \$ 1737	2.66 ^a	1000000
MIXED MEDIA PRESS. FILT.					MIXED MEDIA PRESS. FILT.				
9239	4	\$ 1135235 460	5000	340000	9239	4	\$ 1135235 460	5000	340000
CARBON COLUMN WITH THERMAL REG					SOLVENT EXTRACTION				
9219	1	\$ 3591065 47821	21000	1000000	9245	4	\$ 5323248 \$ 3018722	60000	8 ^f
CONVEYOR SCREW					SUMP-STL OR MI				
9231	3	\$ 4566 \$ 2000	1 ^b	25 ^c	9228	1	\$ 19006 \$ 0	200000	1000000
WASTE CARBON TNK-STL OR MI					FRACTIONAL DISTILLATION				
9214	3	\$ 7612 \$ 0	25000	10000	9246	1	\$ 2433326 \$ 420390	12.9 ^f	1000000
CARBON REGEN FURNACE					SURF. STR/MIX/BODY FEED TNK				
9211	1	\$ 1339783 \$ 147598	1 ^b	300 ^d	9224	2	\$ 1361 \$ 0	500	0 ^b
CARBON DE-FINE TANK					CHEMICAL FEEDER				
9240	1	\$ 1408525 2000	25000	25000	9225	2	\$ 3000 \$ 1000	1 ^b	1 ^b
HOLDING TANK					HOLDING TANK				
9223	1	\$ 7612 \$ 0	25000	1000000	9223	1	\$ 7612 \$ 0	25000	1000000

--CONTINUED

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet
- f = ten thousand pounds per day



PUMP-PRESS. BACKWASH
9204 1 \$ 3700 \$ 83 31.6^a 100000
VIRGIN CARBON STORAGE TANK
9208 1 \$ 7709 \$ 0 24000 24000

PUMP-PRESS. BACKWASH
9204 1 \$ 3700 \$ 83 31.6^a 100000

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

NOTE: Not all values shown relate to column headings.
a = hydraulic horsepower



COMPUTER OUTPUT 3.1.3.5b
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C))
 WITH TREATMENT B (LIQUID - LIQUID EXTRACTION).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 2510422 AND FOR ALTERNATIVE B = \$24381527;
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = 9.71; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 100000 GALLONS; SYSTEM B = 1000000 GALLONS

```
*****
```

VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	1022000	2981000	5798000	9401000	13723000	18706000
TOT. OP. COSTS FOR ALTERN. B \$	59366000	173113000	336673000	545863000	796850000	?????????
CURRENT SALVAGE VALUE FOR A \$	2092000	1673000	1255000	836000	418000	-1000
CURRENT SALVAGE VALUE FOR B \$	20317000	16254000	12190000	8127000	4063000	-1000
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	4.02386	1.60045	.59678	.19780	.04917	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	1750	3500	5250	7000	8750	10500
TOT. FLOW (MGAL) FOR ALTERN B	1750	3500	5250	7000	8750	10500
RSUM FOR ALTERNATIVE A	0.75366	1.77567	2.57859	3.11204	3.43841	3.62852
RSUM FOR ALTERNATIVE B	43.75987	?????????	?????????	?????????	?????????	?????????
* THE DISCRIMINANT IS	-48.1087	?????????	?????????	?????????	?????????	?????????
PVUC (\$/MGAL PROCESSED): A \$	820	790	770	750	730	710
PVUC (\$/MGAL PROCESSED): B \$	36200	34800	33400	32200	31000	29800

```
*****
```


STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".

Here values have exceeded the capacity of the computer.






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 LIQUID - LIQUID EXTRACTION
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 LIQUID - LIQUID EXTRACTION
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981



COMPUTER OUTPUT 3.1.3.6b
SUMMARY OF PVUC ANALYSIS COMPARING
SYSTEM (A): CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C)⁽⁶⁾
WITH SYSTEM (B): ULTRAFILTRATION
FOR FLOW RATE OF 1 000 000 GPD

BY
GEORGE A. GARRIGAN
SEPTEMBER 10, 1981



COMPUTER OUTPUT 3.1.3.6b
 LISTING OF ALL COMPONENTS FOR PVUC STUDY.
 BASELINE FOR ALL COSTS IS DECEMBER, 1980 UNLESS
 INDICATED OTHERWISE IN THE BODY OF THE TABLE. THE
 LIFE SPAN FOR ALL UNITS IS SET AT 30 YEARS AND THE
 FLOW IS 1 000 000 GPD.

ALTERNATIVE (A)					ALTERNATIVE (B)				
CARBON: THERMAL REGEN. (0.657 LBS INT/LB C)					MEMBRAN FILTRATION				
*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	UNIT	*CAT NOS.	UNIT	UNIT CAPACITY	UNIT	UNIT
*NO.	UNIT CAP COST	O&M COST (GAL)	GPD	GPD	NO.	UNIT CAP COST	O&M COST (GAL)	GPD	GPD
SUMP-STL OR MI					SUMP-STL OR MI				
9228	1	\$ 19006 \$ 0	200000	1000000	9228	1	\$ 19006 \$ 0	200000	1000000
PUMP-PRESS. SUMP					HOLDING TANK				
9207	2	\$ 1786 \$ 3326	7.58 ^a	1000000	9223	1	\$ 7612 \$ 0	25000	1000000
EQUALIZATION/SEDIMENTATION TAN					PUMP-PRESS. SUMP				
9218	2	\$ 68176 \$ 0	1000000	1000000	9207	2	\$ 1786 \$ 3326	7.58 ^a	1000000
PUMP-PRESS. EQUALIZATION					EQUALIZATION/SEDIMENTATION TAN				
9206	2	\$ 1047 \$ 1737	2.66 ^a	1000000	9218	2	\$ 68176 \$ 0	1000000	1000000
MIXED MEDIA PRESS. FILT.					PUMP-PRESS. EQUALIZATION				
9239	4	\$ 113523 \$ 460	5000	340000	9206	2	\$ 1047 \$ 1737	2.66 ^a	1000000
CARBON COLUMN WITH THERMAL REG					MIXED MEDIA PRESS. FILT.				
9219	1	\$ 359106 \$ 47821	21000	1000000	9239	4	\$ 113523 \$ 460	5000	340000
CONVEYOR SCREW					UF MEMBRANE MODULE				
9231	3	\$ 4566 \$ 2000	1 ^b	25 ^c	9227	100	\$ 1512889 \$ 219239	.1 ^g	0 ^b
WASTE CARBON TANK-STL OR MI					PUMP-PRESS. BACKWASH				
9214	3	\$ 7612 \$ 0	25000	100000	9204	1	\$ 3700 \$ 83	31.6 ^a	100000
CARBON REGEN FURNACE					UF-RECIRC. PUMP				
9211	1	\$ 1339783 \$ 147598	1 ^b	300 ^d	9226	100	\$ 5774 \$ 13844	75.6 ^a	4320000
CARBON DE-FINE TANK									
9240	1	\$ 140852 \$ 2000	25000	25000					
HOLDING TANK									
9223	1	\$ 7612 \$ 0	25000	1000000					

--CONTINUED

NOTE: Not all values shown relate to column headings.

- a = hydraulic horsepower
- b = BASIC coding
- c = length in feet
- d = square feet
- g = million gallons per day



PUMP-PRESS. BACKWASH			
9204	1	\$ 3700 \$ 83	31.6 ^a 100000
VIRGIN CARBON STORAGE TANK			
9208	1	\$ 7709 \$ 0	24000 24000

***** NOTE: ALL VALUES ROUNDED TO NEAREST INTEGER *****

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

NOTE: Not all values shown relate to column headings,
a = hydraulic horsepower



COMPUTER OUTPUT 3.1.3.6b
 PRESENT VALUE UNIT COST ANALYSIS
 COMPARING TREATMENT A (CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C))
 WITH TREATMENT B (ULTRAFILTRATION).
 SYSTEM LIFESPAN TO BE 30 YEARS WITH 350 OP. DAYS PER YEAR.
 ANALYSES ARE OVER FIVE YEAR SPANS (OR 'HORIZONS').

TOTAL CAPITAL COSTS FOR ALTERNATIVE A = \$ 2510422 AND FOR ALTERNATIVE B = \$?????????
 RATIO OF CAPITAL COSTS OF B TO CAPITAL COSTS OF A = 60.78; INTEREST RATE = .15;
 INFLATION RATE = .13; FLOW RATIO OF A TO B ('ALPHA') = 1.0000
 DAILY FLOW IN SYSTEM A = 100000 GALLONS; SYSTEM B = 100000 GALLONS


VALUES USED FOR DECISION PROCESS	TOTAL YR 1 TO 5	TOTAL YR 1 TO 10	TOTAL YR 1 TO 15	TOTAL YR 1 TO 20	TOTAL YR 1 TO 25	TOTAL YR 1 TO 30
TOT. OP. COSTS FOR ALTERN. A \$	1022000	2981000	5798000	9401000	13723000	18706000
TOT. OP. COSTS FOR ALTERN. B \$	110657000	322680000	627553000	????? ???	?????????	?????????
CURRENT SALVAGE VALUE FOR A \$	2092000	1673000	1255000	876000	418000	-1000
CURRENT SALVAGE VALUE FOR B \$	127160000	101728000	76296000	50864000	25432000	0
SLVG PER DISCNT CAP. (THETA-A)	.41431	.16478	.06144	.02036	.00506	< 10E-5
SLVG PER DISCNT CAP. (THETA-B)	25.18353	10.01653	3.73499	1.23796	.30774	< 10E-5
TOT. FLOW (MGAL) FOR ALTERN A	1750	3500	5250	7000	8750	10500
TOT. FLOW (MGAL) FOR ALTERN B	1750	3500	5250	7000	8750	10500
RSUM FOR ALTERNATIVE A	0.75366	1.77567	2.57859	3.11204	3.43841	3.62852
RSUM FOR ALTERNATIVE B	81.56774	?????????	?????????	?????????	?????????	?????????
*THE DISCRIMINANT IS	?????????	?????????	?????????	?????????	?????????	?????????
PVUC (\$/MGAL PROCESSED): A \$	820	790	770	750	730	710
PVUC (\$/MGAL PROCESSED): B \$	77700	75100	72600	70200	67900	65800

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981

* The "Discriminant" is the normalized difference between PVUC "A" and PVUC "B".
 Here the value has exceeded the capacity of the computer.






DISCRIMINANT VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 ULTRAFILTRATION
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981





PVUC \$/MGAL PROCESSED VS YEARS FOR SYSTEM (A):
 CARBON: THERMAL REGEN. (0.652 LBS TNT/LB C) AND SYSTEM (B):
 ULTRAFILTRATION
 FOR FLOW OF 1 000 000 GPD.

STUDY CONDUCTED BY GEORGE A. GARRIGAN

SEPTEMBER 10 1981



3.1.4 Table 3.2 presents a compilation of the calculated capital and annual operating costs for each of the seven treatment technologies. It indicates those systems that are either capital or operating intensive and provides a quick reference for making gross comparisons. Tables 3.3 and 3.4 represent the calculated PVUC's of the alternatives, for each of the specified daily flows, given an anticipated thirty-year system life. The unit costs are for five-year interval time horizons, and are expressed as present value dollars per thousand gallons of pink water treated (\$/K-GAL).

These PVUC values were calculated on a yearly basis and reported at the five-year intervals. They are the outputs produced by the computer simulations which compared the treatment alternatives according to the schedule shown in Table 3.1. The discount factor and inflation rate used were 15 percent and 13 percent respectively. These are reasonable assumptions based upon figures reported by the Federal Government for 1980 as discussed in Section 2.8.2

Figures 3.1 and 3.2 are the graphical representations of the calculated costs tabulated in Tables 3.3 and 3.4. These diagrams clearly show a distinct breakpoint of the calculated costs into those below \$7.00/K-GAL and those above \$10.00/K-GAL. The breakpoint is so apparent that it immediately suggests how expensive ultrafiltration and liquid/liquid extraction are as compared to the other technologies under consideration.

3.1.5 In order to provide a convenient means to tabulate the calculated PVUC values for each of the alternative schemes, Tables 3.5 and 3.6 were constructed. These matrices, which list the alternative schemes in both the columns and rows, show not only the combinations of comparisons examined but also the calculated PVUC values (as the elements of the matrix) for the first five-year horizon.

3.1.6 A "Discriminant", which is the normalized indicator showing whether, for any given horizon, one alternative is less or more expensive than a competitive alternative, was calculated and listed as an output in the computer simulations or runs. Subsequently, Tables 3.7 and 3.8 were constructed to tabulate the results comparing the six other alternatives to Granular Carbon Adsorption with Thermal Regeneration. These tables show a range of anticipated dollar savings by using the Granular Carbon Adsorption with Thermal Regeneration alternative



100,000 GPD			
Capital Costs	15,311,815	2,750,668	623,380
Average Annual O & M Costs (Based on first 5-year horizon)	2,223,200	1,575,200	309,480
Ultrafiltration			
Liquid / Liquid Extraction			
UV-Ozone			
Powdered Carbon w/AST Regen.		669,416	148,000
Surfactant Complexing		136,445	139,400
Granular Carbon w/ No Regen.		307,750	88,800
Granular Carbon w/Thermal Regen.		974,080	47,000

1,000,000 GPD			
Capital Costs	>10 ⁸	24,381,527	3,570,436
Average Annual O & M Costs (Based on first 5-year horizon)	2,213,140	11,873,200	2,697,000
		931,600	1,279,800
		3,033,189	488,588
		1,029,786	2,510,422
		727,200	204,400

**TABLE 3.2
CALCULATED CAPITAL & ANNUAL OPERATING
COSTS FOR EACH ALTERNATIVE CONSIDERED**



TIME HORIZON (Years)	Granular Carbon w/ Thermal Regen.	Granular Carbon w/ No Regen.	Surfactant Complexing	Powdered Carbon w/ AST Regen.	UV-Ozone	Liquid/Liquid Extraction	Ultrafiltration
5	2.27	2.80	4.10	4.80	9.40	47.60	78.10
10	2.20	2.70	3.90	4.60	9.00	45.70	75.40
15	2.10	2.60	3.70	4.50	8.70	43.90	72.90
20	2.10	2.50	3.60	4.30	8.30	42.20	70.50
25	2.00	2.40	3.40	4.20	8.00	40.60	68.30
30	2.00	2.30	3.30	4.00	7.70	39.10	66.10

TABLE 3.3
CALCULATED PVUC (\$/K-GAL) FOR EACH ALTERNATIVE
30-Year Planning Horizon
100,000 GPD



TIME HORIZON (Years)	Granular Carbon w/ Thermal Regen.	Granular Carbon w/ No Regen.	Surfactant Complexing	Powdered Carbon w/ AST Regen.	UV-Ozone	Liquid/Liquid Extraction	Ultrafiltration
5	0.82	2.10	3.70	2.90	8.00	36.20	77.70
10	0.79	2.00	3.50	2.80	7.70	34.80	75.10
15	0.77	2.00	3.40	2.70	7.40	33.40	72.60
20	0.75	1.90	3.20	2.60	7.10	32.20	70.20
25	0.73	1.80	3.10	2.50	6.80	31.00	67.90
30	0.71	1.70	3.00	2.40	6.50	29.80	65.80

TABLE 3.4

**CALCULATED PVUC (\$/K-GAL) FOR EACH ALTERNATIVE
30-Year Planning Horizon
1,000,000 GPD**






FIGURE 3.1
CALCULATED PVUC (\$/K-GAL) FOR EACH ALTERNATIVE VS PLANNING HORIZONS
100,000 GPD






FIGURE 3.2
CALCULATED PVUC (\$/K-GAL) FOR EACH ALTERNATIVE VS PLANNING HORIZONS
1,000,000 GPD





Alternative "A"	Alternative "B"						
	Granular Carbon w/ Thermal Regen.	Granular Carbon w/ No Regen.	Surfactant Complexing	Powdered Carbon w/ AST Regen.	UV-Ozone	Liquid/Liquid Extraction	Ultrafiltration
1	A= 2.80 B= 2.20	A= 4.10 B= 2.20	A= 4.80 B= 2.20	A= 9.40 B= 2.20	A=47.60 B= 2.20	A=78.60 B= 2.20	
2	A= 2.20 B= 2.80	A= 4.10 B= 2.80	A= 4.80 B= 2.80	A= 9.40 B= 2.80	A=47.60 B= 2.80	A=78.60 B= 2.80	
3	A= 2.20 B= 4.10	A= 2.80 B= 4.10	A= 4.80 B= 4.10	A= 9.40 B= 4.10	A=47.60 B= 4.10	A=78.60 B= 4.10	
4	A= 2.20 B= 4.80	A= 2.80 B= 4.80	A= 4.10 B= 4.80	A= 9.40 B= 4.80	A=47.60 B= 4.80	A=78.60 B= 4.80	
5	A= 2.20 B= 9.40	A= 2.80 B= 9.40	A= 4.10 B= 9.40	A= 4.80 B= 9.40	A=47.60 B= 9.40	A=78.60 B= 9.40	
6	A= 2.20 B=47.60	A= 2.80 B=47.60	A= 4.10 B=47.60	A= 4.80 B=47.60	A=47.60 B=47.60	A=78.60 B=47.60	
7	A= 2.20 B=78.60	A= 2.80 B=78.60	A= 4.10 B=78.60	A= 4.80 B=78.60	A=47.60 B=78.60	A=78.60 B=78.60	

TABLE 3.5
 CALCULATED PVUC (\$/K-GAL) FOR EACH ALTERNATIVE
 5-Year Horizon
 100,000 GPD



Alternative "B"	Alternative "A"		Alternative "B"						
	Granular Carbon w/ Thermal Regen.	Granular Carbon w/ No Regen.	Surfactant Complexing	Powdered Carbon w/ AST Regen.	UV-Ozone	Liquid/Liquid Extraction	Ultrafiltration		
1		A= 2.10 B= 0.82	A= 3.70 B= 0.82	A= 2.90 B= 0.82	A= 8.00 B= 0.82	A=36.20 B= 0.82	A=77.70 B= 0.82		
2	Granular Carbon w/ No Regen.	A= 0.82 B= 2.10	A= 3.70 B= 2.10	A= 2.90 B= 2.10	A= 8.00 B=2.10	A=36.20 B= 2.10	A=77.70 B= 2.10		
3	Surfactant Complexing	A= 0.82 B= 3.70		A= 2.90 B= 3.70	A= 8.00 B= 3.70	A=36.20 B= 3.70	A=77.70 B= 3.70		
4	Powdered Carbon w/ AST Regen.	A= 0.82 B= 2.90	A= 3.70 B= 2.90		A= 8.00 B= 2.90	A=36.20 B= 2.90	A=77.70 B= 2.90		
5	UV-Ozone	A= 0.82 B= 8.00	A= 3.70 B= 8.00	A= 2.90 B= 8.00		A=36.20 B= 8.00	A=77.70 B= 8.00		
6	Liquid/Liquid Extraction	A= 0.82 B=36.20	A= 3.70 B=36.20	A= 2.90 B=36.20	A= 8.00 B=36.20		A=77.70 B=36.20		
7	Ultrafiltration	A= 0.82 B=77.70	A= 3.70 B=77.70	A= 2.90 B=77.70	A= 8.00 B=77.70	A=36.20 B=77.70			

TABLE 3.6
 CALCULATED PVUC (\$/K-GAL) FOR EACH ALTERNATIVE
 5-Year Horizon
 1,000,000GPD

Alternative Scheme	Year	PVUC \$/KGal		Savings Over Horizon \$	Annual Savings \$
Granular Carbon w/ Thermal Regen.	5	2.20	Discriminant	Savings = Cap.S(A) x Disc.	Annual Savings = Savings/Yrs.
	10	2.20			
	15	2.10			
	20	2.10			
	25	2.00			
	30	2.00			
Granular Carbon w/ No Regen.	5	2.80	- 0.0083	8,084	1,617
	10	2.70	- 1.1596	1,129,543	112,954
	15	2.60	- 2.2779	2,218,857	147,924
	20	2.50	- 3.0806	3,000,750	150,038
	25	2.40	- 3.5930	3,499,869	139,995
	30	2.30	- 3.8998	3,798,717	126,624
Surfactant Complexing	5	4.10	- 0.3738	364,111	72,822
	10	3.90	- 1.3492	1,314,229	131,423
	15	3.70	- 2.1952	2,138,300	142,553
	20	3.60	- 2.7809	2,708,819	135,441
	25	3.40	- 3.1478	3,066,209	122,648
	30	3.30	- 3.3647	3,277,487	109,250
Powdered Carbon w/ AST Regen.	5	5.50	- 0.7766	756,471	151,294
	10	5.30	- 2.0002	1,948,355	194,836
	15	5.10	- 2.9905	2,912,986	194,199
	20	5.00	- 3.6571	3,562,308	178,115
	25	4.80	- 4.0679	3,962,460	158,498
	30	4.70	- 4.3035	4,196,824	139,894
UV-Ozone	5	9.40	- 2.2817	2,222,558	444,512
	10	9.10	- 5.5721	5,427,671	542,767
	15	8.70	- 8.1905	7,978,202	531,880
	20	8.30	- 9.9400	9,682,355	484,118
	25	8.00	-11.0139	10,728,420	429,137
	30	7.70	-11.6409	11,339,168	377,972
Liquid/Liquid Extraction	5	47.60	-15.5841	15,180,160	3,036,032
	10	45.70	-35.7237	34,797,742	3,479,774
	15	43.90	-51.3769	50,045,211	3,336,374
	20	42.20	-61.7264	60,126,452	3,006,323
	25	40.60	-68.0403	66,276,695	2,651,068
	30	39.10	-71.7110	69,852,251	2,328,408
Ultrafiltration	5	78.10	-29.3042	28,544,635	5,708,927
	10	75.40	-61.0137	59,432,225	5,943,223
	15	72.90	-84.5593	82,367,523	5,491,168
	20	70.50	-99.7963	97,209,580	4,860,479
	25	68.30	EXCEEDED CAPACITY OF PROGRAMMED PRINTOUT		
	30	66.10			

TABLE 3.7
CALCULATED ANNUAL SAVINGS BY USING GRANULAR CARBON
WITH THERMAL REGENERATION
100,000 GPD



Alternative Scheme	Year	PVUC \$/KGal		Savings Over Horizon \$	Annual Savings \$
Granular Carbon w/ Thermal Regen.	5	0.82	Discriminant	Savings = Cap. \$(A) x Disc	Annual Savings= Savings/Years
	10	0.79			
	15	0.77			
	20	0.75			
	25	0.73			
	30	0.71			
Granular Carbon w/ No Regen.	5	2.10	- 3.8543	9,675,920	1,935,184
	10	2.00	- 9.8643	24,763,556	2,476,356
	15	2.00	-14.7191	36,951,152	2,463,410
	20	1.90	-17.9843	45,148,182	2,257,409
	25	1.80	-19.9960	50,198,398	2,007,936
	30	1.70	-21.1734	53,154,169	1,771,806
Surfactant Complexing	5	3.70	- 3.4918	8,765,892	1,753,178
	10	3.50	- 8.6657	21,754,564	2,175,456
	15	3.40	-12.8051	32,146,205	2,143,080
	20	3.20	-15.5775	39,106,099	1,955,305
	25	3.10	-17.2816	43,384,109	1,735,364
	30	3.00	-18.2773	45,883,736	1,529,458
Powdered Carbon w/ AST Regen.	5	2.90	- 2.8023	7,034,956	1,406,991
	10	2.80	- 6.4891	16,290,379	1,629,038
	15	2.70	- 9.3663	23,513,366	1,567,558
	20	2.60	-11.2720	28,297,477	1,414,874
	25	2.50	-12.4359	31,219,357	1,248,774
	30	2.40	-13.1131	32,919,415	1,097,314
UV-Ozone	5	8.20	- 9.4342	23,683,823	4,736,765
	10	7.90	-21.9975	55,223,008	5,522,301
	15	7.60	-31.8285	79,902,967	5,326,865
	20	7.30	-38.3485	96,270,918	4,813,546
	25	7.00	-42.3332	106,274,197	4,250,968
	30	6.70	-44.6527	112,097,120	3,736,571
Liquid/ Liquid Extraction	5	36.20	-48.1087	371,820,000	74,364,000
	10	34.80	EXCEEDED CAPACITY OF PROGRAMMED PRINTOUT		
	15	33.40			
	20	32.20			
	25	31.00			
	30	29.80			
Ultrafiltration	5	77.70	EXCEEDED CAPACITY OF PROGRAMMED PRINTOUT		
	10	75.10			
	15	72.60			
	20	70.20			
	25	67.90			
	30	65.80			

TABLE 3.8.
CALCULATED ANNUAL SAVINGS BY USING GRANULAR CARBON
WITH THERMAL REGNERATION
1,000,000 GPD



over the others. Specifically, Table 3.7 shows that if the granular carbon with thermal regeneration treatment scheme is selected over the granular carbon with no regeneration scheme (for 10^5 GPD), then a predicted annual savings over the first five-year horizon is \$8,084 and for the ten-year horizon it is \$1,129,543, and so forth. Similar comparisons and calculated annual savings predictions are shown in Tables 3.7 and 3.8 for the other alternative pink water treatment schemes for both the 10^5 and 10^6 GPD flows.

3.1.7 As is to be expected in comparing a series of wastewater treatment methods on a unit cost basis, there will be the most economical methods, the least economical methods, and the other treatment techniques will fall somewhere in between the two extremes. The two granular carbon adsorption techniques, with and without regeneration, were the most economically favorable methods found in this study. The two least economically favorable methods were found to be liquid/liquid extraction and ultrafiltration. The powdered carbon with AST regeneration method, the surfactant complexing method and the UV-Ozone method fell between the cost extremes. See Figure 3.2.

The high treatment unit cost of ultrafiltration is caused by its inefficiency in removing the low molecular weight constituent in pink wastewater. The high unit cost is reflected in both the capital investment for the series of ultrafiltration membrane modules and the high annual power requirements for recirculation pumping. The relatively high liquid/liquid extraction unit costs are mainly influenced by the capital costs for fractional distillation equipment and for solvent extraction columns; operation and maintenance expenditures for the solvent extraction columns are also estimated to be high.

For the middle cost range methods, UV-Ozone costs are influenced by the capital cost of the ozone reactor plus the purchase cost of the ozone generator. The high operation and maintenance costs are reflected in the annual requirement to replace a large number of UV lamps plus the cost of electrical power to operate the lamps continuously. The ultrafiltration method and the UV-Ozone method are the most power intensive treatment techniques. The operation cost of the ozone generator is also considerable.



The largest capital investment for surfactant complexing is for the vacuum filter, and this method's highest operation and maintenance costs arise from the amount and concentration of surfactant introduced constantly into the surfactant reaction tanks. An additional significant operation and maintenance factor is the cost of acid neutralization of the surfactant treated alkaline wastewaters.

The main capital costs for the powdered carbon method are those for the AST furnace, the clarifiers and for the vacuum filters. The largest operation and maintenance costs are likewise expected to occur in the operation of the AST furnace, the clarifiers and the dry feed equipment.

The highest capital cost for granular carbon without regeneration is for the carbon column unit and that unit is expected to incur the largest operation and maintenance cost for carbon replacement on a once-used basis. The highest capital cost for granular carbon with regeneration is for the carbon furnace and it is in this unit that the highest operation and maintenance costs are expected to occur. The second highest capital outlay cost in the regeneration treatment method is for the carbon column unit which is expected to incur only modest annual operating costs.

The real economic advantage of granular carbon adsorption, both with and without regeneration, lies in relatively low average annual operation and maintenance costs compared to the other treatment methods. See Table 3.2. For instance, even though the 10^5 GPD plant total capital cost of granular carbon with regeneration is higher than the total capital cost of surfactant complexing or granular carbon without regeneration or powdered carbon with AST regeneration or UV-Ozone, the calculated low average annual operation and maintenance cost for granular carbon with regeneration makes it the most attractive of all pink wastewater treatment methods studied on a unit cost basis.

3.2 SENSITIVITY ANALYSIS

Analysis and discussion of the findings presented in the above paragraphs yield sufficient information so that a rational "ranking" of the seven technologies could be made by engineering and management personnel directly concerned with the pink water problem. However, several significant operating and cost parameters are worthy of further analyses, especially because of their



respective impact upon decision parameters, namely, the PVUC and the discriminant. Analytical experiments were conducted to examine the "sensitivity" of these decision parameters to variations in selected significant factors, such as the adsorption rate for carbon (lbs of TNT/lb of carbon) or the number of ultraviolet lamps. The experimental results were obtained and discussion of those findings are presented below.

3.2.1 Sensitivity of the Granular Carbon With and Without Regeneration Alternatives to the Adsorption Rate of the Carbon.

The range of granular activated carbon adsorption rates reported in the literature and from on-site visits varies between 0.2 to 0.652 lbs TNT per lb of carbon available. For the purposes of this sensitivity analysis, 5 adsorption rate values ranging from 0.2 to 1.0 lb TNT per lb of carbon at intervals of 0.2 lb were selected. Calculations were made for each value to determine the frequency of replacing spent or exhausted carbon for a 350 day operational year, assuming all other factors remained as originally given. This information, in turn, was used to adjust the appropriate capital and operating cost functions associated with each of the carbon adsorption rates. Those values were then entered into the data sets of both the non-regeneration and thermal regeneration treatment schemes from which the PVUC values were calculated. Results of these computer experiments - for the first five-year horizon - are presented in Figure 3.2.1 for the specified daily flows of 10^5 and 10^6 GPD. Interpretation of Figure 3.2.1 indicates that the non-regenerative alternative is particularly sensitive to the TNT/carbon adsorption rate. It would appear to be a worthwhile venture to search for and develop a better or more efficient carbon in terms of the adsorption rate. Such research and development is appropriate to an adsorption rate of 0.6. Beyond that value, little gain in reduction of the treatment system unit costs appears feasible. However, in the range of 0.2 to 0.65, the estimated reduction from \$6.00/K-GAL at 0.2 to \$2.70/K-GAL at 0.65 for the 10^5 GPD flow and \$5.10/K-GAL to \$2.30/K-GAL for the 10^6 GPD flow is significant. The increased frequency of replacement and its associated disposal costs for the lower adsorption rate carbon, force the dramatic cost shifts. In general, the costs for non-regenerative carbon systems are best reduced through the






FIGURE 3.2.1
SENSITIVITY OF THE GRANULAR CARBON ALTERNATIVE TO
THE ADSORPTION RATE OF CARBON



development and incorporation of higher adsorption rate carbon as might be expected. However, beyond 0.65 lb TNT/lb carbon little if any savings would be realized.

In the thermal regenerative carbon system, where virgin carbon replacement was held to approximately 10 percent per regenerative cycle, the calculated PVUC costs for the lowest adsorption rate carbon (0.2) is not much greater than the PVUC costs for the more efficient carbon (0.65). The flat slope of the curve over the range of adsorption rates indicates that substantial savings in system costs of operating the thermal carbon regeneration alternative are not to be found in the use of higher efficiency carbons but rather in other features, such as perhaps improved regenerative technology. Throughout the ranges studied, the carbon regenerative alternative was found to have a consistently lower calculated PVUC than the non-regenerative system. This held true for both daily flow rates considered. The difference was greatest with the lower adsorption rate carbons, i.e., approximately a 62 percent difference for carbons adsorbing about 0.2 lbs TNT/lb carbon at 10^5 GPD and about 75 percent at 10^6 GPD flows. Higher efficiency carbons decreased this difference to about 14 percent for carbons adsorbing about 1 lb TNT/lb carbon at 10^5 GPD and 58 percent for 10^6 GPD.

3.2.2 Sensitivity of the UV-Ozone Alternative to the Number of UV Lamps Compared with Granular Carbon with Thermal Regeneration.

One analytical experiment compared the calculated PVUC for the Granular Carbon With Thermal Regeneration alternative with the UV-Ozone alternative employing from 2 to 8 lamps per square foot of reactor surface area assuming the system efficiency remained constant. The results are presented in Figure 3.2.2 which presents the calculated outputs from the computer analysis for the first five-year horizon and flow rates of 10^5 and 10^6 GPD. For the Granular Carbon With Thermal Regeneration alternative, the calculated values shown are based upon a carbon adsorption rate of 0.65 lb TNT/lb carbon. The PVUC costs for the UV-Ozone treatment alternative decrease linearly (from \$9.40/K-GAL for the 10^5 GPD and \$8.00/K-GAL for the 10^6 GPD flow) with decreasing numbers of UV lamps. However, even at the lowest value of 2 lamps per square foot of reactor surface






FIGURE 3.2.2
SENSITIVITY OF THE UV-OZONE ALTERNATIVE TO
THE NUMBER OF UV LAMPS USED



area the calculated PVUC costs are substantially higher, i.e., \$5.20/K-GAL for the 10^5 GPD and \$3.80/K-GAL for the 10^6 GPD, than the baseline costs of \$2.20 and \$0.82/K-GAL respectively for the granular carbon with thermal regeneration alternative.

One must note here that the question of pink water removal efficiencies has not yet been assessed as the number of UV lamps was decreased. It is anticipated that efficiencies would decrease sharply even though they were held constant in this set of calculations. In spite of holding efficiencies constant, the calculated PVUC, even at the 2 UV lamps per square foot value, was still higher than the granular carbon alternative.

3.2.3 Sensitivity of the Surfactant Complexing Alternative to Varying Surfactant Dosages Compared with Granular Carbon with Thermal Regeneration.

In the treatment of the pink waters by the Surfactant Complexing alternative, the dosage of Duoquad* surfactant required (127 lbs/day) and its cost (\$1.00/lb) are two very significant variables affecting the economic competitiveness of this technology. This sensitivity analysis considered the impact of these factors on the calculated PVUC when this technology was compared with thermally regenerated carbon at a flow rate of 10^5 GPD.

The information presented in Figure 3.2.3 is based on the granular carbon having an adsorption rate of 0.65 lbs TNT/lb carbon. The point, where both alternatives would be economically equivalent, is calculated to be at about a surfactant dosage of 85 lbs/day. That is, if the Surfactant Complexing alternative is to be considered as strong competition for the Granular Carbon With Thermal Regeneration, then the maximum dosage for Duoquad at a unit price of \$1.00/lb must be about 85 lbs/day. To be more favorable, the Duoquad dosage must be less than 85 lbs/day and achieve the same pink water removal efficiency. Use of a less efficient carbon, say 0.2 lbs TNT/lb carbon (at 10^5 GPD), raises the Granular Carbon with Thermal Regeneration alternative PVUC to approximately \$2.50/K-GAL, slightly increasing the range over which Surfactant Complexing alternative would be cost competitive. On the other hand, the use of more efficient carbon (i.e., 1.0 lb TNT/lb carbon) would reduce the Granular Carbon

*Duoquad T-50 has exhibited mutagenic characteristics. (37)






FIGURE 3.2.3
SENSITIVITY OF THE SURFACTANT COMPLEXING ALTERNATIVE TO
THE REQUIRED DOSAGE & PRICE

100,000 GPD



with Thermal Regeneration alternative baseline PVUC to about \$1.90/KGAL thereby decreasing the economic competitiveness of the Surfactant Complexing alternative.

As surfactant costs vary, the amount of surfactant that can be used and still keep that alternative competitive with thermally regenerated carbon decreases from a high dosage of approximately 128 lbs/day at \$0.70/lb to about 75 lbs/day surfactant dosage costing \$1.40/lb. Thus, as the price of surfactant increases to \$1.40/lb, the surfactant dosage required to make that alternative equivalent to the carbon would have to approach approximately 65 lbs/day.

Two factors which have been minimized in the analyses of the surfactant complexing alternative are:

- a) the assumption that the rotary vacuum filtration of the complexed and settled pink waters is feasible; and
- b) the ultimate disposal of the concentrated sludge generated in this treatment.

The first factor has the effect of greatly reducing the size of the vacuum filtration equipment required while the second presumes that ultimate disposal is available within the confines of the installation but not constructed and operated as a dedicated process to the Surfactant Complexing alternative treatment system. Hence, one must anticipate that although Surfactant Complexing appears to be a competitive alternative to the Granular Carbon With Thermal Regeneration alternative, these two factors would interplay to increase the unit cost of the surfactant treatment.

Another consideration worthy of further discussion is the relative strengths of the respective data bases for these two alternatives. The data sets for Granular Carbon With Thermal Regeneration are extensive with operating experiences documented at both the laboratory- and pilot-scale. While the Surfactant Complexing alternative has been conducted only on the smaller research bench-scale, and hence the data sets for both surfactant removal efficiencies and costs are not as extensive nor complete as for granular carbon.

The data presented in Figure 3.2.3 indicate quantified direction objectives and goals that must be achieved in order to make the Surfactant Complexing



alternative a serious contender to thermally regenerated granular carbon.

3.2.4 Sensitivity of the Powdered Carbon Alternative to the Adsorption Rate of the Powdered Carbon and to the AST Regeneration Costs.

As with granular carbon, the adsorption rate for powdered carbons was analyzed for impact upon their calculated PVUC's. Here the unit process of interest was the clarifier and the associated dosages of powdered carbon needed to effectively remove the dissolved TNT. Figure 3.2.4 shows the results obtained by varying the adsorption rate, for both the 10^5 and 10^6 GPD flow rates. As might be expected, an increase in carbon efficiency would decrease the unit cost of treatment. Specifically, there were decreases of 55 percent and 64 percent respectively for 10^5 GPD and 10^6 GPD flows as carbon efficiency increases from 0.2 to 1.0 lbs TNT/lb powdered carbon. An examination of Figure 3.2.4 suggests that the comparative competitiveness of the two systems at either of the flow rates studied, will not be altered by merely increasing the efficiency of the powdered carbon.

Figure 3.2.5 presents the results obtained when both the capital and operating costs of the AST regeneration process were reduced by increments of 25 percent from the base furnace cost of \$134,000 to 25 percent of that value, in order to estimate its effect upon the powdered carbon alternative. Successive cost reductions were compared with the Granular Carbon With Thermal Regeneration alternative in an attempt to determine if there existed a cost equivalency point. A cross-over point was not obtained (Figure 3.2.5) indicating that even if reductions to 25 percent of furnace capital costs in the AST regeneration process could be achieved, the PVUC of the Powdered Carbon alternative would still remain higher than that for the Granular Carbon alternative.



System (A): Granular Carbon
w/ Thermal Regen.

System (B): Powdered Carbon
w/ AST Regen.




FIGURE 3.2.4
SENSITIVITY OF THE POWDERED CARBON ALTERNATIVE TO
THE ADSORPTION RATE OF THE CARBON






FIGURE 3.2.5
SENSITIVITY OF THE POWDERED CARBON ALTERNATIVE TO
REDUCED AST CARBON REGENERATION COSTS

100,000 GPD



4.0 CONCLUSIONS (NOT IN ANY ORDER OF PRIORITY)

1. Based on the PVUC cost analyses of the seven feasible pink water treatment alternatives:
 - a) The most promising state-of-the-art methods in a low-to-high order of increasing unit treatment costs are:
 - i) Granular carbon with regeneration
 - ii) Granular carbon without regeneration
 - iii) Surfactant complexing
 - iv) Powdered carbon
 - v) UV-Ozone
 - b) The least promising state-of-the-art methods in a high-to-low order of decreasing unit treatment costs are:
 - i) Ultrafiltration
 - ii) Liquid/liquid extraction
2. Based on the extensive literature search and review conducted:
 - a) The best documented pink water treatment processes are the granular carbon methods.
 - b) The least documented pink water treatment processes are the surfactant complexing, ultrafiltration and liquid/liquid extraction methods.
3. The non-regenerative granular carbon alternative is particularly sensitive to the TNT/carbon adsorption rate but only appears to be so to an adsorption rate of 0.6 and not beyond.
4. In the thermal regenerative granular carbon alternative, the calculated PVUC costs for the lowest carbon adsorption rate (0.2) is not significantly greater than the PVUC costs for the more efficient exchange rate (0.65).
5. The surfactant complexing alternative, when compared to the regenerative carbon system, becomes less cost attractive as the TNT/carbon adsorption rate increases from 0.2 to 0.65 and beyond to 1.0 (two other factors minimized; see Section 3.2.3).



6. The cost competitiveness of the regenerative powdered carbon system as compared with the regenerative granular carbon system is not altered by increasing the adsorption efficiency of the powdered carbon.

7. The competitiveness of the powdered carbon system as compared with the regenerative granular carbon system is not altered even if the AST furnace cost is reduced 75 percent.



5.0 RECOMMENDATIONS

In order to economically treat pink water to meet expected discharge limits, it is recommended that the U.S. Army:

5.1 Conduct research efforts to improve the efficiencies of those unit processes identified in the Granular Carbon With Thermal Regeneration alternative. Efforts should be directed towards more effective regeneration processes rather than improving the carbon adsorption rates.

5.2 Continue research on the Surfactant Complexing alternative to determine efficient clarifying techniques and to identify a more efficient complexing agent free of either mutagenic or carcinogenic characteristics.

5.3 Conduct research to document the performance characteristics of surfactant complexing clarification, sludge dewatering and ultimate disposal.

5.4 Consider the applicability of combined treatment methods to the processing of pink wastewaters. (Based on the literature review, indications are that combined systems present a viable alternative worthy of further consideration).



6.0 REFERENCES

1. Catherine C. Andrews, Photooxidative Treatment of TNT Contaminated Waste Water, Weapons Quality Engineering Center, Naval Weapons Support Center, Crane, IN, WQEC/C 80-137, Jan. 1980.
2. Army Environmental Hygiene Agency, Carbon Column System Removal Efficiency Study, Iowa Army Ammunition Plant, USAEHA, Aberdeen Proving Ground, MD, Study No. 24-033-73/74, Feb. 1974.
3. Robert I. Brabets and Gayle E. Marks, Ozonolysis of Pink Water, Phase I, IIT Research Institute, Chicago, IL, IITRI-C6275, 1974.
4. John A. Brown and Bossie Jackson, Jr., White Oil Solvent Extraction of TNT from Pink Wastewater, Large Caliber Weapons System Laboratory, USAARADCOM, Dover, NJ, ARLCD-TR-79020, Dec. 1979.
5. Stephen L. Brown, Joel M. Cohen, Nigel I. Marcree, and Mitchell J. Small, Setting Priorities for R&D on Army Chemicals, Contract DAMD 17-75-C-5071, SRI International, Menlo Park, CA, CRESS Report No. 56, May 1978.
6. William Buckley, Jr., Bossie Jackson, Jr., and Milton Roth, "Advanced Technology for Abatement of Nitrobody Pollution," Safety, Pollution Abatement, and Conservation of Energy Review (SPACER) for Munitions Plant Modernization Third Presentation for the Army Research Office (ARO), Large Caliber Weapon Systems Laboratory, ARRADCOM, Dover, NJ, Sept. 1979.
7. V. J. Ciccone, et al., "A Present Value-Unit Cost Methodology for Evaluating Wastewater Reclamation and Direct Reuse," Water Resources Bulletin, Vol. 11, No. 1, 1975.
8. David G. Derrick and Jerry R. Perrich, "Guide to Ozone Equipment Selection," Pollution Engineering, 42-44, Nov. 1979.



9. Environmental Protection Agency, Solvent Extraction Status Report, Environmental Protection Technology Series, EPA-R2-72-073, Dec. 1972.
10. Frank C. Farrell, Jack D. Zeff, Thomas C. Crase, David T. Boylan, Development Effort to Design and Describe Pink Water Abatement Processes, Final Technical Report, Westgate Research Corporation, West Los Angeles, CA, Aug. 1977.
11. Iowa Army Ammunition Plant, "Nitrobody Characterization of Pink Wastewater at Iowa AAP (Preliminary)", undated.
12. Iowa Army Ammunition Plant, "UV/Ozonolysis Treatment of Pink Wastewater/Iowa AAP, 100,000 Gallons/Day - One Load Line (Full Mobilization) (Preliminary)", undated.
13. Bossie Jackson, Jr., "Pink Water Treatment and Disposal", Safety Pollution Abatement, and Conservation of Energy Review (SPACER) for Munitions Plant Modernization Second Presentation for the Army Research Office (ARO), Large Caliber Weapon Systems Laboratory, ARRADCOM, Dover, NJ, May 1978.
14. J. M. Morgan, Jr., V. J. Ciccone and J. E. Martin, Economic Evaluation of Munitions Manufacturing Wastewater Treatment Alternatives Using a Present Value-Unit Cost Methodology, Prepared for U.S. Army Mobility Equipment and Development Command, Ft. Belvoir, VA, Contract No. DAAK70-76-C-0052, Feb. 1980.
15. "Nitrobody Characterization of Pink Wastewater at Iowa AAP", (Preliminary), Feb. 18, 1981, (Anon).
16. Notes, working meeting, MERADCOM, Ft. Belvoir, VA, 3 July 1980.
17. Notes, working meeting, USATHAMA, Aberdeen Proving Ground, MD, 31 July 1980.



18. Notes, working meeting, USAARADCOM, Dover, NJ, 22 Oct. 1980.
19. Notes, working meeting, IAAP, Burlington, IA, 10-11 Dec. 1980.
20. Notes, working meeting, USAARADCOM, Dover, NJ, 12 Jan. 1981.
21. Notes, working meeting, NATICK, Natick, MA, 9 Feb. 1981.
22. Notes, working meeting, VJCA, Woodbridge, VA, 12 Feb. 1981.
23. Notes, working meeting, VJCA, Woodbridge, VA, 29 May 1981.
24. Notes, working meeting, USATHAMA, Aberdeen Proving Ground, MD, 16 July 1981.
25. James Patterson, John Brown, William Duckert, Jack Polson, and Norman I. Shapira, State-of-the-Art-Study: Wastewater Treatment in the Military Explosives and Propellants Production Industry, Vol. I, Technical Report, American Defense Preparedness Assoc., Washington, DC, Oct. 1975.
26. James Patterson, John Brown, William Duckert, Jack Polson, and Norman I. Shapira, State-of-the-Art-Study, Wastewater Characteristics, Vol. II, American Defense Preparedness Assoc., Washington, DC, Oct. 1975
27. James Patterson, John Brown, William Duckert, Jack Polson, and Norman I. Shapira, State-of-the-Art-Study: Wastewater Treatment, Vol. III, American Defense Preparedness Assoc., Washington, DC, Oct. 1975.
28. Y. Okamoto, E. J. Chou, M. Crole, and M. Roth, Application of Foam Separation to Aqueous Solutions of Trinitrotoluene (TNT) Part II, Removal of Organic Explosives with Surfactants, Large Caliber Weapon Systems Laboratory, USAARADCOM, Dover, NJ, ARLCD-CR-78020, Dec. 1978.



29. Y. Okamoto, E. J. Chou, and J. Yang, The Removal of 2, 4, 6-Trinitrotoluene (TNT) from Aqueous Solution with Surfactants, Large Caliber Weapons System Laboratory, USAARADCOM, Dover, NJ, ARLCD-TR-77038, Oct. 1977.
30. Jerry L. Osmon and C. C. Andrews, The Biodegradation of TNT in Enhanced Soil and Compost Systems, Large Caliber Weapon Systems Laboratory, USAARADCOM, Dover, NJ, ARLCD-TR-77032, Jan. 1978.
31. Milton Roth and Egerton A. Boyce, Continuous Monitoring of Pink Water from Carbon Adsorption Process, Large Caliber Weapon System Laboratory, USAARADCOM, Dover, NJ, ARLCD-TR-77047, Apr. 1978.
32. Milton Roth and Joseph M. Murphy, Jr., Ultraviolet-Ozone and Ultraviolet-Oxidant Treatment of Pink Water, Large Caliber Weapon Systems Laboratory, USAARADCOM, Dover, NJ, Nov. 1978.
33. T. R. Sundaram, J. E. Santo, and A. F. Tatyrek, Hydroperm Microfiltration System for Treatment of TNT Pink Wastewater - Part I, No Pretreatment, Large Caliber Weapon Systems Laboratory, USAARADCOM, Dover, NJ, ARLCD-CR-80031, Apr. 1981.
34. James M. Szachta, Analysis of Carbon versus Resin, Chemical Systems Laboratory, USAARADCOM, Aberdeen Proving Ground, MD, ARLSL-TR-78013, March 1978.
35. James E. Tash, William S. Layne, and Phillip A. Goodfellow, Liquid-Liquid Extraction of TNT from Pink Water with Paraffinic (White) Oil or Toluene, Technical Report No. 327, Mason & Hanger - Silas Mason Co., Inc., Iowa Army Ammunition Plant, 30 Dec. 1980.
36. Alfred F. Tatyrek, Treatment of TNT Munitions Wastewaters - The Current State of the Art, Technical Report 4909, Picatinny Arsenal, NJ, Oct. 1976.



37. Committee on Environmental Sciences and Resources Recovery of the Advisory Board on Military Personnel Supplies, ABMPS Report No. 115, Periodic Report, National Research Council, National Academy Press, Washington, DC, 1981.
38. Federal Register, Environmental Protection Agency, Hazardous Waste Management System, Vol. 45, No. 98, May 19, 1980.
39. Federal Register, Environmental Protection Agency, Hazardous Waste Management System: Identification and Listing of Hazardous Waste, Vol. 46, No. 221, November 17, 1981.



7.0 GLOSSARY OF SELECTED TERMS

Atomized Suspension Technique (AST):

A thermal method for regenerating powdered carbon.

DNT (Dinitrotoluene):

A nitrobody, which has been identified as a potential carcinogen.

Granular Carbon Adsorption:

A method of attracting and accumulating certain organic materials, including TNT, on the surface of activated granular carbon. The granular carbon may or may not be thermally regenerated for cost incentive. Regenerated carbon may be reused; non-regenerated carbon is used on a once-through basis.

HMX (Cyclotetramethylene-tetranitramine):

A nitrobody found in pink water.

Laboratory-Scale Experiments:

Bench-type research confined generally to chemistry laboratory experimentation involving glass or plastic hardware and flexible tubing usually of a temporary nature.

Liquid/Liquid Extraction:

A counter current flow of TNT wastewaters versus an immiscible solute which distributes by stages between the two liquids to reach an equilibrium and extraction of the TNT.

Load, Assemble and Pack (LAP):

Mechanical operations located at Army Ammunition Plants involving loading, unloading, assembling and demilitarizing various shell casings and munitions canisters.

Nitrobodies:

Nitro compounds which includes DNT, HMX, RDX and various isomers of TNT which may be toxic and hazardous. Nitrobodies may include seilite process products and by-products from the munitions production process.

Pilot-Plant Scale Experiments:

Half-size or less research experimentation confined generally to chemical engineering type laboratory experimentation involving manufactured or designed hardware of a semi-permanent nature.

Pink Water or Pink Wastewater:

A common name given to the complex aqueous colored waste at all TNT manufacturing plants, at all LAP operations where propellants and explosives containing TNT are transformed into live munitions, or where TNT-loaded munitions are demilitarized or unloaded. Pink waters, so-called because of their characteristic color, contain mostly TNT and lesser amounts of other nitro compounds (nitrobodies).

Powdered Carbon Adsorption:

A TNT treatment method in which the unwanted constituents are adsorbed on well-mixed, finely divided activated carbon particles which may be thickened into a sludge. The resulting carbon sludge may be reprocessed by an Atomized Suspension Technique for carbon reuse.

Present Value-Unit Cost:

A methodology utilizing a computerized mathematical model approach which considers capital and operating costs, depreciation, interest, effects of inflation, salvage value, and other related factors over varying periods of time (see Time Horizons) and wastewater loading rates. The relative cost of each alternative yields the minimum cost per thousand gallons of wastewater to be treated daily over the anticipated time horizons.

RDX (Cyclotrimethylene-trinitramine):

A nitrobody found in pink water.



Red Water:

A highly concentrated sulfonated nitrobody generated in the TNT purification process which utilizes sellite, a solution (16 percent) of sodium sulfite; the sellite solution and the accompanying rinse waters constitute the red water.

Surfactant Complexing:

A method of reducing TNT concentrations in pink water by the addition of a surfactant in the presence of a strong alkaline and later neutralizing the waste with an acid. Sludges are expected to result from the process.

Time Horizon:

Six periods of five years each which serve as computation parameters for PVUC over the thirty year lifespan of the treatment system.

TNT (2,4,6-trinitrotoluene):

Exists as 2,4,6-trinitrotoluene (alpha-TNT) $[(NO_2)_3C_6H_2CH_3]$, an aromatic ring compound.

Ultrafiltration:

The process of removing TNT material by a pressure active physical separation process employing a selective porous membrane to restrict the passage of unwanted material.

Ultraviolet-Ozone:

The process of treating TNT wastes by two processes simultaneously. Ozone is induced into the pink waters and the waters are permitted to flow around banks of ultraviolet light lamps.

USARRADCOM:

U.S. Army Armament Research and Development Command, Dover, New Jersey.

USATHAMA:

U.S. Army Toxic and Hazardous Materials Agency, Aberdeen Proving Ground, Maryland.



USAMERADCOM:

U.S. Army Mobility Equipment Research and Development Command, Ft. Belvoir,
Virginia.

\$/K-GAL:

Dollars per thousand gallons.

\$/M-GAL:


Dollars per million gallons.



APPENDIX A

FLOW DIAGRAMS AND DESIGN DATA SHEETS





- NOTES
- 1 - SECTION A - REGENERATION SYSTEM W/ 9040/9240
 - 2 - SECTION B-B - 9013 9213 W/O REGENERATION
 - 3 - SECTION C-C - REGENERATION SYSTEM W/ 9011/9211

FIGURE A-1. GRANULAR CARBON ADSORPTION

PLANT IDENTIFICATION	DESCRIPTION
9006	PUMP, WASH WATER
9007	PUMP, PRESSURE EQUALIZATION
9008	PUMP, PRESSURE SUMP
9009	WASTE CARBON TANK
9010	FILTER PRESSURE DE (OR MIX MEDIA) CARBONIZATION SEPARATION TANK
9011	CARBON REGENERATION SYSTEM
9012	CARBON COLUMN - GRANULAR (W/O REGEN)
9013	WASTE CARBON TANK
9014	PUMP
9015	TANK
9016	CARBONIZATION TANK WITH THERMAL REGEN
9017	FILTER PRESSURE DE (OR MIX MEDIA) CARBONIZATION SEPARATION TANK
9018	CARBONIZATION TANK WITH THERMAL REGEN
9019	HOLDING TANK
9020	SCREW
9021	CARBON DE-FINE TANK
9022	MULTI HEARTH FURNACE
9023	PULVER

ZONE	REV	DESCRIPTION	DATE	APPROVED
			2-19-82	

INTEREST PARTIES IN THIS PROJECT

ACCREDITED BY 800-823-100 FOR CREDIT RATING

CONTRACT NO. 9011-9211

DATE 2-19-82

SCALE 1/8" = 1'-0"

FIGURE A-1

SHEET 1 OF 15

V.J. CICCOONE
V.J. & ASSOCIATES, INC.
ENGINEERING SERVICES

REV	DESCRIPTION	DATE	APPROVED
1		2-19-58	

TABLE A-1a DATA SHEET, GRANULAR CARBON ADSORPTION 10⁵ GPD

UNIT	Q904	Q906	Q907	Q908	Q911	Q913	Q914	Q915	Q916	Q919	Q925	Q926	Q931	Q940
NAME/TYPE	RAWN BAWM PUMP	PUMP PRESS.	PUMP SUMP	TANK VERTICAL	TRIG. CARBON SYSTEM	CARBON COLUMN	WASTE TANK	FILTER D.E.	TANK EQUAL	CARBON COLUMN	TANK HOLDING	SUMP	CONV. TANK	TANK
DIMENSIONS	2 x 2	2 x 2	2 x 2	800 x 800	60" D	100" x 60"	500-800	150 x 100	40" x 40"	100" x 100"	400-700	800-1700	900-2501	1000-1400
CAPACITY				20,000 (2000 GAL)	1000 (1000 GAL)	2000 (2000 GAL)	2000 (2000 GAL)	2000 (2000 GAL)	1000 (1000 GAL)	3000 (3000 GAL)	2500 (2500 GAL)	2000 (2000 GAL)	3000 (3000 GAL)	3000 (3000 GAL)
MATERIAL	A.I.	A.I.	A.I.	STEEL	A.I.	STEEL	STEEL	STEEL	STEEL	STEEL	STEEL	STEEL	STEEL	STEEL
TYPE	CNTFGL	CNTFGL	CNTFGL	VERT. CYL.	VERT. CYL.	CARBON	VERT. CYL.	VERT. CYL.	RECT.	CARBON	VERT. CYL.	VERT. CYL.	CYL.	VERT. CYL.
ENERGY REQ.	2.5 KW	4 KW	4 KW		5-6 KW			45-55 PSI		25 PSI			1.5 KW	1.5 KW
PRESSURE	45 PSI	65 PSI	25 PSI		25 PSI			70 GPA		70 GPA			250 LBS/HR	200 GPA
RATE	70 GPA	70 GPA	150 GPA		1.85 / 111	70 GPA		70 GPA		70 GPA			250 LBS/HR	200 GPA
LOAD					200 LBS/HR	18 GPM/HR		15 GPM/HR		18 GPM/HR			250 LBS/HR	200 GPA
EFFICIENCY					100%	30-50%		20%		30-50%				
AREA					200 SQ FT	30-50 SQ FT		20 SQ FT		30-50 SQ FT				
VOLUME					2000 LBS	3000 LBS		2000 LBS		3000 LBS				
WEIGHT					2000 LBS	3000 LBS		2000 LBS		3000 LBS				
TYPE					50 MIN	1 HR		10 GPA		35 MIN		1 HR		15 MIN
HYDRAULIC HP	1.9 HP	2.6 HP	2.2 HP						28 HP			1 HR		
DETAILED		(2.6 HP)	(1.5 HP)											
EQUIP QUANTITY	1	2	2	1	1	1	3	2	1	1	1	1	1	1
OTHER DATA				3-CARBON COLUMN		1 UNIT - 3 COLUMN WITHOUT REGEN	3-CARBON COLUMN			W/REGEN ONLY				

NOTE:
NUMBER IN PARENTHESIS IS VALUE
USED IN THE ECONOMIC PVUC MODEL

V.J. CICCOBE & ASSOCIATED, INC.
ENGINEERING SERVICES

GRANULAR CARBON ADSORPTION
10⁵ GPD

INTERPRET DRAWING IN ACCORD WITH 888-170-100 CONTRACT
DRAWN TO: 80-C-101
DATE: 2-19-58

DESIGNED BY: JSD
CHECKED BY: JSD
DATE: 2-19-58

SCALE: 1" = 1'-0"

SHEET 2 OF 15

DATE	DESCRIPTION	APPROVED
2-19-82		

TABLE A-2 b. DATA SHEET, SURFACTANT COMPLEXING 10⁶ GPD

PVIC CAT. NUMBER	9206	9207	9215	9222	9224	9225	9228	9234	9235	9243
NOMENCLATURE	PUMP PRESS. SWAP	PUMP SWAP	TANK EMAN	NEUT. TANK	SURFACT. TANK	FEEDER CHENICAL	SUMP	VACUUM FILTER	TAJUS SURFACT.	INCIN.
DIMENSIONS	3 x 4	3 x 4	70" x 25" x 12"	24" x 20" x 12"	8' x 6' x 10'		55" x 100" x 110"	30" x 30" x 10"	24" x 20" x 12"	
CAPACITY			250 GPD	1200 GPD	1800 GPD		200 GPD	1000 GPD	1000 GPD	
MATERIAL	M.I.	M.I.	CONCRETE	COATED STEEL	STEEL	STEEL	STEEL	DATA	STEEL	
TYPE	CATFGL.	CATFGL.	RECT.	VERT. CYL.	RECT.	GRAVITY	VERT. CYL.	PEREZENT	VERT. CYL.	
ENERGY REQ.	25 Kw/h	25 Kw/h		10 Kw/h		37 Kw/h		20" Hg	10 Kw/h	
PRESSURE	45 PST	45 PST				30 LBS/HR		10 GPD		
RATE	700 GPD	700 GPD						105 GPD/FT		
HYDR. LOAD								200 FT/HR		
EFFECTIVE AREA										
MEDIA VOLUME										
SKW PERIOD										
PAU RATE	15 SHIP (1.9)	15 SHIP (7.6)				SHIP				
HYDRAULIC HP										
DETN TIME			12 HRS.	60 MIN	20 MIN STORAGE		48 HRS		30-60 MIN	
EQUIP QUANTITY	5	2	2	1	3	3	1	1	2	
OTHER DATA								WATER		

PHANTOM

NOTE:
NUMBER IN PARENTHESIS IS VALUE
USED IN THE ECONOMIC PVIC MODEL

INTERPRET DRAWING IN ACCORD WITH 880-110-100 CONTRACT

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES UNLESS OTHERWISE SPECIFIED:

3 PLACE DECIMALS ± .005
2 PLACE DECIMALS ± .010
1 PLACE DECIMALS ± .015

THIS DOCUMENT IS PROPERTY OF J. J. GIBSON & ASSOCIATES, INC. IT IS TO BE USED ONLY FOR THE PROJECT AND SHALL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, FOR PUBLICATION, ADVERTISING, OR PROMOTIONAL PURPOSES WITHOUT THE WRITTEN PERMISSION OF J. J. GIBSON & ASSOCIATES, INC.

DATE _____

APPROVED _____

DESIGNED BY _____


SCALE _____

TABLE A-2 b

SHEET 6 OF 16

J. J. GIBSON & ASSOCIATES, INC.
ENGINEERING SERVICES

SURFACTANT COMPLEXING
10⁶ GPD



REV. NO.	DESCRIPTION	DATE	BY

NOTE
SECTION A-A : 9032 & 9232
(AST REGENERATION SCHEME)

FIGURE A-3, POWDERED CARBON ADSORPTION

CAT. NUMBER	NO. ENCLATURE
9004	PUMP-PRESSURE BACKWASH-DE
9006	PUMP-PRESSURE EQUALIZATION
9007	PUMP-PRESSURE SU/MP
9015	FILTER-PRESSURE-DE (M/ANX AEMDA)
9018	EQUALIZATION SEDIMENTATION TANK
9023	HOLDING TANK
9024	MIX TANK
9026	SU/MP
9028	TURKENER - GRAVITY
9030	CONVEYOR - SCREW
9031	AST REGENERATION SCHEME
9032	POLYMER ADDITION
9033	VACUUM FILTER POWDERED CARBON
9034	POWDERED CARBON MIXING TANK
9036	POWDERED CARBON CLAMIFIER
9037	DRY FEEDER
9044	

INTERPRET DRAWING IN ACCORD WITH 900-810-100

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES

TOLERANCES: ANGLES: PLACE DECIMALS: DRAWN BY: CHECKED BY: APPROVED BY: DATE:

PROJECT: POWDERED CARBON ADSORPTION

SCALE: C

FIGURE NO: FIGURE A-3

SHEET: 7 OF 15

TABLE A-3 a, DATA SHEET, POWDERED CARBON ADSORPTION 10⁵ GPD

	9004	9006	9007	9015	9016	9025	9024	9028	9030	9031	9032	9033	9034	9036	9037	9044
PVUC CAT NUMBER	9004	9006	9007	9015	9016	9025	9024	9028	9030	9031	9032	9033	9034	9036	9037	9044
NO. Nomenclature	RUP BKUH	RUP PRESS	RUP SUAP	FLTR DE	TANK EQUAL	TANK LOADING	TANK MIX	SUPAD	GRAVITY MIXER	CONVR SCREW	NOZZLE SPINBL	POLY ADDITION	VACUUM FILTER	TANK MIXING	CLARIFIER	FEEDER
DIMENSIONS	2 x 2	2 x 2	2 x 2	21.0 x 50.0	37 x 45 x 0	11.00 x 70.0	60.0 x 30.0	1000 x 20.0	600 x 55.0	900 x 50.0	100 x 100.0	75.0 x 25.0	85.0 x 100.0	100 CAL	85.0 x 100.0	
CAPACITY					100,000	25,000	655 CAL	25,000 GPM	1000 CAL		70000/DY		2000/DY	100 CAL	300 CAL	
MATERIAL	A.I.	A.I.	A.I.	A.I.	STEEL	STEEL	STEEL	STEEL	COATED STEEL	STEEL			A.I.	COATED STEEL	UP FLOW	
TYPE	CUTFLG	CUTFLG	CUTFLG	VERT CYL	RECT.	VERT CYL	VERT CYL	VERT CYL	UPLIFT				ROTARY DRUM			COBILITY
ENERGY REQ.	49 KW/H	4 KW/H	4 KW/H	0.5 KW/H					OPEN TMC				2 KW/H		0.7 KW/H	0.5 KW/H
PRESSURE	45 PSI	65 PSI	25 PSI	45-55 PSI					70 GPM				6 GPM		70 GPM	70 LBS / HR
RATE	70 GPM	150 GPM		70 GPM	70 GPM				70 GPM						1.77 GPM PER FT ²	
HYDR. LOAD				75 GPM/FT ²					0.75 GPM PER FT ²						20 FT ² /HR	
EFFECTIVE AREA				76 FT ²					28 FT ²							
MEDIA VOLUME				7200 LB/HR												
BKW. PERIOD				5 MIN												
BKW. RATE				70 GPM												
HYDRAULIC LP	1.9 LP	2 GUP	2.4 LP													
DETA. TIME					24 HRS									10 MIN	10 MIN	
EQUIP QUANTITY	1	5	2	2	1	1	2	1	1	2	1	1	1	1	2	2
OTHER DATA											90% EFF		OPERATES 24 HRS/DY			

NOTE:
NUMBER IN PARENTHESIS IS VALUE
USED IN THE ECONOMIC PVUC MODEL

INTERPRET DRAWING IN ACCORD WITH 888-118-100 CONTRACT

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES: ANGLES: ± 0.015" (1/16") ± 0.005" (1/32") ± 0.002" (1/160") ± 0.001" (1/1000")

DATE: 2-19-82

APPROVED: [Signature]

Y. J. SICORE & ASSOCIATES, INC. ENGINEERING SERVICES

POWDERED CARBON ADSORPTION 10⁵ GPD

TABLE A-3a

SHEET 8 OF 13

TABLE A-3 b, DATA SHEET. POWDERED CARBON ADSORPTION 10% GPD

PVIC CAT. NUMBER	9204	9206	9207	9215	9223	9224	9228	9230	9231	9232	9233	9234	9236	9237	9239	9244
NOMENCLATURE	PUMP DOWN	PUMP PRESS	PUMP EQUAL	TANK HOLDING	TANK HOLDING	TANK MIX	SUMP	GRAVITY THUNDER	CONVR. SCREW	AGITATE	POLY ADDITION	VACUUM FILTER	TANK (MIXING)	CLARIFIER	CLARIFIER	FEEDER
DIMENSIONS	4 x 5	3 x 4	3 x 4	10' x 25' x 2'	15'0" x 20'0"	6'-0" x 4'	55'0" x 12'0"	10'0" x 25'1"	9'0" x 25'1"	7'0" x 5'0"	8'0" x 10'0"	10'0" x 10'0"	10'0" x 10'0"	7'0" x 10'0"	17'5" x 8'0"	
CAPACITY				250,000	250,000	1800 GALS. (5000)	200,000	25,000	900,251	700	2000 LBS PER DAY	800 LBS/DY.	1000	35,000		
MATERIAL	A.I.	A.I.	A.I.	CONCRETE	STEEL	STEEL	STEEL	CORTED STEEL	STEEL			DRUM	STEEL	CORTED STEEL	STEEL	
TYPE	CNT'GAL.	CNT'GAL.	CNT'GAL.	RECT.	VERT. CYL.	RECT.	VERT. CYL.	CORTED STEEL	SCREW			PRES. CONT.	VERT. CYL.	VERT. CYL.	VERT. CYL.	GRAVITY DRY
ENERGY REQ.	23 Kw-h	23 Kw-h	23 Kw-h								2 Kw-h			7 Kw-h		5 Kw-h
PRESSURE	25 PSI	15 PSI	45 PSI					70 GPM						700 GPM	350 GPM	70 LBS/HR
RATE	1200 GPM	700 GPM	700 GPM	350 GPM				70 GPM						130 GPM	546 FT	117 FT
LAYER LOAD								0.25 GPM/FT								
EFFECTIVE AREA								728 FT ²								
AREA VOLUME																
REV PERIOD	10 MIN.															
REV RATE	150 GPM/FT															
HYDRAULIC UP	10 UP (316)	10 UP (316)	10 UP (316)													
DEIN TIME				12 LBS.												
EQUIP QUANTITY	1	3	2	2	1	2	1	1	2	1	1	1	1	2	4	2
UTILET DATA										50% EFF						

NOTE.
NUMBER IN PARENTHESES IS VALUE
USED IN THE ECONOMIC PVIC MODEL

V J CICCORE & ASSOCIATES, INC.
ENGINEERING SERVICES

POWDERED CARBON ADSORPTION
10% G.P.D

UNLESS OTHERWISE SPECIFIED
ALL DIMENSIONS ARE IN FEET - INCHES
3 PLACE DECIMALS - 4 PLACE DECIMALS
DRAWN BY: [] CHECKED BY: [] DATE: []

INTERPRET DRAWING IN
ACCORD WITH 008-518-100
CONTRACT NO. 70-80 C. 001
THIS DRAWING IS PART OF
A PROJECT FOR V. J. CICCORE
& ASSOCIATES, INC. AND
IS NOT TO BE REPRODUCED
OR USED IN ANY FORM, IN
WHOLE OR IN PART, WITHOUT
EXCEPT WHERE OTHER-
WISE AUTHORIZED.

SHEET 9 OF 15

REV	DESCRIPTION	DATE	APPROVED
1		2-19-82	





FIGURE A-4, UV-OZONE

PVUC CAT. NUMBER	NO. IN CLATURE
9003	9203
9004	9204
9005	9205
9006	9206
9007	9207
9012	9212
9015	9239
9016	9216
9021	9221
9023	9223
9028	9228
9041	9241
9042	9242
9007A	9207A



 V. J. CICCHINI & ASSOCIATES, INC.
 ENGINEERING SERVICES

INTEREST DRAWING NO. 9007A-100
 ACCORD WITH 889-178-100 CONTRACT
 DRAW TO SDC Q101
 THIS DRAWING IS FOR THE PROJECT TO BE COMPLETED BY THE CONTRACTOR. IT IS THE CONTRACTOR'S RESPONSIBILITY TO VERIFY ALL DIMENSIONS AND CONDITIONS IN THE FIELD. NO PART OF THIS DRAWING SHALL BE REPRODUCED OR TRANSMITTED IN ANY FORM, NOR BE LOANED TO OTHERS, WITHOUT THE WRITTEN AUTHORIZATION OF THE ENGINEER.

DATE: 2-19-82
 DRAWN BY: JLD
 CHECKED BY: JLD
 APPROVED BY: JLD
 SCALE: AS SHOWN
 FIGURE NO: FIGURE A-4
 SHEET NO OF 15

TABLE A-4b, DATA SHEET, UV-OZONE 10⁶ GPD

PVUC CAT NUMBER	9203	9204	9205	9206	9207A	9207	9212	9218	9221	9223	9225	9239	9241	9242
NOVENCULATURE	OZONE REACTOR	PUMP	UV LAMPS	PUMP PRESS	PUMP COOLING	PUMP SWAP	CONTROL VALVE	TANK EDU	CHILLER	TANK WOLK	TANK SWIM	FILTER	EXHAUST	ROVER
DIMENSIONS	40' x 5'	4 x 5	2 x 5'	3 x 4	8 x 8	3 x 4	170-72-12	170-72-12		100-100-100	5500-7000	100-100-100	100-100-100	100-100-100
CAPACITY	30,000 GPH						250,000	250,000		75,000 GPH	200,000			
MATERIAL	CHES	M.I	QUARTZ	M.I	M.I	M.I	CONCRETE	CONCRETE	COOLING	STEEL	STEEL	STEEL	CRES	CRES
TYPE	8-STAGES	CNTFGL		CNTFGL	CNTFGL	CNTFGL	RECT.	RECT.	DRYER	VERT CYL	VERT CYL	VERT CYL	VERT CYL	VERT CYL
ENERGY REQ.		25 KwH	197 KwH	25 KwH	25 KwH	25 KwH	2800 KwH		1000 KwH					
PRESSURE		25 PSI	50 PSI	45 PSI	25 PSI	45 PSI			25 PSI					
RATE	175 GPH	1200 GPH	60 WATTS PER LAMP	100 GPH	2500 GPH	700 GPH		500 GPH	4000 GPH					
LYDR. LOAD							8000 G/L							
EFFECTIVE AREA														
MEDIA VOLUME														
BLW. PERIOD		10 MIN												
BLW. RATE		15 GPM/FT												
HYDRAULIC HP		18 HP (31 C)		18.3 HP (7.6)	24 HP (7.6)	18.3 HP (7.6)								
DETL TIME	2.5 HRS						12 HRS							
EQUIP. QUANTITY	4		23,040 LAMPS	2	FOR CHILLER									
OTHER DATA			5700/FT PUMP/FT											

NOTE:
NUMBER IN PARENTHESES IS VALUE
USED IN THE ECONOMIC PVUC MODEL

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES: ANGLES: ± .015 PLACE DECIMALS ± .015

INTERPRET DRAWING IN ACCORD WITH 900-110-100 CONTRACT

THIS DOCUMENT IS PROPERTY OF MERRILL LYNCH, PIERCE, FENNER & SMITH, INC. IT IS TO BE USED ONLY FOR THE PROJECT AND NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM, FOR ANY PURPOSE, WITHOUT THE WRITTEN PERMISSION OF MERRILL LYNCH, PIERCE, FENNER & SMITH, INC.

DATE: 11/21/01

SCALE: AS SHOWN

TABLE: A-4b

PROJECT NO.: 106-GP2

UV-OZONE

MERRILL LYNCH, PIERCE, FENNER & SMITH, INC. ENGINEERING SERVICES




FIGURE A-6, ULTRA-FILTRATION

DATE	REV	DESCRIPTION	DATE	APPROVER
8-19-62				


		M. A. FICHERS & ASSOCIATES, INC. ENGINEERING SERVICES	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES: ANGLES: ± 0.015" PLACES: DIMENSIONS: ± 0.015"		DRAWN BY: [] CHECKED BY: [] APPROVED BY: [] DATE: []	
PROJECT NUMBER: [] SHEET NO. OF 110		TITLE: ULTRA-FILTRATION FIGURE A-6	

TABLE A-6a, DATA SHEET, ULTRA-FILTRATION 105 GPD

PUVC CAT. NUMBER	9004	9006	9007	9015	9025	9026	9027	9028	9045
MANUFACTURE	2x2	2x2	2x2	2x2	2x2	2x2	2x2	2x2	2x2
DIMENSIONS	2x2	2x2	2x2	2x2	2x2	2x2	2x2	2x2	2x2
CAPACITY	100,000	100,000	100,000	100,000	100,000	100,000	100,000	100,000	100,000
MATERIAL	STEEL	STEEL	STEEL	STEEL	STEEL	STEEL	STEEL	STEEL	STEEL
TYPE	VERT. CYL	VERT. CYL	VERT. CYL	VERT. CYL	VERT. CYL	VERT. CYL	VERT. CYL	VERT. CYL	VERT. CYL
ENERGY REQ	4 Kw/h	4 Kw/h	4 Kw/h	4 Kw/h	4 Kw/h	4 Kw/h	4 Kw/h	4 Kw/h	4 Kw/h
PRESSURE	45 PSI	45 PSI	45 PSI	45 PSI	45 PSI	45 PSI	45 PSI	45 PSI	45 PSI
RATE	70 GPD	70 GPD	70 GPD	70 GPD	70 GPD	70 GPD	70 GPD	70 GPD	70 GPD
HYDRO LOAD	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT
EFFECTIVE AREA	75 FT ²	75 FT ²	75 FT ²	75 FT ²	75 FT ²	75 FT ²	75 FT ²	75 FT ²	75 FT ²
AREA VALUE	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT	75 GPD/FT
PER PERIOD	5 MIN	5 MIN	5 MIN	5 MIN	5 MIN	5 MIN	5 MIN	5 MIN	5 MIN
PER RATE	1.9 HP	1.9 HP	1.9 HP	1.9 HP	1.9 HP	1.9 HP	1.9 HP	1.9 HP	1.9 HP
HYDRAULIC HP	(2.2)	(2.2)	(2.2)	(2.2)	(2.2)	(2.2)	(2.2)	(2.2)	(2.2)
DEFN TIME	24 HRS	24 HRS	24 HRS	24 HRS	24 HRS	24 HRS	24 HRS	24 HRS	24 HRS
EQUIP QUANTITY	1	2	2	2	2	2	2	2	2
OTHER DATA									

NOTE:
NUMBER IN PARENTHESIS IS VALUE
USED IN THE ECONOMIC PVUC MODEL

V.A. CICCOBE & ASSOCIATES, INC.
ENGINEERING SERVICES

ULTRA-FILTRATION
105 GPD

INTERPRET DRAWING IN ACCORD WITH 008-810-100
CONVERT TO 40 C. 0101
DRAWN BY: S3
CHECKED BY: S3
DATE: 2-19-82

APPROVED BY: [Signature]
DATE: 2-19-82

TABLE A-6a

4 3 2 1

TABLE A-G.b. DATA SHEET, ULTRA-FILTRATION 10⁶ GPD

PVC CAT NUMBER	9204	9206	9207	9210	9225	9227	9228	9250	9253
MANUFACTURE	TRUMP PUMP PUMP	TRUMP PUMP PUMP	TRUMP PUMP PUMP	TRUMP PUMP PUMP	TRUMP PUMP PUMP	TRUMP PUMP PUMP	TRUMP PUMP PUMP	TRUMP PUMP PUMP	TRUMP PUMP PUMP
DIMENSIONS	4 x 5	3 x 4	3 x 4	100-25-12	100-25-12	100-25-12	100-25-12	100-25-12	100-25-12
CAPACITY				250,000	250,000	250,000	250,000	250,000	250,000
MATERIAL	A I	A I	A I	CONCRETE	STEEL	STEEL	STEEL	STEEL	STEEL
TYPE	CNTFGL	CNTFGL	CNTFGL	RECT.	VERT CYL	VERT CYL	VERT CYL	VERT CYL	VERT CYL
ENERGY REQ	25 KW	25 KW	25 KW						
PRESSURE	25 PSI	45 PSI	45 PSI						
RATE	1200 GPM	700 GPM	700 GPM	350 GPM					
HYDR LOAD									
EFFECTIVE AREA									
MEDIA VOLUME	10/AIN								
BAW PERIOD	10/AIN								
BSW OR.	15 GPM/FT								
INTRINSIC HP	18.5 HP	18.5 HP	18.5 HP						
DETN TIME	1	2	2	12 HRS					
EQUIP QUANTITY									
OTHER DATA									

PHANTOM 3

NOTE
NUMBER IN PARENTHESES IS VALUE
USED IN THE ECONOMIC PVC MODEL

REV	DESCRIPTION	DATE	APPROVED
1		2-10-82	

INTERPRET DRAWINGS IN
CONCORDANCE WITH THE
CONTRACT
DRAWING NO. 80-C-0101
DATE 10-1-82
BY V. J. CICCO
V. J. CICCO & ASSOCIATES, INC.
ENGINEERING SERVICES

ULTRA-FILTRATION
10⁶ GPD

SCALE: 1" = 10'-0"

TABLE A-G.b
SHEET 15 OF 15

APPENDIX B

DATA SET FOR PVUC ANALYSES INVOLVING
FLOW RATES OF 100 000 GPD

THE TITLE OF EACH UNIT IS GIVEN FOLLOWED BY:

CAT NUM	CAPACITY IN GAL OR NUM OF UNITS	GALLONS PER DAY SEEN BY UNIT	UNIT CAPITAL COST FUNCTION	O & M FUNCTION

OZONE REACTOR				
9003	10000	100000	326000	0
PUMP-PRESS. BACKWASH-D.E.				
9004	1.89	10000	$636 * G1^{0.51}$	$3.76 * (G1^{0.62}) * .25 * .33 * D9 * .03$
UV LAMPS				
9005	2304	100000	1	$((1.25 * G1) * 50 + G1 * .095 * 24 * .035 * D9)$
PUMP-PRESS. EQUALIZATION				
9006	2.66	100000	$636 * G1^{0.51}$	$3.76 * (G1^{0.62}) * 24 * D9 * .03$
PUMP-PRESS. SUMP				
9007	7.58	100000	$636 * G1^{0.51}$	$3.76 * (G1^{0.62}) * 24 * D9 * .03$
VIRGIN CARBON STORAGE TANK				
9008	24000	24000	$74.5 * G1^{0.46}$	0
CARBON WASH TNK -STL OR MI				
9009	3000	5000	$88.4 * G1^{0.44}$	0
QUENCH TANK -STL OR MI				
9010	5000	1000	$13E3 + .27 * G2$	1E3
CARBON REGEN FURNACE				
9011	1	30	$133745 * G2^{0.404}$	$2500 * G2^{0.715}$
OZONE GENERATOR				
9012	1	100000	$148113 * E9^{0.78E-6 * G2}$	$8064 * .035 * D9$
CARBON COLUMN-GRANULAR				
9013	2000	100000	$137513 * (E9^{0.96E-8 * G2})$	$4.32E4 * E9^{0.2E-6 * G2} + 27E3$
WASTE CARBON TNK-STL OR MI				
9014	12000	1000	$88.4 * G1^{0.44}$	0



CAT NUM	CAPACITY IN GAL OR NUM OF UNITS	GALLONS PER DAY SEEN BY UNIT	UNIT CAPITAL COST FUNCTION	O & M FUNCTION

FILTER-PRESSURE-DE				
9015	200	50000	$307466 * ((G2 * 1E-6) \textcircled{.65})$	$844 * E9 \textcircled{(1.2E-6 * G2)}$
EQUALIZATION TNK-CONC.				
9016	.1	.1	$279105 * E9 \textcircled{(.49 * G1)}$	$276 * E9 \textcircled{(.6 * G2)}$
EQUALIZATION TNK-EARTHEN				
9017	.1	.1	$197432 * (G1 \textcircled{.41})$	0
EQUALIZATION/SEDIMENTATION TANK -STL				
9018	100000	25000	$29.76 * G1 \textcircled{.56}$	0
CARBON COLUMN WITH THERMAL REGEN.				
9019	2000	100000	$137513 * (E9 \textcircled{(96E-8 * G2)})$	$5.8E3 * E9 \textcircled{(2.2E-6 * G2)}$
SCRUBBER				
9020	100	.1	$2 * (8547 + 489 * G1 - 1.02 * G1 \textcircled{2})$	$.35 * G2$
COOLER-CHILLER				
9021	1	1	5000	2000
NEUTRALIZATION TANK				
9022	5000	100000	$88.4 * G1 \textcircled{.44}$	$(450 * D9 * .50) + 2E3$
HOLDING TANK				
9023	25000	100000	$88.4 * G1 \textcircled{.44}$	0
SURF. STR/MIX/BODY FEED TNK				
9024	500	0	$88.4 * G1 \textcircled{.44}$	0
CHEMICAL FEEDER				
9025	1	1	$3E3$	$1E3$
UF-RECIRC. PUMP				
9026	75.6	4320000	$636 * G1 \textcircled{.51}$	$3.76 * (G1 \textcircled{.62}) * 24 * D9 * .03$
UF MEMBRANE MODULE				
9027	.1	.1	$7080991 * G1 \textcircled{.67}$	$796011 * G1 \textcircled{.56}$
SUMP-STL OR MI				
9028	20000	100000	$88.4 * G1 \textcircled{.44}$	0



CAT NUM	CAPACITY IN GAL OR NUM OF UNITS	GALLONS PER DAY SEEN BY UNIT	UNIT CAPITAL COST FUNCTION	O & M FUNCTION
CLARIFIER-CIRCULAR				
9029	6000	100000	$1083E2*(G2*1E-6)^{.45}$	$6550*(G2*1E-6)^{.474}$
THICKENER-GRAVITY				
9030	2000	10000	$2654E2*(G2*1E-6)^{.52}$	$3E4*(G2*1E-6)^{.44}$
CONVEYOR SCREW				
9031	1	25	$2*(633+66*G2)$	1E3
AST-FURNACE (250 LB/DAY)				
9032	1	100000	$2*(67E3)$	24E3
POLYMER ADDITION				
9033	500	100000	$68E2*E9^{.9}(G2*1E-6)$	$7E3*E9^{.9}(G2*.95E-6)$
VACUUM FILTER POWDERED CARB.				
9034	1	20	$128E2*(G2^{.584})$	$((50*G2^{.73})+(60*G2^{.70})+(66*G2^{.88}))$
SURFACT REACT TANK				
9035	5000	100000	$(88.4*G1^{.44})+2E3$	$(60*D9*1.00)+2E3$
POWD. CARB. MIX TANK				
9036	100	100000	$88.4*G1^{.44}$	1E3
POWD. CARB. CLARIFIER				
9037	5000	100000	$247E3*((G2*1E-6)^{.31})$	$(26E4*((G2*1E-6)^{.58})-(183*D9*.60))$
VACUUM FILTER-SURFACTANTS				
9038	1	278	$128E2*(G2^{.584})$	$150*G2^{.88}+250*D9*.15$
CARBON DE-FINE TANK				
9040	2500	2500	$137513*(E9^{.9}(96E-8*G2))$	1E3
OZONE PRECONTACTOR				
9041	1000	100000	$88.4*G1^{.44}$	0
OZONE DESTROYER				
9042	1	1	1	0



CAT NUM	CAPACITY IN GAL OR NUM OF UNITS	GALLONS PER DAY SEEN BY UNIT	UNIT CAPITAL COST FUNCTION	O & M FUNCTION
DRY FEEDER				
9044	100000	100000	$3.75E4-88.4*G1^{\circ}.44$	2.1E4
SOLVENT EXTRACTION				
9045	6000	.84	$1.2E6*G2^{\circ}.7$	$86.4*G2^{\circ}.59$
FRACTIONAL DISTILLATION				
9046	1.29	1000000	$403140*G1^{\circ}.703$	$78142*G1^{\circ}.658$
DUMMY				
9058	1	1	1	1

NOTES: D9 = number of operating days

E9 = function e

$1En = 10^n$

© = power function, i.e., raised to the number that follows



APPENDIX C

DATA SET FOR PVUC ANALYSES INVOLVING
FLOW RATES OF 1 000 000 GPD

THE TITLE OF EACH UNIT IS GIVEN AND FOLLOWED BY:

CAT NUM	CAPACITY IN GAL OR NUM OF UNITS	GALLONS PER DAY SEEN BY UNIT	UNIT CAPITAL COST FUNCTION	O & M FUNCTION

OZONE REACTOR				
9203	30000	1000000	2*326000	0
PUMP-PRESS. BACKWASH				
9204	31.6	100000	636*G1 ^{0.51}	3.76*(G1 ^{0.62})*.25*D9*.03
UV LAMPS/REACTOR TANK				
9205	5760	1000000	1	((1.25*G1)*50+G1*.095*24*.035*D9)
PUMP-PRESS. EQUALIZATION				
9206	2.66	1000000	636*G1 ^{0.51}	3.76*(G1 ^{0.62})*24*D9*.03
PUMP-PRESS. SUMP				
9207	7.58	1000000	636*G1 ^{0.51}	3.76*(G1 ^{0.62})*24*D9*.03
VIRGIN CARBON STORAGE TANK				
9208	24000	24000	74.5*G1 ^{0.46}	0
CARBON WASH TNK -STL OR MI				
9209	30000	50000	88.4*G1 ^{0.44}	0
QUENCH TANK -STL OR MI				
9210	25000	10000	13E3+.27*G2	1E3
CARBON REGEN FURNACE				
9211	1	300	133745*G2 ^{0.404}	2500*G2 ^{0.715}
OZONE GENERATOR				
9212	1	1000000	148113*E9 ⁰ (.78E-6*G2)	60360*.035*D9
CARBON COLUMN-GRANULAR				
9213	21000	1000000	137513*(E9 ⁰ (96E-8*G2))	53E3*E9 ⁰ (2.2E-6*G2)+27E4
WASTE CARBON TNK-STL OR MI				
9214	25000	10000	88.4*G1 ^{0.44}	0



CAT NUM	CAPACITY IN GAL OR NUM OF UNITS	GALLONS PER DAY SEEN BY UNIT	UNIT CAPITAL COST FUNCTION	O & M FUNCTION
FILTER-PRESSURE-D.E.				
9215	2000	340000	$307466 * ((G2 * 1F - 6) \ominus .65)$	$844 * E9 \ominus (1.2E - 6 * G2)$
EQUALIZATION TNK-CONC.				
9216	.1	.1	$279105 * E9 \ominus (.49 * G1)$	$276 * E9 \ominus (.6 * G2)$
EQUALIZATION TNK-EARTHEN				
9217	.1	.1	$197432 * (G1 \ominus .41)$	0
EQUALIZATION/SEDIMENTATION TANK-STL				
9218	100000	1000000	$29.76 * G1 \ominus .56$	0
CARBON COLUMN WITH THERMAL REGEN.				
9219	21000	1000000	$137513 * (E9 \ominus (.96E - 8 * G2))$	$5.3E3 * E9 \ominus (2.2E - 6 * G2)$
SCRUBBER				
9220	100	.1	$2 * (8547 + 489 * G1 - 1.02 * G1 \ominus 2)$	$.35 * G2$
COOLER-CHILLER				
9221	1	1	5000	2000
NEUTRALIZATION TANK				
9222	25000	1000000	$(88.4 * G1 \ominus .44) + 2E3$	$(4500 * D9 * .50) + 2E3$
HOLDING TANK				
9223	25000	1000000	$88.4 * G1 \ominus .44$	0
SURF. STR/MIX/BODY FEED TNK				
9224	500	0	$88.4 * G1 \ominus .44$	0
CHEMICAL FEEDER				
9225	1	1	3E3,	1E3"
UF-RECIRC. PUMP				
9226	75.6	4320000	$636 * G1 \ominus .51$	$3.76 * (G1 \ominus .62) * 24 * D9 * .03$
UF MEMBRANE MODULE				
9227	.1	.1	$7080991 * G1 \ominus .67$	$796011 * G1 \ominus .56$
SUMP-STL OR MI				
9228	200000	1000000	$88.4 * G1 \ominus .44$	0



CAT NUM	CAPACITY IN GAL OR NUM OF UNITS	GALLONS PER DAY SEEN BY UNIT	UNIT CAPITAL COST FUNCTION	O & M FUNCTION
CLARIFIER-CIRCULAR				
9229	6000	1000000	$1083E2*(G2*1E-6) \circ .445$	$6550*(G2*E1-6) \circ .474$
THICKNER-GRAVITY				
9230	2000	1000000	$200E2*(G2*1E-6) \circ .52$	$3E4*(G2*1E-6) \circ .44$
CONVEYOR SCREW				
9231	1	25	$2*(633+66*G2)$	2E3
AST-FURNACE (250 LB/DAY)				
9232	1	1000000	1.5E6	238E3
POLYMER ADDITION				
9233	500	1000000	$68E2*E9 \circ (G2*1E-6)$	$7E3*E9 \circ (G2*.95E-6)$
VACUUM FILTER POWDERED CARB.				
9234	1	200	$128E2*(G2 \circ .584)$	$(50*G2 \circ .73)+(60*G2 \circ .70)+(66*G2 \circ .88)$
SURFACT REACT TANK				
9235	25000	1000000	$(88.4*G1 \circ .44)+2E3$	$(750*G9*1.00)+2E3$
POWD. CARB. MIX TANK				
9236	1000	1000000	$88.4*G1 \circ .44$	3E3
POWD. CARB. CLARIFIER				
9237	36000	1000000	$247E3*(G2*1E-6) \circ .31$	$(26E4*(G2*1E-6) \circ .58)-(183*G9*.60)$
VACUUM FILTER-SURFACTANTS				
9238	1	468	$128E2*(G2 \circ .584)$	$150*G2 \circ .88+250*G9*.15$
MIXED MEDIA PRESS. FILT.				
9239	5000	340000	$77575*E9 \circ (1.12*G2*1E-6)$	$269*E9 \circ (.82*G2*1E-6)+77*E9 \circ (.91*G2*1E-6)$
CARBON DE-FINE TANK				
9240	25000	25000	$137513*(E9 \circ (96E-8*G2))$	2E3
OZONE PRECONTACTOR				
9241	10000	1000000	$88.4*G1 \circ .44$	0
OZONE DESTROYER				
9242	1	1	1	0



CAT NUM	CAPACITY IN GAL OR NUM OF UNITS	GALLONS PER DAY SEEN BY UNIT	UNIT CAPITAL COST FUNCTION	C & M FUNCTION
------------	--	---------------------------------------	-------------------------------	-------------------

DRY FEEDER

9244	1000000	1000000	$7.5E4-88.4*G1^{\circ}.44$	1.23E5
------	---------	---------	----------------------------	--------

SOLVENT EXTRACTION

9245	60000	8.4	$1.2E6*G2^{\circ}.7$	$86E4*G2^{\circ}.59$
------	-------	-----	----------------------	----------------------

FRACTIONAL DISTILLATION

9246	12.9	1000000	$403140*G1^{\circ}.703$	$78142*G1^{\circ}.658$
------	------	---------	-------------------------	------------------------

DUMMY

9250	1	1	1	1
------	---	---	---	---

NOTES: D9 = number of operating days

E9 = function e

$1E_n = 10^n$

© = power function, i.e., raised to the number that follows



DISTRIBUTION LIST

Addressee	Number of Copies
Defense Technical Information Center Cameron Station Alexandria, VA 22314	12
Defense Logistics Studies Information Exchange U.S. Army Logistics Management Center Fort Lee, VA 23801	2
Commander U.S. Army Toxic and Hazardous Materials Agency ATTN: DRXTH-ES Aberdeen Proving Ground, MD 21010	2
Commander U.S. Army Toxic and Hazardous Materials Agency ATTN: DRXTH-TE-D Aberdeen Proving Ground, MD 21010	6
Commander U.S. Army Armament Research and Development Command ATTN: DRDAR-LCE-C Dover, NJ 07801	1
Commander Tooele Army Depot ATTN: SDSTE-AEO Tooele, UT 84074	1
Commander U.S. Army Environmental Hygiene Agency ATTN: HSE-EW Aberdeen Proving Ground, MD 21010	1
Commander U.S. Army Mobility Equipment Research and Development Command ATTN: DRDME-PEA Fort Belvoir, VA 22060	1



Addressee	Number of Copies
Commander U.S. Army Mobility Equipment Research and Development Command ATTN: DRDME-GS Fort Belvoir, VA 22060	2
Commander U.S. Army Material Development and Readiness Command ATTN: DRCIS-A 5001 Eisenhower Avenue Alexandria, VA 22333	1
Commander DARCOM Installations and Services Activity ATTN: DRCIS-Ri-C Rock Island, IL 61299	1
Commander U.S. Army Munitions Production Base Modernization Agency ATTN: SARPM-PBM-EC (Mr. Wong) Dover, NJ 07801	1
Commander U.S. Army Armament Material Readiness Command ATTN: DRSAR-ISE Rock Island, IL 61299	1
Commander U.S. Army Armament Material Readiness Command ATTN: DRSAR-IRC Rock Island, IL 61299	1
Commander U.S. Army Depot System Command ATTN: DRSDS-EF Chambersburg, PA 17201	1
Commander U.S. Army Armament Research and Development Command ATTN: DRDAR-LCM-SA Dover, NJ 07801	1

