


AD-A115 327 SCHOOL OF AEROSPACE MEDICINE BROOKS AFB TX F/G 6/11
AUTOMATED CALCULATION OF PROTECTION FACTORS FOR THE DI-2-ETHYLH--ETC(U)
DEC 81 E S KOLESAR
UNCLASSIFIED SAM-TR-81-35

NL

1 of 2

AD-A
15 327





MICROCOPY RESOLUTION TEST CHART
NATIONAL BUREAU OF STANDARDS-1963-A

AD A 115827

Report SAM-TR-81-35

**AUTOMATED CALCULATION OF PROTECTION FACTORS
FOR THE DI-2-ETHYLHEXYL PHTHALATE
RESPIRATOR QUANTITATIVE FIT TEST INSTRUMENT**


Edward S. Kolesar, Jr., Captain, USAF

December 1981

Final Report for Period 1 March 1981 - 30 June 1981

Approved for public release; distribution unlimited.

**USAF SCHOOL OF AEROSPACE MEDICINE
Aerospace Medical Division (AFSC)
Brooks Air Force Base, Texas 78235**



DTIC FILE COPY

NOTICES

This final report was submitted by personnel of the Crew Environments Branch, Crew Technology Division, USAF School of Aerospace Medicine, Aerospace Medical Division, AFSC, Brooks Air Force Base, Texas, under job order 2729-00-20.

When U.S. Government drawings, specifications, or other data are used for any purpose other than a definitely related Government procurement operation, the Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise, as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

This report has been reviewed by the Office of Public Affairs (PA) and is releasable to the National Technical Information Service (NTIS). At NTIS, it will be available to the general public, including foreign nations.

This technical report has been reviewed and is approved for publication.

Edward S. Kolesar, Jr.

EDWARD S. KOLESAR, JR., Captain, USAF
Project Scientist

Richard L. Miller

RICHARD L. MILLER, Ph.D.
Supervisor

Roy L. DeHart


ROY L. DEHART
Colonel, USAF, MC
Commander

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER SAM-TR-81-35	2. GOVT ACCESSION NO. AD A115327	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) AUTOMATED CALCULATION OF PROTECTION FACTORS FOR THE DI-2-ETHYLHEXYL PHTHALATE RESPIRATOR QUANTITATIVE FIT TEST INSTRUMENT		5. TYPE OF REPORT & PERIOD COVERED Final Report 1 Mar 1981 - 30 June 1981
7. AUTHOR(s) Edward S. Kolesar, Jr., Captain, USAF		6. PERFORMING ORG. REPORT NUMBER
9. PERFORMING ORGANIZATION NAME AND ADDRESS USAF School of Aerospace Medicine (VNL) Aerospace Medical Division (AFSC) Brooks Air Force Base, Texas 78235		8. CONTRACT OR GRANT NUMBER(s)
11. CONTROLLING OFFICE NAME AND ADDRESS USAF School of Aerospace Medicine (VNL) Aerospace Medical Division (AFSC) Brooks Air Force Base, Texas 78235		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 62202F 2729-00-20
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		12. REPORT DATE December 1981
		13. NUMBER OF PAGES 130
		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Chemical warfare defense RQFT Respirator quantitative fit test DEHP Respirator test and evaluation Di-2-ethylhexyl phthalate RQFT Integrator RQFT man-hour savings PF Scattered-light photometer Protection factor Voltage-to-frequency conversion		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) An automated procedure for calculating a respirator protection factor is presented in this report. This procedure not only reduces the di-2-ethylhexyl phthalate leak test data, but also calculates a protection factor by using a voltage-to-frequency converter circuit to do time-averaged integration. A computer program has been developed to calculate individual exercise, averaged, and time-weighted averaged protection factors.		

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)



SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

PREFACE

The author is grateful to those people at the USAF School of Aerospace Medicine, Brooks AFB, Tex., who contributed suggestions and criticisms during the development of this report. Special thanks are due to Dr. Richard L. Miller, Mr. Clarence F. Theis, and Staff Sergeant Colette M. de la Barre of the Crew Environments Branch.

The author also expresses particular appreciation to Mr. Daniel Sears, Engineering and Maintenance Services Branch, for fabricating the electronic integrator and buffer power amplifier.



Accession For	
NTIS CR&I	☒
DTIC TAB	☐
Unannounced	☐
Justification	
By	
Distribution/	
Availability Codes	
Alphabetical and/or	
Special	
A	

CONTENTS

	<u>Page</u>
INTRODUCTION.....	5
DEHP RESPIRATOR QUANTITATIVE FIT TEST INSTRUMENT.....	6
Instrument Description.....	6
Generation of the DEHP Challenge Aerosol Test Booth Atmosphere.....	6
Measurement of DEHP Respirator Leakage.....	8
Scattered-Light Photometer Detector.....	8
Calibration Procedure.....	9
CONVENTIONAL PROTECTION FACTOR CALCULATIONS.....	9
Protection Factor.....	9
Manual Method of Calculating a Protection Factor.....	14
Manual Strip-Chart Recorder Data Reduction and Analysis.....	16
USING A VOLTAGE-TO-FREQUENCY CONVERTER CIRCUIT TO DO TIME-AVERAGED INTEGRATION.....	19
Description of the Voltage-to-Frequency (V/F) Integrator.....	20
Adaptation of the V/F Integrator to the DEHP RQFT Instrument.....	20
Data Collection with the DEHP RQFT Instrument and V/F Integrator.....	20
COMPUTER PROGRAM TO CALCULATE PROTECTION FACTORS.....	26
Discussion of the Computer Algorithm to Calculate Protection Factors.....	27
Discussion of the Computer Program for Processing the DEHP RQFT Integrator Data.....	29
CONCLUSION.....	30
REFERENCES.....	33
APPENDIX A: Technical Note--USAFSAM Di-2-ethylhexyl Phthalate Respirator Quantitative Fit Test Instrument (Dynatech Frontier Corporation Model FE259H) Calibration Procedure.....	37
Introduction.....	38
Analytic Performance Equations.....	38
Example Calculation.....	39
Conclusion.....	40
References.....	41
Attachment A-1: Figure A-1 and Table A-1.....	43
Attachment A-2: Fortran Computer Program Listing Used To Generate Table A-1.....	83
APPENDIX B: DEHPRQFT.FOR Fortran Listing.....	87

Contents (Cont'd.)	Page
APPENDIX C: DATA X.XXX File Contents for Data in Table 3.....	109
APPENDIX D: CALCX.XXX File Contents for Data in Table 4.....	113
APPENDIX E: User's Guide for the DEHPRQFT.FOR Computer Program.....	117
ABBREVIATIONS, ACRONYMS, AND SYMBOLS.....	128

FIGURES

Figure No.

1. USAFSAM di-2-ethylhexyl phthalate respirator quantitative fit test instrument.....	7
2. Aluminum sampling tube for the MBU-13/P respirator.....	10
3. Aircrew MBU-13/P CW respirator with aluminum sampling tube.....	11
4. A light-scattering photometer (functional diagram).....	12
5. Strip-chart recording of a di-2-ethylhexyl phthalate respirator quantitative fit test.....	15
6. USAFSAM voltage-to-frequency integrator.....	21
7. Di-2-ethylhexyl phthalate buffer power amplifier circuit.....	22
8. Adaptation of the V/F integrator to the di-2-ethylhexyl phthalate instrument.....	23
9. Di-2-ethylhexyl phthalate RQFT data collection form No. 1.....	24
10. Di-2-ethylhexyl phthalate RQFT data collection form No. 2.....	25
A-1. Organization of data for Table A-1.....	44

TABLES

Table No.

1. Quantitative fit test strip-chart record.....	17
2. Quantitative fit test protection factors record.....	19
3. Integrator count data for the strip-chart recording in Figure 5.....	31
4. Protection factor computer program calculations for the data in Table 3.....	32
A-1. Aerosol generator air pressure versus aerosol dilution air differential pressure--magnehelic gauge setting--for various ambient temperatures and barometric pressures.....	45

AUTOMATED CALCULATION OF PROTECTION FACTORS FOR THE
DI-2-ETHYLHEXYL PHTHALATE RESPIRATOR QUANTITATIVE FIT
TEST INSTRUMENT

INTRODUCTION

The purpose of this report is to present an automated procedure for calculating a respirator's protection factor (PF), afforded to the respiratory tract and eyes, against chemical warfare (CW) agents in particulate, aerosol, or vapor form. The Los Alamos Scientific Laboratory (LASL) is credited with developing the basic di-2-ethylhexyl phthalate (DEHP) respirator quantitative fit test (RQFT) method [1, 2]. Two United States manufacturers market a commercial version of the LASL DEHP RQFT instrument [3, 4]:

1. Air Techniques Incorporated
1717 Whitehead Road
Baltimore, Maryland 21207

Telephone No.: (301) 944-6037

(Mr. Samuel B. Steinberg, President)

2. Dynatech Frontier Corporation
P.O. Box 30041
Albuquerque, New Mexico 87110

Telephone No.: (505) 226-7932

(Dr. Charles L. Wright, Jr., President)

The United States Air Force School of Aerospace Medicine (USAFSAM) has several years of laboratory experience with RQFT research and development, and currently operates a sodium chloride (NaCl) and DEHP instrument [5, 6].

Our experience with RQFT instrumentation has shown one area to be of particular concern; namely, the method of reducing the collected data (respirator penetration concentration for a particular exercise protocol) and calculating a protection factor. Several interested organizations have developed and reported the following data reduction schemes for respirator quantitative fit testing [1, 2, 5-36]:

- a. selection of the overall maximum output peak
- b. arithmetic average of the maximum output peaks
- c. arithmetic average of the maximum output peaks and minimum valleys (midpoint)

EDITOR'S NOTE: Available, on pp. 128 - 130, is a selective list (plus definitions) of the "Abbreviations, Acronyms, and Symbols" used throughout this volume.

- d. visual estimation of the midpoint between the maximum output peaks and minimum valleys
- e. time-averaged or integrated value.

This report develops an automated procedure to reduce the DEHP respirator leak test data and calculate a composite protection factor. A similar procedure has been adapted to the USAFSAM NaCl RQFT instrument [37]. An overview of the DEHP RQFT instrument is followed by: a discussion of conventional PF calculations; the use of a voltage-to-frequency (V/F) converter circuit to do time-averaged integration; and, finally, a computer program to calculate PFs.

DEHP RESPIRATOR QUANTITATIVE FIT TEST INSTRUMENT

The Dynatech Frontier Corporation's DEHP RQFT Instrument (Model FE259H) and Test Booth (Model FE222) have been adapted and modified by USAFSAM to measure the PF in the respiratory and eye compartments of aircrew and groundcrew chemical defense respirators [4]. This instrument generates a polydispersed liquid aerosol of di-2-ethylhexyl phthalate as the challenge atmosphere. The concentration of the challenge atmosphere in a respirator is quantified using a five-decade, linear-forward-light-scattering photometer; and the result is displayed on a strip-chart recorder. This technique allows protection factors as high as 10^6 to be calculated.

Instrument Description

Illustrated in Figure 1 are the primary components used in the USAFSAM modified version of the Dynatech Frontier Corporation's (Model FE259H) DEHP RQFT instrument [4]. The two fundamental systems constituting the DEHP RQFT instrument are: the aerosol generator, and light-scattering photometer.

Generation of the DEHP Challenge Aerosol Test Booth Atmosphere

The aerosol generating system consists of a source of laboratory compressed air, pressure regulator and gauge, aerosol impactor, generator, reservoir, mixing chamber, and dilution air blower (Fig. 1). The DEHP challenge aerosol test booth atmosphere is generated by atomizing the liquid DEHP from the reservoir of the aerosol generator.

The aerosol generator is supplied with a source of filtered and dried compressed laboratory air that is regulated to be in the range from 2-6 psig. The aerosol generator is a Naval Research Laboratory (NRL) Model III design [38]. When the laboratory compressed air enters the aerosol generator, a coarse DEHP aerosol is produced by high-velocity air jets that shear off droplets of the liquid DEHP. This coarse aerosol enters the impactor. The round jet impactor design is used to produce a DEHP aerosol with a mass median aerodynamic diameter (MMAD) particle size that ranges from 0.5 to 0.6 μm [4, 39]. The concentration of the impactor's refined DEHP aerosol is controlled in the mixing chamber with a regulated air supply provided by the dilution air blower. The result of the generation, impaction, mixing, and dilution processes is a DEHP test booth aerosol challenge atmosphere whose particle size and concentration are, respectively, 0.5 - 0.6 μm and $25 \text{ mg/m}^3 \pm 5 \text{ mg/m}^3$.




Figure 1. USAFSAM di-2-ethylhexyl phthalate respirator quantitative fit test instrument.

Measurement of DEHP Respirator Leakage

When evaluating the performance of a full-face chemical defense respirator, a primary concern is the penetration of the DEHP challenge atmosphere into the visual compartment. To make this measurement, an aluminum tube, approximately 1 in. (2.54 cm) long and 0.25 in. (0.635 cm) i.d., is fitted and sealed to the respirator's visor so that the distance from the cornea to the open end of the aluminum sampling tube (interior to the respirator's visor) is not greater than 0.8 in. (2 cm) [40]. Shown in Figure 2 is the aluminum sampling tube developed and used at USAFSAM; and, in Figure 3, an MBU-13/P aircrew CW respirator fitted with the sampling tube.

The concentration of the DEHP challenge atmosphere that has leaked into the visual compartment of the respirator is determined by continuously sampling gas from this site, and analyzing this gas with the linear-forward-light-scattering photometer. Sampling is accomplished by attaching one end of a short length of Tygon tubing to the open end of the aluminum sampling tube (exterior to the respirator's visor), and then passing the opposite end of the plastic tubing through a sealed port in the test booth (Fig. 1). A small capacity sampling pump is connected to the open end of the Tygon tubing to draw a gas sample from the respirator's visual compartment (constant 3-liter/min flow). The 3-liter/min sampling rate was selected to minimize negative pressure within the respirator's visual compartment; i.e., a greater sampling rate would tend to exaggerate the penetration measurement [4, 20].

Scattered-Light Photometer Detector

A five-decade, linear-forward-light-scattering photometer is used to analyze the DEHP aerosol sampled from the interior of the respirator. The photometer measures aerosol concentration by detecting the intensity of light scattered by the aerosol particles that are drawn through the light-scattering chamber of the photometer. The scattered-light intensity is converted to an electrical current which is electronically processed and displayed on a calibrated meter, as well as on a linear strip-chart recorder [4, 20]. A functional diagram of a light-scattering photometer is shown in Figure 4 [4, 20, 41, 42].

To develop a complete understanding of the proposed method to automate the calculation of protection factors, a review of the scattered-light photometer's signal generating process is presented next.

The incident light intensity (I_i), generated by a high-intensity filament lamp, is focused into the light-scattering chamber (Fig. 4). When a sample of air containing DEHP aerosol is introduced into the light-scattering chamber, a fixed amount of the incident light intensity (I_i) is absorbed (I_a) in direct proportion to the concentration of the DEHP aerosol. Thus, the scattered-light intensity (I_s) can be expressed as:

$$I_s = I_i - I_a \quad (1)$$

The scattered-light intensity (I_s) is focused on a photomultiplier tube (PMT) which converts the light into a corresponding electrical current. The relative magnitude of the electrical current produced by the PMT is a function of the high-voltage power supply (Fig. 4). Thus, the sensitivity of the PMT, for a given DEHP aerosol sample concentration, can be established by varying the magnitude of the high-voltage power supply. A current-to-voltage operational amplifier circuit is used to produce a voltage signal compatible with the strip-chart recorder. The current-to-voltage conversion process is determined by the value of the feedback resistance (R) (Fig. 4). Thus, selection of R determines the range and magnitude of the voltage signal that can be displayed on the strip-chart recorder. One of the important elements of the light-scattering photometer is the stray light circuit. A component of the scattered light (I_s) is due to undesirable reflections, imperfect optics, contamination of the system, and the PMT's dark current response. Thus, the light incident on the PMT is composed of a component due to scattering by the sampled DEHP aerosol, and a stray or undesirable component. To assure that the strip-chart recorder only displays the voltage signal that corresponds to the DEHP aerosol concentration, it is necessary to compensate for the stray light component. The compensation process is implemented by purging the light-scattering chamber of DEHP aerosol with clean ambient air via a high-efficiency filter in the sampling system (Fig. 1). The stray light component is eliminated, by an operator adjustment of the instrument's stray light circuit control, to produce a zero reading on the instrument's front panel meter. The effect of the stray light compensating adjustment is to produce an opposite current signal (i_{s1}) which, when added to the PMT's current signal (i_{PMT}), results in a net current signal of zero magnitude. Finally, the current-to-voltage operational amplifier yields a voltage signal of zero magnitude for a zero magnitude input current signal.

Calibration Procedure

The calibration procedure used for the DEHP RQFT instrument is developed and discussed in a technical note included as Appendix A.

CONVENTIONAL PROTECTION FACTOR CALCULATIONS

A general discussion of a protection factor (PF) is presented here, along with a description of the manual calculation method. With this information, the reader can evaluate the respective advantages and disadvantages of the manual and automated methods of calculating PF's.

Protection Factor

A respiratory protection factor is defined as the ratio of the ambient challenge atmosphere concentration external to the respiratory protective device to that of the sampled leakage concentration drawn from the interior of the device [5, 7, 9-14, 20, 25, 27, 30, 34-37].




Figure 1. Sampling tube for the M41-13/p respirator.



Figure 3. Aircrow MBU-13/P respirator with aluminum sampling tube.




Figure 4. A light-scattering photometer (functional diagram).

Formally, this relationship can be expressed as:

$$PF = \frac{C_a}{C_s} \quad (2)$$

where

PF = protection factor

C_a = ambient challenge atmosphere concentration

C_s = sampled leakage concentration.

Note that a PF is a dimensionless quantity. In the ratio, the units of concentration in the numerator and denominator cancel (assuming that C_a and C_s were measured and appropriately converted to a consistent set of concentration units; e.g., part per million, micrograms per liter, percent, etc.).

Also important in respirator quantitative fit testing is the calculation of an average protection factor ($\overline{PF}$). This calculation becomes important when the subject being evaluated performs a series of breathing and head movement exercises, each of which is designed to stress the face-to-facepiece seal. In mathematical terms:

$$\overline{PF} = \frac{\sum_{i=1}^n PF_i}{n} \quad (3)$$

where

$\overline{PF}$ = average protection factor for n exercises

i = the i^{th} exercise, $i = 1, 2, 3, \dots, n$

PF = protection factor associated with a particular exercise.

Similarly, an average weighted protection factor can be calculated when greater or lesser degrees of relative importance are assigned to individual exercise PF's. The most common example is that in which each exercise in an exercise protocol is performed for a different length of time; in this case, time would become the weighting factor. For completeness, a mathematical expression for an average weighted PF is:

$$\overline{PF}_w = \frac{\sum_{i=1}^n w_i PF_i}{\sum_{i=1}^n w_i} \quad (4)$$

where

$\overline{PF}_w$ = weighted average protection factor for n exercises

i = the i^{th} exercise, $i = 1, 2, 3, \dots, n$

w_i = weighting factor for the i^{th} exercise

PF = protection factor associated with a particular exercise.


Manual Method of Calculating a Protection Factor

The DEHP RQFT instrument, as well as most of the similar systems, does not display, record, or calculate PF's. The instrument does, however, record and display the relative penetration (leakage) of the challenge atmosphere into a respirator's facepiece. The calculation of PF's for the DEHP RQFT instrument can be explained through an example. Shown in Figure 5 is a typical quantitative fit test strip-chart recording that includes the preliminary calibration and penetration information for a set of six exercises:

- a. normal breathing (NB)
- b. deep breathing (DB)
- c. talking (T)
- d. turning head side-to-side with deep breathing (TH)
- e. moving head up-and-down with deep breathing (UD)
- f. facial grimacing (FG).

The analysis of Figure 5 begins at the bottom of the strip-chart recording. The first section of information uniquely identifies the particular subject and type of respirator.

The next section contains the instrument calibration data (a steady-state response for upstream sampling of the ambient DEHP challenge aerosol concentration in the test booth with the sampling range switch in the 100.0 percent



position; a steady-state baseline response for sampling in the clear mode with the sampling range switch in the 0.01 percent position). The subject wearing a test respirator enters the test booth and breathes normally for about 5 minutes to establish a baseline in the challenge atmosphere. The subject then performs the six exercises in sequence, each for a predetermined time period. After the exercises are completed, and before the subject exits the test booth, a final check is made on the baseline (clear sampling mode) and ambient challenge (upstream sampling mode) concentration.

The cyclic nature of the recorder's trace during the exercises is a direct function of the subject's breathing cycle. Figure 5, for instance, reveals that the slight negative pressure created in the facepiece during inhalation increases the penetration of the challenge atmosphere. Exhalation, on the other hand, creates a slightly positive pressure, and acts to reduce the penetration of the challenge atmosphere. Because samples are drawn from the visual cavity of chemical defense respirators, absorption of the DEHP aerosol by the lungs is negligible. Therefore, respirator performance is based on the average of the penetration peaks and valleys for each of the exercises. Finally, the overall respirator performance is based on the arithmetic or time-weighted average of the exercise PF's.

Manual Strip-Chart Recorder Data Reduction and Analysis

Manual strip-chart recorder data reduction and analysis can be accomplished with a straight edge, pencil, and calculator. The analysis begins by drawing a series of dashed lines through the average of the strip-chart recording peaks and valleys associated with the individual calibration and exercise leak test measurements. The average of the peaks and valleys (location of their midpoint) is generally deduced visually. Table 1 is a summary of the "visual averages" identified for the strip-chart recording shown in Figure 5.

From the discussion in the previous section, an average PF for a particular exercise can be expressed as:

$$PF = \frac{\text{Average Corrected Test Booth Ambient Challenge Concentration (as a Percent)}}{\text{Average Corrected Respirator Sampled Leakage (as a Percent)}} \quad (5)$$

The average corrected test booth ambient challenge concentration (as a percent) is given by:

$$C_{cor} = \left[\frac{(C_i + C_f)(K_{cc})}{2} - \frac{(B_i + B_f)(K_{bc})}{2} \right] \quad (6)$$

where

C_{cor} = average corrected test booth ambient challenge concentration (as a percent)

C_i = initial ambient test booth challenge concentration

C_f = final ambient test booth challenge concentration

K_{cc} = instrument's sampling range switch position (typically 100.0 percent)

B_i = initial baseline concentration

B_f = final baseline concentration

K_{bc} = instrument's sampling range switch position (typically 10.0-0.01 percent).

TABLE 1. QUANTITATIVE FIT TEST STRIP-CHART RECORD

Parameter	Average strip-chart average value for a 0-100 scale	Sampling range switch position as a percent
Calibration ambient test booth challenge concentration (C_c)	95.0	100.0
Calibration baseline concentration (B_c)	5.2	0.01
Initial ambient test booth challenge concentration (C_i)	94.25	100.0
Initial baseline concentration (B_i)	5.2	0.01
Normal breathing (RE_{NB})	5.5	0.01
Deep breathing (RE_{DB})	1.0	0.01
Turning head side-to-side with deep breathing (RE_{TH})	2.4	0.01
Moving head up-and-down with deep breathing (RE_{UD})	2.2	0.01
Talking (RE_T)	1.9	0.01
Facial grimacing (RE_{FG})	1.5	0.01
Final baseline concentration (B_f)	5.25	0.01
Final ambient test booth challenge concentration (C_f)	95.5	100.0

The average corrected respirator sampled leakage (as a percent), for a particular exercise, is given by:

$$RE_{(cor, x)} = \left[(RE_x)(KE) - \frac{(B_i + B_f)(K_{bc})}{2} \right] \quad (7)$$

where

$RE_{(cor, x)}$ = average corrected respirator sampled leakage (as a percent) for a particular exercise x , for $x = \{NB, DB, TH, UD, T, \text{ or } FG\}$

RE_x = average respirator sampled leakage determined from a strip-chart recording for a particular exercise x , for $x = \{NB, DB, TH, UD, T, \text{ or } FG\}$

KE = instrument's sampling range switch position used during the exercise measurement (typically 10.0-0.01 percent)

B_i = initial baseline concentration

B_f = final baseline concentration

K_{bc} = instrument's sampling range switch position (typically 10.0-0.01 percent).

Thus, Equation (5) can be rewritten as:

$$PF_x = \left[\frac{C_{cor}}{RE_{(cor, x)}} \right] \quad (8)$$

where

PF_x = protection factor for a particular exercise x , for $x = \{NB, DB, TH, UD, T, \text{ or } FG\}$

C_{cor} = average corrected test booth ambient challenge concentration (as a percent)

$RE_{(cor, x)}$ = average corrected respirator sampled leakage (as a percent) for a particular exercise x , for $x = \{NB, DB, TH, UD, T, \text{ or } FG\}$.

The results for the data in Table 1 (derived from the strip-chart recording in Fig. 5) are shown in Table 2.

TABLE 2. QUANTITATIVE FIT TEST PROTECTION FACTORS RECORD

Exercise	PF
Normal breathing (NB)	1.0×10^{6a}
Deep breathing (DB)	2.0×10^5
Turning head side-to-side with deep breathing (TH)	5.1×10^4
Moving head up-and-down with deep breathing (UD)	5.7×10^4
Talking (T)	6.9×10^4
Facial grimacing (FG)	9.5×10^4
Overall average PF = 2.5×10^5	

^aNOTE: Protection factors (PF) calculated to be greater than 1.0×10^6 are always reported as 1.0×10^6 , because the instruments' sensitivity is limited to measuring PF's of 1.0×10^6 .

Although the strip-chart recorder data can be interpreted without significant mathematical rigor, this exercise can be exasperating when more than a dozen subjects are involved. Having analyzed a large volume of tests, I have developed an alternative method that utilizes the USAFSAM VAX 11/780 computer to perform these calculations. This automated scheme yields a data reduction turn-around time of approximately 4 min per subject vs. 20 min per subject by manual calculation.

USING A VOLTAGE-TO-FREQUENCY CONVERTER CIRCUIT TO DO TIME-AVERAGED INTEGRATION

The basic function of a voltage-to-frequency (V/F) converter is to transform a variable direct-current voltage (typically 0 - 10 volts) into a pulse train whose repetition rate (frequency) is a direct linear function of the input voltage. An excellent technique for precisely integrating an analog

voltage signal is simply to add a counter stage to the output of a V/F converter and accumulate the pulse count. By accumulating the V/F converter output pulses, the "area under the input voltage curve," or integral, is calculated.

The attractive features of the V/F integration technique stimulated the development and adaptation of an integrator design that is currently used with the USAFSAM RQFT sodium chloride instrument [37].

Description of the Voltage-to-Frequency (V/F) Integrator

A comprehensive theoretical description and design of a V/F integrator (Fig. 6) has been reported by this author in a recent publication [37]. The same design has been adapted, without modification, for use with the DEHP RQFT instrument. However, because the V/F integrator requires an input analog direct-current voltage signal spanning approximately 0-10 volts, and since the current-to-voltage operational amplifier circuit in the DEHP RQFT instrument generates an analog output voltage signal spanning 0-100 mV, a buffer power amplifier (Fig. 7) was designed to make the RQFT instrument's output signal compatible with the integrator. The optimum gain of the buffer power amplifier was empirically found to range between 50 and 70. This gain span amplified the DEHP RQFT instrument's photometer signal to range approximately 0 to 6 ± 1 volts; at the same time, the amplifier's stability was maximized, and the noise was minimized.

Adaptation of the V/F Integrator to the DEHP RQFT Instrument

Adaptation of the V/F integrator to the DEHP RQFT instrument is quite simple. The integrator's utility and compatibility can be appreciated by analyzing Figure 8. The buffer power amplifier is connected to the DEHP RQFT instrument at two readily accessible terminals, and a single connection is made between the amplifier's output and V/F integrator's input.

Data Collection with the DEHP RQFT Instrument and V/F Integrator

The collection of RQFT data for subsequent PF calculations is a simple process when the integrator is used. The data sheets used for this purpose are shown in Figures 9 and 10. After the DEHP RQFT instrument has reached its operating equilibrium (45 min), and the buffer power amplifier and V/F integrator electronics have stabilized (30 min), the test booth's challenge atmosphere concentration is checked; then the conventional procedure for setting the DEHP instrument's photometer gain and stray light potentiometers is accomplished. After these adjustments are made, a subject can be tested.

After the subject enters the test booth and makes the appropriate connections to the sampling line, breathing gas supply, and intercom, the subject's name, type of respirator, date, and time are recorded on the appropriate data collection form (Figs. 9 and 10). The average initial voltage associated with the maximum test booth challenge concentration measurement is made.




Figure 6. USAFSAM voltage-to-frequency integrator.




Figure 7. Di-2-ethylhexyl phthalate buffer power amplifier circuit.




Figure 8. Adaptation of the V/F integrator to the di-2-ethylhexyl phthalate instrument.

DEHP RQFT DATA

SUBJECT NAME: _____
 TYPE OF RESPIRATOR: _____
 DATE TESTED: _____
 TIME TESTED: _____

DEHP RQFT CALIBRATION DATA:

CALIBRATION PARAMETER	SAMPLING RANGE SWITCH POSITION (AS A PERCENT)	AVERAGE VOLTAGE (IN VOLTS)
AVERAGE INITIAL VOLTAGE ASSOCIATED WITH THE MAXIMUM CHAMBER CHALLENGE CONCENTRATION		
AVERAGE INITIAL VOLTAGE ASSOCIATED WITH THE BASELINE OF THE DEHP RQFT INSTRUMENT		
AVERAGE FINAL VOLTAGE ASSOCIATED WITH THE BASELINE OF THE DEHP RQFT INSTRUMENT		
AVERAGE FINAL VOLTAGE ASSOCIATED WITH THE MAXIMUM CHAMBER CHALLENGE CONCENTRATION		

EXERCISE INTEGRATOR COUNT INFORMATION:

EXERCISE	INTEGRATOR COUNT	TIME PERIOD (IN SECONDS)	SAMPLING RANGE SWITCH POSITION (AS A PERCENT)
NORMAL BREATHING STRAIGHT AHEAD			
DEEP BREATHING STRAIGHT AHEAD			
TALKING			
SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING)			
UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)			
FACIAL GRIMACING			

Figure 9. Di-2-ethylhexyl phthalate RQFT data collection form No. 1.

DEHP RQFT DATA

SUBJECT NAME: _____
 TYPE OF RESPIRATOR: _____
 DATE TESTED: _____
 TIME TESTED: _____

DEHP RQFT CALIBRATION DATA:

CALIBRATION PARAMETER	SAMPLING RANGE SWITCH POSITION (AS A PERCENT)	AVERAGE VOLTAGE (IN VOLTS)
AVERAGE INITIAL VOLTAGE ASSOCIATED WITH THE MAXIMUM CHAMBER CHALLENGE CONCENTRATION		
AVERAGE INITIAL VOLTAGE ASSOCIATED WITH THE BASELINE OF THE DEHP RQFT INSTRUMENT		
AVERAGE FINAL VOLTAGE ASSOCIATED WITH THE BASELINE OF THE DEHP RQFT INSTRUMENT		
AVERAGE FINAL VOLTAGE ASSOCIATED WITH THE MAXIMUM CHAMBER CHALLENGE CONCENTRATION		

EXERCISE INTEGRATOR COUNT INFORMATION:

EXERCISE	INTEGRATOR COUNT	TIME PERIOD (IN SECONDS)	SAMPLING RANGE SWITCH POSITION (AS A PERCENT)
NORMAL BREATHING STRAIGHT AHEAD			
NORMAL BREATHING LEFT			
NORMAL BREATHING RIGHT			
NORMAL BREATHING DOWN			
NORMAL BREATHING UP			
DEEP BREATHING STRAIGHT AHEAD			
DEEP BREATHING LEFT			
DEEP BREATHING RIGHT			
DEEP BREATHING DOWN			
DEEP BREATHING UP			
TALKING			
FACIAL GRIMACING			
SIDE-TO-SIDE HEAD MOVEMENTS (NORMAL BREATHING)			
UP-AND-DOWN HEAD MOVEMENTS (NORMAL BREATHING)			
SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING)			
UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)			

Figure 10. Di-2-ethylhexyl phthalate RQFT data collection form No. 2.

This measurement is readily accomplished by reading the digital voltmeter on the V/F integrator's front panel (Fig. 6). This steady-state voltage and the associated sampling range switch position are recorded on the appropriate data collection form (Figs. 9 and 10). Next, the average initial voltage associated with the baseline of the DEHP RQFT instrument is made and recorded along with the corresponding sampling range switch position.

Because the output signal of the DEHP RQFT instrument is biased with a low-level noise component, the integrator must be adjusted to compensate for the noise before the exercises are initiated. The degree of compensation is accomplished by so rotating the integrator's PMT noise offset voltage adjustment potentiometer (Fig. 6) that a setting is found where the integrator count stops accumulating. This adjustment is accomplished immediately after having made the average initial voltage measurement associated with the baseline of the DEHP RQFT instrument. The exercise protocol can now be initiated.

After each exercise is accomplished, the following information is recorded: the integrator count on the 6-digit light-emitting diode (LED) display (Fig. 6); the time period on the 4-digit LED display (Fig. 6); and the RQFT instrument's sampling range switch position. The elapsed-time 4-digit LED display (Fig. 6) is used to initiate and terminate each exercise. Before proceeding to the next exercise, the integrator displays are reset to zero (Fig. 6). After the exercise measurements have been made, the average final voltage associated with the baseline of the DEHP RQFT instrument, and the sampling range switch position are recorded. The facts recorded are the average final voltage associated with the maximum test booth challenge concentration, and the sampling range switch position.

After all subjects have been tested, the user proceeds to a computer terminal and enters the information from the data collection forms. The interactive PF calculation program described in the next section is used to process the RQFT data.

COMPUTER PROGRAM TO CALCULATE PROTECTION FACTORS

The primary advantages in using the integrator and computer algorithm to process the raw RQFT data are threefold. First, the V/F integrator has the ability to resolve very small voltage fluctuations that are characteristic of the DEHP RQFT photometer's response for the exercises performed. The sensitivity of the integrator is 1000 counts/volt-sec [37]. For a 1-sec interval, the integrator can resolve 0.001 volts (1 mV). The human eye, for instance, can only resolve one minor division on the strip-chart recording paper used with the instrument; that is, the human's resolution capability, on a comparable basis, is approximately 0.1 volts. Thus, a more accurate average respirator leakage measurement can be made with the V/F integrator, because it offers two orders of magnitude resolution improvement. Second, the use of the V/F integrator eliminates human error and variability associated with reading and interpolating strip-chart recordings. Third, the V/F integration scheme permits RQFT data to be reduced in approximately one-fifth the time required for manual calculations (4 min vs. 20 min).

Discussion of the Computer Algorithm to Calculate Protection Factors

The calculation of a respirator's PF is readily accomplished using Equations (5-8). Since a one-to-one correspondence exists between the scattered light photometer's output voltage and the sampled concentration of DEHP, Equation (6) can be rewritten as:

$$C_{cor} = \left[\frac{(VC_i + VC_f)(K_{cc})}{2} - \frac{(VB_i + VB_f)(K_{bc})}{2} \right] \quad (9)$$

where

C_{cor} = average corrected test booth ambient challenge concentration (as a percent)

VC_i = average initial voltage response associated with the test booth challenge concentration (corresponds to C_i)

VC_f = average final voltage response associated with the test booth challenge concentration (corresponds to C_f)

K_{cc} = instrument's sampling range switch position (typically 100.0 percent)

VB_i = average voltage response associated with the initial baseline concentration (corresponds to B_i)

VB_f = average voltage response associated with the final baseline concentration (corresponds to B_f)

K_{bc} = instrument's sampling range switch position (typically 10.0-0.01 percent).

The integrator count--the source of data used to calculate a respirator leakage concentration--is, in reality, a time-averaged voltage response. This fact can be derived through the following analyses:

- a. Integrator sensitivity is 1000 counts/volt·sec.
- b. Each exercise is performed for a predetermined length of time; for example, 10 sec
- c. The integrator count (IC) value recorded for a particular exercise is actually the time-averaged area under the strip-chart recorder response (refer to Fig. 5).

Therefore,

$$IC \text{ (counts)} = (1000 \text{ counts/volt} \cdot \text{sec}) \cdot (\text{time in sec}) (\bar{V} \text{ volts}) \quad (10)$$

or, rearranging Equation 10 yields

$$\bar{V} \text{ volts} = \frac{(IC \text{ counts})(\text{volt} \cdot \text{sec})}{(1000 \text{ counts})(\text{time in sec})} \quad (11)$$

Thus,

$$\bar{V} \text{ volts} = \frac{IC}{(1000)(\text{time in sec})} \quad (12)$$

in which $\bar{V}$ volts is the time-averaged voltage for a particular exercise.

Thus, since a one-to-one correspondence exists between the scattered-light photometer's output voltage and the sampled concentration of DEHP, Equation (7) can be rewritten as:

$$RE_{(\text{cor}, x)} = \left[(VRE_x)(KE) - \frac{(VB_i + VB_f)(K_{bc})}{2} \right] \quad (13)$$

where

$RE_{(\text{cor}, x)}$ = average corrected respirator sampled leakage (as a percent) for a particular exercise x , for $x = \{\text{NB, DB, TH, UD, T, or FG}\}$

VRE_x = average voltage response associated with the average respirator sampled leakage determined from the integration count for a particular exercise x , for $x = \{\text{NB, DB, TH, UD, T, or FG}\}$

KE = instrument's sampling range switch position used during the exercise measurement time period (typically 10.0-0.01 percent)

VB_i = average voltage response associated with the initial baseline concentration (corresponds to B_i)

VB_f = average voltage response associated with the final baseline concentration (corresponds to B_f)

K_{bc} = instrument's sampling range switch position (typically 10.0-0.01 percent).

A computer program has been written to accept the DEHP RQFT instrument's calibration voltages, exercise integrator count data, time duration for each exercise, and the associated range switch positions. The program calculates: the corrected test booth ambient challenge concentration; the corresponding time-averaged voltage associated with each exercise; the corrected respirator sampled leakage for a particular exercise; an exercise protection factor; an arithmetic average protection factor for all exercises; and, finally, a time-weighted average protection factor for all exercises. Equations (3-5) and (8-13) are used in the computer program to accomplish the calculations.

The corresponding V/F integrator data associated with Figure 5 and Table 1 are shown in Table 3; and the computer calculated results, in Table 4. As shown by these illustrations, the results for manual and computer calculations are very similar.

Discussion of the Computer Program for Processing the DEHP RQFT Integrator Data

A single computer program, named DEHPRQFT.FOR, is used to process the exercise data collected with the V/F integrator. The purpose of DEHPRQFT.FOR is to use the RQFT information collected on the RQFT data form (Figs. 9 or 10) and calculate a set of PF's. The results of this program are stored on two disk files:

1. DATAX.XXX contains the initial calibration data, the test identification data, the time period for each exercise, a listing of the exercises performed, the associated integrator count values, and the sampling range switch positions.
2. CALCX.XXX contains a composite listing of the identification data, the exercises performed and their corresponding PF's, and the average PF's.

The DEHPRQFT.FOR program is documented with comments that define the variables and explain the mathematical operations performed. Therefore, a line-by-line analysis of the Fortran code is not included in this report. For the interested reader, however, the following information is available:

Appendix A: Technical Note - USAFSAM Di-2-ethylhexyl Phthalate (DEHP) Respirator Quantitative Fit Test (RQFT) Instrument (Dynatech Frontier Corporation Model FE259H) Calibration Procedure

Appendix B: DEHPRQFT.FOR Fortran listing

Appendix C: DATA.XXX file contents for data in Table 3

Appendix D: CALCX.XXX file contents for data in Table 4

Appendix E: User's guide for the DEHPRQFT.FOR computer program.

CONCLUSION

The USAFSAM DEHP RQFT instrument satisfies the need for a simple and rugged, yet sensitive and accurate tool for fitting personnel with chemical warfare defense respirators. Because of this work, the man-hour savings per respirator fit trial have been reduced by more than 20 percent, and human mathematical errors have been eliminated.

TABLE 3. INTEGRATOR COUNT DATA FOR THE STRIP-CHART RECORDING
IN FIGURE 5

DEHP RQFT DATA

SUBJECT NAME: CAPTAIN EDWARD S. KOLESAR, JR.
TYPE OF RESPIRATOR: USA XM-29; MEDIUM; NO GLASSES
DATE TESTED: 18 JUNE 1981
TIME TESTED: 1127 HRS

DEHP RQFT CALIBRATION DATA:

CALIBRATION PARAMETER	SAMPLING RANGE SWITCH POSITION (AS A PERCENT)	AVERAGE VOLTAGE (IN VOLTS)
AVERAGE INITIAL VOLTAGE ASSOCIATED WITH THE MAXIMUM CHAMBER CHALLENGE CONCENTRATION	100.00	5.820
AVERAGE INITIAL VOLTAGE ASSOCIATED WITH THE BASELINE OF THE DEHP RQFT INSTRUMENT	0.01	0.090
AVERAGE FINAL VOLTAGE ASSOCIATED WITH THE BASELINE OF THE DEHP RQFT INSTRUMENT	0.01	0.050
AVERAGE FINAL VOLTAGE ASSOCIATED WITH THE MAXIMUM CHAMBER CHALLENGE CONCENTRATION	100.00	5.800

EXERCISE INTEGRATOR COUNT INFORMATION:

EXERCISE	INTEGRATOR COUNT	TIME PERIOD (IN SECONDS)	SAMPLING RANGE SWITCH POSITION (AS A PERCENT)
NORMAL BREATHING STRAIGHT AHEAD	131	10	0.01
DEEP BREATHING STRAIGHT AHEAD	3757	10	0.01
TALKING	11871	10	0.01
SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING)	11074	10	0.01
UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)	8997	10	0.01
FACIAL GRIMACING	6752	10	0.01

TABLE 4. PROTECTION FACTOR COMPUTER PROGRAM CALCULATIONS FOR THE
DATA IN TABLE 3

THE DESCRIPTIVE AND PROTECTION FACTOR CALCULATIONS

SUBJECT NAME: CAPTAIN EDWARD S. KOLESAR, JR.
TYPE OF RESPIRATOR: USA XM-29; MEDIUM; NO GLASSES
DATE TESTED: 18 JUNE 1981
TIME TESTED: 1127 HRS

<u>EXERCISE</u>	<u>PROTECTION FACTOR</u>
NORMAL BREATHING STRAIGHT AHEAD	1.0E+06
DEEP BREATHING STRAIGHT AHEAD	1.9E+05
TALKING	5.2E+04
SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING)	5.6E+04
UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)	7.0E+04
FACIAL GRIMACING	9.6E+04
OVERALL ARITHMETIC AVERAGE PROTECTION FACTOR FOR ALL CATEGORIES OF EXERCISES ACTUALLY PERFORMED =	2.4E+05
OVERALL TIME WEIGHTED AVERAGE PROTECTION FACTOR FOR ALL CATEGORIES OF EXERCISES ACTUALLY PERFORMED =	2.4E+05

NOTE: Any protection factor that is listed as 1.0E+06 has been assigned this value by default because the sensitivity of this RQFT instrument is at most one part in ten to the sixth. The integrator count value for a particular exercise in question is merely representative of integrating the electrical noise and the true protection factor is indeed greater than 1.0E+06. Any exercise scaled integrator count value yielding a protection factor greater than 1.0E+06 will be reported as 1.0E+06.

REFERENCES

1. Hyatt, E. C., J. A. Pritchard, and C. P. Richards. Respirator efficiency measurement using quantitative DOP man tests. *Am Ind Hyg Assoc J* 33:635 (1972).
2. Hyatt, E. C., J. A. Pritchard, C. P. Richards, L. A. Geoffrion, and I. K. Kressin. Respirator research and development related to quality control. LASL project R-037, Document L-4908-PR (quarterly report: July 1 through Sept 30, 1971). Los Alamos Scientific Laboratory, Los Alamos, N. Mex., Dec 1971.
3. Air Techniques Incorporated. TDA-50 DOP aerosol man test system, and TDS-80 DOP portable facefit tester. Baltimore, Md., Jan 1, 1979.
4. Dynatech Frontier Corporation. Model FE222 Test Booth, Model FE250A Portable DOP Aerosol Quantitative Man Fit Test System; Model FE257 Table-Top DOP Aerosol Quantitative Respirator Fit Test Instrument; and Model FE259H Polydispersed DOP Aerosol Test System. Albuquerque, N. Mex., May 1, 1979.
5. Kolesar, E. S., Jr. Respirator qualitative/quantitative fit test method analysis. SAM Aeromed Rev 2-80, Aug 1980.
6. Kolesar, E. S., Jr. and C. M. de la Barre. Sodium chloride respirator quantitative fit test instrument. SAM-TR-81-22, Nov 1981.
7. Hounam, R. F., D. J. Morgan, D. T. O'Connor, and R. J. Sherwood. The evaluation of protection provided by respirators. *Ann Occup Hyg* 7:353 (1964).
8. Griffin, O. G., and D. J. Longson. The hazard due to inward leakage of gas into a full face mask. *Ann Occup Hyg* 13:147 (1970).
9. Adley, F. E., and R. J. Uhle. Protection factors of self-contained compressed-air breathing apparatus. *Am Ind Hyg Assoc J* 30:355 (1969).
10. White, J. M., and R. J. Beal. The measurement of leakage of respirators. *Am Ind Hyg Assoc J* 27:239 (1966).
11. Burgess, W. A., and P. C. Reist. Supply rates for powered air-purifying respirators. *Am Ind Hyg Assoc J* 30:1 (1969).
12. Adley, F. E., and D. E. Wisehart. Methods for performance testing of respiratory protective equipment. *Am Ind Hyg Assoc J* 23:251 (1962).
13. Burgess, W. A., L. Silverman, and F. Stein. A new technique for evaluating respirator performance. *Am Ind Hyg Assoc J* 22:422 (1961).
14. Packard, L. H., H. L. Brady, and O. F. Schum. Quantitative fit testing of personnel utilizing a mouthpiece respirator. *Am Ind Hyg Assoc J* 39:723 (1978).

15. Lowry, P. L., L. D. Wheat, and J. M. Bustos. Quantitative fit-test method for powered air-purifying respirators. *Am Ind Hyg Assoc J* 40:291 (1979).
16. Burgess, W. A., and W. C. Hinds. Performance and acceptance of respirator facial seals. *Ergonomics* 13:455 (1970).
17. DeSteiguer, D., E. B. McFadden, M. S. Pinski, and J. R. Bannister. The use of n-pentane as a tracer gas for the quantitative evaluation of aircrew protective breathing equipment. *Proc. Fourteenth Annual SAFE Symposium, San Diego, Calif.*, pp. 15-19, Sept 1976.
18. DeSteiguer, D., M. S. Pinski, J. R. Bannister, and E. B. McFadden. The objective evaluation of aircrew protective breathing equipment: II. Fullface masks and hoods. *Proc. Fourteenth Annual SAFE Symposium, San Diego, Calif.*, pp. 10-12, Sept 1976.
19. Cyr, R. R., and D. W. Watkins. Facepiece-to-face leakage evaluation using a helium leak detection method. *J Vac Sci Tech* 12:419 (1975).
20. Williams, F. T. Photometric measurement of respirator fit test protection factors and their interpretation, use, and meaning. Technical Note 108-0008. Dynatech Frontier Corporation, Albuquerque, N. Mex., Nov 18, 1978.
21. Minutes of the ASTM Committee, E-34.14 Task Group, Occupational Health and Safety. Department of Labor, Occupational Safety and Health Administration, Constitution Avenue, Washington, D.C., 27-28 Feb 1979.
22. Lowry, P. L., C. P. Richards, L. A. Geoffrion, S. K. Yasuda, L. D. Wheat, J. M. Bustos, and D. D. Douglas. Respirator studies for the National Institute for Occupational Safety and Health. Progress Report LA-7317-PR (Jan 1 - Dec 31, 1977). Los Alamos Scientific Laboratory, Los Alamos, N. Mex., June 1981.
23. Hyatt, E. C., J. A. Pritchard, B. J. Held, D. A. Bevis, T. O. Davis, L. A. Geoffrion, A. L. Hack, P. L. Lowry, T. O. Moore, C. P. Richards, and L. D. Wheat. Respiratory studies for the National Institute for Occupational Safety and Health. Progress Report LA-5620-PR, (July 1, 1972 - June 3, 1973). Los Alamos Scientific Laboratory, Los Alamos, N. Mex., May 1974.
24. Jones, R. E. Quantitative measurement of face seal leakage and related contributory factors. Report NA-68-383. North American Rockwell Corporation, Los Angeles Division, 1968.
25. Watson, H. A., P. M. Gussey, and A. J. Beckert. Evaluation of chemical-cartridge respirator face fit. Report of Investigations: 7431. U.S. Department of the Interior, Bureau of Mines, Washington, D.C., 1970.
26. Sodium chloride test system instruction manual. Internal report (not published). USAF School of Aerospace Medicine, Crew Protection Branch, Brooks Air Force Base, Tex. (current revision: 25 Jan 1979).

27. Pritchard, J. A. A guide to industrial respiratory protection. NIOSH Publication 76-189. U.S. Department of Health, Education and Welfare, Public Health Service, Center for Disease Control, National Institute for Occupational Safety and Health, Cincinnati, Ohio, June 1976.
28. Pasternack, A. The Model 80 face mask fit-tester. Draeger Rev 41:32 (1978).
29. Douglas, D. D., W. Revior, J. A. Pritchard, A. L. Hack, L. A. Geoffrion, T. O. Davis, P. L. Lowry, C. P. Richards, L. D. Wheat, J. M. Bustos, and P. R. Hesck. Respirator studies for the National Institute for Occupational Safety and Health. Progress Report LA-6386-PR (July 1, 1974 - June 30, 1975). Los Alamos Scientific Laboratory, Los Alamos, N. Mex, Aug 1976.
30. Hyatt, E. C. Respirator protection factors. Informal Report LA-6084-MS. Los Alamos Scientific Laboratory, Los Alamos, N. Mex., Jan 1976.
31. Hyatt, E. C., J. A. Pritchard, L. A. Geoffrion, and C. P. Richards. Respirator performance measurement using quantitative sodium chloride aerosol man tests. Technical Report LA-DC-13306. Los Alamos Scientific Laboratory, Los Alamos, N. Mex., May 1972.
32. Griffin, O. G., and D. L. Longson. Influence of facemask design on operational performance. In NASA SP-302: Second Conf. on Portable Life Support Systems. National Aeronautics and Space Administration, Ames Research Center, Moffett Field, Calif., May 11-13, 1971.
33. Hounam, R. F. A method for evaluating the protection afforded when wearing a respirator. Report AERE-R4125. Atomic Energy Research Establishment, Harwell, England, 1962.
34. Leigh, J. D. Quantitative respirator man-testing and anthropometric survey. RFP-2358. Dow Chemical Company, Rocky Flats Division, Golden, Colo., 1975.
35. Field test method for fitting respirators. National Safety News 100:41 (1969).
36. Hammond, S. E., and J. E. Hill. Rocky Flats respirator-fitting program. Dow Chemical Company, Rocky Flats Division, Golden, Colo. (1966).
37. Kolesar, E. S., Jr. Automated calculation of protection factors for the sodium chloride respirator quantitative fit test instrument. SAM-TR-80-50, Dec 1980.
38. Echols, W. H., and J. A. Young. Studies of portable operated aerosol generators. NRL report 5929. U.S. Naval Research Laboratory, Protective Chemistry Branch, Washington, D.C. 20375, July 26, 1963.
39. Mercer, T. T., and R. G. Stafford. Impaction from round jets. Ann Occup Hyg 12:41 (1969).

40. NATO Standardization Agreement (STANAG), First Draft STANAG 3864 AMD [Aeromedical]. The measurement of protection provided to the respiratory tract and eyes against NBC agents in particulate, aerosol and vapour form. Military Agency for Standardization (Air Board), MAS (AIR) (79) (68), 29 Mar 1979. [Available: HQ NATO, MAS, Brussels, Belgium]
41. Sinclair, D., and V. LaMer. Light scattering as a measure of particle size in aerosols. Chem Rev 44:245 (1949).
42. Hodgkinson, J. R., and J. R. Greenfield. Response calculations for light scattering aerosol counters and photometers. Appl Opt 4:1463 (1965).

APPENDIX A:

Technical Note

USAFSAM Di-2-ethylhexyl Phthalate Respirator Quantitative Fit
Test Instrument (Dynatech Frontier Corporation Model FE259H)
Calibration Procedure

Edward S. Kolesar, Jr., Captain, USAFSAM/VNL
Colette M. de la Barre, Staff Sergeant, USAFSAM/VNL

5 January 1981

--APPENDIX A--

USAFSAM Di-2-ethylhexyl Phthalate Respirator Quantitative Fit Test Instrument (Dynatech Frontier Corporation Model FE259H) Calibration Procedure

INTRODUCTION

The Dynatech Frontier Corporation Model FE259H polydispersed di-2-ethylhexyl phthalate (DEHP) respirator quantitative fit test (RQFT) instrument is designed to generate a liquid aerosol challenge atmosphere that is reproducible in particle size $\{[0.5 - 0.6 \mu\text{m}] - [\text{mass median aerodynamic diameter (MMAD)}]\}$ and in concentration $(25 \pm 5 \mu\text{g/liter})$ [1-6]. The major subsystems of the FE259H RQFT instrument are the Model FE971 linear forward light scattering photometer, an aerosol generator, a dilution air system, and a Model FE701 strip-chart recorder [1, 3-5]. When the FE259H instrument is used in conjunction with the Model FE222 test booth, measurements of RQFT protection factors (PFs) can be accomplished [2, 5].

This technical note describes the analytical procedures that can be used to generate and maintain a known test booth challenge concentration of DEHP (normally, 30 $\mu\text{g/liter}$ for full-face respirator tests). Implementation of this procedure will require the operator to make only two adjustments to the instrument. After the ambient temperature ($^{\circ}\text{F}$) and barometric pressure (cm Hg) are measured, the FE259H aerosol generator air pressure and aerosol dilution air differential pressure settings are made. These two settings will optimize the test booth's response time (time required for the test booth to attain an equilibrium aerosol challenge concentration from an initial start-up), and the instrument's dynamic capability to achieve and maintain a desired challenge aerosol concentration.

ANALYTIC PERFORMANCE EQUATIONS

Five equations predict the performance and operation of the USAFSAM DEHP RQFT instrument [1, 3-10]:

$$\dot{M}_g = CQ_t \quad (\text{A-1})$$

$$P_g = (\dot{M}_g - a_0)/a_1 \quad (\text{A-2})$$

$$Q_g = b_1 P_g + b_0 \quad (\text{A-3})$$

$$Q_d = Q_t - Q_g \quad (\text{A-4})$$

$$\Delta P = (Q_d/k)^2 (P/T) \quad (\text{A-5})$$

where,

ΔP = aerosol dilution air differential pressure setting [also the magnehelic water column gauge setting (inches of H_2O)]

--APPENDIX A--

P_g = aerosol generator air pressure (psig)

P = average ambient barometric pressure (cm of Hg)

$\dot{M}_g$ = aerosol generator mass flow rate (mg/min)

Q_t = total system volumetric aerosol flow rate (liters/min)

Q_d = volumetric dilution air flow rate (liters/min)

Q_g = volumetric aerosol generator flow rate (liters/min)

C = chamber concentration of DEHP ($\mu\text{g/liter}$)

T = average ambient temperature ($^{\circ}\text{K}$)

a_0 , a_1 , b_0 , b_1 , and k = unique instrumental calibration constants
supplied by the manufacturer.

For the USAFSAM instrument [1, 3-5]:

a_0 = -23.9 mg/min

a_1 = 9.26 mg/min $\cdot$ psig

b_0 = 17.2 liter/min

b_1 = 2.72 liters/min $\cdot$ psig

k = 119.0 liters $\cdot$ cm Hg $^{\frac{1}{2}}$ /min $\cdot$ $^{\circ}\text{K}^{\frac{1}{2}}$ $\cdot$ psig $^{\frac{1}{2}}$

C = 30 $\mu\text{g/liter}$

EXAMPLE CALCULATION

As an example, a typical calculation can be accomplished considering the following conditions:

T = 72 $^{\circ}\text{F}$

P = 75 cm Hg

Q_t = 849.6 liters/min (30 cfm)

--APPENDIX A--

The aerosol generator's mass flow rate can be calculated using Equation (A-1):

$$\dot{M}_g = (30 \text{ } \mu\text{g/liter}) (1 \text{ mg}/1000 \text{ } \mu\text{g}) (849.6 \text{ liters/min})$$

$$\dot{M}_g = 25.49 \text{ mg/min}$$

The aerosol generator pressure setting can be calculated using Equation (A-2):

$$P_g = \frac{(25.49 \text{ mg/min}) - (-23.9 \text{ mg/min})}{(9.26 \text{ mg/min} \cdot \text{psig})}$$

$$P_g = 5.33 \text{ psig}$$

The volumetric aerosol generator air flow rate can be calculated using Equation (A-3):

$$Q_g = (2.72 \text{ liters/min} \cdot \text{psig}) (5.33 \text{ psig}) + (17.2 \text{ liters/min})$$

$$Q_g = 31.70 \text{ liters/min}$$

The volumetric dilution air flow rate can be calculated using Equation (A-4):

$$Q_d = (849.6 \text{ liters/min}) - (31.70 \text{ liters/min})$$

$$Q_d = 817.9 \text{ liters/min}$$

Finally, the aerosol dilution air differential pressure setting can be calculated using Equation (A-5):

$$\Delta P = \frac{\frac{817.9 \text{ liters}}{\text{min}}}{\frac{119 \text{ liters} \cdot \text{cm Hg}^{\frac{1}{2}}}{\text{min} \cdot \text{ } ^\circ\text{K}^{\frac{1}{2}} \cdot \text{psig}}} \cdot \left[\frac{(75 \text{ cm Hg})}{(295.4 \text{ } ^\circ\text{K})} \right]$$

--APPENDIX A--

$$\Delta P = 12.0 \text{ psig}$$

where

$$^{\circ}\text{K} = (^{\circ}\text{F} - 32) \frac{5}{9} + 273.15$$

Thus, for this example, the DEHP instrument's front panel aerosol generator air pressure gauge would be adjusted to 5.33 psig, and the aerosol dilution air differential pressure (magnehelic gauge) would be adjusted to 12.0 psig. These settings (at the temperature and barometric pressure considered) mean that the test booth's concentration of DEHP will be established and maintained at 30 $\mu\text{g}/\text{liter}$.

CONCLUSION

Because the aerosol generator air pressure and aerosol dilution air differential pressure (magnehelic gauge) must be adjusted for ambient temperature and barometric pressure, a table of these two settings can be constructed for various combinations of ambient temperatures and barometric pressures.

Figure A-1 illustrates the organization of Table A-1. To use Table A-1, the technician should: first, identify the aerosol generator air pressure he would like to use; second, identify the ambient temperature and barometric pressure; and, finally, read from the Table (an element x_{ij}) the aerosol dilution air differential pressure (magnehelic gauge) setting. If the situation arises that the magnehelic gauge setting is off-scale for the instrument, the technician should select a different aerosol generator air pressure setting and repeat the foregoing iterative process. Table A-1 will facilitate calibration of the instrument by the laboratory technician.

The following pages ("Attachment A-1") contain Figure A-1 and the computer-generated information for Table A-1. (Thereafter, "Attachment A-2" provides a listing of the Fortran computer program used to generate the data in Table A-1).

REFERENCES

1. Frontier Enterprises, Incorporated. Customer training workshop and seminar series manual: Aerosol instrumentation for respiratory protective apparatus testing and training (DOP quantitative man fit testing - DOP apparatus quality surveillance testing), 12 June 1978.
2. Frontier Enterprises, Incorporated. Some general properties of airborne particulates. Technical Note TN 106.000, 14 Mar 1974.

NOTE: Frontier Enterprises, Incorporated, is now Dynatech Frontier Corporation, Albuquerque, N. Mex.

--APPENDIX A--

3. Frontier Enterprises, Incorporated. Aerosol concentration calculation procedures for the Model FE259H DOP aerosol test system. Technical Note TN 108.0001, 6 Feb 1976.
4. Frontier Enterprises, Incorporated. Dynamic aerosol characteristics of the Model FE259H DOP aerosol test system. Technical Note TN 108.0007, 24 Jan 1979.
5. Dynatech Frontier Corporation. Polydispersed DOP aerosol system Model FE259H operating manual, Albuquerque, N. Mex., 18 Apr 1980.
6. Dynatech Frontier Corporation. Photometric measurement of respirator quantitative fit test protection factors and their interpretation, use, and meaning. Albuquerque, N. Mex., 18 Nov 1978.
7. Liu, B. Y. H. (ed.). Fine particles, aerosol generation, measurement, sampling, and analysis. New York: Academic Press, 1976.
8. Echols, W. H., and J. A. Young. Studies of portable air-operated aerosol generators. NRL Report 5929. U.S. Naval Research Laboratory, Chemistry Division, Washington, D.C., 16 July 1963.
9. Davis, C. H. (ed.). Aerosol science. New York: Academic Press, 1966.
10. Hidy, G. M., and J. R. Brock. The dynamics of aerocolloidal systems. Int Rev Aerosol and Chemistry 1:1 (1970).

--APPENDIX A--

ATTACHMENT A-1:

Figure A-1 and Table A-1

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR		AIR PRESSURE (PSIG) = (DESIRED SETTING)												
		Ambient Barometric Pressure in cm Hg												
		72	72.5	73	73.5	74	74.5	75	75.5	76	76.5	77	77.5	78
A	80	x _{1,1}	x _{1,2}	x _{1,3}	x _{1,4}	x _{1,5}	x _{1,6}	x _{1,7}	x _{1,8}	x _{1,9}	x _{1,10}	x _{1,11}	x _{1,12}	x _{1,13}
m	79.5	x _{2,1}	x _{2,2}	x _{2,3}	x _{2,4}									
b	79	x _{3,1}												
i	78.5													
e	78													
n	77.5													
t	77													
T	76.5													
r	76													
e	75.5													
m	75													
p	74.5													
e	74													
r	73.5													
a	73													
t	72.5													
u	72													
r	71.5													
e	71													
f	70.5													
f	70													
n	69.5													
D	69													
e	68.5													
e	68													
g	67.5													
r	67													
e	66.5													
e	66													
s	65.5													
65														
F	64.5													
64														
63.5														
63														
62.5														
62														
61.5														
61														
60.5														
60	x	41.1												x
														41.13

Figure A-1. Organization of data for Table A-1. (Aerosol generator air pressure vs. aerosol dilution air differential pressure--magnehelic gauge setting--for various ambient temperatures and barometric pressures.)

--APPENDIX A--
(Attachment A-1)

TABLE A-1. AEROSOL GENERATOR AIR PRESSURE VS. AEROSOL DILUTION AIR DIFFERENTIAL PRESSURE (MAGNEHELIC GAUGE SETTING) FOR VARIOUS AMBIENT TEMPERATURES AND BAROMETRIC PRESSURES

AEROSOL GENERATOR PRESSURE (PSIG) = 2.86

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
M	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
B	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
I	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
E	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
N	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
V	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
T	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
E	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
M	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
P	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
E	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
R	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
A	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Y	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
U	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
R	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
E	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
I	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
N	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
D	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
E	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
C	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
F	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 3.04

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
M	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
B	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
I	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
E	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
N	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Y	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
E	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
N	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
T	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
E	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
X	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
P	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
E	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
A	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
T	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
N	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
R	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
F	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
I	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
N	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
D	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
E	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
G	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
L	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

AEROSOL GENERATOR PRESSURE (PSIG) = 3.13

AMBIENT BAROMETRIC PRESSURE IN CM HG

48

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 3.22

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
80.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
79.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
79.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
78.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
78.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
77.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
77.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
76.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
76.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
75.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
75.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
74.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
74.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
73.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
73.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
72.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
72.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
71.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
71.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
70.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
70.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
69.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
69.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
68.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
68.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
67.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
67.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
66.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
66.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
65.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
65.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
64.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
64.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
63.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
63.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
62.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
62.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
61.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
61.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
60.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
60.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5

A M P R E T E M P E R A T U R E I N D E G F

AEROSOL GENERATOR PRESSURE (PSIG) = 3.31

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	60.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
M	79.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
B	79.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
H	78.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
I	78.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
E	77.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
N	77.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
Y	76.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
T	76.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
P	75.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
M	75.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
P	74.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
F	74.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
R	73.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
A	73.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
U	72.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
F	60.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
I	60.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
N	67.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
D	66.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
D	66.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
E	65.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
C	65.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
G	64.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
F	64.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
I	63.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
N	63.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
D	62.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
D	62.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
E	61.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
C	61.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
G	60.5	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
F	60.0	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7

AMBIENT BAROMETRIC PRESSURE IN CM HG

51

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 3.50

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	1.1	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
M	1.1	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
R	1.1	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
77.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
77.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
76.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
76.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
75.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
75.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
74.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
74.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
73.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
73.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
72.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
72.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
69.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
69.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
68.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
68.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
67.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
67.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
66.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
66.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
65.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
65.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
64.5	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
64.0	1.1	1.1	1.1	1.1	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
63.5	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
63.0	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
62.5	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
62.0	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
61.5	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
61.0	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
60.5	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
60.0	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 3.59

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A 68.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5
H 79.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 79.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 78.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 78.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 77.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 77.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 76.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 76.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 75.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 75.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 74.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 74.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 73.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 73.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 72.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 72.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 71.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 71.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 70.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 70.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 69.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 69.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 68.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 68.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 67.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 67.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 66.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 66.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 65.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 65.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 64.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 64.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 63.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 63.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 62.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 62.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 61.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 61.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 60.5	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5
H 60.0	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.5	1.5	1.5	1.5	1.5

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 3.60

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
60.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
60.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
61.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
61.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
62.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
62.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
63.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
63.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
64.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
64.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
65.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
65.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
66.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
66.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
67.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
67.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
68.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
68.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
69.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
69.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
70.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
70.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
71.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
71.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
72.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
72.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
73.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
73.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
74.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
74.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
75.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
75.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
76.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
76.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
77.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
77.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
78.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
78.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
79.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
79.5	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
80.0	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7

A M B I E N T B A R O M E T R I C P R E S S U R E I N C M H G

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 3.77

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
80.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
79.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
79.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
78.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
78.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
77.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
77.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
76.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
76.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
75.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
75.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
74.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
74.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
73.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
73.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
72.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
72.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
71.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
71.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
70.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
70.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
69.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
69.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
68.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
68.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
67.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
67.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
66.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
66.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
65.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
65.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
64.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
64.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
63.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
63.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
62.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
62.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
61.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
61.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
60.5	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1
60.0	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1

TEMPERATURE IN DEGREE F

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 3.07

AMBIENT BAROMETRIC PRESSURE IN CM HG

	12.0	12.5	13.0	13.5	14.0	14.5	15.0	15.5	16.0	16.5	17.0	17.5	18.0
80.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
79.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
79.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
78.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
78.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
77.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
77.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
76.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
76.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
75.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
75.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
74.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
74.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
73.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
73.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
72.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
72.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
71.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
71.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
70.5	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
70.0	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5
69.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
69.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
68.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
68.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
67.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
67.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
66.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
66.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
65.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
65.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
64.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
64.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
63.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
63.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
62.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
62.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
61.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
61.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
60.5	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6
60.0	2.4	2.4	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.6

A M B I E N T B A R O M E T R I C P R E S S U R E I N C M H G

AMBIENT BAROMETRIC PRESSURE IN CM HG

57

--APPENDIX A--
(Attachment A-1)

AEROBOL GENERATOR PRESSURE (PSIG)= 4.05

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
60.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
79.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
79.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
78.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
78.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
77.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
77.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
76.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
76.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
75.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
75.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
74.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
74.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
73.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
73.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
72.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
72.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
71.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
71.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
70.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
70.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
69.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
69.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
68.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
68.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
67.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
67.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
66.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
66.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
65.5	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
65.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3
64.5	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
64.0	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
63.5	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
63.0	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
62.5	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
62.0	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
61.5	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
61.0	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
60.5	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4
60.0	3.2	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4	3.4

AMBIENT BAROMETRIC PRESSURE IN CM HG

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 4.14

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	80.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
M	79.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
B	79.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
I	78.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
N	78.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
T	77.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	77.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
P	76.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
R	76.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
U	75.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
R	75.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	74.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	74.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	73.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	73.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	72.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	72.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	71.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	71.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	70.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	70.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	69.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	69.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	68.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	68.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	67.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	67.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	66.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	66.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	65.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	65.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	64.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	64.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	63.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	63.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	62.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	62.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	61.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	61.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	60.5	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8
E	60.0	3.5	3.5	3.6	3.6	3.6	3.6	3.6	3.7	3.7	3.7	3.7	3.8

AMBIENT BAROMETRIC PRESSURE IN CM HG

60

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 4.42

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	60.0	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
M	79.5	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
I	79.0	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
E	78.5	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
N	78.0	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
A	77.5	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
M	77.0	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
I	76.5	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
E	76.0	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
N	75.5	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
A	75.0	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
M	74.5	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
I	74.0	4.9	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
E	73.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
N	73.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
A	72.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
M	72.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
I	71.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
E	71.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
N	70.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
A	70.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
M	69.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
I	69.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
E	68.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
N	68.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
A	67.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
M	67.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
I	66.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
E	66.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
N	65.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
A	65.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
M	64.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
I	64.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
E	63.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
N	63.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
A	62.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
M	62.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
I	61.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
E	61.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
N	60.5	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3
A	60.0	5.0	5.0	5.0	5.0	5.1	5.1	5.1	5.2	5.2	5.2	5.3	5.3

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 4.51

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	80.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	79.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	79.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	78.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	78.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	77.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	77.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	76.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	76.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	75.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	75.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	74.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	74.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	73.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	73.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	72.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	72.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	71.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	71.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	70.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	70.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	69.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	69.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	68.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	68.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	67.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	67.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	66.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	66.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	65.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	65.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	64.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	64.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	63.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	63.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	62.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	62.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
M	61.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
T	61.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
R	60.5	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8
L	60.0	5.4	5.5	5.5	5.6	5.6	5.6	5.7	5.7	5.7	5.8	5.8	5.8

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 4.60

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
79.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
79.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
80.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
80.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
81.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
81.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
82.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
82.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
83.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
83.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
84.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
84.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
85.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
85.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
86.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
86.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
87.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
87.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
88.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
88.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
89.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
89.5	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5
90.0	6.0	6.0	6.1	6.1	6.1	6.2	6.2	6.3	6.3	6.3	6.4	6.4	6.5

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 4.69

AMBIENT BAROMETRIC PRESSURE IN CM HG

	122.0	122.5	123.0	123.5	124.0	124.5	125.0	125.5	126.0	126.5	127.0	127.5	128.0
80.0	6.5	6.6	6.6	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
79.5	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
79.0	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
78.5	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
78.0	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
77.5	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
77.0	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
76.5	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
76.0	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
75.5	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
75.0	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
74.5	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
74.0	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
73.5	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
73.0	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
72.5	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
72.0	6.6	6.6	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1
71.5	6.7	6.7	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2
71.0	6.7	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2
70.5	6.7	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2
70.0	6.7	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2
69.5	6.7	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2
69.0	6.7	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2
68.5	6.7	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2
68.0	6.7	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2
67.5	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2	7.3
67.0	6.7	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.1	7.1	7.2	7.2	7.3
66.5	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.3
66.0	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.3
65.5	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.3
65.0	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.3
64.5	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.3
64.0	6.7	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.3
63.5	6.8	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.3
63.0	6.8	6.8	6.9	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.3
62.5	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.2	7.3
62.0	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.2	7.3
61.5	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.2	7.3
61.0	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.2	7.3
60.5	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.2	7.3
60.0	6.8	6.8	6.9	6.9	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.2	7.3

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 4.76

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
80.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
79.5	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
79.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
78.5	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
78.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
77.5	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
77.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
76.5	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
76.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
75.5	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
75.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
74.5	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
74.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
73.5	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
73.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
72.5	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
72.0	7.2	7.2	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.6	7.7	7.7
71.5	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
71.0	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
70.5	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
70.0	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
69.5	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
69.0	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
68.5	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
68.0	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
67.5	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
67.0	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
66.5	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
66.0	7.3	7.3	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.7	7.8	7.8
65.5	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
65.0	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
64.5	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
64.0	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
63.5	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
63.0	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
62.5	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
62.0	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
61.5	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
61.0	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
60.5	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9
60.0	7.4	7.4	7.5	7.5	7.6	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9

A M B I E N T B A R O M E T R I C P R E S S U R E I N C M H G

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 4.97

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
60.0	0.4	0.5	0.6	0.6	0.7	0.7	0.8	0.9	0.9	9.0	9.0	9.1	9.1
79.5	0.5	0.5	0.6	0.6	0.7	0.7	0.8	0.9	0.9	9.0	9.0	9.1	9.2
79.0	0.5	0.5	0.6	0.6	0.7	0.8	0.8	0.9	0.9	9.0	9.0	9.1	9.2
78.5	0.5	0.5	0.6	0.6	0.7	0.8	0.8	0.9	0.9	9.0	9.1	9.1	9.2
78.0	0.5	0.5	0.6	0.7	0.7	0.8	0.8	0.9	0.9	9.0	9.1	9.1	9.2
77.5	0.5	0.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2
77.0	0.5	0.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2
76.5	0.5	0.6	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2
76.0	0.5	0.6	0.6	0.7	0.7	0.8	0.9	0.9	9.0	9.0	9.1	9.2	9.2
75.5	0.5	0.6	0.6	0.7	0.8	0.8	0.9	0.9	9.0	9.0	9.1	9.2	9.2
75.0	0.5	0.6	0.6	0.7	0.8	0.8	0.9	0.9	9.0	9.0	9.1	9.2	9.2
74.5	0.5	0.6	0.6	0.7	0.8	0.8	0.9	0.9	9.0	9.1	9.1	9.2	9.2
74.0	0.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2
73.5	0.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2
73.0	0.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2
72.5	0.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2
72.0	0.6	0.6	0.7	0.7	0.8	0.9	0.9	9.0	9.0	9.1	9.2	9.2	9.2
71.5	0.6	0.6	0.7	0.8	0.8	0.9	0.9	9.0	9.1	9.1	9.2	9.2	9.2
71.0	0.6	0.6	0.7	0.8	0.8	0.9	0.9	9.0	9.1	9.1	9.2	9.2	9.2
70.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
70.0	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
69.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
69.0	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
68.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
68.0	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
67.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
67.0	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
66.5	0.6	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2
66.0	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
65.5	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
65.0	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
64.5	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
64.0	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
63.5	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
63.0	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
62.5	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
62.0	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
61.5	0.7	0.7	0.8	0.8	0.9	9.0	9.0	9.1	9.1	9.2	9.2	9.2	9.2
61.0	0.8	0.8	0.9	0.9	9.0	9.1	9.1	9.2	9.2	9.2	9.2	9.2	9.2
60.5	0.8	0.8	0.9	0.9	9.0	9.1	9.1	9.2	9.2	9.2	9.2	9.2	9.2
60.0	0.8	0.8	0.9	0.9	9.0	9.1	9.1	9.2	9.2	9.2	9.2	9.2	9.2

A M B I F N T P E H A U R F T N D E C F

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 3.06

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	80.0	9.1	9.2	9.3	9.4	9.4	9.5	9.6	9.6	9.7	9.8	9.8	9.9
B	79.5	9.1	9.2	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.8	9.9
C	79.0	9.1	9.2	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.8	9.9
D	78.5	9.2	9.2	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	9.9
E	78.0	9.2	9.2	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	9.9
F	77.5	9.2	9.2	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	9.9
G	77.0	9.2	9.3	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
H	76.5	9.2	9.3	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
I	76.0	9.2	9.3	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
J	75.5	9.2	9.3	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
K	75.0	9.2	9.3	9.3	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
L	74.5	9.2	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
M	74.0	9.2	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
N	73.5	9.2	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
O	73.0	9.3	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
P	72.5	9.3	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
Q	72.0	9.3	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
R	71.5	9.3	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
S	71.0	9.3	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	9.8	9.9	10.0
T	70.5	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.7	9.8	9.9	10.0
U	70.0	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.7	9.8	9.9	10.0
V	69.5	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.7	9.8	9.9	10.0
W	69.0	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.7	9.8	9.9	10.0
X	68.5	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.7	9.8	9.9	10.0
Y	68.0	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.7	9.8	9.9	10.0
Z	67.5	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AA	67.0	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AB	66.5	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AC	66.0	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AD	65.5	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AE	65.0	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AF	64.5	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AG	64.0	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AH	63.5	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AI	63.0	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AJ	62.5	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AK	62.0	9.4	9.4	9.5	9.5	9.6	9.6	9.6	9.6	9.7	9.8	9.9	10.0
AL	61.5	9.5	9.5	9.6	9.6	9.7	9.7	9.7	9.7	9.8	9.9	10.0	10.0
AM	61.0	9.5	9.5	9.6	9.6	9.7	9.7	9.7	9.7	9.8	9.9	10.0	10.0
AN	60.5	9.5	9.5	9.6	9.6	9.7	9.7	9.7	9.7	9.8	9.9	10.0	10.0
AO	60.0	9.5	9.5	9.6	9.6	9.7	9.7	9.7	9.7	9.8	9.9	10.0	10.0

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 5.15

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	80.0	9.9	10.0	10.0	10.1	10.2	10.3	10.3	10.4	10.5	10.5	10.6	10.7
M	79.5	9.9	10.0	10.1	10.1	10.2	10.3	10.3	10.4	10.5	10.5	10.6	10.7
I	79.0	9.9	10.0	10.1	10.1	10.2	10.3	10.3	10.4	10.5	10.5	10.6	10.7
E	78.5	9.9	10.0	10.1	10.2	10.2	10.3	10.4	10.4	10.5	10.6	10.6	10.7
N	78.0	9.9	10.0	10.1	10.2	10.2	10.3	10.4	10.4	10.5	10.6	10.6	10.7
T	77.5	10.0	10.0	10.1	10.2	10.2	10.3	10.4	10.4	10.5	10.6	10.6	10.7
H	77.0	10.0	10.0	10.1	10.2	10.2	10.3	10.4	10.4	10.5	10.6	10.7	10.7
I	76.5	10.0	10.0	10.1	10.2	10.3	10.3	10.4	10.5	10.5	10.6	10.7	10.7
E	76.0	10.0	10.1	10.1	10.2	10.3	10.3	10.4	10.5	10.5	10.6	10.7	10.7
N	75.5	10.0	10.1	10.1	10.2	10.3	10.3	10.4	10.5	10.5	10.6	10.7	10.8
T	75.0	10.0	10.1	10.1	10.2	10.3	10.3	10.4	10.5	10.5	10.6	10.7	10.8
H	74.5	10.0	10.1	10.1	10.2	10.3	10.4	10.4	10.5	10.6	10.6	10.7	10.8
I	74.0	10.0	10.1	10.2	10.2	10.3	10.4	10.4	10.5	10.6	10.6	10.7	10.8
E	73.5	10.0	10.1	10.2	10.2	10.3	10.4	10.4	10.5	10.6	10.7	10.7	10.8
N	73.0	10.0	10.1	10.2	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.7	10.8
T	72.5	10.0	10.1	10.2	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.8	10.9
H	72.0	10.0	10.1	10.2	10.3	10.3	10.4	10.5	10.5	10.6	10.7	10.8	10.9
I	71.5	10.0	10.1	10.2	10.3	10.4	10.4	10.5	10.6	10.6	10.7	10.8	10.9
E	71.0	10.0	10.1	10.2	10.3	10.4	10.4	10.5	10.6	10.7	10.7	10.8	10.9
N	70.5	10.0	10.1	10.2	10.3	10.4	10.4	10.5	10.6	10.7	10.7	10.8	10.9
T	70.0	10.0	10.1	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.7	10.8	10.9
H	69.5	10.0	10.1	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.7	10.8	10.9
I	69.0	10.0	10.1	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.7	10.8	10.9
E	68.5	10.1	10.1	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.8	10.9	10.9
N	68.0	10.1	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9
T	67.5	10.1	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	11.0
H	67.0	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0
I	66.5	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0
E	66.0	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0
N	65.5	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0
T	65.0	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0
H	64.5	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0
I	64.0	10.1	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0
E	63.5	10.2	10.2	10.4	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0
N	63.0	10.2	10.2	10.4	10.5	10.5	10.6	10.7	10.7	10.8	10.9	10.9	11.0
T	62.5	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.7	10.8	10.9	11.0	11.0
H	62.0	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.8	10.8	10.9	11.0	11.0
I	61.5	10.2	10.3	10.4	10.5	10.5	10.6	10.7	10.8	10.8	10.9	11.0	11.0
E	61.0	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.8	10.9	11.0	11.0
N	60.5	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.8	10.9	11.0	11.0
T	60.0	10.2	10.3	10.4	10.5	10.6	10.6	10.7	10.8	10.9	10.9	11.0	11.1

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 5.24

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
80.0	10.6	10.7	10.7	10.8	10.9	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.5
79.5	10.6	10.7	10.7	10.8	10.9	11.0	11.0	11.1	11.2	11.3	11.3	11.4	11.5
79.0	10.6	10.7	10.7	10.8	10.9	11.0	11.0	11.1	11.2	11.3	11.3	11.4	11.5
78.5	10.6	10.7	10.8	10.8	10.9	11.0	11.1	11.1	11.2	11.3	11.3	11.4	11.5
78.0	10.6	10.7	10.8	10.8	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5
77.5	10.6	10.7	10.8	10.8	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.4	11.5
77.0	10.6	10.7	10.8	10.9	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.5	11.5
76.5	10.6	10.7	10.8	10.9	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.5	11.5
76.0	10.7	10.7	10.8	10.9	11.0	11.0	11.1	11.2	11.3	11.3	11.4	11.5	11.5
75.5	10.7	10.7	10.8	10.9	11.0	11.0	11.1	11.2	11.3	11.3	11.4	11.5	11.5
75.0	10.7	10.8	10.8	10.9	11.0	11.0	11.1	11.2	11.3	11.3	11.4	11.5	11.6
74.5	10.7	10.8	10.8	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5	11.6
74.0	10.7	10.8	10.8	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.5	11.5	11.6
73.5	10.7	10.8	10.9	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.5	11.5	11.6
73.0	10.7	10.8	10.9	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.5	11.5	11.6
72.5	10.7	10.8	10.9	11.0	11.0	11.1	11.2	11.2	11.3	11.4	11.5	11.5	11.6
72.0	10.7	10.8	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5	11.6	11.7
71.5	10.7	10.8	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.5	11.5	11.6	11.7
71.0	10.8	10.8	10.9	11.0	11.1	11.2	11.3	11.3	11.4	11.5	11.6	11.6	11.7
70.5	10.8	10.8	10.9	11.0	11.1	11.2	11.3	11.4	11.4	11.5	11.6	11.7	11.7
70.0	10.8	10.9	10.9	11.0	11.1	11.2	11.3	11.4	11.4	11.5	11.6	11.7	11.7
69.5	10.8	10.9	10.9	11.0	11.1	11.2	11.3	11.4	11.5	11.5	11.6	11.7	11.7
69.0	10.8	10.9	10.9	11.0	11.1	11.2	11.3	11.4	11.5	11.5	11.6	11.7	11.7
68.5	10.8	10.9	11.0	11.0	11.1	11.2	11.3	11.4	11.5	11.5	11.6	11.7	11.7
68.0	10.8	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.5	11.5	11.6	11.7	11.7
67.5	10.8	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.5	11.5	11.6	11.7	11.7
67.0	10.8	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.5	11.5	11.6	11.7	11.7
66.5	10.9	11.0	11.0	11.1	11.2	11.3	11.3	11.4	11.5	11.5	11.6	11.7	11.8
66.0	10.9	11.0	11.1	11.1	11.2	11.3	11.3	11.4	11.5	11.5	11.6	11.7	11.8
65.5	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5	11.5	11.6	11.7	11.8
65.0	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5	11.5	11.6	11.7	11.8
64.5	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5	11.5	11.6	11.7	11.8
64.0	10.9	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5	11.5	11.6	11.7	11.8
63.5	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.4	11.5	11.5	11.6	11.7	11.8
63.0	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.4	11.5	11.5	11.6	11.7	11.8
62.5	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.4	11.5	11.5	11.6	11.7	11.8
62.0	10.9	11.0	11.1	11.2	11.2	11.3	11.4	11.4	11.5	11.5	11.6	11.7	11.8
61.5	11.0	11.0	11.1	11.2	11.3	11.3	11.4	11.4	11.5	11.6	11.6	11.7	11.8
61.0	11.0	11.1	11.1	11.2	11.3	11.3	11.4	11.4	11.5	11.6	11.7	11.7	11.8
60.5	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5	11.6	11.7	11.7	11.8	11.9
60.0	11.0	11.1	11.1	11.2	11.3	11.4	11.4	11.5	11.6	11.7	11.7	11.8	11.9

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 5.33

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
80.0	11.3	11.4	11.5	11.6	11.7	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3
79.5	11.4	11.5	11.6	11.7	11.7	11.8	11.9	12.0	12.1	12.1	12.1	12.2	12.3
79.0	11.4	11.5	11.6	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.2	12.3
78.5	11.4	11.5	11.6	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.2	12.3
78.0	11.4	11.5	11.6	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.3
77.5	11.4	11.5	11.6	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.3
77.0	11.4	11.5	11.6	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.4
76.5	11.4	11.5	11.6	11.7	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3	12.4
76.0	11.4	11.5	11.6	11.7	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3	12.4
75.5	11.4	11.5	11.6	11.7	11.8	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4
75.0	11.5	11.5	11.6	11.7	11.8	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4
74.5	11.5	11.5	11.6	11.7	11.8	11.9	11.9	12.0	12.1	12.2	12.3	12.3	12.4
74.0	11.5	11.6	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.3	12.4
73.5	11.5	11.6	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.4	12.4
73.0	11.5	11.6	11.7	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3	12.4	12.5
72.5	11.5	11.6	11.7	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3	12.4	12.5
72.0	11.5	11.6	11.7	11.8	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4	12.5
71.5	11.5	11.6	11.7	11.8	11.9	11.9	12.0	12.1	12.2	12.3	12.4	12.5	12.5
71.0	11.5	11.6	11.7	11.8	11.9	11.9	12.0	12.1	12.2	12.3	12.4	12.5	12.5
70.5	11.5	11.6	11.7	11.8	11.9	11.9	12.0	12.1	12.2	12.3	12.4	12.5	12.5
70.0	11.6	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.4	12.5	12.5
69.5	11.6	11.7	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3	12.4	12.5	12.5
69.0	11.6	11.7	11.8	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4	12.5	12.6
68.5	11.6	11.7	11.8	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4	12.5	12.6
68.0	11.6	11.7	11.8	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4	12.5	12.6
67.5	11.6	11.7	11.8	11.9	11.9	12.0	12.1	12.2	12.3	12.3	12.4	12.5	12.6
67.0	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.4	12.4	12.5	12.6
66.5	11.6	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.4	12.5	12.5	12.6
66.0	11.6	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3	12.4	12.5	12.5	12.6
65.5	11.7	11.7	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4	12.5	12.5	12.6
65.0	11.7	11.7	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4	12.5	12.6	12.6
64.5	11.7	11.8	11.8	11.9	12.0	12.1	12.2	12.3	12.3	12.4	12.5	12.6	12.7
64.0	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.4	12.4	12.5	12.6	12.7
63.5	11.7	11.8	11.9	12.0	12.0	12.1	12.2	12.3	12.4	12.4	12.5	12.6	12.7
63.0	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3	12.4	12.4	12.5	12.6	12.7
62.5	11.7	11.8	11.9	12.0	12.1	12.1	12.2	12.3	12.4	12.5	12.5	12.6	12.7
62.0	11.7	11.8	11.9	12.0	12.1	12.2	12.2	12.3	12.4	12.5	12.6	12.6	12.7
61.5	11.7	11.8	11.9	12.0	12.1	12.2	12.3	12.3	12.4	12.5	12.6	12.7	12.7
61.0	11.8	11.8	11.9	12.0	12.1	12.2	12.3	12.3	12.4	12.5	12.6	12.7	12.7
60.5	11.8	11.9	11.9	12.0	12.1	12.2	12.3	12.3	12.4	12.5	12.6	12.7	12.8
60.0	11.8	11.9	11.9	12.0	12.1	12.2	12.3	12.4	12.4	12.5	12.6	12.7	12.8

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 5.43

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	60.0	12.1	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.1
M	79.5	12.1	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2
R	72.0	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.2
A	78.5	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.2
P	70.0	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.2
U	77.5	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.2
E	76.0	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.2
N	77.5	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.2
D	76.0	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.2
E	75.5	12.2	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.2
G	74.0	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.3
L	73.5	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.3
	72.5	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.3
	71.5	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.3
	71.0	12.3	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4
	70.5	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.4
	70.0	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.4
	69.5	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.4
	69.0	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.4
	68.5	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.4
	68.0	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.4
	67.5	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5
	67.0	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5
	66.5	12.4	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5
	66.0	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.5
	65.5	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.5
	65.0	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.5
	64.5	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.5
	64.0	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.5
	63.5	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6
	63.0	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6
	62.5	12.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6
	62.0	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.6
	61.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.6
	61.0	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.6
	60.5	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.6
	60.0	12.6	12.7	12.8	12.9	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 5.52

AMBIENT BAROMETRIC PRESSURE IN C4 HC

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	60.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
M	72.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
R	74.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
I	76.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
E	77.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
H	79.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
F	80.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
P	82.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
R	83.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
A	85.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
U	86.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
P	88.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
F	89.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
I	91.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
N	92.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
D	94.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
G	95.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
L	97.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	98.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	100.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	101.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	103.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	104.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	106.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	107.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	109.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	110.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	112.0	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0
	113.5	13.0	13.1	13.2	13.3	13.4	13.5	13.6	13.7	13.8	13.9	14.0	14.0

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 5.61

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	90.0	13.8	13.9	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
M	70.5	13.6	13.9	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
B	70.5	13.6	13.9	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
I	70.5	13.6	13.9	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
E	70.5	13.9	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
N	70.5	13.9	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
T	70.5	13.9	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
P	70.5	13.9	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
E	70.5	13.9	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0
R	70.5	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1
A	70.5	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1
T	70.5	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1
U	70.5	14.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1
R	69.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2
E	68.5	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2
I	67.5	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2
N	67.0	14.1	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2
D	66.5	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3
E	66.0	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3
G	65.5	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3
F	65.0	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3
	64.5	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3
	64.0	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3
	63.5	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3
	63.0	14.2	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3
	62.5	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3	15.4
	62.0	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3	15.4
	61.5	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3	15.4
	61.0	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3	15.4
	60.5	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3	15.4
	60.0	14.3	14.4	14.5	14.6	14.7	14.8	14.9	15.0	15.1	15.2	15.3	15.4

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 5.70

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
80.0	14.7	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9
79.5	14.7	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9
79.0	14.7	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9
78.5	14.7	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9
78.0	14.7	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9
77.5	14.7	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9
77.0	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0
76.5	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0
76.0	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0
75.5	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0
75.0	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0
74.5	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0
74.0	14.6	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0
73.5	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1
73.0	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1
72.5	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1
72.0	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1
71.5	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1
71.0	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1
70.5	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1
70.0	14.9	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1
69.5	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2
69.0	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2
68.5	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2
68.0	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2
67.5	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2
67.0	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2
66.5	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2
66.0	15.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2
65.5	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3
65.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3
64.5	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3
64.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3
63.5	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3
63.0	15.1	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3
62.5	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3	16.4
62.0	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3	16.4
61.5	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3	16.4
61.0	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3	16.4
60.5	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3	16.4
60.0	15.2	15.3	15.4	15.5	15.6	15.7	15.8	15.9	16.0	16.1	16.2	16.3	16.4

AMBIENT BAROMETRIC PRESSURE IN CM HG

77

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 5.00

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
80.0	16.5	16.6	16.7	16.8	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	17.9
79.5	16.5	16.6	16.7	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.7	17.8	17.9
79.0	16.5	16.6	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	17.9
78.5	16.5	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	17.9
78.0	16.6	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	18.0
77.5	16.6	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	18.0
77.0	16.6	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	18.0
76.5	16.6	16.7	16.8	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	17.9	18.0
76.0	16.6	16.7	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	17.9	18.0
75.5	16.6	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	17.9	18.0
75.0	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	17.9	18.0
74.5	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	17.9	18.0
74.0	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	18.0	18.1
73.5	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	18.0	18.1
73.0	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	18.0	18.1
72.5	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	18.0	18.1
72.0	16.7	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.8	18.0	18.1
71.5	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.2
71.0	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.2
70.5	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.2
70.0	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.2
69.5	16.8	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.2
69.0	16.8	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.3
68.5	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.3
68.0	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.3
67.5	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.3
67.0	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.3
66.5	16.9	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.3
66.0	16.9	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.4
65.5	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.4
65.0	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.4
64.5	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.4
64.0	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.4
63.5	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.4
63.0	17.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.4
62.5	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.3	18.5
62.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.3	18.5
61.5	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.3	18.5
61.0	17.1	17.2	17.3	17.4	17.5	17.6	17.7	17.9	18.0	18.1	18.2	18.3	18.5
60.5	17.1	17.2	17.4	17.5	17.6	17.7	17.8	17.9	18.1	18.2	18.3	18.4	18.5
60.0	17.1	17.3	17.4	17.5	17.6	17.7	17.8	18.0	18.1	18.2	18.3	18.4	18.6

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 5.98

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
60.0	17.4	17.6	17.7	17.8	17.9	18.1	18.2	18.3	18.4	18.5	18.7	18.8	18.9
79.5	17.5	17.6	17.7	17.8	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	18.9
79.0	17.5	17.6	17.7	17.8	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	18.9
78.5	17.5	17.6	17.7	17.8	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	18.9
78.0	17.5	17.6	17.7	17.8	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	18.9
77.5	17.5	17.7	17.8	17.9	18.0	18.2	18.3	18.4	18.5	18.6	18.7	18.9	19.0
77.0	17.5	17.7	17.8	17.9	18.0	18.2	18.3	18.4	18.5	18.6	18.7	18.9	19.0
76.5	17.6	17.7	17.8	17.9	18.1	18.2	18.3	18.4	18.5	18.7	18.8	18.9	19.0
76.0	17.6	17.7	17.8	17.9	18.1	18.2	18.3	18.4	18.5	18.7	18.8	18.9	19.0
75.5	17.6	17.7	17.8	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	18.9	19.0
75.0	17.6	17.7	17.8	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	18.9	19.0
74.5	17.6	17.7	17.9	18.0	18.1	18.2	18.4	18.5	18.6	18.7	18.9	19.0	19.1
74.0	17.6	17.8	17.9	18.0	18.1	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1
73.5	17.7	17.8	17.9	18.0	18.2	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1
73.0	17.7	17.8	17.9	18.0	18.2	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1
72.5	17.7	17.8	17.9	18.1	18.2	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1
72.0	17.7	17.9	18.0	18.1	18.2	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1
71.5	17.7	17.9	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	19.0	19.1	19.2
71.0	17.7	17.9	18.0	18.1	18.2	18.4	18.5	18.6	18.7	18.9	19.0	19.1	19.2
70.5	17.8	17.9	18.0	18.1	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1	19.2
70.0	17.8	17.9	18.0	18.2	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1	19.2
69.5	17.8	17.9	18.0	18.2	18.3	18.4	18.5	18.7	18.8	18.9	19.0	19.2	19.3
69.0	17.8	17.9	18.1	18.2	18.3	18.4	18.6	18.7	18.8	18.9	19.0	19.2	19.3
68.5	17.8	18.0	18.1	18.2	18.3	18.4	18.6	18.7	18.8	18.9	19.1	19.2	19.3
68.0	17.8	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	19.0	19.1	19.2	19.3
67.5	17.9	18.0	18.1	18.2	18.4	18.5	18.6	18.7	18.8	19.0	19.1	19.2	19.3
67.0	17.9	18.0	18.1	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1	19.2	19.4
66.5	17.9	18.0	18.1	18.3	18.4	18.5	18.6	18.7	18.9	19.0	19.1	19.3	19.4
66.0	17.9	18.0	18.2	18.3	18.4	18.5	18.7	18.8	18.9	19.0	19.2	19.3	19.4
65.5	17.9	18.1	18.2	18.3	18.4	18.6	18.7	18.8	18.9	19.1	19.2	19.3	19.4
65.0	17.9	18.1	18.2	18.3	18.4	18.6	18.7	18.8	18.9	19.1	19.2	19.3	19.4
64.5	18.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	19.0	19.1	19.2	19.3	19.5
64.0	18.0	18.1	18.2	18.4	18.5	18.6	18.7	18.9	19.0	19.1	19.2	19.4	19.5
63.5	18.0	18.1	18.3	18.4	18.5	18.6	18.8	18.9	19.0	19.1	19.3	19.4	19.5
63.0	18.0	18.1	18.3	18.4	18.5	18.6	18.8	18.9	19.0	19.1	19.3	19.4	19.5
62.5	18.0	18.2	18.3	18.4	18.5	18.7	18.8	18.9	19.0	19.2	19.3	19.4	19.5
62.0	18.1	18.2	18.3	18.4	18.6	18.7	18.8	18.9	19.1	19.2	19.3	19.4	19.6
61.5	18.1	18.2	18.3	18.4	18.6	18.7	18.8	18.9	19.1	19.2	19.3	19.4	19.6
61.0	18.1	18.2	18.3	18.5	18.6	18.7	18.8	19.0	19.1	19.2	19.3	19.5	19.6
60.5	18.1	18.2	18.4	18.5	18.6	18.7	18.9	19.0	19.1	19.2	19.4	19.5	19.6
60.0	18.1	18.2	18.4	18.5	18.6	18.8	18.9	19.0	19.1	19.3	19.4	19.5	19.6

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG)= 6.07

AMBIENT BAROMETRIC PRESSURE IN CM HG

	122.0	122.5	123.0	123.5	124.0	124.5	125.0	125.5	126.0	126.5	127.0	127.5	128.0
A	18.4	18.6	18.7	18.8	18.9	19.1	19.2	19.3	19.5	19.6	19.7	19.8	19.9
B	18.5	18.7	18.8	18.9	19.0	19.1	19.2	19.3	19.5	19.6	19.7	19.8	19.9
C	18.6	18.8	18.9	19.0	19.1	19.2	19.3	19.4	19.6	19.7	19.8	19.9	20.0
D	18.7	18.9	19.0	19.1	19.2	19.3	19.4	19.5	19.7	19.8	19.9	20.0	20.1
E	18.8	19.0	19.1	19.2	19.3	19.4	19.5	19.6	19.8	19.9	20.0	20.1	20.2
F	18.9	19.1	19.2	19.3	19.4	19.5	19.6	19.7	19.9	20.0	20.1	20.2	20.3
G	19.0	19.2	19.3	19.4	19.5	19.6	19.7	19.8	20.0	20.1	20.2	20.3	20.4
H	19.1	19.3	19.4	19.5	19.6	19.7	19.8	19.9	20.1	20.2	20.3	20.4	20.5
I	19.2	19.4	19.5	19.6	19.7	19.8	19.9	20.0	20.2	20.3	20.4	20.5	20.6
J	19.3	19.5	19.6	19.7	19.8	19.9	20.0	20.1	20.3	20.4	20.5	20.6	20.7
K	19.4	19.6	19.7	19.8	19.9	20.0	20.1	20.2	20.4	20.5	20.6	20.7	20.8
L	19.5	19.7	19.8	19.9	20.0	20.1	20.2	20.3	20.5	20.6	20.7	20.8	20.9
M	19.6	19.8	19.9	20.0	20.1	20.2	20.3	20.4	20.6	20.7	20.8	20.9	21.0
N	19.7	19.9	20.0	20.1	20.2	20.3	20.4	20.5	20.7	20.8	20.9	21.0	21.1
O	19.8	20.0	20.1	20.2	20.3	20.4	20.5	20.6	20.8	20.9	21.0	21.1	21.2
P	19.9	20.1	20.2	20.3	20.4	20.5	20.6	20.7	20.9	21.0	21.1	21.2	21.3
Q	20.0	20.2	20.3	20.4	20.5	20.6	20.7	20.8	21.0	21.1	21.2	21.3	21.4
R	20.1	20.3	20.4	20.5	20.6	20.7	20.8	20.9	21.1	21.2	21.3	21.4	21.5
S	20.2	20.4	20.5	20.6	20.7	20.8	20.9	21.0	21.2	21.3	21.4	21.5	21.6
T	20.3	20.5	20.6	20.7	20.8	20.9	21.0	21.1	21.3	21.4	21.5	21.6	21.7
U	20.4	20.6	20.7	20.8	20.9	21.0	21.1	21.2	21.4	21.5	21.6	21.7	21.8
V	20.5	20.7	20.8	20.9	21.0	21.1	21.2	21.3	21.5	21.6	21.7	21.8	21.9
W	20.6	20.8	20.9	21.0	21.1	21.2	21.3	21.4	21.6	21.7	21.8	21.9	22.0
X	20.7	20.9	21.0	21.1	21.2	21.3	21.4	21.5	21.7	21.8	21.9	22.0	22.1
Y	20.8	21.0	21.1	21.2	21.3	21.4	21.5	21.6	21.8	21.9	22.0	22.1	22.2
Z	20.9	21.1	21.2	21.3	21.4	21.5	21.6	21.7	21.9	22.0	22.1	22.2	22.3
AA	21.0	21.2	21.3	21.4	21.5	21.6	21.7	21.8	22.0	22.1	22.2	22.3	22.4
AB	21.1	21.3	21.4	21.5	21.6	21.7	21.8	21.9	22.1	22.2	22.3	22.4	22.5
AC	21.2	21.4	21.5	21.6	21.7	21.8	21.9	22.0	22.2	22.3	22.4	22.5	22.6
AD	21.3	21.5	21.6	21.7	21.8	21.9	22.0	22.1	22.3	22.4	22.5	22.6	22.7
AE	21.4	21.6	21.7	21.8	21.9	22.0	22.1	22.2	22.4	22.5	22.6	22.7	22.8
AF	21.5	21.7	21.8	21.9	22.0	22.1	22.2	22.3	22.5	22.6	22.7	22.8	22.9
AG	21.6	21.8	21.9	22.0	22.1	22.2	22.3	22.4	22.6	22.7	22.8	22.9	23.0
AH	21.7	21.9	22.0	22.1	22.2	22.3	22.4	22.5	22.7	22.8	22.9	23.0	23.1
AI	21.8	22.0	22.1	22.2	22.3	22.4	22.5	22.6	22.8	22.9	23.0	23.1	23.2
AJ	21.9	22.1	22.2	22.3	22.4	22.5	22.6	22.7	22.9	23.0	23.1	23.2	23.3
AK	22.0	22.2	22.3	22.4	22.5	22.6	22.7	22.8	23.0	23.1	23.2	23.3	23.4
AL	22.1	22.3	22.4	22.5	22.6	22.7	22.8	22.9	23.1	23.2	23.3	23.4	23.5
AM	22.2	22.4	22.5	22.6	22.7	22.8	22.9	23.0	23.2	23.3	23.4	23.5	23.6
AN	22.3	22.5	22.6	22.7	22.8	22.9	23.0	23.1	23.3	23.4	23.5	23.6	23.7
AO	22.4	22.6	22.7	22.8	22.9	23.0	23.1	23.2	23.4	23.5	23.6	23.7	23.8
AP	22.5	22.7	22.8	22.9	23.0	23.1	23.2	23.3	23.5	23.6	23.7	23.8	23.9
AQ	22.6	22.8	22.9	23.0	23.1	23.2	23.3	23.4	23.6	23.7	23.8	23.9	24.0
AR	22.7	22.9	23.0	23.1	23.2	23.3	23.4	23.5	23.7	23.8	23.9	24.0	24.1
AS	22.8	23.0	23.1	23.2	23.3	23.4	23.5	23.6	23.8	23.9	24.0	24.1	24.2
AT	22.9	23.1	23.2	23.3	23.4	23.5	23.6	23.7	23.9	24.0	24.1	24.2	24.3
AU	23.0	23.2	23.3	23.4	23.5	23.6	23.7	23.8	24.0	24.1	24.2	24.3	24.4
AV	23.1	23.3	23.4	23.5	23.6	23.7	23.8	23.9	24.1	24.2	24.3	24.4	24.5
AW	23.2	23.4	23.5	23.6	23.7	23.8	23.9	24.0	24.2	24.3	24.4	24.5	24.6
AX	23.3	23.5	23.6	23.7	23.8	23.9	24.0	24.1	24.3	24.4	24.5	24.6	24.7
AY	23.4	23.6	23.7	23.8	23.9	24.0	24.1	24.2	24.4	24.5	24.6	24.7	24.8
AZ	23.5	23.7	23.8	23.9	24.0	24.1	24.2	24.3	24.5	24.6	24.7	24.8	24.9
BA	23.6	23.8	23.9	24.0	24.1	24.2	24.3	24.4	24.6	24.7	24.8	24.9	25.0
BB	23.7	23.9	24.0	24.1	24.2	24.3	24.4	24.5	24.7	24.8	24.9	25.0	25.1
BC	23.8	24.0	24.1	24.2	24.3	24.4	24.5	24.6	24.8	24.9	25.0	25.1	25.2
BD	23.9	24.1	24.2	24.3	24.4	24.5	24.6	24.7	24.9	25.0	25.1	25.2	25.3
BE	24.0	24.2	24.3	24.4	24.5	24.6	24.7	24.8	25.0	25.1	25.2	25.3	25.4
BF	24.1	24.3	24.4	24.5	24.6	24.7	24.8	24.9	25.1	25.2	25.3	25.4	25.5
BG	24.2	24.4	24.5	24.6	24.7	24.8	24.9	25.0	25.2	25.3	25.4	25.5	25.6
BH	24.3	24.5	24.6	24.7	24.8	24.9	25.0	25.1	25.3	25.4	25.5	25.6	25.7
BI	24.4	24.6	24.7	24.8	24.9	25.0	25.1	25.2	25.4	25.5	25.6	25.7	25.8
BJ	24.5	24.7	24.8	24.9	25.0	25.1	25.2	25.3	25.5	25.6	25.7	25.8	25.9
BK	24.6	24.8	24.9	25.0	25.1	25.2	25.3	25.4	25.6	25.7	25.8	25.9	26.0
BL	24.7	24.9	25.0	25.1	25.2	25.3	25.4	25.5	25.7	25.8	25.9	26.0	26.1
BM	24.8	25.0	25.1	25.2	25.3	25.4	25.5	25.6	25.8	25.9	26.0	26.1	26.2
BN	24.9	25.1	25.2	25.3	25.4	25.5	25.6	25.7	25.9	26.0	26.1	26.2	26.3
BO	25.0	25.2	25.3	25.4	25.5	25.6	25.7	25.8	26.0	26.1	26.2	26.3	26.4
BP	25.1	25.3	25.4	25.5	25.6	25.7	25.8	25.9	26.1	26.2	26.3	26.4	26.5
BQ	25.2	25.4	25.5	25.6	25.7	25.8	25.9	26.0	26.2	26.3	26.4	26.5	26.6
BR	25.3	25.5	25.6	25.7	25.8	25.9	26.0	26.1	26.3	26.4	26.5	26.6	26.7
BS	25.4	25.6	25.7	25.8	25.9	26.0	26.1	26.2	26.4	26.5	26.6	26.7	26.8
BT	25.5	25.7	25.8	25.9	26.0	26.1	26.2	26.3	26.5	26.6	26.7	26.8	26.9
BU	25.6	25.8	25.9	26.0	26.1	26.2	26.3	26.4	26.6	26.7	26.8	26.9	27.0
BV	25.7	25.9	26.0	26.1	26.2	26.3	26.4	26.5	26.7	26.8	26.9	27.0	27.1
BW	25.8	26.0	26.1	26.2	26.3	26.4	26.5	26.6	26.8	26.9	27.0	27.1	27.2
BX	25.9	26.1	26.2	26.3	26.4	26.5	26.6	26.7	26.9	27.0	27.1	27.2	27.3
BY	26.0	26.2	26.3	26.4	26.5	26.6	26.7	26.8	27.0	27.1	27.2	27.3	27.4
BZ	26.1	26.3	26.4	26.5	26.6	26.7	26.8	26.9	27.1	27.2	27.3	27.4	27.5
CA	26.2	26.4	26.5	26.6	26.7	26.8	26.9	27.0	27.2	27.3	27.4	27.5	27.6
CB	26.3	26.5	26.6	26.7	26.8	26.9	27.0	27.1	27.3	27.4	27.5	27.6	27.7
CC	26.4	26.6	26.7	26.8	26.9	27.0	27.1	27.2	27.4	27.5	27.6	27.7	27.8
CD	26.5	26.7	26.8	26.9	27.0	27.1	27.2	27.3	27.5	27.6	27.7	27.8	27.9
CE	26.6	26.8	26.9	27.0	27.1	27.2	27.3	27.4	27.6	27.7	27.8	27.9	28.0
CF	26.7	26.9	27.0	27.1	27.2	27.3	27.4	27.5	27.7	27.8	27.9	28.0	28.1
CG	26.8	27.0	27.1	27.2	27.3	27.4	27.5	27.6	27.8	27.9	28.0	28.1	28.2
CH	26.9	27.1	27.2	27.3	27.4	27.5	27.6	27.7	27.9	28.0	28.1	28.2	28.3
CI	27.0	27.2	27.3	27.4	27.5	27.6	27.7	27.8	28.0	28.1	28.2	28.3	28.4
CJ	27.1	27.3	27.4	27.5	27.6	27.7	27.8	27.9	28.1	28.2	28.3	28.4	28.5
CK	27.2	27.4	27.5	27.6	27.7	27.8	27.9	28.0	28.2	28.3	28.4	28.5	28.6
CL	27.3	27.5	27.6	27.7	27.8	27.9	28.0	28.1	28.3	28.4	28.5	28.6	28.7
CM	27.4	27.6	27.7	27.8	27.9	28.0	28.1	28.2	28.4	28.5	28.6	28.7	28.8
CN	27.5	27.7	27.8	27.9	28.0	28.1	28.2	28.3	28.5	28.6	28.7	28.8	28.9
CO	27.6	27.8	27.9	28.0	28.1	28.2	28.3	28.4	28.6	28.7	28.8	28.9	29.0
CP	27.7	27.9	28.0	28.1	28.2	28.3	28.4	28.5	28.7				

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 6.16

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	80.0	19.4	19.6	19.7	19.8	20.0	20.1	20.2	20.4	20.5	20.6	20.9	21.1
M	79.5	19.5	19.6	19.7	19.9	20.0	20.1	20.3	20.4	20.5	20.6	20.9	21.1
H	79.0	19.5	19.6	19.9	20.0	20.2	20.3	20.4	20.6	20.7	20.8	21.0	21.1
I	78.5	19.5	19.6	19.9	20.0	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.1
E	78.0	19.5	19.6	19.9	20.0	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.2
N	77.5	19.5	19.7	19.8	20.0	20.1	20.2	20.4	20.5	20.6	20.9	21.0	21.2
T	77.0	19.5	19.7	19.8	20.0	20.1	20.2	20.4	20.5	20.6	20.9	21.0	21.2
M	76.5	19.6	19.7	19.8	20.0	20.1	20.3	20.4	20.5	20.6	20.9	21.1	21.2
I	76.0	19.6	19.7	19.9	20.0	20.1	20.3	20.4	20.7	20.8	20.9	21.1	21.2
E	75.5	19.6	19.7	19.9	20.0	20.1	20.3	20.4	20.6	20.7	20.8	21.0	21.2
N	75.0	19.6	19.8	19.9	20.0	20.2	20.3	20.4	20.6	20.7	20.8	21.0	21.3
T	74.5	19.6	19.8	19.9	20.0	20.2	20.3	20.5	20.6	20.7	20.9	21.1	21.3
I	74.0	19.7	19.8	19.9	20.1	20.2	20.3	20.5	20.6	20.7	20.9	21.2	21.3
E	73.5	19.7	19.8	19.9	20.1	20.2	20.4	20.5	20.6	20.8	20.9	21.2	21.3
M	73.0	19.7	19.8	20.0	20.1	20.3	20.4	20.5	20.6	20.8	20.9	21.1	21.4
P	72.5	19.7	19.8	20.0	20.1	20.3	20.4	20.5	20.7	20.8	21.0	21.1	21.4
E	72.0	19.7	19.9	20.0	20.2	20.3	20.4	20.6	20.7	20.8	21.0	21.1	21.4
R	71.5	19.7	19.9	20.0	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.1	21.4
A	71.0	19.8	19.9	20.0	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.1	21.4
U	70.5	19.8	19.9	20.1	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.1	21.4
R	70.0	19.8	20.0	20.1	20.2	20.4	20.5	20.6	20.8	20.9	21.0	21.1	21.4
E	69.5	19.8	20.0	20.1	20.3	20.4	20.5	20.7	20.8	20.9	21.1	21.2	21.5
E	69.0	19.8	20.0	20.1	20.3	20.4	20.5	20.7	20.8	21.0	21.1	21.2	21.5
I	68.5	19.9	20.0	20.1	20.3	20.4	20.5	20.7	20.8	21.0	21.1	21.2	21.5
I	68.0	19.9	20.0	20.2	20.3	20.4	20.6	20.7	20.8	21.0	21.1	21.2	21.5
M	67.5	19.9	20.0	20.2	20.3	20.4	20.6	20.7	20.9	21.0	21.1	21.2	21.5
D	67.0	19.9	20.1	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.1	21.2	21.5
E	66.5	19.9	20.1	20.2	20.3	20.5	20.6	20.8	20.9	21.0	21.2	21.3	21.6
G	66.0	20.0	20.1	20.2	20.4	20.5	20.6	20.8	20.9	21.1	21.2	21.3	21.6
C	65.5	20.0	20.1	20.3	20.4	20.5	20.7	20.8	21.0	21.1	21.2	21.4	21.6
F	65.0	20.0	20.1	20.3	20.4	20.5	20.7	20.8	21.0	21.1	21.2	21.4	21.6
	64.5	20.0	20.1	20.3	20.4	20.6	20.7	20.9	21.0	21.1	21.3	21.4	21.6
	64.0	20.0	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.1	21.3	21.4	21.6
	63.5	20.0	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.2	21.3	21.4	21.6
	63.0	20.1	20.2	20.3	20.5	20.6	20.8	20.9	21.1	21.2	21.3	21.5	21.7
	62.5	20.1	20.2	20.4	20.5	20.6	20.8	20.9	21.1	21.2	21.3	21.5	21.7
	62.0	20.1	20.2	20.4	20.5	20.7	20.8	20.9	21.1	21.2	21.3	21.5	21.7
	61.5	20.1	20.3	20.4	20.5	20.7	20.8	21.0	21.1	21.2	21.3	21.5	21.7
	61.0	20.1	20.3	20.4	20.6	20.7	20.8	21.0	21.1	21.3	21.4	21.5	21.7
	60.5	20.2	20.3	20.4	20.6	20.7	20.9	21.0	21.1	21.3	21.4	21.6	21.8
	60.0	20.2	20.3	20.5	20.6	20.7	20.9	21.0	21.2	21.3	21.4	21.6	21.9

--APPENDIX A--
(Attachment A-1)

AEROSOL GENERATOR PRESSURE (PSIG) = 6.25

AMBIENT BAROMETRIC PRESSURE IN CM HG

	72.0	72.5	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0	77.5	78.0
A	80.0	20.5	20.6	20.9	21.0	21.2	21.3	21.5	21.6	21.7	21.9	22.0	22.2
M	79.5	20.5	20.6	20.9	21.1	21.2	21.3	21.5	21.6	21.8	21.9	22.1	22.2
B	79.0	20.5	20.7	20.8	21.1	21.2	21.4	21.5	21.7	21.8	21.9	22.1	22.2
I	78.5	20.5	20.7	20.8	21.0	21.1	21.2	21.5	21.7	21.8	22.0	22.1	22.2
T	78.0	20.5	20.7	20.8	21.0	21.1	21.3	21.4	21.5	21.7	22.0	22.1	22.3
N	77.5	20.6	20.7	20.8	21.0	21.1	21.4	21.6	21.7	21.8	22.0	22.1	22.3
D	77.0	20.6	20.7	20.9	21.0	21.2	21.3	21.6	21.7	21.9	22.0	22.2	22.3
E	76.5	20.6	20.7	20.9	21.0	21.2	21.3	21.5	21.6	21.9	22.1	22.2	22.3
N	76.0	20.6	20.8	20.9	21.1	21.2	21.4	21.5	21.6	21.9	22.1	22.2	22.4
T	75.5	20.7	20.8	20.9	21.1	21.3	21.5	21.7	21.8	22.0	22.1	22.2	22.4
E	75.0	20.7	20.8	21.0	21.1	21.3	21.6	21.7	21.8	22.0	22.1	22.3	22.4
M	74.5	20.7	20.8	21.0	21.1	21.3	21.6	21.7	21.8	22.0	22.1	22.3	22.4
T	74.0	20.7	20.8	21.0	21.1	21.3	21.6	21.7	21.8	22.0	22.1	22.3	22.4
E	73.5	20.7	20.9	21.0	21.1	21.3	21.6	21.7	21.8	22.0	22.1	22.3	22.4
M	73.0	20.7	20.9	21.0	21.1	21.3	21.6	21.7	21.8	22.0	22.1	22.3	22.4
P	72.5	20.8	20.9	21.0	21.2	21.3	21.6	21.7	21.8	22.0	22.1	22.3	22.5
E	72.0	20.8	20.9	21.1	21.2	21.4	21.7	21.8	22.0	22.1	22.2	22.4	22.5
R	71.5	20.8	20.9	21.1	21.2	21.4	21.7	21.8	22.0	22.1	22.2	22.4	22.5
A	71.0	20.8	21.0	21.1	21.2	21.5	21.7	21.8	22.0	22.1	22.3	22.4	22.5
T	70.5	20.8	21.0	21.1	21.3	21.4	21.6	21.7	21.8	22.0	22.1	22.3	22.6
U	70.0	20.9	21.0	21.1	21.3	21.6	21.7	21.9	22.0	22.2	22.3	22.4	22.6
R	69.5	20.9	21.0	21.3	21.5	21.6	21.7	21.9	22.0	22.2	22.3	22.5	22.6
E	69.0	20.9	21.0	21.3	21.5	21.6	21.8	21.9	22.1	22.2	22.3	22.5	22.6
F	68.5	20.9	21.1	21.2	21.5	21.6	21.8	22.0	22.1	22.2	22.4	22.5	22.7
I	68.0	20.9	21.1	21.2	21.5	21.7	21.8	22.0	22.1	22.3	22.4	22.6	22.7
N	67.5	21.0	21.1	21.3	21.6	21.7	21.8	22.0	22.1	22.3	22.4	22.6	22.7
D	67.0	21.0	21.1	21.3	21.6	21.7	21.8	22.0	22.1	22.3	22.5	22.6	22.7
E	66.5	21.0	21.2	21.3	21.6	21.7	21.9	22.0	22.2	22.3	22.5	22.6	22.8
G	66.0	21.0	21.2	21.3	21.6	21.8	21.9	22.1	22.2	22.3	22.5	22.6	22.8
E	65.5	21.1	21.2	21.4	21.6	21.8	22.0	22.1	22.2	22.4	22.5	22.7	22.8
G	65.0	21.1	21.2	21.4	21.7	21.8	22.0	22.1	22.2	22.4	22.5	22.7	22.8
F	64.5	21.1	21.2	21.4	21.7	21.8	22.0	22.1	22.2	22.4	22.5	22.7	22.9
	64.0	21.1	21.2	21.4	21.7	21.8	22.0	22.1	22.2	22.4	22.5	22.7	22.9
	63.5	21.1	21.3	21.4	21.7	21.9	22.0	22.2	22.3	22.5	22.6	22.7	22.9
	63.0	21.1	21.3	21.4	21.7	21.9	22.0	22.2	22.3	22.5	22.6	22.9	22.9
	62.5	21.2	21.3	21.5	21.8	21.9	22.1	22.2	22.3	22.5	22.6	22.9	23.0
	62.0	21.2	21.3	21.6	21.8	21.9	22.1	22.2	22.3	22.5	22.7	22.8	23.0
	61.5	21.2	21.3	21.6	21.8	21.9	22.1	22.2	22.4	22.5	22.7	22.8	23.0
	61.0	21.2	21.4	21.7	21.8	22.0	22.1	22.2	22.4	22.5	22.7	22.8	23.0
	60.5	21.2	21.4	21.7	21.8	22.0	22.1	22.2	22.4	22.5	22.7	22.9	23.0
	60.0	21.3	21.4	21.7	21.8	22.0	22.1	22.3	22.4	22.6	22.7	22.9	23.0

--APPENDIX A--

ATTACHMENT A-2:

Fortran Computer Program Listing
Used To Generate Table A-1

--APPENDIX A--
(Attachment A-2)

FORTTRAN COMPUTER PROGRAM LISTING
USED TO GENERATE TABLE A-1

C THIS PROGRAM PRODUCES A TABLE FOR USE IN THE USAFSAM DEHP RQFT
C INSTRUMENT CALIBRATION PROCEDURE (DYNATECH FRONTIER CORP. MODEL
C FE259H).
C
C

```

DIMENSION QT(40),DELTA P(41,13),T1(42),P(13)
REAL MG
INTEGER TEMP,PRESS
BYTE WORD(41)
OPEN (UNIT=1,DISPOSE='SAVE',TYPE='NEW',NAME='TABLE.DAT')
  WORD(6)='A'
  WORD(7)='M'
  WORD(8)='B'
  WORD(9)='I'
  WORD(10)='E'
  WORD(11)='N'
  WORD(12)='T'
  WORD(13)=' '
  WORD(14)='T'
  WORD(15)='E'
  WORD(16)='M'
  WORD(17)='P'
  WORD(18)='E'
  WORD(19)='R'
  WORD(20)='A'
  WORD(21)='T'
  WORD(22)='U'
  WORD(23)='R'
  WORD(24)='E'
  WORD(25)=' '
  WORD(26)='I'
  WORD(27)='N'
  WORD(28)=' '
  WORD(29)='D'
  WORD(30)='E'
  WORD(31)='G'
  WORD(32)=' '
  WORD(33)='F'
DO 15 I2=1,5
15 WORD(I2)=' '
DO 17 I3=34,41
17 WORD(I3)=' '

```

C
C THE FOLLOWING SET OF VARIABLES ARE UNIQUE INSTRUMENTAL
C CALIBRATION CONSTANTS SUPPLIED BY THE MANUFACTURER:
A0=(-23.9)
A1=9.26
B0=17.2
B1=2.72
K=119.0

C
C
C QT(I)=THE TOTAL SYSTEM VOLUMETRIC AEROSOL FLOW RATE
C (LITERS/MIN OR CFM X 28.32). RANGE OF QT(I) IS
C 3-40 CFM.

--APPENDIX A--
(Attachment A-2)

```

C
C C= 30 MICROGRAM/LITER = CHAMBER CONCENTRATION OF
C DEHP (MICROGRAM/LITER)
C   C=30.
C
C MG=C/1000 X QT(I)=AEROSOL GENERATOR MASS FLOW RATE
C
C
C T(1)=INITIAL TEMPERATURE IN FAHRENHEIT
C   T1(1)=80.
C
C   WRITE(1,5)
C   5 FORMAT ('1',T31,'TABLE1. AEROSOL GENERATOR AIR PRESSURE VERSUS '
C     *,'AEROSOL DILUTION AIR'/T31,'DIFFERENTIAL PRESSURE (MAGNEHELIC GUA
C     *GE SETTING) FOR VARIOUS AMBIENT'/T46,'TEMPERATURES AND BAROMETRIC
C     * PRESSURES')
C
C
C   DO 10 I=3,40
C   P(PRESS)=72.=INITIAL AMBIENT BAROMETRIC PRESSURE (CM HG)
C     P(1)=72.
C     QT(I)=I*28.32
C     MG=C/1000*QT(I)
C   PG=(MG-A0)/A1=AEROSOL GENERATOR PRESSURE (PSIG)
C     PG=(MG-A0)/A1
C   QG=B1 X PG + B0=VOLUMETRIC AEROSOL GENERATOR FLOW RATE (LITERS/MIN)
C     QG=B1*PG+B0
C   QD=QT(I)-QG = VOLUMETRIC AEROSOL GENERATOR FLOW RATE (LITERS/MIN)
C     QD=QT(I)-QG
C
C PRINT TABLE HEADINGS
C   WRITE (1,25) PG
C   25 FORMAT ('0',T47,'AEROSOL GENERATOR PRESSURE (PSIG)=' ,F5.2//
C     *T48,'AMBIENT BAROMETRIC PRESSURE IN CM HG'///)
C
C CALCULATE DELTA P
C   DO 20 PRESS=1,13
C   DO 30 TEMP=1,41
C CHANGE FROM FAHRENHEIT TO KELVIN
C   T=(T1(TEMP)-32.)*(5./9.)+273.15
C   DELTA P(TEMP,PRESS)=(QD/K)**2*(P(PRESS)/T)
C   30 T1(TEMP+1)=T1(TEMP)-0.5
C   20 P(PRESS+1)=P(PRESS)+0.5
C PRINT TABLE COLUMNS
C   WRITE (1,35) (P(PRESS),PRESS=1,13)
C   35 FORMAT (' ',T15,' ',T17,F4.1,12(5X,F4.1))
C   WRITE (1,36)
C   36 FORMAT (' ',T9,'-----')
C   *-----')
C PRINT TABLE VALUES
C   DO 40 TEMP=1,41
C   WRITE (1,45) WORD(TEMP),T1(TEMP)
C   *,(DELTA P(TEMP,PRESS),PRESS=1,13)
C   45 FORMAT (' ',T6,A1,T9,F4.1,T15,' ',T17,12(F4.1,5X),F4.1)

```

--APPENDIX A--
(Attachment A-2)

```
40 CONTINUE
   WRITE (1,36)
   WRITE (1,47)
47 FORMAT('1')
C
C
C ANOTHER AEROSOL GENERATOR PRESSURE SETTING ( ANOTHER PAGE PRINTED)
10 CONTINUE
   CLOSE (UNIT=1)
   STOP
   END
```

APPENDIX B:

DEHPRQFT.FOR Fortran Listing

--APPENDIX B--

DEHPRQFT.FOR Fortran Listing

C
C THIS PROGRAM CALCULATES PROTECTION FACTORS FOR DATA COLLECTED ON
C THE USAFSAM/VNL DI-2-ETHYLHEXYL PHTHALATE (DEHP) RESPIRATOR
C QUANTITATIVE FIT TEST (RQFT) INSTRUMENT.

C THE CALCULATION OF A RESPIRATOR'S PROTECTION FACTOR (PF) IS
C ACCOMPLISHED USING THE FOLLOWING RELATIONSHIP:

C
$$PF = (CC) / (RL)$$

C WHERE,

C PF=PROTECTION FACTOR

C CC=AVERAGE CORRECTED CHAMBER CHALLENGE CONCENTRATION

C RL=AVERAGE CORRECTED RESPIRATOR LEAKAGE CONCENTRATION FOR A
C PARTICULAR EXERCISE

C THE AVERAGE CORRECTED CHAMBER CHALLENGE CONCENTRATION (CC) IS
C GIVEN BY:

C
$$CC = [(CI + CF)(KCC) / 2 - (BI + BF)(KBC) / 2]$$

C OR EQUIVALENTLY (SINCE THERE IS A ONE-TO-ONE CORRESPONDENCE
C BETWEEN THE SCATTERED LIGHT PHOTOMETER'S OUTPUT VOLTAGE AND THE
C CONCENTRATION OF DEHP),

C
$$CC = [(VCI + VCF)(KCC) / 2 - (VBI + VBF)(KBC) / 2]$$

C WHERE,

C CI=AVERAGE INITIAL CHAMBER CHALLENGE CONCENTRATION (MEASURED
C AFTER THE SUBJECT ENTERS THE CHAMBER AND JUST PRIOR TO
C INITIATING THE FIRST EXERCISE)

C CF=AVERAGE FINAL CHAMBER CHALLENGE CONCENTRATION (MEASURED
C AFTER ALL EXERCISES HAVE BEEN COMPLETED AND JUST PRIOR TO
C THE SUBJECT'S EXIT FROM THE CHAMBER)

C KCC=INSTRUMENT'S SAMPLING RANGE SWITCH POSITION (TYPICALLY
C 100 PERCENT)

C BI=AVERAGE INITIAL BASELINE CONCENTRATION (MEASURED AFTER
C THE SUBJECT ENTERS THE CHAMBER AND JUST PRIOR TO
C INITIATING THE FIRST EXERCISE)

C BF=AVERAGE FINAL BASELINE CONCENTRATION (MEASURED AFTER ALL
C EXERCISES HAVE BEEN COMPLETED AND JUST PRIOR TO THE
C SUBJECT'S EXIT FROM THE CHAMBER)

C KBC=INSTRUMENT'S SAMPLING RANGE SWITCH POSITION (TYPICALLY
C 10.0 - 0.01 PERCENT)

C VCI=AVERAGE INITIAL VOLTAGE RESPONSE OF THE SCATTERED LIGHT
C PHOTOMETER (CORRESPONDS TO THE VALUE FOR CI)

PRECEDING PAGE BLANK-NOT FILLED

--APPENDIX B--

```

C
C
C      VCF=AVERAGE FINAL VOLTAGE RESPONSE OF THE SCATTERED LIGHT
C      PHOTOMETER (CORRESPONDS TO THE VALUE FOR CF)
C
C      VBI=AVERAGE INITIAL VOLTAGE RESPONSE OF THE SCATTERED LIGHT
C      PHOTOMETER (CORRESPONDS TO THE VALUE OF BI)
C
C      VBF=AVERAGE FINAL VOLTAGE RESPONSE OF THE SCATTERED LIGHT
C      PHOTOMETER (CORRESPONDS TO THE VALUE OF BF)
C
C      THE AVERAGE CORRECTED RESPIRATOR LEAKAGE CONCENTRATION (RL) IS
C      GIVEN BY:
C
C       $RL = [(RE)(KE) - (BI+BF)(KBC)/2]$ 
C
C      OR EQUIVALENTLY (SINCE THERE IS A ONE-TO-ONE CORRESPONDENCE
C      BETWEEN THE SCATTERED LIGHT PHOTOMETER'S OUTPUT VOLTAGE AND THE
C      CONCENTRATION OF DEHP),
C
C       $RL = [(ASLPVO)(KE) - (VBI+VBF)(KBC)/2]$ 
C
C      WHERE,
C
C      RE=AVERAGE RESPIRATOR LEAKAGE CONCENTRATION FOR A PARTICULAR
C      EXERCISE
C
C      KE=INSTRUMENT'S SAMPLING RANGE SWITCH POSITION USED DURING
C      THE EXERCISE MEASUREMENT TIME PERIOD (TYPICALLY 10 - 0.01
C      PERCENT)
C
C      ASLPVO=AVERAGE SCATTERED LIGHT PHOTOMETER VOLTAGE OUTPUT
C      FOR A PARTICULAR EXERCISE (CORRESPONDS TO THE VALUE
C      OF RE)
C
C*****
C***** IF YOU HAVE ANY QUESTIONS CONCERNING THIS PROGRAM CALL *****
C***** CAPTAIN EDWARD S. KOLESAR, JR. *****
C***** USAFSAM/VNL   BROOKS AFB TX *****
C***** AUTOVON 240-2154 OR COMMERCIAL (512)536-2154 *****
C*****
C*****
C
C      IMPLICIT INTEGER*4 (I-N)
C      INTEGER FILTK
C      REAL KBC,KCC
C      DIMENSION ICCBS(2),IC(20),ICTP(20),SRSP(20),PF(20),RL(20),XC(20)
C      BYTE SECN(9),P(10),C(10),NAME(45),MASK(45),DATE(45),TIME(45)
C      BYTE GROUP 1,GROUP 2,YES,NO,REP,SELECT(7)
C      DATA SECN/'1','2','3','4','5','6','7','8','9'/
C      YES='Y'
C      NO='N'

```

--APPENDIX B--

```

C
C   ICCBS(*) AND 4137 FORMAT ELEMENTS ARE USED IN A CRT
C   SCREEN CLEARING ALGORITHM
C
C   ICCBS(1)=72*256+27
C   ICCBS(2)=74*256+27
4137 FORMAT(1H ,2A2)
C
C   ESTABLISH A FILE COUNTER AND DECLARE THE FILE NAMES
C
5101 FILTK=1
C
C   THE FILE CALLED DATX.XXX CONTAINS THE RQFT DESCRIPTIVE
C   INFORMATION, DEHP CALIBRATION DATA, AND EXERCISE INTEGRATOR
C   COUNT DATA
C
C   THE FILE CALLED CALCX.XXX CONTAINS THE RQFT DESCRIPTIVE
C   INFORMATION, THE EXERCISE PF CALCULATIONS, AND ARITHMETIC
C   AVERAGE AND TIME-WEIGHTED AVERAGE PF CALCULATIONS
C
C   THE FILES ARE NUMBERED SEQUENTIALLY SO THAT THEY CAN BE EASILY
C   RETRIEVED FOR PRINTING AND ANALYSIS
C
C   THE FILES THAT HOLD VARIOUS SEGMENTS OF DATA ARE NAMED
C
C   P(1)='D'
C   P(2)='A'
C   P(3)='T'
C   P(4)='A'
C   P(5)=SECN(FILTK)
C   P(6)='.'
C   P(10)=0
C   C(1)='C'
C   C(2)='A'
C   C(3)='L'
C   C(4)='C'
C   C(5)=SECN(FILTK)
C   C(6)='.'
C   C(10)=0
C   TYPE 2006
2006 FORMAT(1X,' '////)
C   TYPE 4137,ICCBS(1),ICCBS(2)
C   TYPE 2006
C   GO TO 3081
C
C   IF MORE THAN ONE SET OF RQFT DATA IS TO BE PROCESSED
C   DURING A COMPUTER RUN, THE FILE COUNTER IS AUTOMATICALLY
C   INCREMENTED TO FACILITATE KEEPING TRACK OF THE DATX.XXX
C   AND CALCX.XXX FILES
C
6000 FILTK=FILTK+1
C   P(5)=SECN(FILTK)
C   C(5)=SECN(FILTK)
C   TYPE 2006
C   TYPE 4137,ICCBS(1),ICCBS(2)
C   TYPE 2006
3081 CONTINUE

```

--APPENDIX B--

```

      TYPE 2002
2002 FORMAT(1X,'USER ATTENTION:  IN ORDER TO KEEP TRACK OF THE  '/'
      C' DATA FILES (DATA*.XXX) BEING ANALYZED,  IT IS RECOMMENDED  '/'
      C' THAT THEY BE SEQUENTIALLY NUMBERED.'/)
      TYPE 306
306  FORMAT(1X,' '/')
      TYPE 2003
2003 FORMAT(1X,'ENTER THE FOLLOWING:  001 FOR THE FIRST DATA  '/'
      C' FILE;  002 FOR THE SECOND DATA FILE;  003 FOR THE THIRD '/'
      C' DATA FILE;  ETC.'/)
      TYPE 306
      TYPE 2004
2004 FORMAT(1X,'ENTRY= ',S)
      ACCEPT 2005,P(7),P(8),P(9)
2005 FORMAT(3A1)
      TYPE 2006
      TYPE 4137,ICCBS(1),ICCBS(2)
      TYPE 2006
      TYPE 5100
5100 FORMAT(1X,'USER ATTENTION:  IN ORDER TO KEEP TRACK OF THE '/'
      C' CALCULATION FILES (CALCX*.XXX),  IT IS RECOMMENDED THAT  '/'
      C' THEY BE SEQUENTIALLY NUMBERED.'/)
      TYPE 306
      TYPE 5200
5200 FORMAT(1X,'ENTER THE FOLLOWING:  001 FOR THE FIRST  '/'
      C' CALCULATION FILE;  002 FOR THE SECOND CALCULATION FILE;  '/'
      C' 003 FOR THE THIRD CALCULATION FILE;  ETC.'/)
      TYPE 306
      TYPE 2004
      ACCEPT 2005,C(7),C(8),C(9)
      TYPE 2006
      TYPE 4137,ICCBS(1),ICCBS(2)
      TYPE 2006
      OPEN(UNIT=2,NAME=B,DISPOSE='SAVE',TYPE='NEW')
      OPEN(UNIT=3,NAME=C,DISPOSE='SAVE',TYPE='NEW')
C
C      THE RQFT DATA TO BE PROCESSED IS NOW ENTERED
C
C      ENTER THE DESCRIPTIVE INFORMATION CONCERNING THE SUBJECT,
C      RESPIRATOR TYPE, DATE, AND TIME TESTED
C
      TYPE 2006
      TYPE 4137,ICCBS(1),ICCBS(2)
      TYPE 2006
      TYPE 5300
5300 FORMAT(1X,'DEHP RQFT DATA:  '/')
      TYPE 2006
      TYPE 3065
3065 FORMAT(1X,'SUBJECT NAME:  ',2X,S)
      ACCEPT 3086,NAME
3086 FORMAT(45A1)
      TYPE 3087
3087 FORMAT(1X,'TYPE OF RESPIRATOR:  ',2X,S)
      ACCEPT 3086,MASK
      TYPE 3088
3088 FORMAT(1X,'DATE TESTED:  ',2X,S)
      ACCEPT 3086,DATE

```

--APPENDIX B--

```

3089 TYPE 3089
    FORMAT(1X,'TIME TESTED: ',2X,S)
    ACCEPT 3086,TIME
    TYPE 2006
C
C   THE DEHP RQFT CALIBRATION DATA IS ENTERED
C
C   THIS INFORMATION IS AVAILABLE FROM THE DATA SHEET USED
C   DURING AN RQFT
C
    TYPE 2006
    TYPE 4137,ICCBS(1),ICCBS(2)
    TYPE 2006
    TYPE 99
99  FORMAT(1X,'DEPRESS THE RETURN KEY AFTER ENTERING A'/
C' SWITCH POSITION AND VOLTAGE'////////)
    TYPE 2006
    TYPE 40
40  FORMAT(1X,'DEHP RQFT CALIBRATION DATA: '///)
    TYPE 41
41  FORMAT(1X,'CALIBRATION PARAMETER',17X,'SAMPLING RANGE',8X,'AVERAGE
C')
    TYPE 42
42  FORMAT(1X,38X,'SWITCH POSITION',7X,'VOLTAGE')
    TYPE 43
43  FORMAT(1X,39X,'(IN PERCENT)',8X,'(IN VOLTS)')
    TYPE 44
44  FORMAT(1X,'AVERAGE INITIAL VOLTAGE')
    TYPE 45
45  FORMAT(1X,'ASSOCIATED WITH THE MAXIMUM')
    TYPE 46
46  FORMAT(1X,'CHAMBER CHALLENGE CONCENTRATION',S)
    ACCEPT 64,KCC
    CALL CLEAR(LINES)
    TYPE 47,KCC
47  FORMAT(1H+,'CHAMBER CHALLENGE CONCENTRATION',T44,F6.2,T63,1H,S)
    ACCEPT 48,VCI
48  FORMAT(1F6.3)
    TYPE 306
    TYPE 49
49  FORMAT(1X,'AVERAGE INITIAL VOLTAGE')
    TYPE 50
50  FORMAT(1X,'ASSOCIATED WITH THE BASELINE')
    TYPE 51
51  FORMAT(1X,'OF THE DEHP RQFT INSTRUMENT',S)
    ACCEPT 64,KBC
    CALL CLEAR(LINES)
    TYPE 52,KBC
52  FORMAT(1H+,'OF THE DEHP RQFT INSTRUMENT',T44,F6.2,T63,1H,S)
    ACCEPT 48,VBI
    TYPE 306
    TYPE 53
53  FORMAT(1X,'AVERAGE FINAL VOLTAGE')
    TYPE 50
    TYPE 51
    ACCEPT 64,KBC
    CALL CLEAR(LINES)

```

--APPENDIX B--

```

TYPE 52,KBC
ACCEPT 48,VBF
TYPE 306
TYPE 53
TYPE 45
TYPE 46
ACCEPT 64,KCC
CALL CLEAR(LINES)
TYPE 47,KCC
ACCEPT 48,VCF
TYPE 2006
TYPE 4137,ICCBS(1),ICCBS(2)
TYPE 2006
C
C   SELECT THE PROPER EXERCISE PROTOCOL
C
TYPE 3127
3127 FORMAT(1X,'THE USER IS FREE TO SELECT ONE OF TWO GROUPS OF'/
C' EXERCISE PROTOCOLS'//)
TYPE 3128
3128 FORMAT(1X,'THE [GROUP 1] EXERCISE PROTOCOL CONSISTS OF:'//
C' [1] NORMAL BREATHING STRAIGHT AHEAD'//
C' [2] DEEP BREATHING STRAIGHT AHEAD'//
C' [3] TALKING'//
C' [4] SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING)'//
C' [5] UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)'//
C' [6] FACIAL GRIMACING'//)
TYPE 2006
TYPE 4137,ICCBS(1),ICCBS(2)
TYPE 2006
TYPE 3129
3129 FORMAT(1X,'THE [GROUP 2] EXERCISE PROTOCOL CONSISTS OF:'//
C' [1] NORMAL BREATHING STRAIGHT AHEAD'//
C' [2] NORMAL BREATHING LEFT'//
C' [3] NORMAL BREATHING RIGHT'//
C' [4] NORMAL BREATHING DOWN'//
C' [5] NORMAL BREATHING UP'//
C' [6] DEEP BREATHING STRAIGHT AHEAD'//
C' [7] DEEP BREATHING LEFT'//
C' [8] DEEP BREATHING RIGHT'//
TYPE 3130
3130 FORMAT(1X,'[9] DEEP BREATHING DOWN:'//
C' [10] DEEP BREATHING UP'//
C' [11] TALKING'//
C' [12] FACIAL GRIMACING'//
C' [13] SIDE-TO-SIDE HEAD MOVEMENTS (NORMAL BREATHING)'//
C' [14] UP-AND-DOWN HEAD MOVEMENTS (NORMAL BREATHING)'//
C' [15] SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING)'//
C' [16] UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)'//)
4138 TYPE 2006
TYPE 4137,ICCBS(1),ICCBS(2)
TYPE 2006
TYPE 3131
3131 FORMAT(1X,'TO SPECIFY THE EXERCISE PROTOCOL GROUP OF INTEREST,'/
C' TYPE EITHER: GROUP 1 OR GROUP 2 ')
TYPE 306
TYPE 2004

```


AD-A115 327 SCHOOL OF AEROSPACE MEDICINE BROOKS AFB TX F/G 6/11
AUTOMATED CALCULATION OF PROTECTION FACTORS FOR THE DI-2-ETHYLH--ETC(U)
DEC 81 E S KOLESAR
UNCLASSIFIED SAM-TR-81-35 NL

2 OF 2

411 2
-4-10-1



END
DATE
FILMED
10-7-82
DTIC



MICROCOPY RESOLUTION TEST CHART
NATIONAL BUREAU OF STANDARDS-1963-A

--APPENDIX B--

```

3122 ACCEPT 3122,SELECT
    FORMAT(7A1)
    IF(SELECT(7).NE.'1'.AND.SELECT(7).NE.'2') GO TO 4138
    TYPE 2006
    TYPE 4137,ICCBS(1),ICCBS(2)
    TYPE 2006

C
C   ENTER THE EXERCISE INTEGRATION COUNT DATA
C
C   THIS INFORMATION IS AVAILABLE FROM THE DATA SHEET USED
C   DURING THE RQFT
C
    TYPE 3021
3021 FORMAT(1X,'USER ATTENTION:  IF NO EXERCISE COUNT DATA WAS'/
    C' COLLECTED FOR A PARTICULAR EXERCISE, TYPE: 000001.  ALSO,'/
    C' FOR EACH EXERCISE INTEGRATOR COUNT DATA ENTRY, SIX DIGITS MUST')
    TYPE 3022
3022 FORMAT(1X,'BE TYPED, THAT IS, IF YOU HAVE A SIX DIGIT NUMBER,'/
    C' TYPE ALL SIX DIGITS.  IF YOU HAVE A FIVE DIGIT NUMBER, TYPE'/
    C' ONE LEADING ZERO AND THEN THE FIVE DIGITS.  IF YOU HAVE A')
    TYPE 3033
3033 FORMAT(' FOUR DIGIT NUMBER, TYPE TWO LEADING ZEROS AND THEN THE'/
    C' FOUR DIGITS, ETC.  SEVERAL EXAMPLES FOLLOW AS AN ILLUSTRATION')
    TYPE 3034
3034 FORMAT(1X,'FOR EXAMPLE:  COUNT DATA=743182    TYPED ENTRY=743182')
    TYPE 3035
3035 FORMAT(1X,'FOR EXAMPLE:  COUNT DATA=18726     TYPED ENTRY=018726')
    TYPE 3036
3036 FORMAT(1X,'FOR EXAMPLE:  COUNT DATA=6412      TYPED ENTRY=006412')
    TYPE 2006
    TYPE 4137,ICCBS(1),ICCBS(2)
    TYPE 2006
    TYPE 3119
3119 FORMAT(1X,'DEPRESS THE RETURN KEY AFTER ENTERING AN'/
    C' INTEGRATOR COUNT MAGNITUDE, TIME PERIOD, AND'/
    C' SWITCH POSITION')
    TYPE 2006
    TYPE 3037
3037 FORMAT(1X,'EXERCISE INTEGRATOR COUNT INFORMATION:')
    TYPE 3038
3038 FORMAT(1X,'EXERCISE',26X,'INTEGRATOR',3X,'TIME PERIOD',6X,'SAMPLIN
    CG RANGE')
    TYPE 3126
3126 FORMAT(1X,37X,'COUNT',5X,'(IN SECONDS)',5X,'SWITCH POSITION')
    TYPE 61
    61 FORMAT(1X,64X,'(AS A PERCENT)')
    IF(SELECT(7).EQ.'2') GO TO 3133
    TYPE 3039
3039 FORMAT(1X,'NORMAL BREATHING STRAIGHT AHEAD    ',S)
    ACCEPT 3040,IC1
3040 FORMAT(I6)
    CALL CLEAR(LINES)
    TYPE 3112,IC1
3112 FORMAT(1H+,'NORMAL BREATHING STRAIGHT AHEAD',T37,I6,T52,1H ,S)
    ACCEPT 3113,ICTP1
3113 FORMAT(I2)
    CALL CLEAR(LINES)

```

--APPENDIX B--

```

        TYPE 62,IC1,ICTP1
62  FORMAT(1H+,'NORMAL BREATHING STRAIGHT AHEAD',T37,I6,T53,I2,T69,1H
    C , $)
        ACCEPT 64,SRSP1
        TYPE 3041
3041  FORMAT(1X,'DEEP BREATHING STRAIGHT AHEAD      ', $)
        ACCEPT 3040,IC2
        CALL CLEAR(LINES)
        TYPE 3114,IC2
3114  FORMAT(1H+,'DEEP BREATHING STRAIGHT AHEAD',T37,I6,T52,1H , $)
        ACCEPT 3113,ICTP2
        CALL CLEAR(LINES)
        TYPE 63,IC2,ICTP2
63  FORMAT(1H+,'DEEP BREATHING STRAIGHT AHEAD',T37,I6,T53,I2,T69,1H , $
    C)
64  FORMAT(1F6.2)
        ACCEPT 64,SRSP2
        TYPE 3042
3042  FORMAT(1X,'TALKING                          ', $)
        ACCEPT 3040,IC3
        CALL CLEAR(LINES)
        TYPE 3115,IC3
3115  FORMAT(1H+,'TALKING',T37,I6,T52,1H , $)
        ACCEPT 3113,ICTP3
        CALL CLEAR(LINES)
        TYPE 65,IC3,ICTP3
65  FORMAT(1H+,'TALKING',T37,I6,T53,I2,T69,1H , $)
        ACCEPT 64,SRSP3
        TYPE 3043
3043  FORMAT(1X,'SIDE-TO-SIDE HEAD MOVEMENTS'/
    C' (DEEP BREATHING)                          ', $)
        ACCEPT 3040,IC4
        CALL CLEAR(LINES)
        TYPE 3116,IC4
3116  FORMAT(1H+,'(DEEP BREATHING)',T37,I6,T52,1H , $)
        ACCEPT 3113,ICTP4
        CALL CLEAR(LINES)
        TYPE 66,IC4,ICTP4
66  FORMAT(1H+,'(DEEP BREATHING)',T37,I6,T53,I2,T69,1H , $)
        ACCEPT 64,SRSP4
        TYPE 3044
3044  FORMAT(1X,'UP-AND-DOWN HEAD MOVEMENTS'/
    C' (DEEP BREATHING)                          ', $)
        ACCEPT 3040,IC5
        CALL CLEAR(LINES)
        TYPE 3116,IC5
        ACCEPT 3113,ICTP5
        CALL CLEAR(LINES)
        TYPE 66,IC5,ICTP5
        ACCEPT 64,SRSP5
        TYPE 3045
3045  FORMAT(1X,'FACIAL GRIMACING                  ', $)
        ACCEPT 3040,IC6
        CALL CLEAR(LINES)
        TYPE 3117,IC6
3117  FORMAT(1H+,'FACIAL GRIMACING',T37,I6,T52,1H , $)
        ACCEPT 3113,ICTP6

```

--APPENDIX B--

```

CALL CLEAR(LINES)
TYPE 67,IC6,ICTP6
67 FORMAT(1H+,'FACIAL GRIMACING',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP6
TYPE 2006
TYPE 4137,ICCB(1),ICCB(2)
TYPE 2006
GO TO 3153
3133 CONTINUE
TYPE 3039
ACCEPT 3040,IC1
CALL CLEAR(LINES)
TYPE 3112,IC1
ACCEPT 3113,ICTP1
CALL CLEAR(LINES)
TYPE 62,IC1,ICTP1
ACCEPT 64,SRSP1
TYPE 3134
3134 FORMAT(1X,'NORMAL BREATHING LEFT',T37,I6,T53,I2,T69,1H , $)
ACCEPT 3040,IC2
CALL CLEAR(LINES)
TYPE 3135,IC2
3135 FORMAT(1H+,'NORMAL BREATHING LEFT',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP2
CALL CLEAR(LINES)
TYPE 68,IC2,ICTP2
68 FORMAT(1H+,'NORMAL BREATHING LEFT',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP2
TYPE 3136
3136 FORMAT(1X,'NORMAL BREATHING RIGHT',T37,I6,T53,I2,T69,1H , $)
ACCEPT 3040,IC3
CALL CLEAR(LINES)
TYPE 3137,IC3
3137 FORMAT(1H+,'NORMAL BREATHING RIGHT',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP3
CALL CLEAR(LINES)
TYPE 69,IC3,ICTP3
69 FORMAT(1H+,'NORMAL BREATHING RIGHT',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP3
TYPE 3138
3138 FORMAT(1X,'NORMAL BREATHING DOWN',T37,I6,T53,I2,T69,1H , $)
ACCEPT 3040,IC4
CALL CLEAR(LINES)
TYPE 3139,IC4
3139 FORMAT(1H+,'NORMAL BREATHING DOWN',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP4
CALL CLEAR(LINES)
TYPE 70,IC4,ICTP4
70 FORMAT(1H+,'NORMAL BREATHING DOWN',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP4
TYPE 3140
3140 FORMAT(1X,'NORMAL BREATHING UP',T37,I6,T53,I2,T69,1H , $)
ACCEPT 3040,IC5
CALL CLEAR(LINES)
TYPE 3141,IC5
3141 FORMAT(1H+,'NORMAL BREATHING UP',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP5

```

--APPENDIX B--

```

CALL CLEAR(LINES)
TYPE 71,IC5,ICTP5
71 FORMAT(1H+,'NORMAL BREATHING UP',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP5
TYPE 3041
ACCEPT 3040,IC6
CALL CLEAR(LINES)
TYPE 3114,IC6
ACCEPT 3113,ICTP6
CALL CLEAR(LINES)
TYPE 63,IC6,ICTP6
ACCEPT 64,SRSP6
TYPE 3142
3142 FORMAT(1X,'DEEP BREATHING LEFT',T37,I6,T52,1H , $)
ACCEPT 3040,IC7
CALL CLEAR(LINES)
TYPE 3143,IC7
3143 FORMAT(1H+,'DEEP BREATHING LEFT',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP7
CALL CLEAR(LINES)
TYPE 72,IC7,ICTP7
72 FORMAT(1H+,'DEEP BREATHING LEFT',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP7
TYPE 3144
3144 FORMAT(1X,'DEEP BREATHING RIGHT',T37,I6,T52,1H , $)
ACCEPT 3040,IC8
CALL CLEAR(LINES)
TYPE 3145,IC8
3145 FORMAT(1H+,'DEEP BREATHING RIGHT',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP8
CALL CLEAR(LINES)
TYPE 73,IC8,ICTP8
73 FORMAT(1H+,'DEEP BREATHING RIGHT',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP8
TYPE 3146
3146 FORMAT(1X,'DEEP BREATHING DOWN',T37,I6,T52,1H , $)
ACCEPT 3040,IC9
CALL CLEAR(LINES)
TYPE 3147,IC9
3147 FORMAT(1H+,'DEEP BREATHING DOWN',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP9
CALL CLEAR(LINES)
TYPE 74,IC9,ICTP9
74 FORMAT(1H+,'DEEP BREATHING DOWN',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP9
TYPE 3148
3148 FORMAT(1X,'DEEP BREATHING UP',T37,I6,T52,1H , $)
ACCEPT 3040,IC10
CALL CLEAR(LINES)
TYPE 3149,IC10
3149 FORMAT(1H+,'DEEP BREATHING UP',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP10
CALL CLEAR(LINES)
TYPE 75,IC10,ICTP10
75 FORIAT(1H+,'DEEP BREATHING UP',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP10
TYPE 3042

```

--APPENDIX B--

```
ACCEPT 3040,IC11
CALL CLEAR(LINES)
TYPE 3115,IC11
ACCEPT 3113,ICTP11
CALL CLEAR(LINES)
TYPE 65,IC11,ICTP11
ACCEPT 64,SRSP11
TYPE 3045
ACCEPT 3040,IC12
CALL CLEAR(LINES)
TYPE 3117,IC12
ACCEPT 3113,ICTP12
CALL CLEAR(LINES)
TYPE 67,IC12,ICTP12
ACCEPT 64,SRSP12
TYPE 3150
3150 FORMAT(1X,'SIDE-TO-SIDE HEAD MOVEMENTS'/
C' (NORMAL BREATHING) ', $)
ACCEPT 3040,IC13
CALL CLEAR(LINES)
TYPE 3151,IC13
3151 FORMAT(1H+,'(NORMAL BREATHING)',T37,I6,T52,1H , $)
ACCEPT 3113,ICTP13
CALL CLEAR(LINES)
TYPE 76,IC13,ICTP13
76 FORMAT(1H+,'(NORMAL BREATHING)',T37,I6,T53,I2,T69,1H , $)
ACCEPT 64,SRSP13
TYPE 3152
3152 FORMAT(1X,'UP-AND-DOWN HEAD MOVEMENTS'/
C' (NORMAL BREATHING) ', $)
ACCEPT 3040,IC14
CALL CLEAR(LINES)
TYPE 3151,IC14
ACCEPT 3113,ICTP14
CALL CLEAR(LINES)
TYPE 76,IC14,ICTP14
ACCEPT 64,SRSP14
TYPE 3043
ACCEPT 3040,IC15
CALL CLEAR(LINES)
TYPE 3116,IC15
ACCEPT 3113,ICTP15
CALL CLEAR(LINES)
TYPE 66,IC15,ICTP15
ACCEPT 64,SRSP15
TYPE 3044
ACCEPT 3040,IC16
CALL CLEAR(LINES)
TYPE 3116,IC16
ACCEPT 3113,ICTP16
CALL CLEAR(LINES)
TYPE 66,IC16,ICTP16
ACCEPT 64,SRSP16
TYPE 2006
TYPE 4137,ICCBS(1),ICCBS(2)
3153 TYPE 2006
C
```

--APPENDIX B--

```
C      TRANSFER INFORMATION TO THE DATA.XXX FILE
C
      WRITE(2,2006)
      WRITE(2,306)
      WRITE(2,4004)
4004  FORMAT(6X,'DEHP RQFT DATA'///)
      WRITE(2,3046)NAME
3046  FORMAT(6X,'SUBJECT NAME:',2X,45A1)
      WRITE(2,3047)MASK
3047  FORMAT(6X,'TYPE OF RESPIRATOR:',2X,45A1)
      WRITE(2,3048)DATE
3048  FORMAT(6X,'DATE TESTED:',2X,45A1)
      WRITE(2,3049)TIME
3049  FORMAT(6X,'TIME TESTED:',2X,45A1)
      WRITE(2,2006)
      WRITE(2,54)
54  FORMAT(6X,'DEHP RQFT CALIBRATION DATA: '///)
      WRITE(2,55)
55  FORMAT(6X,'CALIBRATION PARAMETER',17X,'SAMPLING RANGE',8X,'AVERAGE
C')
      WRITE(2,56)
56  FORMAT(6X,38X,'SWITCH POSITION',7X,'VOLTAGE')
      WRITE(2,57)
57  FORMAT(6X,39X,'(IN PERCENT)',8X,'(IN VOLTS)'/)
      WRITE(2,58)
58  FORMAT(6X,'AVERAGE INITIAL VOLTAGE')
      WRITE(2,59)
59  FORMAT(6X,'ASSOCIATED WITH THE MAXIMUM')
      WRITE(2,30)KCC,VCI
30  FORMAT(6X,'CHAMBER CHALLENGE CONCENTRATION',12X,F6.2,12X,F6.3/)
      WRITE(2,58)
      WRITE(2,32)
32  FORMAT(6X,'ASSOCIATED WITH THE BASELINE')
      WRITE(2,33)KBC,VBI
33  FORMAT(6X,'OF THE DEHP RQFT INSTRUMENT',16X,F6.2,12X,F6.3/)
      WRITE(2,34)
34  FORMAT(6X,'AVERAGE FINAL VOLTAGE')
      WRITE(2,32)
      WRITE(2,33)KBC,VBF
      WRITE(2,34)
      WRITE(2,59)
      WRITE(2,30)KCC,VCF
      WRITE(2,2006)
      WRITE(2,2006)
      WRITE(2,2006)
      WRITE(2,2006)
      WRITE(2,2006)
      WRITE(2,2006)
      WRITE(2,77)
77  FORMAT(6X,'EXERCISE INTEGRATOR COUNT INFORMATION::///)
      WRITE(2,78)
78  FORMAT(6X,'EXERCISE',26X,'INTEGRATOR',3X,'TIME PERIOD',6X,'SAMPLIN
CG RANGE')
      WRITE(2,79)
79  FORMAT(6X,37X,'COUNT',5X,'(IN SECONDS)',5X,'SWITCH POSITION')
      WRITE(2,80)
80  FORMAT(6X,64X,'(AS A PERCENT)'/)
```

--APPENDIX B--

```

C      IF(SELECT(7).EQ.'2') GO TO 3154
C
C      TRANSFER THE DEHP RQFT INPUT DATA TO ARRAYS TO FACILITATE
C      PF CALCULATIONS
C
      IC(1)=IC1
      IC(2)=IC2
      IC(3)=IC3
      IC(4)=IC4
      IC(5)=IC5
      IC(6)=IC6
      ICTP(1)=ICTP1
      ICTP(2)=ICTP2
      ICTP(3)=ICTP3
      ICTP(4)=ICTP4
      ICTP(5)=ICTP5
      ICTP(6)=ICTP6
      SRSP(1)=SRSP1
      SRSP(2)=SRSP2
      SRSP(3)=SRSP3
      SRSP(4)=SRSP4
      SRSP(5)=SRSP5
      SRSP(6)=SRSP6
      WRITE(2,3051)IC1,ICTP1,SRSP1
3051  FORMAT(6X,'NORMAL BREATHING STRAIGHT AHEAD',5X,I6,10X,I2,11X,F6.2)
      WRITE(2,3052)IC2,ICTP2,SRSP2
3052  FORMAT(6X,'DEEP BREATHING STRAIGHT AHEAD',7X,I6,10X,I2,11X,F6.2)
      WRITE(2,3053)IC3,ICTP3,SRSP3
3053  FORMAT(6X,'TALKING',29X,I6,10X,I2,11X,F6.2)
      WRITE(2,3054)IC4,ICTP4,SRSP4
3054  FORMAT(6X,'SIDE-TO-SIDE HEAD MOVEMENTS'/
      C'      (DEEP BREATHING)',20X,I6,10X,I2,11X,F6.2)
      WRITE(2,3055)IC5,ICTP5,SRSP5
3055  FORMAT(6X,'UP-AND-DOWN HEAD MOVEMENTS'/
      C'      (DEEP BREATHING)',20X,I6,10X,I2,11X,F6.2)
      WRITE(2,3056)IC6,ICTP6,SRSP6
3056  FORMAT(6X,'FACIAL GRIMACING',20X,I6,10X,I2,11X,F6.2//)
      GO TO 3155
3154  CONTINUE
      IC(1)=IC1
      IC(2)=IC2
      IC(3)=IC3
      IC(4)=IC4
      IC(5)=IC5
      IC(6)=IC6
      IC(7)=IC7
      IC(8)=IC8
      IC(9)=IC9
      IC(10)=IC10
      IC(11)=IC11
      IC(12)=IC12
      IC(13)=IC13
      IC(14)=IC14
      IC(15)=IC15
      IC(16)=IC16
      ICTP(1)=ICTP1

```

--APPENDIX B--

```
ICTP(2)=ICTP2
ICTP(3)=ICTP3
ICTP(4)=ICTP4
ICTP(5)=ICTP5
ICTP(6)=ICTP6
ICTP(7)=ICTP7
ICTP(8)=ICTP8
ICTP(9)=ICTP9
ICTP(10)=ICTP10
ICTP(11)=ICTP11
ICTP(12)=ICTP12
ICTP(13)=ICTP13
ICTP(14)=ICTP14
ICTP(15)=ICTP15
ICTP(16)=ICTP16
SRSP(1)=SRSP1
SRSP(2)=SRSP2
SRSP(3)=SRSP3
SRSP(4)=SRSP4
SRSP(5)=SRSP5
SRSP(6)=SRSP6
SRSP(7)=SRSP7
SRSP(8)=SRSP8
SRSP(9)=SRSP9
SRSP(10)=SRSP10
SRSP(11)=SRSP11
SRSP(12)=SRSP12
SRSP(13)=SRSP13
SRSP(14)=SRSP14
SRSP(15)=SRSP15
SRSP(16)=SRSP16
WRITE(2,3051) IC1,ICTP1,SRSP1
WRITE(2,3156) IC2,ICTP2,SRSP2
3156 FORMAT(6X,'NORMAL BREATHING LEFT',15X,I6,10X,I2,11X,F6.2)
WRITE(2,3157) IC3,ICTP3,SRSP3
3157 FORMAT(6X,'NORMAL BREATHING RIGHT',14X,I6,10X,I2,11X,F6.2)
WRITE(2,3158) IC4,ICTP4,SRSP4
3158 FORMAT(6X,'NORMAL BREATHING DOWN',15X,I6,10X,I2,11X,F6.2)
WRITE(2,3159) IC5,ICTP5,SRSP5
3159 FORMAT(6X,'NORMAL BREATHING UP',17X,I6,10X,I2,11X,F6.2)
WRITE(2,3052) IC6,ICTP6,SRSP6
WRITE(2,3160) IC7,ICTP7,SRSP7
3160 FORMAT(6X,'DEEP BREATHING LEFT',17X,I6,10X,I2,11X,F6.2)
WRITE(2,3161) IC8,ICTP8,SRSP8
3161 FORMAT(6X,'DEEP BREATHING RIGHT',16X,I6,10X,I2,11X,F6.2)
WRITE(2,3162) IC9,ICTP9,SRSP9
3162 FORMAT(6X,'DEEP BREATHING DOWN',17X,I6,10X,I2,11X,F6.2)
WRITE(2,3163) IC10,ICTP10,SRSP10
3163 FORMAT(6X,'DEEP BREATHING UP',19X,I6,10X,I2,11X,F6.2)
WRITE(2,3053) IC11,ICTP11,SRSP11
WRITE(2,3164) IC12,ICTP12,SRSP12
3164 FORMAT(6X,'FACIAL GRIMACING',20X,I6,10X,I2,11X,F6.2)
WRITE(2,3165) IC13,ICTP13,SRSP13
3165 FORMAT(6X,'SIDE-TO-SIDE HEAD MOVEMENTS'/
C'      (NORMAL BREATHING)',18X,I6,10X,I2,11X,F6.2)
WRITE(2,3166) IC14,ICTP14,SRSP14
3166 FORMAT(6X,'UP-AND-DOWN HEAD MOVEMENTS'/
```

--APPENDIX B--

```

C'      (NORMAL BREATHING)',18X,I6,10X,I2,11X,F6.2)
WRITE(2,3054)IC15,ICTP15,SRSP15
WRITE(2,3055)IC16,ICTP16,SRSP16
3155 CONTINUE
C
C      CALCULATE THE AVERAGE SCATTERED LIGHT PHOTOMETER VOLTAGE
C      OUTPUT FOR EACH EXERCISE
C
      IF(SELECT(7).EQ.'2') GO TO 3167
      DO 3093 I=1,6
      XC(I)=IC(I)
      XC(I)= XC(I)/(1000.0 * ICTP(I))
3093 CONTINUE
      GO TO 3168
3167 CONTINUE
      DO 3169 I=1,16
      XC(I)=IC(I)
      XC(I)=XC(I)/(1000.0 * ICTP(I))
3169 CONTINUE
3168 CONTINUE
      ENDFILE 2
      REWIND 2
      TYPE 2006
      TYPE 4137,ICCBS(1),ICCBS(2)
      TYPE 2006
C
C      CALCULATE THE INDIVIDUAL EXERCISE PROTECTION FACTORS
C      USING THE RELATIONSHIP :  $PF=(CC)/(RL)$ 
C
C      CALCULATION OF: (CC) IS GIVEN BY:
C
C       $(CC)=[(VCI+VCF)(KCC)/2 - (VBI+VBF)KBC/2]$ 
C
C
C      CALCULATION OF: (RL) IS GIVEN BY:
C
C       $(RL)=[(XC(I)*SRSP(I) - (VBI+VBF)(KBC))/2]$ 
C
C
C      NOTE: SINCE THE LEAK MEASURING SENSITIVITY OF THE DEHP RQFT
C      INSTRUMENT IS ONE PART IN TEN TO THE SIXTH, ANY EXERCISE
C      SCALED INTEGRATOR COUNT VALUE YIELDING A PROTECTION
C      FACTOR GREATER THAN  $1.0E+06$ , WILL BE REPORTED AS
C       $1.0E+06$ . REPORTING A PROTECTION FACTOR GREATER THAN
C       $1.0E+06$  WOULD BE ERRONEOUS. ANY EXERCISE SCALED
C      INTEGRATOR COUNT VALUE YIELDING A PROTECTION FACTOR
C      GREATER THAN  $1.0E+06$  WILL BE REPORTED AS  $1.0E+06$ .
C
      TYPE 2006
      TYPE 4137,ICCBS(1),ICCBS(2)
      TYPE 2006
      CC=[((VCI+VCF)*(KCC))/2 - ((VBI+VBF)*(KBC))/2]
      IF(SELECT(7).EQ.'2') GO TO 3173
      DO 3174 I=1,6

```

--APPENDIX B--

```

      RL(I)=((XC(I)*SRSP(I))-((VBI+VBF)*(KBC)))/2)
      IF(RL(I).LE.0.0) GO TO 9227
      PF(I)=CC/RL(I)
      IF(PF(I).GE.1000000.0) GO TO 9227
      GO TO 3174
9227 PF(I)=1000000.00
3174 CONTINUE
      GO TO 9173
3173 DO 9173 I=1,16
      RL(I)=((XC(I)*SRSP(I))-((VBI+VBF)*(KBC)))/2)
      IF(RL(I).LE.0.0) GO TO 4136
      PF(I)=CC/RL(I)
      IF(PF(I).GE.1000000.0) GO TO 4136
      GO TO 9173
4136 PF(I)=1000000.00
9173 CONTINUE
C
C   CALCULATE AN OVERALL ARITHMETIC AVERAGE PROTECTION FACTOR FOR
C   ALL EXERCISES
C
      IF(SELECT(7).EQ.'2') GO TO 10
      IDL=6
      IDLP=7
      GO TO 11
10 CONTINUE
      IDL=16
      IDLP=17
11 CONTINUE
      KOUNT=0
      PFSUM=0.0
      DO 3060 MT=1,IDL
      KOUNT=KOUNT + 1
      PFSUM=PFSUM + PF(MT)
3060 CONTINUE
      PF(IDLP)=PFSUM/KOUNT
C
C   CALCULATE AN OVERALL TIME WEIGHTED AVERAGE PROTECTION FACTOR FOR
C   ALL EXERCISES
C
      WPF=0.0
      KKOUNT=0
      PPSUM=0.0
      DO 3194 INT=1,IDL
      KKOUNT=KKOUNT + ICTP(INT)
      PPSUM=PPSUM + (PF(INT)*ICTP(INT))
3194 CONTINUE
      WPF=PPSUM/KKOUNT
C
C   TRANSFER THE CALCULATED RESULTS TO THE CALCUL.HMM FILE
C
      WRITE(3,3061)
3061 FORMAT(1H1)
      WRITE(3,3062)
3062 FORMAT(6X,'THE DESCRIPTIVE AND PROTECTION FACTOR CALCULATIONS:')
      WRITE(3,9542)
9542 FORMAT(6X,'NOTE: ANY PROTECTION FACTOR THAT IS LISTED AS'
C'      1.0E+06 HAS BEEN ASSIGNED THIS VALUE BY DEFAULT')

```

--APPENDIX B--

```
C'      BECAUSE THE SENSITIVITY OF THIS RQFT INSTRUMENT IS'//
C'      AT MOST ONE PART IN TEN TO THE SIXTH.  THE INTEGRATOR'//
C'      COUNT VALUE FOR A PARTICULAR EXERCISE IN QUESTION'//
C'      IS MERELY REPRESENTATIVE OF INTEGRATING THE ELECTRICAL'//
C'      NOISE AND THE TRUE PROTECTION FACTOR IS INDEED GREATER')
WRITE(3,9543)
9543 FORMAT(6X,'THAN 1.0E+06.  ANY EXERCISE SCALED INTEGRATOR'//
C'      COUNT VALUE YIELDING A PROTECTION FACTOR GREATER'//
C'      THAN 1.0E+06 WILL BE REPORTED AS 1.0E+06.'//)
WRITE(3,3176)
3176 FORMAT(1X,' '///)
TYPE 3062
TYPE 2006
TYPE 9542
TYPE 9543
TYPE 2006
TYPE 4137,ICCBS(1),ICCBS(2)
TYPE 2006
WRITE(3,3046)NAME
WRITE(3,3047)MASK
WRITE(3,3048)DATE
WRITE(3,3049)TIME
WRITE(3,3176)
TYPE 3046,NAME
TYPE 3047,MASK
TYPE 3048,DATE
TYPE 3049,TIME
TYPE 2006
WRITE(3,3063)
3063 FORMAT(6X,'EXERCISE',29X,'PROTECTION FACTOR'//
IF(SELECT(7).EQ.'2') GO TO 3175
WRITE(3,3064)PF(1)
TYPE 3064,PF(1)
3064 FORMAT(6X,'NORMAL BREATHING STRAIGHT AHEAD',6X,1PE12.1)
WRITE(3,3065)PF(2)
TYPE 3065,PF(2)
3065 FORMAT(6X,'DEEP BREATHING STRAIGHT AHEAD',8X,1PE12.1)
WRITE(3,3066)PF(3)
TYPE 3066,PF(3)
3066 FORMAT(6X,'TALKING',30X,1PE12.1)
WRITE(3,3067)PF(4)
TYPE 3067,PF(4)
3067 FORMAT(6X,'SIDE-TO-SIDE HEAD MOVEMENTS'//
C'      (DEEP BREATHING)',21X,1PE12.1)
WRITE(3,3068)PF(5)
TYPE 3068,PF(5)
3068 FORMAT(6X,'UP-AND-DOWN HEAD MOVEMENTS'//
C'      (DEEP BREATHING)'21X,1PE12.1)
WRITE(3,3069)PF(6)
TYPE 3069,PF(6)
3069 FORMAT(6X,'FACIAL GRIMACING',21X,1PE12.1)
TYPE 2006
WRITE(3,2006)
WRITE(3,3070)PF(7)
TYPE 3070,PF(7)
3070 FORMAT(1H0,5X,'OVERALL ARITHMETIC AVERAGE PROTECTION FACTOR'//
C'      FOR ALL CATEGORIES OF EXERCISES ACTUALLY PERFORMED = ')
```

--APPENDIX B--

```

C,1PE8.1)
TYPE 2006
WRITE(3,2006)
TYPE 3195,WPF
WRITE(3,3195)WPF
3195 FORMAT(1H0,5X,'OVERALL TIME WEIGHTED AVERAGE PROTECTION FACTOR'/
C'      FOR ALL CATEGORIES OF EXERCISES ACTUALLY PERFORMED = '
C,1PE8.1)
GO TO 3177
3175 CONTINUE
WRITE(3,3064)PF(1)
TYPE 3064,PF(1)
WRITE(3,3179)PF(2)
TYPE 3179,PF(2)
3179 FORMAT(6X,'NORMAL BREATHING LEFT',16X,1PE12.1)
WRITE(3,3180)PF(3)
TYPE 3180,PF(3)
3180 FORMAT(6X,'NORMAL BREATHING RIGHT',15X,1PE12.1)
WRITE(3,3181)PF(4)
TYPE 3181,PF(4)
3181 FORMAT(6X,'NORMAL BREATHING DOWN',16X,1PE12.1)
WRITE(3,3182)PF(5)
TYPE 3182,PF(5)
3182 FORMAT(6X,'NORMAL BREATHING UP',13X,1PE12.1)
WRITE(3,3065)PF(6)
TYPE 3065,PF(6)
WRITE(3,3184)PF(7)
TYPE 3184,PF(7)
3184 FORMAT(6X,'DEEP BREATHING LEFT',18X,1PE12.1)
WRITE(3,3185)PF(8)
TYPE 3185,PF(8)
3185 FORMAT(6X,'DEEP BREATHING RIGHT',17X,1PE12.1)
WRITE(3,3186)PF(9)
TYPE 3186,PF(9)
3186 FORMAT(6X,'DEEP BREATHING DOWN',18X,1PE12.1)
WRITE(3,3187)PF(10)
TYPE 3187,PF(10)
3187 FORMAT(6X,'DEEP BREATHING UP',20X,1PE12.1)
WRITE(3,3066)PF(11)
TYPE 3066,PF(11)
WRITE(3,3069)PF(12)
TYPE 3069,PF(12)
WRITE(3,3190)PF(13)
TYPE 3190,PF(13)
3190 FORMAT(6X,'SIDE-TO-SIDE HEAD MOVEMENTS'/
C'      (NORMAL BREATHING)',19X,1PE12.1)
WRITE(3,3191)PF(14)
TYPE 3191,PF(14)
3191 FORMAT(6X,'UP-AND-DOWN HEAD MOVEMENTS'/
C'      (NORMAL BREATHING)',19X,1PE12.1)
WRITE(3,3067)PF(15)
TYPE 3067,PF(15)
WRITE(3,3068)PF(16)
TYPE 3068,PF(16)
WRITE(3,2006)
TYPE 3068,PF(16)
TYPE 39
39 FORMAT(1X,////)

```

--APPENDIX B--

```

WRITE(3,3070)PF(IDLP)
TYPE 3070,PF(IDLP)
TYPE 2006
WRITE(3,3176)
TYPE 3195,WPF
WRITE(3,3195)WPF
3177 CONTINUE
TYPE 2006
TYPE 4137,ICCBS(1),ICCBS(2)
TYPE 2006

C
C   CLOSE THE DATA.XXX AND CALCX.XXX FILES
C
C   CLOSE(UNIT=2)
C   CLOSE(UNIT=3)

C
C   THE OPTION OF PROCESSING UP TO NINE SETS OF DEHP RQFT DATA
C   DURING A SINGLE COMPUTER RUN CAN BE ACCOMPLISHED
C
29 TYPE 14
14 FORMAT(1X,'DO YOU WISH TO CALCULATE PROTECTION FACTORS FOR'/
C' A DIFFERENT SUBJECT ? (ANSWER YES OR NO) ',2X,$)
ACCEPT 1002,REP
1002 FORMAT(1A1)
IF(REP.EQ.YES)GO TO 6000
IF(REP.EQ.NO)GO TO 28
IF(REP.NE.YES.AND.REP.NE.NO) GO TO 29
28 CONTINUE
TYPE 2006
TYPE 4137,ICCBS(1),ICCBS(2)
TYPE 2006
TYPE 2006

C
C   NOTIFICATION ON THE CRT SCREEN FOR A SUCCESSFUL
C   COMPUTER RUN IS PROVIDED
C
TYPE 9599
9599 FORMAT(1X,12X,'JOB SUCCESSFULLY COMPLETED',////)
STOP
END

C
C   SUBROUTINE CLEAR IS USED TO ALLOW THE OPERATOR TO MAKE
C   MORE THAN ONE DATA ENTRY ON THE SAME CRT LINE. THIS
C   SUBROUTINE ERASES THE LINE ON WHICH THE FIRST DATA
C   ENTRY WAS MADE, AND RETYPES THAT LINE, INCLUDING THE
C   FIRST DATA ENTRY; THIS ALLOWS ADDITIONAL DATA ENTRIES
C   TO BE MADE ON THE SAME LINE BY MERELY DEPRESSING
C   THE CRT RETURN KEY
C
SUBROUTINE CLEAR(LINES)
BYTE A(3)
A(1)=27
A(2)=65
A(3)=75
IF(LINES.EQ.0) LINES=1
DO 1 I=1,LINES
1 TYPE 4,A(1),A(2),A(3)

```

--APPENDIX B--

```
LINES=0  
RETURN  
4 FORMAT(1H+,4A1,$)  
END
```

APPENDIX C:

DATA.XXX File Contents for Data in Table 3

(Integrator count data for the strip-
chart recording in Fig. 5)

--APPENDIX C--

DEHP RQFT DATA

SUBJECT NAME: CAPTAIN EDWARD S. KOLESAR, JR.
TYPE OF RESPIRATOR: USA XM-29; MEDIUM; NO GLASSES
DATE TESTED: 18 JUNE 1981
TIME TESTED: 1127 HRS

DEHP RQFT CALIBRATION DATA:

CALIBRATION PARAMETER	SAMPLING RANGE SWITCH POSITION (AS A PERCENT)	AVERAGE VOLTAGE (IN VOLTS)
AVERAGE INITIAL VOLTAGE ASSOCIATED WITH THE MAXIMUM CHAMBER CHALLENGE CONCENTRATION	100.00	5.820
AVERAGE INITIAL VOLTAGE ASSOCIATED WITH THE BASELINE OF THE DEHP RQFT INSTRUMENT	0.01	0.090
AVERAGE FINAL VOLTAGE ASSOCIATED WITH THE BASELINE OF THE DEHP RQFT INSTRUMENT	0.01	0.050
AVERAGE FINAL VOLTAGE ASSOCIATED WITH THE MAXIMUM CHAMBER CHALLENGE CONCENTRATION	100.00	5.800

EXERCISE INTEGRATOR COUNT INFORMATION:

EXERCISE	INTEGRATOR COUNT	TIME PERIOD (IN SECONDS)	SAMPLING RANGE SWITCH POSITION (AS A PERCENT)
NORMAL BREATHING STRAIGHT AHEAD	131	10	0.01
DEEP BREATHING STRAIGHT AHEAD	3757	10	0.01
TALKING	11871	10	0.01
SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING)	11074	10	0.01
UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)	8997	10	0.01
FACIAL GRIMACING	6752	10	0.01

AUTHOR'S NOTE: The information in Table 3, in the text, is repeated here to show the format of the computer-generated data file.

APPENDIX D:

CALCX.XXX File Contents for Data in Table 4

(Protection factor computer program calculation for the data in Table 3)

PRECEDING PAGE BLANK-NOT FILMED

--APPENDIX D--

THE DESCRIPTIVE AND PROTECTION FACTOR CALCULATIONS

NOTE: ANY PROTECTION FACTOR THAT IS LISTED AS 1.0E+06 HAS BEEN ASSIGNED THIS VALUE BY DEFAULT BECAUSE THE SENSITIVITY OF THIS RQFT INSTRUMENT IS AT MOST ONE PART IN TEN TO THE SIXTH. THE INTEGRATOR COUNT VALUE FOR A PARTICULAR EXERCISE IN QUESTION IS MERELY REPRESENTATIVE OF INTEGRATING THE ELECTRICAL NOISE AND THE TRUE PROTECTION FACTOR IS INDEED GREATER THAN 1.0E+06. ANY EXERCISE SCALED INTEGRATOR COUNT VALUE YIELDING A PROTECTION FACTOR GREATER THAN 1.0E+06 WILL BE REPORTED AS 1.0E+06.

SUBJECT NAME: CAPTAIN EDWARD S. KOLESAR, JR.
TYPE OF RESPIRATOR: USA XM-29; MEDIUM; NO GLASSES
DATE TESTED: 18 JUNE 1981
TIME TESTED: 1127 HRS

EXERCISE	PROTECTION FACTOR
NORMAL BREATHING STRAIGHT AHEAD	1.0E+06
DEEP BREATHING STRAIGHT AHEAD	1.9E+05
TALKING	5.2E+04
SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING)	5.6E+04
UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)	7.0E+04
FACIAL GRIMACING	9.6E+04
OVERALL ARITHMETIC AVERAGE PROTECTION FACTOR FOR ALL CATEGORIES OF EXERCISES ACTUALLY PERFORMED =	2.4E+05
OVERALL TIME WEIGHTED AVERAGE PROTECTION FACTOR FOR ALL CATEGORIES OF EXERCISES ACTUALLY PERFORMED =	2.4E+05

AUTHOR'S NOTE: The information in Table 4, in the text, is repeated here to show the format of the computer-generated data file.

PRECEDING PAGE BLANK-NOT FILMED

APPENDIX E:

User's Guide for the DEHPRQFT.FOR
Computer Program

PRECEDING PAGE BLANK-NOT FILLED

RESPIRATOR QUANTITATIVE FIL TESTING

INSTRUCTIONS FOR USING THE COMPUTER TERMINALS IN USAFSM/VN TO PROCESS THE DATA COLLECTED ON THE DEHP ROFT INSTRUMENT

- KEY:**
- COMPUTER GENERATED INFORMATION (CRT SCREEN)
 - Program User Generated Information (entered via the keyboard; information displayed on the CRT screen)
 - Sequential Step Numbers; not displayed on CRT screen
 - Comments to help the program user

CRT SCREEN DISPLAY

- 1) WELCOME TO THE USAFSM COMPUTER SELECTOR
SELECT 70, VAX, OR UNIVAC: _
- 2) WELCOME TO THE USAFSM COMPUTER SELECTOR
SELECT 70, VAX, OR UNIVAC: VAX _
- 3) USERNAME: _
- 4) USERNAME: XXXXXX
- 5) PASSWORD: _
- 6) PASSWORD: XXXX _

COMMENT

- Computer response after depressing any key on the keyboard.
Type 'VAX'; depress the "RETURN" key on the keyboard twice.
Computer response.
Type your last name; depress the "RETURN" key on the keyboard.
Computer response.
Type your password; depress the "RETURN" key on the keyboard. Password characters are not displayed on the CRT screen.

--APPENDIX E--

CRT SCREEN DISPLAY

COMMENT

- | | | | |
|-----|--|--------------------------------------|--|
| 7) | . | | |
| | : | | |
| | : | (SERIES OF COMPUTER SYSTEM MESSAGES) | No response required on your part. |
| | : | | |
| | : | | |
| 8) | ENTER TERMINAL "WHITE TAG" SITE ID [1-300]:? | | Last message of group. |
| 9) | ENTER TERMINAL "WHITE TAG" SITE ID [1-300]:? | | Type is terminal site ID number; depress the "RETURN" key on the keyboard. |
| 10) | ARE YOU IN BUILDING; XXX ROOM: XX
PHONE: XXXX [Y/N]?_ | | Computer response. |
| 11) | ARE YOU IN BUILDING; XXX ROOM: XX
PHONE: XXXX [Y/N]? Y_ | | Type 'Y'; depress the "RETURN" key on the keyboard. |
| 12) | ARE YOU ON A VT100 {Y/N}?:_ | | Computer response. |
| 13) | ARE YOU ON A VT100 {Y/N}? Y_ | | Type 'Y'; depress the "RETURN" key on the keyboard. |
| 14) | \$_ | | Computer is ready. |
| 15) | \$RUN [KOLESAR]DEHPROFT_ | | Type 'RUN [KOLESAR]DEHPROFT'; depress the "RETURN" key on the keyboard. |

--APPENDIX E--

CRT SCREEN DISPLAY

COMMENT

- 16) USER ATTENTION: IN ORDER TO KEEP TRACK OF THE DATA FILES (DATA-XXX) BEING ANALYZED, IT IS RECOMMENDED THAT THEY BE SEQUENTIALLY NUMBERED.
- ENTER THE FOLLOWING: 001 FOR THE FIRST DATA FILE; 002 FOR THE SECOND DATA FILE; 003 FOR THE THIRD DATA FILE; ETC.
- ENTRY= _
- 17) ENTRY=XXX_
- 18) USER ATTENTION: IN ORDER TO KEEP TRACK OF THE CALCULATION FILES (CALCX-XXX), IT IS RECOMMENDED THAT THEY BE SEQUENTIALLY NUMBERED.
- ENTER THE FOLLOWING: 001 FOR THE FIRST CALCULATION FILE; 002 FOR THE SECOND CALCULATION FILE; 003 FOR THE THIRD CALCULATION FILE; ETC.
- ENTRY= _
- 19) ENTRY=XXX_
- 20) DEHP ROFT DATA:
SUBJECT NAME: _

Computer response.

Type a three-digit number; depress the "RETURN" key on the keyboard.

Computer response.

Type a three-digit number; depress the "RETURN" key on the keyboard.

Computer response.

--APPENDIX E--

CRT SCREEN DISPLAY

COMMENT

- | | |
|---|--|
| 21) SUBJECT NAME: XXXXXX_ | Type subject's name (up to 45 characters); depress the "RETURN" key on the keyboard. |
| 22) TYPE OF RESPIRATOR: _ | Computer response. |
| 23) TYPE OF RESPIRATOR: XXXXXX_ | Type the kind of respirator tested (up to 45 characters); depress the "RETURN" key on the keyboard. |
| 24) DATE TESTED: _ | Computer response. |
| 25) DATE TESTED: XXXXXX_ | Type the date subject was tested (up to 45 characters); depress the "RETURN" key on the keyboard. |
| 26) TIME TESTED: _ | Computer response. |
| 27) TIME TESTED: XXXXXX_ | Type the time of day subject was tested (for example: 1400 Hrs); depress the "RETURN" key on the keyboard. |
| 28) DEPRESS THE RETURN KEY AFTER ENTERING A SWITCH POSITION AND VOLTAGE | Computer response. |

DEMP ROFT CALIBRATION DATA:

CALIBRATION PARAMETER	SAMPLING RANGE SWITCH POSITION (IN PERCENT)	AVERAGE VOLTAGE (IN VOLTS)
-----------------------	---	----------------------------------

--APPENDIX E--

CRT SCREEN DISPLAY

COMMENT

- | | | | |
|--|--------|-----|--|
| 29) AVERAGE INITIAL VOLTAGE
ASSOCIATED WITH THE
MAXIMUM CHAMBER CHAL-
LENCE CONCENTRATION | 100.00 | XXX | Type '100.00'; depress the "RETURN" key on the keyboard.
Type the average initial voltage associated with the maximum chamber challenge concentration; depress the "RETURN" key on the keyboard |
| 30) AVERAGE INITIAL VOLTAGE
ASSOCIATED WITH THE
BASELINE OF THE DEHP
RQFT INSTRUMENT | 0.01 | XXX | Type '0.01'; depress the "RETURN" key on the keyboard. Type the average initial voltage associated with the baseline of the DEHP RQFT instrument; depress the "RETURN" key on the keyboard. |
| 31) AVERAGE FINAL VOLTAGE
ASSOCIATED WITH THE
BASELINE OF THE DEHP
RQFT INSTRUMENT | 0.01 | XXX | Type '0.01'; depress the "RETURN" key on the keyboard. Type the average final voltage associated with the baseline of the DEHP RQFT instrument; depress the "RETURN" key on the key-board. |
| 32) AVERAGE FINAL VOLTAGE
ASSOCIATED WITH THE
MAXIMUM CHAMBER CHAL-
LENCE CONCENTRATION | 100.00 | XXX | Type '100.00'; depress the "RETURN" key on the keyboard.
Type the average final voltage associated with the maximum chamber challenge concentration; depress the "RETURN" key on the keyboard. |
| 33) THE USER IS FREE TO SELECT ONE OF TWO GROUPS
OF EXERCISE PROTOCOLS | | | Computer response. |
- THE (GROUP 1) EXERCISE PROTOCOL CONSISTS OF:
- [1] NORMAL BREATHING STRAIGHT AHEAD
- [2] DEEP BREATHING STRAIGHT AHEAD

--APPENDIX E--

CRT SCREEN DISPLAY	COMMENT
[3] TALKING [4] SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING) [5] UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING) [6] FACIAL GRIMACING	Computer response.
34) THE [GROUP 2] EXERCISE PROTOCOL CONSISTS OF:	
[1] NORMAL BREATHING STRAIGHT AHEAD [2] NORMAL BREATHING LEFT [3] NORMAL BREATHING RIGHT [4] NORMAL BREATHING DOWN [5] NORMAL BREATHING UP [6] DEEP BREATHING STRAIGHT AHEAD [7] DEEP BREATHING LEFT [8] DEEP BREATHING RIGHT [9] DEEP BREATHING DOWN [10] DEEP BREATHING UP [11] TALKING [12] FACIAL GRIMACING [13] SIDE-TO-SIDE HEAD MOVEMENTS (NORMAL BREATHING) [14] UP-AND-DOWN HEAD MOVEMENTS (NORMAL BREATHING) [15] SIDE-TO-SIDE HEAD MOVEMENTS (DEEP BREATHING) [16] UP-AND-DOWN HEAD MOVEMENTS (DEEP BREATHING)	
ENTRY=	

--APPENDIX E--

CRT SCREEN DISPLAY

COMMENT

- 35) ENTRY=GROUP X_
- Type either 'GROUP 1' or 'GROUP 2'; depress the "RETURN" key on the keyboard.
- 36) USER ATTENTION: IF NO EXERCISE COUNT DATA WAS COLLECTED FOR A PARTICULAR EXERCISE, TYPE: 000001. ALSO, FOR EACH EXERCISE INTEGRATOR COUNT DATA ENTRY, SIX DIGITS MUST BE TYPED, THAT IS, IF YOU HAVE A SIX-DIGIT NUMBER, TYPE ALL SIX DIGITS. IF YOU HAVE A FIVE-DIGIT NUMBER, TYPE
- ONE LEADING ZERO AND THEN THE FIVE DIGITS. IF YOU HAVE A FOUR DIGIT NUMBER, TYPE TWO LEADING ZEROS AND THEN THE FOUR DIGITS, ETC. SEVERAL EXAMPLES FOLLOW AS AN ILLUSTRATION
- FOR EXAMPLE: COUNT DATA=743182 TYPED ENTRY=743182
- FOR EXAMPLE: COUNT DATA=18726 TYPED ENTRY=018726
- FOR EXAMPLE: COUNT DATA=6412 TYPED ENTRY=006412
- DEPRESS THE RETURN KEY AFTER ENTERING AN INTEGRATOR COUNT MAGNITUDE, TIME PERIOD, AND SWITCH POSITION
- EXERCISE INTEGRATOR COUNT INFORMATION:
- EXERCISE INTEGRATOR TIME PERIOD SAMPLING RANGE
COUNT (IN SECONDS) SWITCH POSITION
(AS A PERCENT)
- Computer instructions for entering data. No response required on your part.

--APPENDIX E--

CRT SCREEN DISPLAY

COMMENT

- 37) NORMAL BREATHING STRAIGHT AHEAD XXXXX XX XX
Type the integrator count for this exercise; depress the "RETURN" key on the keyboard. Type the time period; depress the "RETURN" key on the keyboard. Type the sampling range switch position; depress the "RETURN" key on the keyboard.
- 38) DEEP BREATHING STRAIGHT AHEAD XXXXX XX XX
Type the integrator count for this exercise; depress the "RETURN" key on the keyboard. Type the time period; depress the "RETURN" key on the keyboard. Type the sampling range switch position; depress the "RETURN" key on the keyboard.
- 39) TIME DESCRIPTIVE AND PROTECTION FACTOR CALCULATIONS:
Enter integrator count, time period and sampling range switch position for each exercise; depress the "RETURN" key on the keyboard after each data entry.
Computer response.

NOTE: ANY PROTECTION FACTOR THAT IS LISTED AS $1.0E+06$ HAS BEEN ASSIGNED THIS VALUE BY DEFAULT BECAUSE THE SENSITIVITY OF THIS ROFT INSTRUMENT IS AT MOST ONE PART IN TEN TO THE SIXTH. THE INTEGRATOR COUNT VALUE FOR A PARTICULAR EXERCISE IN QUESTION IS MERELY REPRESENTATIVE OF INTEGRATING THE ELECTRICAL NOISE AND THE TRUE PROTECTION FACTOR IS INDEED LESS THAN $1.0E+06$. ANY EXERCISE SCALED INTEGRATOR COUNT VALUE YIELDING A PROTECTION FACTOR GREATER THAN $1.0E+06$ WILL BE REPORTED AS $1.0E+06$.

CRT SCREEN DISPLAY

COMMENT

- 40) ...COMPUTER PROCESSES DATA; ERROR MESSAGES CONCERNING YOUR DATA ENTRIES MAY BE GIVEN; CALCULATION RESULTS WILL BE DISPLAYED.
.
.
.
- No action required on your part; please read information.
If you want to stop the flow of information on the CRT screen, depress simultaneously the 'CTRL' and 'S' keys on the keyboard. To resume the flow of information on the CRT screen, depress simultaneously the 'CTRL' and 'Q' keys on the keyboard.
- 41) DO YOU WISH TO CALCULATE PROTECTION FACTORS FOR A DIFFERENT SUBJECT? (ANSWER YES OR NO)
- Last of the series of computer messages.
- 42) DO YOU WISH TO CALCULATE PROTECTION FACTORS FOR A DIFFERENT SUBJECT? (ANSWER YES OR NO) XXX
- Type the word 'YES' or 'NO'; depress the "RETURN" key on the keyboard. If 'YES' is typed, the computer continues with direction number 16). If 'NO' is typed, the computer continues with 43).
- 43) JOB SUCCESSFULLY COMPLETED
- Computer response.
- FORTRAN STOP
- 44) \$PRINT DATA,XXX
JOB N ENTERED ON QUEUE SYS\$PRINT
\$PRINT CALCX,XXX
JOB N ENTERED ON QUEUE SYS\$PRINT
- If you want a computer print out on paper of the results, type 'PRINT DATA,XXX'; depress the "RETURN" key on the keyboard. Type 'PRINT CALCX,XXX'; depress the "RETURN" key on the keyboard. The first X in DATA,XXX and CALCX,XXX is 1 for the first data set entered, and increments by 1 each time 'YES' is answered in 42). The three X's in DATA,XXX and CALCX,XXX refer to the three digits entered in 17) and 19) respectively.

--APPENDIX E--

CRT SCREEN DISPLAY

COMMENT

The computer responds with a job number for each print request.

Computer printed results can be picked up in the Computer Center, Bldg. 150, approximately 2 hours after you log off the computer terminal.

If you are finished using the computer, type "LOGOUT"; depress the "RETURN" key on the keyboard and you will be automatically logged off the computer terminal.

45) LOGOUT

ABBREVIATIONS, ACRONYMS, AND SYMBOLS

B_f	final baseline concentration
B_i	initial baseline concentration
C	concentration
C_a	ambient challenge atmosphere concentration
C_{cor}	average corrected test booth ambient challenge concentration (as a percent)
C_f	final ambient test booth challenge concentration
C_i	initial ambient test booth challenge concentration
cm	centimeter
C_s	sampled leakage concentration
CW	chemical warfare
DB	deep breathing
DEHP	di-2-ethylhexyl phthalate
E or V	voltage or potential difference
FE222	Dynatech Frontier Corporation test booth
FE259H	Dynatech Frontier Corporation di-2-ethylhexyl phthalate respirator quantitative fit test instrument
FG	facial grimacing
I_a	absorbed light intensity
IC	integrator count
I.d.	inside diameter
I_i	incident light intensity
in.	inch
I_{PMT}	photomultiplier tube current signal
I_s	scattered light intensity
I_{sl}	stray light circuit current signal
K_{bc}	instrument's sampling range switch position (typically 100.0 percent)

(Cont'd. on facing page)

ABBREVIATIONS, ACRONYMS, AND SYMBOLS (Cont'd.)

K_{cc}	Instrument's sampling range switch position (typically 10.0-0.01 percent)
KE	Instrument's sampling range switch position used during the exercise measurement time period (typically 10.0-0.01 percent)
LASL	Los Alamos Scientific Laboratory
LED	light-emitting-diode
m	meter
m^3	cubic meter
MBU-13/P	United States Air Force aircrew chemical-biological oxygen mask
mg	milligrams
min	minute
MMAD	mass median aerodynamic diameter
mV	millivolt
NaCl	sodium chloride
NB	normal breathing
NRL	Naval Research Laboratory
PF	protection factor
$\overline{PF}$	average protection factor
PF_x	protection factor for a particular exercise x, for $x = \{NB, DB, TH, UD, T, \text{ or } FG\}$
PMT	photomultiplier tube
psig	pounds per square inch gauge
R	resistance
$RE_{(cor, x)}$	average corrected respirator sampled leakage (as a percent) for a particular exercise x, for $x = \{NB, DB, TH, UD, T, \text{ or } FG\}$
RE_x	average respirator sampled leakage determined from a strip-chart recording for a particular exercise x, for $x = \{NB, DB, TH, UD, T, \text{ or } FG\}$
RQFT	respirator quantitative fit test
sec	second
T	talking

ABBREVIATIONS, ACRONYMS, AND SYMBOLS (Cont'd.)

TH	turning head side-to-side with deep breathing
UD	moving head up-and-down with deep breathing
USAFSAM	United States Air Force School of Aerospace Medicine
$\bar{V}$	average voltage
V/F	voltage-to-frequency
VB_f	average voltage response associated with the final baseline concentration (corresponds to B_f)
VB_i	average voltage response associated with the initial baseline concentration (corresponds to B_i)
VC_f	average final voltage response associated with the test booth challenge concentration (corresponds to C_f)
VC_i	average initial voltage response associated with the test booth challenge concentration (corresponds to C_i)
VN	Crew Technology Division
VNL	Crew Environments Branch
VRE_x	average voltage response associated with the average respirator sampled leakage determined from the integration count for a particular exercise x, for $x = \{NB, DB, TH, UD, T, \text{ or } FG\}$

7-8