

AD-A118 431

ARMY MISSILE COMMAND REDSTONE ARSENAL AL RESEARCH D--ETC F/6 20/6
MATCHED FILTERING WITH ACHROMATIC OPTICAL CORRELATORS.(U)

FEB 82 J UPATNEIKS, J G DUTHIE, P R ASHLEY

UNCLASSIFIED

DRSMI/RR-82-5-YR

SB1-AD-E950 266

NL

1-1

01-82

END

DATE

FORMED

09-82

DTIC

file 950 266

12

AD A118431



TECHNICAL REPORT RR-82-5

**MATCHED FILTERING WITH ACHROMATIC
OPTICAL CORRELATORS**

Juris Upatnieks, J. G. Duthie and Paul R. Ashley
Research Directorate
US Army Missile Laboratory

23 February 1982



U.S. ARMY MISSILE COMMAND
Redstone Arsenal, Alabama 35809

Approved for public release; distribution unlimited.

DTIC
COLLECTE
AUG 20 1982

DTIC FILE COPY

82 08 03 012

DISPOSITION INSTRUCTIONS

**DESTROY THIS REPORT WHEN IT IS NO LONGER NEEDED. DO NOT
RETURN IT TO THE ORIGINATOR.**

DISCLAIMER

**THE FINDINGS IN THIS REPORT ARE NOT TO BE CONSTRUED AS AN
OFFICIAL DEPARTMENT OF THE ARMY POSITION UNLESS SO DESIGNATED BY OTHER AUTHORIZED DOCUMENTS.**

TRADE NAMES

**USE OF TRADE NAMES OR MANUFACTURERS IN THIS REPORT DOES
NOT CONSTITUTE AN OFFICIAL INDORSEMENT OR APPROVAL OF
THE USE OF SUCH COMMERCIAL HARDWARE OR SOFTWARE.**

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER RR-82-5	2. GOVT ACCESSION NO. AD-A118 431	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) MATCHED FILTERING WITH ACHROMATIC OPTICAL CORRELATORS		5. TYPE OF REPORT & PERIOD COVERED Technical Report
		6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) Juris Upatnieks and J. Graeme Duthie		8. CONTRACT OR GRANT NUMBER(s)
9. PERFORMING ORGANIZATION NAME AND ADDRESS Commander, US Army Missile Command ATTN: DRSMI-RR Redstone Arsenal, AL 35898		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS
11. CONTROLLING OFFICE NAME AND ADDRESS Commander, US Army Missile Command ATTN: DRSMI-RPT Redstone Arsenal, AL 35898		12. REPORT DATE 23 Feb 82
		13. NUMBER OF PAGES 20
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Optical data processing Holography Correlator Optics Missile Guidance		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) An achromatic Fourier transform system for use in an optical correlator has been designed and used with incoherent light to obtain autocorrelations of pictures of aerial views of urban areas. The necessary optics included achromatic lenses and some highly achromatic holographic elements in a unique arrangement to produce wavelength independent Fourier transforms.		

DD FORM 1 JAN 73 1473

EDITION OF 1 NOV 65 IS OBSOLETE

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

CONTENTS

	Page
I. INTRODUCTION.	3
II. ANALYSIS AND COMPARISON OF PROPOSED ACHROMATIC FOURIER TRANSFORM SYSTEMS.	3
III. EXPERIMENTS	9
IV. SUMMARY AND CONCLUSIONS	13
BIBLIOGRAPHY.	15

Accession For		
NTIS GRA&I	☒	
DTIC TAB	☐	
Unannounced	☐	
Justification		
By		
Distribution		
Accession Codes		
Distribution or		
Distribution		
A		



I. INTRODUCTION

Infrared-emitting diodes have high power output, small spatially incoherent radiating surfaces, and potentially low price that would make them useful as radiation sources for coherent optical correlators. Limited spatial coherence reduces alignment accuracy requirements, and to some extent, also scale and orientation accuracy. One limitation of the diode is that it has too broad a bandwidth to be used in a typical coherent correlator.

The basic Fourier transform relationship of a typical coherent optical correlator contains wavelength as one of the factors: the transform scale is proportional to wavelength. With a broadband radiation source, only the transform generated by a narrow portion of the bandwidth matches the scale of the filter. To correct this problem, an achromatic Fourier transform system is needed.

This report compares and evaluates two achromatic Fourier transform systems described in the literature. The performance of the simplest system is estimated and experiments performed with it are described. A bibliography of recent reports and publications on coherent optical correlators from the Research Directorate, United States Army Missile Command at Redstone Arsenal, Alabama, is included.

II. ANALYSIS AND COMPARISON OF PROPOSED ACHROMATIC FOURIER TRANSFORM SYSTEMS

Three publications contain the original derivations and descriptions of achromatic Fourier transform systems. The first by Katyl¹ describes a system in which lateral and axial magnification is held constant and an approximate optical system for implementing it is described. Morris² uses a somewhat similar approach but with great detail and a thorough analysis. He also proposes how to implement the system with greater accuracy than in Katyl's paper. Collins³ uses a linear system analysis approach and includes error analysis of an approximate implementation of his system.


In order to compare the expected performance of the Morris and Collins achromatic Fourier transform systems, a ray tracing analysis approach was used. Figures 1(a) and (b) show the two systems. A ray originates at the input plane at a distance y_1 above the axis in a direction determined both by the frequency of an assumed test grating and the wavelength of radiation. An equation is then written for the intercept of this ray with the output plane assuming perfect thin lenses and using small angle approximations. The equations used for these calculations are as follows:

$$\theta_1 = \lambda f - y_1/F_1 \quad (1)$$


¹Robert H. Katyl, "Compensating Optical Systems. Part 3: Achromatic Fourier Transformation," Appl. Opt. 11, p. 1255 (May 1972).

²G. M. Morris, "Diffraction Theory from Achromatic Fourier Transformation," Appl. Opt. 20, p. 2017 (June 1981).

³G. D. Collins, "Achromatic Fourier Transform Holography," Appl. Opt. 20, p. 3109 (September 1981).



(a) Morris System.



(b) Collins System.

Figure 1. Geometry for ray trace analysis of achromatic Fourier transform.

where λ is the wavelength of light, f is the spatial frequency of the test grating and $-y_1/F_1$ is the angular ray direction change by the lens of focal length F_1 in contact with the grating. At other lenses, the ray direction change $\Delta\theta$ is given by

$$\Delta\theta = -y/F \quad , \quad (2)$$

where y is the ray intercept of the lens and F is the focal length.

An expression for the ray y_3 intercept at the last, the Fourier transform, plane is given for Figure 1(a) by

$$y_3 = y_1 + 2F\theta_1 + F\Delta\theta_2 \quad , \quad (3)$$

where

$$\Delta\theta_2 = -y_2/F_2 = -(y_1 + \lambda f F - y_1 F/F_1)/F_2 \quad . \quad (4)$$

Substitutions of Equations (1) and (4) into Equation (3) yields the result

$$y_3 = \lambda f F (2 - F/F_2) + y_1 (1 - 2F/F_1 - F/F_2 + F^2/F_1 F_2) \quad . \quad (5)$$

The desired result is to have y_3 independent of λ and y_1 , or

$$y_3 = \lambda_o f F \quad , \quad (6)$$

which implies that the coefficient of y_1 in Equation (5) should equal to zero. Equating Equation (5) to Equation (6) yields the required focal lengths of the two lenses:

$$1/F_1 = (1/F)(1 - \lambda/\lambda_o) \quad (7)$$

$$1/F_2 = (1/F)(2 - \lambda_o/\lambda) \quad . \quad (8)$$

These results are the same as derived by Morris in Equations (18) and (19). Since y_3 is independent of y_1 , the achromatization is space invariant. The first lens, described by Equation (7), consists of a position achromat of focal length F and negative lens whose focal length is inversely proportional to the wavelength of light, $-F\lambda_o/\lambda$. This element is a holographic lens.

The second lens described by Equation (8) consists of a positive achromat of focal length $F/2$ and a negative lens whose focal length is proportional to the wavelength of light, $-F\lambda/\lambda_o$. This lens cannot be easily implemented, although Morris has designed a rather exact approximation. The above lens combination can be roughly approximated by a single element holographic lens.

This can be explained as follows: let $\lambda = \lambda_0 + \Delta\lambda$ which then gives

$$2 - \lambda_0/\lambda = 1 + \Delta\lambda/\lambda_0 - (\Delta\lambda/\lambda_0)^2 + \dots \quad (9)$$

as the required coefficient of $1/F$. If instead, the coefficient of $1/F$ is that of a holographic lens, λ/λ_0 , then

$$\lambda/\lambda_0 = 1 + \Delta\lambda/\lambda_0 \quad (10)$$

Thus, the first two terms of Equation (1) are the same as those of Equation (9), while the higher order terms of Equation (9) are not generated by the holographic lens.

The achromatic Fourier transform system derived by Collins can be analyzed in a similar way. Because this system contains two achromatic lenses besides the two initially unspecified lenses, the derivation is much more complex. The equations for Figure 1(b) are:

$$y_5 = y_1 + 4F\theta_1 + 3F\Delta\theta_2 + 2F\Delta\theta_3 + F\Delta\theta_4 \quad (11)$$

$$\theta_1 = f\lambda - y_1/F_1 \quad (12)$$

$$\Delta\theta_2 = -y_2/F_2 = -(y_1 + F\theta_1)/F_2 \quad (13)$$

$$\Delta\theta_3 = -y_3/F_3 = -(y_1 + 2F\theta_1 + F\Delta\theta_2)/F_3 \quad (14)$$

$$\Delta\theta_4 = -y_4/F_4 = -(y_1 + 3F\theta_1 + 2F\Delta\theta_2 + F\Delta\theta_3)/F_4 \quad (15)$$

Equations (11) through (15) yield an expression for y_5 :

$$y_5 = -\lambda f F (F/F_3) + y_1 [-1 + F^2/(F_1 F_3)] \quad (16)$$

Letting $y_5 = \lambda_0 f F$ and setting the coefficient of $y_1 = 0$, we can solve for the two unspecified focal lengths:

$$1/F_1 = -(1/F)(\lambda/\lambda_0) \quad (17)$$

$$1/F_3 = -(1/F)(\lambda_0/\lambda) \quad (18)$$

As before, the first lens contains a negative holographic lens but without the achromat; the second lens again requires a lens where focal length is proportional to the wavelength of light. This lens can be approximated by the lens

$$1/F_3 = 1/F(-2 + \lambda/\lambda_0) \quad (19)$$

consisting of a negative achromat of focal length $F/2$ and a positive holographic zone plate of focal length $F\lambda_0/\lambda$.

Comparison of Equations (7) and (8) with Equations (17) and (18) shows that both systems require the same type of lenses: one holographic lens and one with focal length proportional to wavelength. In this respect, both systems are similar. Since the Morris proposed system has $2F$ overall length while the Collins system has $4F$ length and, besides that, needs two additional achromatic lenses, the Morris system was selected. Several additional calculations were made about the Morris system.

A spacing was introduced between the object plane and the first lens in Figure 1(a). The calculated values were the same as in Equations (7) and (8), indicating the achromatization is independent of input image position.

A grating was added halfway between the first and second lens element as shown in Figure 2. Using small angle approximations and choosing the carrier frequencies of lens F_1 and F_3 to be half of the grating frequency at plane 2, again the same expressions were found for F_1 and F_3 . This indicates that the required holographic lenses could be recorded on a carrier frequency without destroying the achromatic properties of the system.

Also, Equation (20) in the Morris paper was examined. This equation indicates that an achromat plus a negative holographic lens is needed to correct for residual phase errors. The negative holographic lens could be implemented by recording the matched filter with a diverging reference beam, as in Figure 3. The achromatic lens is of no importance since, typically, an achromatic lens is used anyway to focus the diffracted beam.

Finally, the achromatized system was compared with a chromatic Fourier transform system. In the chromatic system, the ray intercept is given by

$$y = \lambda f F$$

$$= \lambda_o f F (1 + \Delta\lambda/\lambda_o) \quad , \quad (20)$$

where the $\Delta\lambda/\lambda_o$ term represents an error. A similar expression can be derived for the achromatized Morris system using two holographic lenses:

$$y = \lambda_o f F [1 - (\Delta\lambda/\lambda_o)^2] \quad . \quad (21)$$

Thus, the error is reduced by the factor $\Delta\lambda/\lambda_o$. Since the expression

$$N = \lambda/\Delta\lambda \quad (22)$$

was previously derived^{4,5} where N is the number of resolved points that can

⁴J. Upatnieks, "Optical Correlator with Laser Diode Sources," Final Report for Battelle Task Order No. 1095 (October 1979).

⁵J. G. Duthie, J. Upatnieks, C. R. Christensen, and R. D. McKenzie, Jr., "Real-Time Optical Correlators with Solid-State Sources," SPIE Vol. 231, International Optical Computing Conference (1980).




Figure 2. Modified Morris achromatic Fourier transform system.




Figure 3. Filter recording geometry that includes the equivalent of a negative holographic lens.

be correlated by a light source of bandwidth $\Delta\lambda$, then it is reasonable to deduce from Equations (20) to (22) above that

$$N = (\lambda/\Delta\lambda)^2 \quad (23)$$

for the approximate achromatic system.

III. EXPERIMENTS

Figure 4 shows the achromatic Fourier transform coherent optical correlator that was assembled. Two holographic lenses were recorded on Kodak 649F emulsions in dichromated gelatin, as was the grating. The carrier frequencies of the two holographic lenses were the same, and the grating frequency was twice that of the lenses. This system prevented the undiffracted light from reaching the Fourier transform plane. An argon laser was set up nearby so that either a mercury arc lamp or the laser could be used as the light source.

After the system was set up, the point focus of the light source was observed in the Fourier transform plane with a microscope. With a spectrally unfiltered mercury arc lamp as the source, a slight chromatic aberration was visible. It was found that this aberration could be corrected by adjusting the position of lens L_1 which caused the light incident on the input plane to be noncollimated.

Two crossed Ronchi rulings were then inserted at the input plane and the Fourier transform was observed. Some chromatic dispersion was visible which could be corrected by adjusting the spacing between lens L_2 , L_3 , and the grating. The required adjustment for the two orthogonal directions of the transform was somewhat different, thus complete correction could be achieved for only one direction. Figure 5(a) shows a photograph of the spectrum with a chromatic Fourier transform system and Figure 5(b) shows the spectrum taken with the achromatic Fourier transform system.






Figure 4. Experimental achromatic Fourier transform system.



(a)



(b)

Figure 5. Fourier transforms of two crossed gratings: (a) with chromatic system and (b) with achromatic system. The Ronchi rulings had 8 1/mm and 10 1/mm frequency, and the light source was a mercury arc lamp.


Several matched filters were constructed of an aerial view of Huntsville, Alabama, with an argon laser light source operating at 514.5 nm wavelength. Correlations were obtained both the the argon laser as well as with the spectrally unfiltered mercury arc lamp. Figure 6 shows the correlation lines formed by the mercury green line at 546 nm and the amber line at 578 nm simultaneously. Similar results were obtained laser year⁶ with the mercury arc lamp and a chromatic Fourier transform system. In that case, however, correlation could be obtained at one wavelength at a time.

Correlations with a mercury arc lamp could be observed only when an ordinary matched filter was copied onto dichromated gelatin to improve its efficiency. Even then, the light level was very low and measurements with a TV camera and line scan recording could not be made. Overall light efficiency of the achromatic system was lower than that of a chromatic system because the holographic lenses and the grating were somewhat lossy, with about 25 percent overall efficiency.

Several observations were made concerning the achromatic correlator:

- With argon laser green light, about $0.02 \mu\text{W}/\text{cm}^2$ object illumination was needed to form a barely visible correlation spot.
- With a 1000-watt mercury arc lamp, 380-mm focal length collimating lens and 25- μm diameter pinhole filter, the object irradiance was at 0.7 to 1.5 $\mu\text{W}/\text{cm}^2$ at the object plane.
- Comparison of the correlation peaks obtained with 25- μm and 100- μm diameter pinholes showed a slight increase in correlation spot diameter with the 100- μm diameter pinhole. This effect was probably caused by imperfect achromatization of the system.
- Best correlations were obtained with an object transparency that was an aerial photograph of Huntsville, Alabama. This photograph contained high spatial frequencies.
- The holographic lenses had several deficiencies: considerable light scattering and less than maximum possible diffraction efficiency. In coherent light, the scattered light strongly correlated with the filter; in broad-spectrum light, only the object correlated because the noise was not achromatized.
- Although the holographic elements had very high efficiencies when measured in the monochromatic light in which they were made, the diffraction efficiencies were strongly wavelength dependent since the Bragg condition was satisfied only for one wavelength. However, in an application using a high power light emitting diode, which has a relatively narrow bandwidth, this may not be as bothersome a deficiency as with the mercury arc lamp source.

⁶J. Upatnieks, "Coherent Optical Correlation with Semicoherent Light Sources," Final Report for Battelle Delivery Order No. 1432 (December 1980).



(a)



(b)

Figure 6. Correlations obtained with the achromatic Fourier transform system: (a) dispersed correlation peak and (b) integrated correlation peak with a mercury arc lamp.

IV. SUMMARY AND CONCLUSIONS

A ray tracing method of analysis was developed and applied to the two proposed achromatic Fourier transform systems. The analysis indicated that both proposed systems should work equally well. The needed wavelength dispersive elements can be approximated with holographic optical elements (HOE's). A modification was introduced to the simplest of the two systems: a grating was added which allowed the HOE's to be recorded on a carrier and without a grating in contact with each of the two elements. This arrangement allowed a reduction of the needed diffractive elements from four to three, and prevented undiffracted light from reaching the Fourier transform plane.

An achromatic Fourier transform system was assembled and tested. Correction of chromatic dispersion of focus and frequency spectrum were achieved over approximately 32 nm bandwidth at a center wavelength of 562 nm. Matched filters were fabricated and correlations were achieved with broadband light over 32 nm bandwidth. The correlation peak was difficult to observe due to low light outputs of the lamp and the losses by the HOE's.

Improved results should be possible by making several improvements in the system. First, the efficiency of the HOE's and gratings should be improved and scattering level should be decreased. Second, a brighter light source, such as the Ozram 100-watt mercury lamp, in conjunction with low-aberration imaging lenses, should be used. The potential increase in available light with the lamp is at least a factor of five. Matched filters should be recorded on dichromated gelatin and their efficiency optimized to the frequency band corresponding to the object.

Many questions remain unanswered concerning the achromatic Fourier transform system. All of the analysis to date is based on idealized thin lens and small angle approximations. More thorough analysis is needed to determine its expected performance and limitations. Such analysis could be done, for example, with ray tracing programs such as the HOAD. Precise experimental investigation also would be useful. The HOE elements and gratings should be fabricated and tested with the same care as high-quality lenses before they are used in an optical system.

The experiments described here proved that correlators can be achromatized over the bandwidth range of a typical infrared-emitting diode. However, the construction of the required HOE's and alignment of the system at an invisible wavelength will not be a simple task.

BIBLIOGRAPHY

1. "Coherent Optical Correlation with Semicoherent Light Sources," Final Report for Battelle Delivery Order No. 1432 (December 1980).
2. "Optical Correlator with Laser Diode Radiation Source," Final Report for Battelle Delivery Order No. 1095 (October 1979).
3. "Vehicle Identification and Tracking Using a Coherent Optical Correlator," Final Report for Battelle Delivery Order No. 0670 (October 1978).
4. J. G. Duthie, Juris Upatnieks, C. R. Christensen, and R. D. McKenzie, Jr., "Real-Time Optical Correlation with Solid-State Sources," SPIE 1980 International Optical Computing Conference, Vol. 231, pp. 281-290.
5. Charles R. Christensen and Richard L. Hartman, "Optical Correlation Seeker," U. S. Army Missile Command Technical Report RR-80-4 (5 May 1980).
6. "Real-Time Optical Correlator for Missile Guidance," Final Report for Battelle Delivery Order No. 0489 (November 1977).
7. B. D. Gunther, C. R. Christensen, and J. Upatnieks, "Coherent Optical Processing: Another Approach," IEEE J. of Quantum Electronics QE-15, No. 12, pp. 1348-1362 (December 1979).
8. C. R. Christensen, J. Upatnieks, and B. D. Guenther, "Vehicle Identification and Tracking Using a Coherent Optical Correlator," U. S. Army Missile Research and Development Command Technical Report T-79-18 (19 January 1979).
9. J. Upatnieks, B. D. Guenther, and C. R. Christensen, "Real-Time Correlation for Missile Terminal Guidance," U. S. Army Missile Research and Development Command Technical Report H-78-5 (1 January 1978).

DISTRIBUTION

	No. of Copies
Commander US Army Research Office ATTN: DRXRO-PH, Dr. R. Lontz P. O. Box 12211 Research Triangle Park, NC 27709	5
US Army Research and Standardization Group (Europe) ATTN: DRXSN-E-RX, LTC D. R. Reinhard Box 65 FPO New York 09510	1
Commander US Army Materiel Development and Readiness Command ATTN: Dr. James Bender Dr. Gordon Bushey 5001 Eisenhower Avenue Alexandria, VA 22333	1 1
Headquarters, Department of the Army Office of the DCS for Research, Development & Acquisition ATTN: DAMA-ARZ Room 3A474, The Pentagon Washington, DC 20301	1
OUSDR&E Room 3D1079, The Pentagon Washington, DC 20301	1
Director Defense Advanced Research Projects Agency 1400 Wilson Boulevard Arlington, VA 22209	1
OUSDR&E ATTN: Dr. G. Gamota Deputy Assistant for Research (Research in Advanced Technology) Room 3D1067, The Pentagon Washington, DC 20301	1
Director of Defense Research and Engineering Engineering Technolgy Washington, DC 20301	1
Director Defense Advanced Research Projects Agency/STO ATTN: Commander T. F. Wiener D. W. Walsh 1400 Wilson Boulevard Arlington, VA 22209	1 1

Commander US Army Aviation Systems Command 12th and Spruce Streets St. Louis, MO 63166	1
Director US Army Air Mobility Research & Development Laboratory Ames Research Center Moffett Field, CA 94035	1
Commander US Army Electronics Research & Development Command ATTN: DRSEL-TL-T, Dr. Jacobs	1
DELEW-R, Henry E. Sonntag	1
Fort Monmouth, NJ 07703	
Director US Army Night Vision Laboratory ATTN: John Johnson	1
John Deline	1
Peter VanAtta	1
Fort Belvoir, VA 22060	
Commander US Army Picatinny Arsenal Dover, NJ 07801	1
Commander US Army Harry Diamond Laboratories 2800 Powder Mill Road Adelphi, MD 20783	1
Commander US Army Foreign Science and Technology Center ATTN: W. S. Alcott	1
Federal Office Building 220 7th Street, NE Charlottesville, VA 22901	
Commander US Army Training and Doctrine Command Fort Monroe, VA 22351	1
Director Ballistic Missile Defense Advanced Technology Center ATTN: ATC-D	1
ATC-O	1
ATC-R	1
ATC-T	1
P. O. Box 1500 Huntsville, AL 35808	
Commander US Naval Air Systems Command Missile Guidance and Control Branch Washington, DC 20360	1

Chief of Naval Research Department of the Navy Washington, DC 20301	1
Commander US Naval Air Development Center Warminster, PA 18974	1
Commander, US Naval Ocean Systems Center Code 6003, Dr. Harper Whitehouse San Diego, CA 92152	1
Director, Naval Research Laboratory ATTN: Dave Ringwolt Code 5570, T. Gialborinzi Washington, DC 20390	1 1
Commander, Rome Air Development Center US Air Force ATTN: James Wasielewski, IRRC Griffiss Air Force Base, NY 13440	1
Commander, US Air Force, AFOSR/NE ATTN: Dr. J. A. Neff Building 410, Bolling Air Force Base Washington, DC 20332	1
Commander, US Air Force Avionics Laboratory ATTN: D. Rees W. Schoonover Dr. E. Champaign Dr. J. Ryles Gale Urban David L. Flannery Wright Patterson Air Force Base, OH 45433	1 1 1 1 1 1
Commander, AFATL/LMT ATTN: Charles Warren Eglin Air Force Base, FL 32544	1
Environmental Research Institute of Michigan Radar and Optics Division ATTN: Dr. A. Kozma Dr. C. C. Aleksoff Juris Upatnieks P. O. Box 8618 Ann Arbor, MI 41807	1 1
IIT Research Institute ATTN: GACIAC 10 West 35th Street Chicago, IL 60616	1
Dr. J. G. Castle 9801 San Gabriel, NE Albuquerque, NM 87111	1

Commander, Center for Naval Analyses ATTN: Document Control 1401 Wilson Boulevard Arlington, VA 22209	1
Dr. J. W. Goodman Information Systems Laboratory Department of Electrical Engineering Stanford University Stanford, CA 04305	1
Eric G. Johnson, Jr. National Bureau of Standards 325 S. Broadway Boulder, CO 80302	1
Dr. Nicholas George The Institute of Optics University of Rochester Rochester, NY 14627	1
Naval Avionics Facility Indianapolis, IN 46218	1
Dr. David Cassasent Carnegie Mellon University Hamerschage Hall, Room 106 Pittsburg, PA 15213	1
Professor Anil K. Jain Department of Electrical Engineering University of California, Davis Davis, CA 95616	1
Terry Turpin Department of Defense 9800 Savage Road Fort George G. Meade, MD 20755	1
Dr. Stuart A. Collins Electrical Engineering Department Ohio State University 1320 Kennear Road Columbus, OH 43212	1
US Army Materiel Systems Analysis Activity ATTN: DRXSY-MP Aberdeen Proving Ground, MD 21005	1
US Army Night Vision Laboratory ATTN: DELNV-L, Dr. R. Buser Ft. Belvoir, VA 22060	1
Dr. F. T. S. Yu Penn State University Department of Electrical Engineering University Park, PA 16802	1

Dr. William P. Bleha	1
Liquid Crystal Light Valve Devices	
Hughes Aircraft Company	
6155 El Camino	
Carlsbad, CA 92008	
DRCPM-PE-E, John Pettitt	1
-PE	1
DRSMI-LP, Mr. Voigt	1
-O	1
-Y	1
-R	1
-RN, Jerry Hagood	1
-RE, W. Pittman	1
-RD	3
-RG	1
-RG, J. A. McLean	1
-RR, Dr. R. L. Hartman	1
Dr. J. S. Bennett	1
Dr. C. R. Christensen	1
Dr. J. G. Duthie	80
-RPR	15
-RPT	1

