


AD-A154161

(2)

RADC-TR-84-244
Final Technical Report
December 1984




AUTOMATED FMEA TECHNIQUES

Hughes Aircraft Company

Peter L. Goddard and Richard Davis

APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED

Reproduced From
Best Available Copy



**ROME AIR DEVELOPMENT CENTER
Air Force Systems Command
Griffiss Air Force Base, NY 13441-5700**

20000811019

85-64 30 457

AD-A154161

DTIC FILE COPY

This report has been reviewed by the RADC Public Affairs Office (PA) and is releasable to the National Technical Information Service (NTIS). At NTIS it will be releasable to the general public, including foreign nations.


RADC-TR-64-244 has been reviewed and is approved for publication.

APPROVED:




HEATHER DUSSAULT
Project Engineer

APPROVED:



ANTHONY J. FEDUCCIA, Acting Chief
Reliability & Compatibility Division

FOR THE COMMANDER:



JOHN A. RITZ
Acting Chief, Plans Office

If your address has changed or if you wish to be removed from the RADC mailing list, or if the addressee is no longer employed by your organization, please notify RADC (RBET) Griffiss AFB NY 13441-5700. This will assist us in maintaining a current mailing list.

Do not return copies of this report unless contractual obligations or notices on a specific document requires that it be returned.

UNCLASSIFIED
SECURITY CLASSIFICATION OF THIS PAGE

REPORT DOCUMENTATION PAGE													
1a. REPORT SECURITY CLASSIFICATION UNCLASSIFIED		1b. RESTRICTIVE MARKINGS N/A											
2a. SECURITY CLASSIFICATION AUTHORITY N/A		3. DISTRIBUTION/AVAILABILITY OF REPORT Approved for public release; distribution unlimited											
2b. DECLASSIFICATION/DOWNGRADING SCHEDULE N/A													
4. PERFORMING ORGANIZATION REPORT NUMBER(S) N/A		5. MONITORING ORGANIZATION REPORT NUMBER(S) RADC-TR-84-244											
6a. NAME OF PERFORMING ORGANIZATION Hughes Aircraft Company		6b. OFFICE SYMBOL (If applicable)		7a. NAME OF MONITORING ORGANIZATION Rome Air Development Center (RBET)									
6c. ADDRESS (City, State and ZIP Code) Ground Systems Group Fullerton CA 92634		7b. ADDRESS (City, State and ZIP Code) Griffiss AFB NY 13441-5700											
8a. NAME OF FUNDING/SPONSORING ORGANIZATION Rome Air Development Center		8b. OFFICE SYMBOL (If applicable) RBET		9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER F30602-82-C-0072									
8c. ADDRESS (City, State and ZIP Code) Griffiss AFB NY 13441-5700		10. SOURCE OF FUNDING NOS. <table border="1"><tr><td>PROGRAM ELEMENT NO. 62702F</td><td>PROJECT NO. 2338</td><td>TASK NO. 02</td><td>WORK UNIT NO. 74</td></tr></table>			PROGRAM ELEMENT NO. 62702F	PROJECT NO. 2338	TASK NO. 02	WORK UNIT NO. 74					
PROGRAM ELEMENT NO. 62702F	PROJECT NO. 2338	TASK NO. 02	WORK UNIT NO. 74										
11. TITLE (Include Security Classification) AUTOMATED FMEA TECHNIQUES													
12. PERSONAL AUTHOR(S) Peter L. Goddard, Richard Davis													
13a. TYPE OF REPORT Final		13b. TIME COVERED FROM Apr 82 TO Mar 84		14. DATE OF REPORT (Yr., Mo., Day) December 1984									
15. PAGE COUNT 166													
16. SUPPLEMENTARY NOTATION N/A <i>Failure Modes and Effects Analysis</i>													
17. COSATI CODES <table border="1"><tr><th>FIELD</th><th>GROUP</th><th>SUB. GR.</th></tr><tr><td>14</td><td>04</td><td>08</td></tr><tr><td>14</td><td>04</td><td>10</td></tr></table>			FIELD	GROUP	SUB. GR.	14	04	08	14	04	10	18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number) FMEA Automated Techniques Standardized Techniques Failure Modes	
FIELD	GROUP	SUB. GR.											
14	04	08											
14	04	10											
19. ABSTRACT (Continue on reverse if necessary and identify by block number) The techniques traditionally in use for FMEA have been fragmented in approach and not fully automated. These limitations can result in FMEA's being performed which are inconsistent in quality and approach. The Advanced Matrix FMEA Technique is presented as a standardized FMEA technique, and the automation of this technique is discussed. Additionally, the results of research into component failure modes to support FMEA are presented. <i>502 p 1</i>													
20. DISTRIBUTION/AVAILABILITY OF ABSTRACT UNCLASSIFIED/UNLIMITED ☒ SAME AS RPT. ☐ DTIC USERS ☐			21. ABSTRACT SECURITY CLASSIFICATION UNCLASSIFIED										
22a. NAME OF RESPONSIBLE INDIVIDUAL Heather B. Dussault			22b. TELEPHONE NUMBER (Include Area Code) (315) 330-2951	22c. OFFICE SYMBOL RADC (RBET)									

TABLE OF CONTENTS

	Page
1. EXECUTIVE SUMMARY	
1.1 Purpose of the Study	1
1.2 Phase I Activity	2
1.3 Phase I Conclusions	3
1.4 Phase II Activity	4
1.5 Recommendations for Future Research	5
 2. PHASE I STUDY ACTIVITY	
2.1 Specification and Standard Evaluation	7
2.2 Current Techniques in FMEA	10
2.2.1 Common Fault/Failure Analysis Techniques	12
2.2.1.1 Fault Tree Analysis	12
2.2.1.2 Failure Modes and Effects Analysis	12
2.2.1.3 Common Cause Analysis	13
2.2.1.4 Event Sequence Analysis	13
2.2.2 Fault/Failure Analysis for Electronics	13
2.2.3 New Developments in FMEA	16
2.2.4 Weak Areas in FMEA	17
2.3 Industry Survey	18
2.3.1 Industry Comments	19
2.3.2 Degree of Industry Automation	21
2.4 Commercially Available FMEA Automated Aids	21
2.4.1 Circuit Analysis Programs	22
2.4.2 Clerical FMEA Programs	22
2.4.3 Overall Evaluation	22
2.5 Phase I Conclusions	23
2.5.1 Feasibility of Developing a Standardized Technique	23
2.5.2 Feasibility of Developing FMEA Automated Tools	25
 3. PHASE II STUDY ACTIVITY OVERVIEW	
3.1 Components Overview	27
3.2 FMEA Recommendations Overview	28

TABLE OF CONTENTS (Continued)

	Page
3.3 Standardized Technique Overview	28
3.4 FMEA Automation Overview	29
 4. COMPONENT ACTIVITY	
4.1 Industry Survey	32
4.2 Literature Search	32
4.3 High Usage Parts	33
4.4 Complex Microelectronic Devices	34
 5. GENERAL FMEA CONSIDERATIONS	
5.1 FMEA Program Phasing	45
5.1.1 Program Phases	46
5.1.1.1 Conceptual Phase	46
5.1.1.2 Validation Phase	46
5.1.1.3 Full-Scale Engineering Development Phase	47
5.1.1.4 Production Phase	48
5.2 FMEA Activity Overview	49
5.3 FMEA Activity in Full-Scale Engineering Development	51
5.4 FMEA Activity During Production	53
5.5 FMEA Procurement Approach	54
5.6 Failure Severity Categorization	55
5.7 Maintainability and Testability Information	57
5.8 Human Engineering Considerations	58
5.9 FMEA Presentation Formats	59
5.10 Background of the FMEA Analyst	63
5.11 FMEA Use Limitations	63
 6. STANDARDIZED FMEA TECHNIQUE	
6.1 Introduction	65
6.2 Technique Overview	65
6.2.1 Advanced Matrix Technique Phasing	66

TABLE OF CONTENTS (Continued)

	Page
6.2.2 Advanced Matrix Technique Structure	68
6.2.3 MIL-STD-1629A Compliance	72
6.3 Advanced Matrix Technique Detail	74
6.3.1 FMEA Planning	75
6.3.2 Initial FMEA Activity	78
6.3.2.1 Specification Development	78
6.3.2.2 Operational Mode Definition	80
6.3.2.3 Define Fundamental Inputs and Outputs	81
6.3.2.4 Mnemonics	82
Mnemonic Assignment	83
6.3.2.5 Failure Effects Lists	85
6.3.2.6 Development of the Top-Level Matrices	86
Top-Level Block Diagram	86
Failure Mode to Operating Modes by Effect	
Matrix (FMOMEM)	87
Failure Mode to Operating Mode by Severity	
Matrix (FMOMSM)	89
6.3.2.7 Initial Activity Completion	90
6.3.3 Intermediate FMEA Activity	91
6.3.3.1 Mnemonics	92
6.3.3.2 Signal Failure Modes/Effects	93
6.3.3.3 Intermediate Matrix Analysis Development	93
Intermediate Matrix Structure	94
Intermediate Matrix Completion	94
Test Point Evaluation	100
Built-In-Test	100
Failure Severity	100
6.3.3.4 Intermediate Analysis Outputs	101
Matrix Outputs	101
Test Point and Indicator Adequacy Assessment	101
Built-in-Test Evaluation	101

TABLE OF CONTENTS (Continued)

	Page
Criticality Analysis	102
Design Guidelines	102
6.3.3.5 Completion of Intermediate FMEA Analysis	102
6.3.4 Detail Level FMEA Activity	103
6.3.4.1 Detail Level Matrix Development	103
Detail Matrix Structure	104
Detail Matrix Completion	104
Component Failure Modes	104
Two Terminal Devices	105
Relays	105
Connectors	105
Discrete Semiconductors	106
Microcircuits	106
Microcomputer and Modern Digital Architectures	107
6.3.4.2 Built-In-Test Assessment	109
6.3.4.3 Criticality Analysis	110
6.3.4.4 Test Point and Indicator Assessment	113
Assessment Development	113
Analysis Uses	115
 7. AUTOMATED TECHNIQUE	
7.1 Introduction	117
7.1.1 Automation Purpose	117
7.1.2 Automation Development Groundrules and Assumptions	117
7.1.2.1 Fortran Based	118
7.1.2.2 User Friendliness	118
7.1.2.3 User Interactive	118
7.1.2.4 Complement Advanced Automated Technique	119
7.1.2.5 Quick Response for Assembly Level Outputs	119
7.1.2.6 Minimum Training Requirement	123
7.1.2.7 Easy to Update	123

TABLE OF CONTENTS (Continued)

	Page
7.1.2.8 Computer Resource Requirements	123
7.1.2.9 System Output Response Time	123
7.2 Automation Package Overview	124
7.2.1 Program Description	124
7.2.2 Program Files	129
7.2.3 Program Outputs	131
7.3 Using FEADS for Advanced Automated Technique FMEAS	133
7.3.1 FMEA Planning	133
7.3.2 Initial FMEA Activity	145
7.3.3 Intermediate and Detail FMEA Activities	145
7.4 Program Limitations	146
 8. RECOMMENDATIONS FOR FURTHER STUDY	
8.1 Components	148
8.1.1 High-Usage Piece-Parts	148
8.1.2 Complex Microcircuits	150
8.2 FMEA Techniques	151
8.3 FMEA Automation	152
 REFERENCES	 153

S DTIC ELECTE D

MAY 29 1985

B

Accession For	
NTIS GRA&I	☒
DTIC TAB	☐
Unannounced	☐
Justification	
By _____	
Distribution/ _____	
Availability Codes	
Dist	Avail and/or Special
A-1	



The
SECTION 1 - EXECUTIVE SUMMARY

1.1 Purpose of the Study

The Study Purpose Was to Determine the Feasibility of Standardizing and Automating FMEA Techniques for Electronics and to Develop Such Techniques.	AUTOMATED FMEA TECHNIQUES
<i>→ See p 12</i> Phase I • Assess the feasibility of developing a standardized FMEA technique for electronic equipment • Determine the amount and type of automation which is both feasible and cost-effective Phase II • Standardize FMEA technique for electronic equipment where possible • Automate the standardized FMEA technique to the maximum extent possible consistent with cost-effectiveness • Assess the feasibility of characterizing the external terminal failure signatures of complex, multi-terminal electronic devices	

42829-1P

The Automated FMEA Techniques study was performed in two phases.

The purpose of Phase I was to assess the need for and feasibility of developing a standardized FMEA technique for electronic equipment. The feasibility of developing the standardized technique was assessed on the basis of a detailed examination of existing techniques for weak or void areas and an analysis of the information which would have to be developed to support a standardized technique. The feasibility of automating the standardized technique was assessed with respect to the use of existing automation tools, the development of a totally new automated tool, and the development of a hybrid package which embodied all or part of an existing tool within the automation package. The desirability of an automation package was assessed with respect to providing greater levels of detail for a fixed level of effort, reducing the overall analysis cost, and increasing the usability of the analysis by the multiple specialty engineering disciplines which could potentially extract data from an FMEA.

The purpose of Phase II was to develop a standardized FMEA technique for electronic equipment. The standard technique was to be based on existing techniques, if possible, and was to resolve any weak or void areas. The standard technique was to be automated to the maximum extent practical, consistent with the performance of a cost-effective FMEA. The developed automation, whether a totally new package, or a combination of existing automation tools and some newly developed automation was to be user friendly, transportable, and supportive of existing FMEA requirements. Additionally, the feasibility of characterizing the failure signatures of complex microelectronic devices, which are observable at the external terminals, was to be investigated and the characterization included in the standardized FMEA, if possible.

SECTION 1 - EXECUTIVE SUMMARY

1.2 Phase I Activity

Phase I Determined the Feasibility of Developing and Automating a Standardized FMEA Technique and Its Appropriate Limitations		AUTOMATED FMEA TECHNIQUES
STUDY TASK	RESULTS	42829-2P
Assess the FMEA specifications and standards currently in use for FMEA	FMEA specifications and standards define the analysis and provide a contractual baseline for deliverable data	
Review the technical literature on FMEA	- Except for G.L. Barbour's matrix technique there has been very little development of new FMEA methodology - There is no recognized single source for component failure modes	
Survey the technical community to assess the availability and existence of proprietary and non proprietary tools and techniques	The amount of computerization accomplished by individual companies is small and limited to some clerical assistance to the engineer performing the analysis	
Survey the commercial marketplace for existing analysis programs which can be used to perform or support FMEA	- Commercially available computer programs are intended for circuit analysis and are limited in FMEA applicability - Commercially available programs are large, expensive, and difficult or impossible to integrate and modify for FMEA requirements	

The approach used in determining the feasibility of developing a standardized, automated FMEA technique was to initially determine the relevant strengths and weaknesses of existing techniques and to examine the feasibility of strengthening any identified weak areas. An availability assessment was then made of the availability of sources of information required for FMEA but not readily available within the electronics industry was then made. This included relevant military and industrial standards, technical literature on FMEA, and a direct survey of the technical community. In addition, an examination was made of automated tools which are currently available and potentially usable for FMEA purposes.

The standards and literature reviewed were limited to material published within the last ten years and to the latest revision of standards available. It was found that the specifications and standards are adequate for their intended purpose. They uniquely define the intended analysis and form a contractual basis for delivery of the FMEA. The technical literature revealed only one significant new technique within the FMEA technology, the matrix technique developed by G.L. Barbour and published in 1977.

The industry survey revealed that very little FMEA computerization has been accomplished and what is available is clerical in nature. The survey of available automated tools found that most design analysis programs had major limitations with respect to FMEA purposes. The one clerical FMEA program identified is expensive and requires specialized user training.

No industry-recognized source for component failure modes and the frequency of their occurrence was found. This information is required if numerically accurate piece-part criticality assessment is to be performed.

SECTION 1 - EXECUTIVE SUMMARY

1.3 Phase I Conclusions

Phase I Concluded that a Standardized, Automated FMEA Technique Using the Matrix Method is Both Needed and Feasible

AUTOMATED FMEA TECHNIQUES

42829-3F

- The current FMEA standards and specifications are adequate for their intended purpose but do not provide a standardized FMEA technique
- Standardization of FMEA techniques is feasible and should be based on an expansion of the matrix technique
- Automation of circuit analysis for direct FMEA use is not feasible
- Automation of the effects analysis functions is feasible and cost-effective
- A compilation of component failure mode data is desirable if it can be obtained cost-effectively

The matrix FMEA technique is the most promising methodology for standardization. It provides a significant reduction in clerical labor compared to the MIL-STD-1629A tabular format, increases readability, and allows information to be readily extracted. Its primary limitation is its inability to contain commentary material.

The development of a standardized technique was determined to be feasible in terms of depth of analysis, program phasing, presentation format, and usability of results. The standardization of electronic circuit analysis, similar to that imposed for reliability predictions by MIL-HDBK-217, was not considered feasible.

An automation tool to perform circuit analysis and provide an FMEA based on that analysis is not considered feasible. Large circuit emulation programs are limited in types and size of circuits analyzed and are structured to produce an output in terms of signal parameters at a specific nodal point. They require the circuit design engineer's interpretation of the effects in every case.

An automation tool to reduce the clerical effort required for an FMEA is feasible. The several proprietary programs in existence are limited in scope. The one commercially available program for clerical workload reduction is fairly expensive and requires a training course.

A compilation of component failure modes for FMEA usage is needed for accurate criticality analysis. There may be adequate compiled failure records and studies available within the electronics industry to allow a centralized source to be developed for components which have been in use for many years. These data compilations should be investigated to determine the approximate component failure modes and their associated rates.

SECTION 1 - EXECUTIVE SUMMARY

1.4 Phase II Activity

In Phase II, a Standardized FMEA Technique Using the Matrix Approach was Developed, Along with Appropriate Automated Aids

**AUTOMATED
FMEA
TECHNIQUES**

4209 AD

Study Task

Result

- | | |
|--|---|
| ● Develop a standardized FMEA technique which is comprehensive, time and cost-effective, and can be automated | — A standardized FMEA technique based on an expansion of the matrix technique has been developed |
| ● Develop an automation tool to accompany the standardized technique | — A computer program which fully automates effects analysis has been developed |
| ● Develop a compilation of high usage piece-part failure mode data if cost-effective | — A list of high usage piece part failure modes was compiled but indicated little correlation between sources |
| ● Assess the feasibility of characterizing the external terminal failure signatures of complex, multi-terminal microelectronic devices | — The electronics industry does not have sufficient data to allow a meaningful characterization of complex microelectronic device failure modes for piece-part FMEA usage |

The Phase II study tasks were undertaken to provide a standardized technique for performing FMEAs of electronic equipment which would provide maximum usability of results while minimizing the effort required. The resulting advanced matrix technique is a significant extension of G. Barbour's original matrix methodology. The technique has been extended to allow the methodology to be used for the entire analysis rather than as a supplement to tabular methods. Also, the extraction of maintenance-related information from the matrix format FMEA has been improved and rigidly defined.

The automation tool which accompanies the advanced matrix technique FMEA is a flexible, user-friendly integration of the technique with the analysis environment. The program has been deliberately designed to ensure ease of use where constant change is a normal part of the design process. The analyst is expected to interact with the computer aid directly while performing the analysis. The computer directs the information entry through the use of a full screen interactive approach.

The Phase I survey of the technical community was extended in Phase II to include a request for component failure modes currently in use by engineers performing FMEA. The failure modes obtained were not traceable to any specific program or data collection effort. The component failure modes currently in use for FMEA are apparently the result of a Delphi process at the various individual organizations. The development of a comprehensive compilation of high-usage component failure mode data was beyond the scope of this study.

A survey of technical and component manufacturing communities revealed that industry does not have a component failure information data base which is sufficient to allow the failure signatures of complex microelectronic devices to be characterized.

SECTION 1 - EXECUTIVE SUMMARY
1.5 Recommendations for Future Research

**The Automated FMEA Study has Identified
Several Areas of FMEA Technology Where
Additional Research is Needed**

**AUTOMATED
FMEA
TECHNIQUES**

42829 SP

- FMEA of software is largely undefined
- FMEA of complex digital circuitry is a problem at the piece-part level of detail
- Component failure mode rates are not known
- The failure modes/signatures of complex, multi-terminal devices are not defined

The Automated FMEA Techniques study has provided both a standardized technique for FMEA on electronic equipment and an automation package to reduce analysis costs and increase analysis usability. The study has not, however, resolved several technical problems which may be of significance to the analysis.

The analysis methods to be used when assessing equipment which is dependent on software performance for correct operation has not been resolved. This is a potentially significant limiting factor with respect to the FMEA process. An increasing number of types of equipment are dependent on software performance for end item function.

The analysis problems associated with the piece-part level FMEA of complex digital circuitry still remain. The failure signatures associated with complex, multi-terminal devices could not be uniquely characterized. Additionally, the increasing use of microelectronic devices with computer bus oriented architectures presents a complexity problem which may preclude any realistic piece-part analysis for some circuitry. Also, the data base which would be required to allow device failure signature characterization may not be developable due to the rapid advance in component technology. Many, and perhaps even most, complex microelectronic devices will be obsolete prior to the accumulation of data, which is sufficiently comprehensive to allow the characterization of the device's failure signatures.

The problem of calculating accurate, traceable and comparable criticality numbers has not been resolved. The component failure modes and associated rates which are in use by the electronics community have been developed through a delphi process rather than data collection. This problem is probably not solvable in a cost-effective manner.

SECTION 2
PHASE I
STUDY ACTIVITY

Phase I study activity was designed to determine the feasibility of developing a standardized FMEA technique for electronic equipment and the feasibility of automating the technique. Additionally, the Phase I study activity was used to provide the scope and focus of the subsequent Phase II activity.

The activity during the Phase I, feasibility phase, of the study consisted of four basic tasks. The specifications and standards which are commonly used to describe and contractually impose FMEA of electronic equipment were reviewed and evaluated with respect to their adequacy in uniquely defining the analysis desired and in providing guidance to the analyst on the technique to be used. The technical literature on FMEA was reviewed to determine applicable techniques, recent developments in FMEA, and any relevant, supplementary information which would assist in the performance of the analysis. The technical community was surveyed to identify FMEA automation tools which had been developed by individual companies to assist their engineers in performing FMEA. Additionally, the survey of the technical community was used to identify sources of component data for use during Phase II of the study. The commercial, technical marketplace was also investigated for any automated tools which were available and could be used to assist in FMEA.

The results of these investigations were then used to determine the appropriate scope and direction of the Phase II study activity.

2.1 SPECIFICATION AND STANDARD EVALUATION

The specifications and standards reviewed comprise two broad general categories, programmatic and procedural. Each specification type, while different in intent, helps define and establish FMEA for electronic equipment.

The programmatic standards describe and provide for the overall linkage of the FMEA to contractual requirements and to the engineering programs for reliability, safety, maintainability, and related disciplines. These standards provide guidance on utilizing the FMEA as an integrated program element within the various disciplines. Guidance is generally given with respect to proper program phasing of the analysis, and

appropriate review points. The programmatic standards are not intended to provide specific guidance on methodology to be used, format required, or other specifics of the analysis. The most commonly invoked programmatic standard for FMEA, MIL-STD-785B, provides guidance to the procuring activity in regards to tailoring the analysis requirements to achieve program objectives.

The procedural standards define the FMEA requirement in detail. These standards define the information required for the analysis output and the typical format the output presentation is to have. The methodology to be used to achieve the analysis is described in general terms.

The specifications and standards reviewed during Phase I of the study are listed in Table 1, along with the title, date, and category of the specification. All standards reviewed were limited to the latest revision released. All outdated revisions and superceded specifications and standards were assumed to have had any relevant requirements incorporated into succeeding revisions or superceding documents.

The most common method of specifying a formal FMEA for U.S. Military procurements is to impose a MIL-STD-785B reliability program with an FMEA in accordance with MIL-STD-1629A. This is typically specified within the contractual Statement of Work (SOW) with associated data delivery required in accordance with the Contract Data Requirements List (CDRL) and DI-R-7085. This requirement is commonly imposed along with a MIL-STD-470 maintainability program, a MIL-STD-882A safety program, and a MIL-STD-1388 logistics support analysis in related disciplines. Standards which represent a tailoring of MIL-STD-785B and MIL-STD-882A such as QR-800-Q and MIL-STD-1574A are substituted for the more common standards in specific procurements. This is particularly prevalent for missile system procurements.

The programmatic standards for reliability in combination with a contractual SOW define the requirements for the FMEA in terms of level of detail and required delivery dates. There does not appear to be any ambiguity introduced with respect to the analysis required, the intended usages of the analysis, or any other specific requirement of the FMEA by the programmatic specifications. There is a potential problem, because the contractual documents do not provide the detailed definition and tailoring required.

TABLE 1. SPECIFICATIONS AND STANDARDS EVALUATED

Standard	Title	Date	Category
MIL-STD-785B	Reliability Program for Systems and Equipment, Development and Production	15 Sep 80	Programmatic
MIL-STD-1629A	Procedures for Performing a Failure Mode Effects and Criticality Analysis	24 Nov 80	Procedural
ARP-926A	Society of Automotive Engineers Recommended Practice Fault/Failure Analysis Procedure	15 Nov 79	Procedural
MIL-STD-1543 thru Notice 2	Reliability Program Requirements for Space and Missile Systems	22 July 77	Programmatic
MIL-STD-882A	System Safety Program Requirements	28 June 77	Programmatic
MIL-STD-470	Maintainability Program Requirements	21 March 66	Programmatic
MIL-STD-1574B	System Safety Program for Space and Missile Systems	15 Aug 79	Programmatic
QR-800-Q	Reliability Program for Equipment Development (U.S. Army Missile Command)	13 Jan 82	Programmatic

The primary FMEA procedural specifications currently in common use are MIL-STD-1629A and ARP-926A. When a formal FMEA process is subject to procuring activity review or contractual delivery, one of these two standards is usually invoked. The U.S. Military procurement agencies normally specify MIL-STD-1629A for FMEA on electronic equipment.

ARP-926A provides a reasonably detailed, but general set of guidelines for performing fault/failure analysis. This includes the approach to be used during the analysis for both FMEA and fault tree methods. The ARP also provides some simple example material to aid the analyst in interpreting the process required. The document

does not mandate a specific format but instead suggests that the analyst develop his own format based on the unique requirements of the particular analysis.

MIL-STD-1629A provides specific guidance with respect to format and information requirements for FMEA. The standard does not provide guidance to the analyst on how to perform the analysis. There is no exemplary material provided within the standard. The document is structured to provide a rigid, contractual requirement for the analysis data rather than a procedure for developing the analysis.

MIL-STD-1629A and ARP-926A are both very general in their description and require significant levels of individual interpretation by the analyst to apply the stated requirements to a particular system. The standards provide adequate guidance to allow analysis of a relatively simple mechanical or electrical product to be performed by an inexperienced analyst. However, the documents provide very little guidance for the analysis of modern, complex electronic equipment. Specific weaknesses include:

- Piece-part failure modes and the percentage each mode represents of the total failure rate are not provided. No guidance is given to an appropriate reference to obtain these modes and percentages. This information is required for FMEA at the piece-part level when criticality analysis is desired
- There is no guidance given for the level of analysis or the treatment of complex electronic devices (microprocessors, memories, etc.).

The standards and specifications, both programmatic and procedural, are adequate in terms of defining the contractual FMEA requirements in terms of a set of specific data, with a mandated level of detail and program phase. The documents provide little or no information on the techniques and methodology to be used in analyzing modern electronic equipment. The only tool presented with the documents is the sample FMEA output form for manual use.

2.2 CURRENT TECHNIQUES IN FMEA

The relevant technical literature was researched as a part of the Phase I study activity to determine what new or improved tools or techniques had been developed to aid in the performance of FMEA and fault/failure analysis in the electronics industry. The review of the technical literature was also used to identify any supplementary technical information which could aid an analyst in performing FMEA. The literature

review was limited to material published within the last ten years. This was considered a reasonable time limitation due to the rapid evolution of electronic technology during the period and the rate at which existing techniques and tools are improved within the electronic and aerospace industries.

The scope of the literature reviewed included improved manual and automated techniques and new technical information relating to expanded or improved applications of existing techniques. This included any technical information which provided the techniques required to allow usage of the FMEA in applications previously considered to be prohibitively difficult.

For the purposes of this study any new or improved technique was expected to either meet the intent of MIL-STD-1629A for informational content or be readily adaptable to meet the intent of the standard. The method would need to provide a complete listing of all single point failures and their effects at each level of indenture. Additionally, criticality or some other relevant categorization of failures which is consistent with MIL-STD-882A would need to be obtainable. The specific format of the output presentation was not considered critical. To be considered an improvement over existing methods, any new techniques were required to provide one or more of the following:

- A reduction in the total labor expended to produce an equivalent analysis or a more detailed analysis for the same labor
- Increased usability in related disciplines (e.g., safety, maintainability, and logistics)
- Improved traceability and readability of the analysis
- Increased accuracy of the analysis
- A reduction in the skill or expertise required of the analyst.

The identification of techniques which would reduce the total labor expended to produce the analysis was considered of critical importance. Any technique which reduced the labor requirements for the analysis would allow easier completion of the FMEA within a time frame which coincided with the design process. This would help ensure that the FMEA results are incorporated into the design at a cost-effective point in the program.

2.2.1 COMMON FAULT/FAILURE ANALYSIS TECHNIQUES

A review of the technical literature reveals two prominent fault/failure analysis techniques currently being utilized within the electronics and aerospace industry: Fault Tree analysis and the FMEA. These are general techniques which are applicable to a wide range of designs to allow reliability and safety assessment. The results of either type of analysis can additionally provide inputs to the maintainability analysis process and aid in the development of training and technical manual material. The two primary fault/failure analysis techniques have been extended with more specialized analysis techniques such as common cause analysis and event sequence analysis. Common cause and event sequence analysis are the most broadly applicable of the many specialized analysis techniques in use. These specialized techniques are supplementary to the primary analysis methods and extend their usability or accuracy in specialized applications. The specialized techniques are not considered to be replacements for either general technique.

2.2.1.1 Fault Tree Analysis

Fault tree analysis is a deductive, top-down, failure analysis technique with wide applicability and use, primarily for system safety analysis. The analysis starts with an undesired top event (failure) and proceeds downward through the hardware under examination to identify all potential single and multiple failure causes (primary events). The resulting fault tree is a Boolean representation of all events which can potentially lead to the undesired top event. A significant body of technical literature on fault tree approaches and uses exist at various levels of mathematical sophistication. R.E. Barlow provided an excellent introductory work in 1973 (1).

2.2.1.2 Failure Modes and Effects Analysis

Failure Modes and Effects Analysis (FMEA) is a bottom-up, inductive, failure analysis technique. This analysis, which is normally performed by reliability engineers, is used to support multiple disciplines. The analysis output supports reliability, maintainability, testability, logistics, and safety activities. The analysis starts with a

single point, low-level failure and proceeds upward through the hardware under analysis to define the failure effect at each level. The analysis method is defined in MIL-STD-1629A and ARP-926A.

2.2.1.3 Common Cause Analysis

Common Cause Analysis is an extension of fault/failure analysis techniques to assess the effects of events common to an entire system (earthquake, overvoltage, temperature, etc.) on what are normally independent failure paths. The technique, which is usually used in conjunction with a fault tree analysis, allows assessment of failures which can simultaneously effect apparently independent features. A variety of approaches to the analysis have been taken with various strengths and weaknesses. A comparative overview of the most common approaches is given by D.M. Rasmuson (2).

2.2.1.4 Event Sequence Analysis

Event sequence analysis (3,4) is an extension of fault tree mathematical techniques which assesses the probability of occurrence of the various elemental events of the tree as a function of their time dependencies. This analysis technique provides for accurate assessment of top event probabilities when the necessary elemental events occupy different sequences in time. The method appears to be particularly effective in assessing conditional failure probabilities.

2.2.2 FAULT/FAILURE ANALYSIS FOR ELECTRONICS

Each of the fault/failure analysis techniques has some applicability to the analysis of electronic equipment. The fault tree analysis and FMEA are the primary analysis techniques and both are used extensively in the assessment of electronic equipment to present the basic failure modes and their effects at each level of indenture for reliability and safety analysis. Both analysis methods have advantages and disadvantages with respect to electronic equipment. The FMEA technique appears

to provide the more accurate results for electronics because the analysis is inductive. Table 2 presents a relative comparison of the two techniques.

The most prevalent criticisms of the FMEA technique in the literature are that it is difficult to apply during early design phases, does not consider multiple point failures, is very labor intensive, and does not provide an output which is readily understandable by design engineering and management personnel. The primary criticism of the fault tree method is that the analyst can miss potential critical failures due to the deductive nature of the approach. However, the deductive approach can be effectively utilized when minimal design information is available. Each of these weaknesses has some validity but is not necessarily critical in the analysis of electronic equipment.

The availability of failure mode and effect information at an early point in the design process has a significant influence on the ability to produce the necessary design changes in the hardware. Information which is provided late in the design process can tend to have little impact due to the high cost associated with changing an existing design. The application of the FMEA process early in the design process is possible. However, the analysis must be approached top down rather than bottom up at this point. When this methodology is applied to electronic devices there is a tendency to identify failure modes and effects which may be impossible in the final design. For example, a signal output from a module not yet designed may have a failure mode of frequency beyond tolerance assigned during the early evolution of the next higher assembly. The final design of the module may contain sufficient band-pass filtering to ensure that an off-frequency condition results in a "no output" failure mode. Therefore, there is no "frequency beyond tolerance" failure mode. This is not necessarily a drawback as it helps focus early design efforts on the elimination of such failure modes when the end item effect is critical.

The FMEA approach to failure analysis does not generally consider multiple failures. Multiple point failures are only considered when a single point failure produces no effect on the performance of the end item system. This does impose some limitation on the applicability of the FMEA technique to extremely large systems which are dependent on a human interface to complete the system (e.g., nuclear power facilities). This limitation occurs because the human failure or inability to perceive the effects of a single point failure is not generally considered. A fault tree approach is generally used in large systems where the human interface is critical, however, the use of FMEA is not precluded. Pearson (5) has reported the use of a single point and multiple point FMEA to assess the design of the DC-10 All-Weather Landing System.

TABLE 2. COMPARISON OF FAULT TREE ANALYSIS TO FMEA

Characteristic	Fault Tree Analysis	FMEA
Primary use	Safety analysis	Reliability analysis
Methodology	Top down - deductive	Bottom up - inductive
Failures Considered	Single and multiple point failures causing undesired top event	All single point failures
Automation Available	Numerous programs for graphics and numerical computation	Limited automation
Readability	Easily understandable to nonspecialists	Difficult to understand for nonspecialists

An FMEA approach has also been used in power production facility safety studies for both nuclear (6,7) and non-nuclear (8) plants and in assessing the safety of the space shuttle payloads (9).

The FMEA technique is very labor intensive. This is due to the nature of the analysis and the small amount of computerization which has been accomplished for FMEAs. Fault trees have had a significantly greater amount of computerization accomplished both for small computers (10,11) and relatively large machines (12,13,14).

The presentation of FMEA data in MIL-STD-1629A tabular form is not as readily understandable to engineers outside the reliability and safety engineering disciplines as the fault tree. This is due to both the method of presentation and the larger quantity of information developed in an FMEA. The fault tree has the advantage of presenting failure effect data in a graphic format which is readily understandable by non-specialists. This has allowed a somewhat greater impact from material presented in fault tree format.

The primary advantage of FMEA with respect to fault tree analysis is in accuracy (completeness). Fault tree analysis requires that the analyst deductively ferret out all failure modes which could singly or in combination cause the undesired top event to occur. The approach is function-oriented and the ability to deduce all such failure modes is largely dependent on the skill of the particular analyst. The methodology, being function-oriented, also tends to be less thorough than FMEA in assessing interface problems. The FMEA, by considering all single point failures in the hardware, ensures that full consideration is given to all possibilities. This is particularly critical in interface areas (wiring, etc.) where designed-in redundancy is often lost and failure

modes which are not apparent (in the schematic circuitry or in the inherent circuit function) are uncovered.

FMEA also develops a larger quantity of information than fault tree analysis. The additional information developed consists of assessment of failure predictability, detectability, and available compensating provisions. This additional detail allows the FMEA data to support maintainability, testability, safety, and logistics studies. The presentation method used for FMEA imposes some difficulty in extracting the required information for these associated purposes. The required information is included but it is not organized in an optimum manner for evaluating maintenance, logistics, and testability parameters. This often imposes a need to manually extract data in the required order.

2.2.3 NEW DEVELOPMENTS IN FMEA

A significant new development within FMEA is the matrix FMEA developed by G.L. Barbour (15) and subsequently computerized by J.M. Legg (16). The matrix FMEA approach is a significant improvement in terms of labor requirements, readability, and traceability of the analysis. The ease of utilization by engineers in disciplines other than reliability and safety is significantly enhanced.

The matrix FMEA approach can result in a reduction in the overall labor expended for the analysis due to reduced clerical requirements. Barbour presented the matrix FMEA as a supplement to the tabular form FMEA. However, the matrix format can present all the data required for the tabular format with some adaptations. The additional information required can be particularly well handled in automated approaches. If a tabular presentation is required, personnel with somewhat lower skill levels than the original analyst can be assigned to extract the required data. There should also be an overall reduction in labor due to the easy traceability of the approach. The conflicts which normally result from the assignment of multiple analysts to the same equipment are reduced by the rigid format requirements of the matrix analysis. The matrix FMEA has been computerized (16) and the users instructions and source listing are in the public domain (17).

The basic format of the matrix FMEA is a significant improvement over tabular presentations in terms of readability and traceability. The improved format allows rapid interpretation of FMEA results by design engineering and management personnel.

This allows hardware changes based on the analysis to be implemented with minimum resistance. The matrix format also allows for more rapid and accurate extraction of analysis data by maintainability and technical publications engineers. The matrix FMEA format tends to improve the overall accuracy of the analysis due to the rigid construction technique employed.

The primary limitation of the matrix FMEA is in its inability to contain comments. This limitation can be significant when dealing with critical failures. A well-designed equipment usually has some method available for minimizing the criticality of failures. These may include such things as alternate operating modes or pilot or operator recognition of the failure under most circumstances. It is important that the actions necessary to minimize critical failures be contained in the FMEA data. This helps ensure preparation of adequate training and technical manual data concerning critical failures.

2.2.4 WEAK AREAS IN FMEA

A considerable amount of technical work in the area of fault/failure analysis and particularly FMEA has been accomplished within the reliability and safety disciplines during the last decade. There are some areas where additional effort is needed in the electronics industry, particularly:

- Increasing the analysis usability, especially with respect to maintainability and technical manual development
- Development of techniques and procedures for assessing real-time firmware based systems
- Standardization of component failure modes and percentages

The cost associated with performing an FMEA, particularly at the component level, mandates that the analysis results need to be as widely used as possible. Duplication of the effort involved in the FMEA needs to be avoided. The basic information contained in the analysis can provide a baseline for maintainability predictions and for technical manual troubleshooting information development, if sufficient information is provided in a usable format. The matrix FMEA provides an adequate format for the recovery of information, and some early work on obtaining the

needed maintainability data has been done by Herrin (19). Conley (20) has demonstrated the use of a tailored FMEA process for assessment of BIT effectiveness. The FMEA technique employed within the electronics industry needs to accommodate the requirements of BIT assessment, test point adequacy evaluation, and identification of test and maintenance ambiguity as an integral part of the analysis. The required information is apparent to the analyst as the FMEA is performed and should be incorporated into the analysis results to prevent duplication of the effort by maintainability engineers or by technical manual preparation activities.

Modern electronic equipment is increasingly being designed with microprocessor-based control functions. This has introduced the problem of identifying the failure modes and effects of the combined hardware and software of the system as a part of the FMEA process. The procedure to be used in these situations is not standardized. The technical literature has suggested both physical simulation of potential faults using existing hardware (21) and the simulation of the suggested design through an automated program (22). An approach which allows the FMEA to be performed for any microprocessor system currently available is needed.

The performance of an FMEA with criticality analysis (FMECA) requires that component failure modes be tabulated along with the probability of the component failing in the particular mode. There is currently no centralized source for this information. AMCP-706-196 (23) provides the most comprehensive listing currently available but is far from complete. A comprehensive assessment of the probability associated with various component failure modes is needed.

The FMEA is uniquely defined in terms of requirements. However, work still remains in developing a comprehensive technique, applicable to electronic equipment, which is accurate, achieves maximum usability, and is cost-effective.

2.3 INDUSTRY SURVEY

As a part of the Phase 1 study activity, a survey of the electronics and aerospace industries was taken. The main objective of the survey was to identify any aids or techniques developed by organizations for the proprietary use of their engineers when performing FMEA which did not appear in the technical literature. The survey was expected to provide some insight into both the total amount of automation of FMEA existing in industry and the need or desire for automated tools to assist in the analysis.

The survey also solicited comments on areas of the FMEA process which were considered by the respondents to need improvement, and on whether or not component failure mode data was available.

A total of 190 questionnaires (see Figure 1), were sent to various companies, organizations, and individuals throughout the electronics and aerospace industries during late March, 1982. A total of 95 responses were received. 20 responding organizations indicated either some degree of computerization or usage of automated tools. Subsequent telephone contact was able to confirm only a total of 17 organizations which had actually developed or were using some degree of automation to aid in fault/failure analysis.

2.3.1 INDUSTRY COMMENTS

A total of 41 responses to the survey included comments concerning the FMEA process. The most common comment (16 responses) was that automation was highly desirable to help reduce the cost of FMEAs. This was offset by seven respondents commenting that automation was probably not possible. Additional comments included a need for standardization (7 responses) and a need for a reduction in the level of detail mandated under contract (8 responses).

A total of 44 respondents indicated that they had information on component failure modes. The comments provided indicated that MIL-HDBK-217 data and various RADC material were being used for failure mode data. Two of the responding organizations indicated that they had developed component failure mode data specialized for their type of equipment. Only three organizations commented on a lack of component failure mode data. This was surprising since a single, industry-recognized, centralized source for detailed component failure modes and the percentage of the total failure rate each mode represented could not be identified. This may be due to very few FMEAs with criticality assessment being done at the piece-part level or the acceptance of less precision in such cases.

HUGHES-FULLERTON
Hughes Aircraft Company
Fullerton, California

AUTOMATED FAILURE MODES AND EFFECTS ANALYSIS (FMEA) TECHNIQUES QUESTIONNAIRE

I. RESPONDEE _____
 COMPANY/AGENCY _____
 ADDRESS _____
 CITY/STATE _____ ZIP _____ TELE _____
 DO YOU WANT A COPY OF THE FINAL REPORT SENT TO YOU?
 YES _____ NO _____

II. FMEA EXPERIENCE:
 1. HAS YOUR COMPANY/AGENCY PERFORMED OR SPECIFIED FMEAS IN THE PAST?
 YES _____ NO _____
 2. WHAT LEVEL FMEAS WERE THEY? HOW PERFORMED?
 MANUAL/AUTOMATED
 a. FUNCTIONAL LEVEL _____
 b. ASSEMBLY/LRU LEVEL _____
 c. PART LEVEL _____
 d. CHIP LEVEL _____
 3. WHAT WERE THE GOVERNING DOCUMENTS?
 MIL-STD-785 _____ MIL-STD-1574 _____ OTHER _____
 MIL-STD-881 _____ MIL-STD-1629/A _____
 MIL-STD-1543 _____ MIL-STD-2070 _____

III. AUTOMATION AIDS:
 1. HAS YOUR COMPANY/AGENCY DEVELOPED OR USED AUTOMATION AIDS FOR FMEAS?
 YES _____ NO _____
 2. IF YES, WHAT WERE THEY? PROPRIETARY?
 YES _____ NO _____
 YES _____ NO _____
 YES _____ NO _____
 YES _____ NO _____

IV. GENERIC DATA:
 1. DOES YOUR COMPANY/AGENCY HAVE STANDARD, GENERIC FAILURE MODE DATA AND PROBABILITY OF OCCURRENCE FOR VARIOUS PART TYPES/CLASSES?
 YES _____ NO _____
 2. DOES YOUR COMPANY/AGENCY HAVE INFORMATION/DATA ON FAILURE MODES OF COMPLEX MICRO-ELECTRONIC DEVICES (e.g., MICROPROCESSORS)?
 YES _____ NO _____

V. GENERAL:
 PLEASE PROVIDE ANY COMMENTS YOU FEEL ARE RELEVANT TO FMEAS, OR THE STANDARDIZATION OR AUTOMATION OF FMEAS. _____

Figure 1. FMEA Industry Survey Questionnaire

2.3.2 DEGREE OF INDUSTRY AUTOMATION

The survey responses received from industry indicated a total of 17 organizations with some computerization of FMEA or usage of automated tools. The total number of programs used reduced to 15 once duplication caused by common usage of the same program by divisions of one company was eliminated. The relatively small amount of automation was surprising as the cost associated with performing an FMEA is typically high. A breakdown of the types of the programs identified is shown in Table 3.

The FMEA programs identified were intended to reduce the clerical work required of the analyst. A computer was used to save on typing and sheet and section renumbering and to allow easy revision of the analysis. The singular exception among the FMEA programs is the matrix FMEA program "FUME" developed by J. Legg of Ford Aerospace. This program provides improved traceability and readability in addition to reducing the clerical load on the analyst.

2.4 COMMERCIALLY AVAILABLE FMEA AUTOMATED AIDS

As a part of the Phase 1 study, a survey of the programs which are commercially available through the various computer time share services was taken to determine the availability of automated tools to assist in FMEA. The programs sampled were not all inclusive due to the large number available. However, a reasonable cross section of the automated tools available was evaluated. The programs which are commercially available consist of two types: circuit design analysis programs, and clerical FMEA programs. There does not appear to be any program which combines the two aspects of the FMEA process.

TABLE 3. COMPUTER PROGRAM TYPES IDENTIFIED
BY INDUSTRY SURVEY

Program Type	Qty
Reliability Prediction or Failure Probability Programs	1
Fault Tree Programs	4
Circuit Analysis Programs	1
FMEA Programs (Clerical)	8
Event Sequence Analysis Programs	1

2.4.1 CIRCUIT ANALYSIS PROGRAMS

The circuit analysis programs evaluated are of three basic types: digital, analog, and RF. There does not appear to be any single program which will handle all three types of circuitry well. The circuit analysis programs were evaluated for their ability to model single point failures within a circuit under analysis. Analog and RF circuit analysis programs were expected to be able to model component shorts, opens, and tolerance errors as a minimum to be useful in the FMEA process. Digital circuit analysis programs needed to be capable of emulating at least stuck-at-one (S-A-1), stuck-at-zero (S-A-0), and stuck-at-an-indeterminant-level (S-A-U). The modeling of the various failure conditions was expected to be automatically done as a part of one or more possible options within the computer program.

The circuit analysis programs which were reviewed included XSCEPTRE, MSINC, SPICE 2, SLICM, LISA, COMPACT, LOGS, TEGAS 5, and SYSCAP II. These programs are all design verification oriented, but a few have enough capabilities to be used for the circuit analysis portion of the FMEA. Some of these programs use convergence techniques and thus may not run when faulted conditions are induced. Also, many of these programs could only be used for an FMEA by "brute forcing" the failed conditions, and thus are not usable for a truly automated FMEA.

2.4.2 CLERICAL FMEA PROGRAMS

Only one clerical FMEA program was identified within the commercial market. The program, PREDICTOR FMEA, is part of an extensive set of reliability/maintainability programs written by Management Sciences Incorporated. The FMEA program was the only section of PREDICTOR evaluated. However, the program is dependent on the file structures created to run the reliability prediction program portion of PREDICTOR. This requires that the reliability prediction program itself must be used in conjunction with the FMEA program.

2.4.3 OVERALL EVALUATION

There are some circuit analysis programs available which are useful for performing FMEA at the piece-part level. The best analog circuit analysis program for

FMEA purposes of those evaluated is SYSCAP II. For digital circuit FMEA, TEGAS 5 was the best program of those evaluated. A circuit analysis program capable of supporting FMEA on high frequency RF circuitry was not identified.

The circuit analysis programs evaluated are not considered feasible for inclusion in an automated FMEA package. These circuit analysis programs do provide some valuable analysis capability and should be considered for use to support piece part FMEAs.

2.5 PHASE I CONCLUSIONS

The Phase I, Feasibility Study, conclusions divide into two distinct areas. The feasibility of developing a standardized, manual technique for FMEA of electronics equipment is considered separately from the degree of automation considered feasible for the technique. These areas of interest need to be considered as separate topics if the standardized technique is to be capable of manual implementation.

2.5.1 FEASIBILITY OF DEVELOPING A STANDARDIZED TECHNIQUE

The development of a standardized technique for performing FMEA on electronic equipment was considered feasible. The FMEA process is being specified and performed on electronic equipment successfully, and FMEA is being used on equipment as diverse as satellites and nuclear power plants. The primary advantage of a standardized FMEA technique would be in its standardizing of the approach, presentation, and program phasing. This should provide consistency in the analysis methodology and a presentation independent of the individual analyst or company.

A standardization of circuit analysis techniques, similar to the standardization imposed on reliability predictions by MIL-HDBK-217, is not considered feasible. The wide variety of potential circuit designs, limited only by the inventiveness of the individual engineer, precludes such standardization. Additionally, any standardization of circuit analysis would be rapidly outdated by the evolving technology within the industry.

A review of the specifications and standards on FMEA undertaken as a part of the Phase I effort shows that they are generally adequate for their purpose. These documents are intended to define an FMEA in terms of deliverable data and to form a contractual baseline for the analysis when it is formally imposed as a part of procurement process. The specification documents provide little or no information on the techniques and methodology to be used in performing the analysis. They are particularly weak with respect to electronic equipment FMEA. The lack of adequate guidance for the analyst has not precluded the use of FMEA for electronic equipment. There appears to be an intuitive knowledge within the industry regarding the techniques required. This reliance on an intuitive definition of approach can result in FMEAs being performed with varying degrees of quality. There is a need for a standardized technique to ensure consistency in approach, level of detail, and presentation.

The review of the technical literature revealed very little in terms of new developments for FMEA use. The most significant development found was the matrix method approach developed by G.L. Barbour in 1977 and subsequently computerized by J.L. Legg in 1978. The matrix method represents a significant improvement in terms of readability, traceability, and reduction of clerical requirements. The method was originally published as a supplement to tabular FMEA methods. The matrix FMEA in its present form cannot be used for the entire analysis due to the inability to include commentary material. The inclusion of commentary material in a modified matrix FMEA technique is possible and is especially easy in an automated implementation. An automated FMEA can allow for the inclusion of comments while retaining the essential matrix FMEA features. The commentary material would be stored in the computer files and recalled as a part of the presentation in appropriate data sorts. The use of automation will allow the FMEA data to be recalled in various sorts depending upon the intended use.

Several weak areas in existing FMEA techniques were identified as a part of the Phase I study. Specifically:

- The lack of an overall standardized technique for FMEA of electronic equipment
- A very high level of clerical detail required by the FMEA which can adversely impact cost and schedule
- The lack of techniques to assess microprocessor based circuitry
- The lack of a single, comprehensive source for piece-part failure modes and relative rates of occurrence thereof.

Each of these weak areas was expected to be adequately addressed as a part of the standardized technique developed during Phase II of the study. The overall success in resolving the last two items, however, depends on the results of further study.

2.5.2 FEASIBILITY OF DEVELOPING FMEA AUTOMATED TOOLS

A partial automation of the standardized technique developed during Phase II of the study was considered both feasible and highly desirable. This is primarily due to the high cost associated with FMEA performed by manual methods. The need for some automated aids has been recognized within the electronics and aerospace industries as evidenced by the development of some limited automation aids by various companies (see Section 2.3). A universally accepted and recognized automation aid had not yet been developed.

The programs currently existing in the electronics industry which can be used for FMEA are of two distinct types. These are circuit analysis programs and clerical FMEA programs. Each program type has features which recommend its use for FMEAs. Clerical programs provide a labor savings by helping to minimize the general clerical load on the analyst. The clerical load imposed by a MIL-STD-1629A FMEA is quite large when manual methods are utilized. Circuit analysis programs provide increased analysis depth and accuracy capability. The circuit analysis programs do not appear to provide a significant time savings due to the effort required to define the circuit to the computer. This may not be the case if the same program is used by the design agency for circuit design and evaluation.

There are a large number of circuit analysis programs available in the commercial marketplace. These programs can generally be accessed through the various computer time-sharing services. The various programs are specialized as to the type of circuit analyzed (e.g., linear, digital, RF, etc.). The programs are oriented in terms of frequency response, amplitude, stability, timing, temperature response, and other relevant circuit parameters. Some of these programs do provide for at least some failure modeling capability which is useful for FMEA. When a parts-level analysis of a complex circuit is required, the use of a circuit analysis program should be considered to ensure the required depth and accuracy.

The inclusion of a circuit analysis computer program in the automation of the standardized technique of electronics FMEA was not considered feasible. Several

factors indicate that the inclusion of a universal, standardized circuit analysis tool within the automated FMEA technique is probably not possible.

- Program Size - The circuit analysis programs currently in use are very large emulation programs developed for limited purposes at a fairly large cost.
- Program Specialization - There are three basic types of circuit analysis programs available: analog, digital, and RF. There does not appear to be a single program capable of doing all three well.
- Program Acquisition Cost - The selection of a program or programs for use as a baseline would probably be prohibitively expensive. Most of the circuit analysis programs are proprietary and contracted through the time-share services on a profit-making basis.
- Program Upkeep - The maintenance and updating of a large circuit analysis program would require a dedicated staff to keep the program current with new parts developments and new techniques in circuit design.

The inclusion of an automated interface between a specific circuit design analysis program and any clerical aid program developed for FMEA use was not considered to be feasible. This direct automated interface between programs would be dependent on the program selected and the circuit under test. The circuit analysis programs examined which allowed failure modeling produced an output in terms of voltage, current, or other signal characteristics at a given point which was defined by the user as the output to be considered. The effect (if any) of an output point being at a given state as a result of a simulated fault is determined by the user. The effect determined by the user is dependent on the design and tolerances of the next circuit in the signal path. The interpreted results from a circuit analysis program must be manually inputted to the FMEA worksheets or a clerical FMEA program.

The development of a reasonably comprehensive, clerical aid and effects analysis type program based on a modified matrix FMEA approach appeared to be feasible and was expected to result in a significant cost reduction for the analysis. The cost of the program development and subsequent maintenance should be significantly less than the cost savings realized. Several companies (see Section 2.3) had developed at least partial aids at their own expense. A single, comprehensive, clerical FMEA program had not yet been developed. Developing such a program was not considered to represent an insurmountable technical challenge.

SECTION 3

PHASE II STUDY ACTIVITY OVERVIEW

The activities undertaken as a part of Phase II of the Automated FMEA Techniques study consist of four tasks. Research was conducted into the amount of information available to allow categorization and quantification of component failure modes. A set of recommendations for improving the FMEA process, independent of the specific technique used for the analysis, was produced. A standardized FMEA technique, the Advanced Matrix Technique was developed. Additionally, an automated aid, the Failure Effects and Data Synthesis program (FEADS), to accompany the Advanced Matrix Technique was developed. An overview of each of these topical activity areas is presented in the following paragraphs.

3.1 COMPONENTS OVERVIEW

The components activity undertaken during phase two of the study was directed at (1) obtaining solutions to the lack of data on the failure mode of common, high useage, parts and at (2) obtaining sufficient information to allow the categorization of the failure signatures of complex microcircuits at the device output pins. The need for a comprehensive, traceable list of piece part failure modes and their associated rates of occurrence had been identified as a part of phase one of the study. These component failure modes are needed to allow accurate evaluation of failure criticality rankings. Also, a knowledge of the prominent component failure modes helps assure that all potential problems are considered.

Data on the failure signatures of complex microcircuits are needed to allow proper consideration of complex microcircuits during piece part FMEAs. Categorizing the failures of complex devices as short or open during FMEA is clearly inadequate. Some state of the art microcircuits have internal complexities approaching that of entire equipment designed twenty years ago.

An integrated approach was taken to the two component data searches. An attempt was made to identify any electronics industry information among component users. This was a follow up to the industry survey started during phase one of the study. Additionally, contacts were made with component manufacturers to determine if useful data could be supplied.

The search for relevant failure mode data was expected to be successful for high usage parts (e.g., resistors, capacitors). The search for data on complex microcircuits was expected to be more difficult than that for high usage parts due to the much smaller number of devices and relatively short usage period. The data available on all types of devices was found to be sparse. The data which was identified appears to be the result of a Delphi process at the various companies. The components efforts and results are detailed in section 4.

3.2 FMEA RECOMMENDATIONS OVERVIEW

Several recommendations for FMEA were developed as a part of the phase two study activity. These recommendations are the result of an assessment of FMEA weaknesses during phase one of the program and the development of the standardized FMEA technique during phase two of the study. Two recommendations of significance resulted. The schedule of performance of FMEAs needs to be accelerated to allow earlier completion of most analysis activity. This earlier performance of tasks is achievable using the advanced matrix technique and its accompanying automation package. Additionally, an FMEA guidance conference is recommended. A guidance conference, very early in the design process, will allow the communication of critical failure concerns so that failure severities can be correctly assigned during the performance of the FMEA. A discussion of general FMEA related considerations and recommendations is provided in section 5 of the report.

3.3 STANDARDIZED TECHNIQUE OVERVIEW

The standardized FMEA technique, the Advanced Matrix Technique, developed during phase two of the study is a comprehensive approach to FMEA which is integrated

with the total design process. The technique represents a significant expansion and refinement of the matrix technique originally presented by Barbour (15). The basic matrix technique has been refined to allow all parts of the FMEA to utilize the matrix format, and provisions for the inclusion of commentary material, failure severity levels, and test point information have been made. Additionally, the basic matrix method has been extended to use all possible failure modes and effects and to provide a means of readily extracting built-in-test and maintenance ambiguity information. Adaptability to computerization is inherent in the structure of the advanced matrix technique. The analysis results are inherently traceable due to its matrix structure. Traceability is further enhanced through the use of signal and assembly mnemonics. The matrix structure, while enhancing traceability of the analysis, also provides the rigid, documentation discipline needed to allow multiple analysts to work on an FMEA successfully. The Advanced Matrix Technique has the ability to accommodate the use of several analysts on a single FMEA. This allows the analysis to be completed in a time frame which is consistent with an ongoing design program, thus helping assure maximum design impact from the analysis results. The Advanced Matrix Technique is presented in detail in section 6.

3.4 FMEA AUTOMATION OVERVIEW

The Failure Effects and Data Synthesis (FEADS) automation package developed during phase two of the study is a comprehensive computer implementation of the Advanced Matrix Technique. The package of FORTRAN programs provides a user friendly environment conducive to easy documentation of FMEA. The user is provided with a direct, on-screen, method of recording circuit analysis results during the performance of FMEA. Additionally, the automation package provides the user with the means to rapidly obtain previously entered analysis material. The user can request any of four different assembly level analysis outputs and seven separate system analysis outputs. The FEADS program features built-in, on-line, guidance to the user which allows an FMEA analyst to use the program after reading the users manual. Formal training in program use is not required. Overall, the FEADS automation package, which is discussed in section 7 is a time and cost effective tool for performing FMEA.

SECTION 4

COMPONENT ACTIVITY

As a part of the Phase II study activity, an attempt to identify component failure modes and their rates of occurrence was made. A knowledge of component failure modes helps ensure that all potential failures are considered as a part of FMEA. A knowledge of the appropriate rate of occurrence for each component failure mode is necessary if accurate criticality analysis is needed. A search for component information sources was considered appropriate in that there was no recognized source for the needed information referenced by either the specification standards which are relevant to FMEA, or by the technical literature on FMEA.

The component activity was divided into two distinct but related activities. One or more definitive sources of information on high usage piece-parts (capacitors, resistors, etc.) was sought. The identification of such a source or sources would allow both the appropriate failure modes and the relevant rates of occurrence to be determined. Additionally, sources of data on complex microcircuit failures were sought. If sufficient data could be obtained, the possibility of characterizing the failure modes of complex microelectronic devices existed.

The approach taken to gathering component information was to pursue three possible sources of information. The technical, component user, community was contacted for information, the available technical literature was searched for relevant information and for references to sources of information, and a sampling of component manufacturers were contacted to determine what information could be provided by them. The overall approach was designed to allow the widest visibility into any existing sources of information.

The success or failure of the search for component information depended on the identification of existing data bases within the electronics industry. The development of new data bases from existing programs was considered to be beyond the scope of this study. A limited compiling and restructuring of existing data was considered reasonable for obtaining complex microelectronic device failure mode information due to the low probability of any single information source being large enough for the purpose of this study.

4.1 INDUSTRY SURVEY

The industry survey for component information performed during Phase II of the FMEA study was an extension of the survey performed as a part of Phase I of the study. During Phase I, a total of 190 questionnaires, as shown in Figure 2.3-1, were sent to industry. A total of 95 responses to the survey were received. Of the 95 responses, 39 respondents indicated at least some component failure data (item IV on survey form). Ten respondents indicated that their companies or organizations had some data on complex microcircuits.

Each organization which indicated component failure mode data was contacted by telephone and questioned regarding the type and amount of data available. This resulted in a total of five listings of high usage component failure modes and their rates of occurrence to be identified and obtained. All of the responses which indicated that companies possessed information on complex microcircuit failure modes resulted in false leads. The various organizations were indicating that they possessed some failure experience on a few complex microelectronic devices. There were no data bases for such information.

A total of 14 microelectronics device manufacturers and two component test laboratories were contacted to identify relevant data sources which they could provide. The component test laboratories were unable to provide any data sources. The component manufacturers had a significant amount of information available on the failure mechanisms (open metalization, etc.) but not on the failure modes (short, open, wrong value, etc.) associated with complex microelectronic devices. The lack of information was not surprising since the component manufacturing industry requires data bases for process control purposes. Process control requires a knowledge of failure mechanism rather than failure mode. This resulted in no relevant data bases for complex microelectronic device failure modes.

4.2 LITERATURE SEARCH

A search of the technical literature on component failure was conducted as a part of the attempt to find relevant component failure modes and their associated rates of occurrence. The initial search of the technical data bases identified a total of 861

candidate published materials for review. A review of the abstracts of the candidate materials resulted in 95 items of potential interest. A review of the 95 published items of interest narrowed the list of directly relevant items to zero. This is a result of the industry requiring information on component failure mechanisms rather than component failure modes. This is not a particularly surprising focus of interest in that component failure mechanisms studies can suggest ways to improve the manufacturing processes associated with components. Component failure modes are primarily of interest to engineers performing FMEA.

4.3 HIGH USAGE PARTS

A total of 15 lists of high usage component part failure modes for use on FMEA were identified through the industry survey and through Hughes Aircraft internal sources. Once duplications between the received lists were eliminated a total of ten lists remained.

Each of the received lists was reorganized to allow direct comparison of the results by component type and failure mode. The resultant combination of lists is shown in Table 4. An examination of the table reveals a lack of commonality between lists with respect to components considered, and the rates of occurrence found for each failure mode.

A follow-up investigation into the sources of the various lists was conducted wherever the source could be identified. The results were that all ten lists shown were from sources which could not be determined (i.e., lists which had been around the various companies for a long time), or were the result of a Delphi process among the engineers at the particular company, or were from published sources (AMCP 706-165) which could not be verified at the source. The lack of consistency between lists suggests that there is too little information available in the component failure mode area to allow a Delphi process to be effective.

The lack of a definitive source for component failure mode and rate of occurrence data represents a potential problem in terms of FMEA accuracy, particularly for criticality analysis. The analyst can assume short and open failure modes for all types of devices. In most cases there are other failure modes that potentially should be considered in the analysis; however, these modes are not well defined. The rates of

occurrence assumed for the various failure modes remain undefined. The best suggestion available to those analysts performing FMEA under Government contract is to use the list contained in AMCP 706-165 (column #1) to the extent possible. This list is not known to be more accurate than any other list encountered. The list in AMCP 706-165 does, however, provide a traceable source for the data used.

4.4 COMPLEX MICROELECTRONIC DEVICES

The feasibility of categorizing the failure modes of complex microelectronic devices based on their failure signature at the output pins was investigated as a part of the components effort. The approach taken was to survey the electronics industry for any relevant data on microelectronic device failure, and the technical literature for information on failure patterns or failure experience with these devices, and then to attempt to produce a categorization scheme based on the failure experience base of the electronics industry.

The survey of the electronics industry produced no useable compilations of data on microelectronic devices. A review of the technical literature revealed a paucity of information on failure mode and rate experience. There is, however, a significant amount of data on failure mechanisms available, but there is not a one to one correspondence between failure mechanism and failure mode. As a result of the lack of correspondence between the available information on failure mechanism and the needed failure mode information, it is not considered feasible to categorize the failure modes of complex microelectronic devices on the basis of their failure signature at the output pins.

If the electronics industry were currently to begin a massive data collection effort on an industry-wide basis to form a pool of information on complex microcircuit failures, the effort still might not produce a useable result. The complex microcircuits currently in use are highly reliable, the data base required to produce meaningful results is very large, and the rate at which complex microelectronic devices are made technologically obsolete is relatively rapid. This combination of characteristics may make any effort to reliably characterize complex device failure modes outdated prior to its completion. The usefulness of this information for FMEA is heavily dependent on its applicability to devices which are being actively used for new design. The advances

In component technology within the electronics industry which have characterized the last decade or more may be occurring too rapidly for the FMEA technology on component failure modes to keep abreast of the latest trends at a reasonable cost.

The analyst who is assigned to perform a piece-part FMEA on modern, complex circuitry, where complex microelectronics devices are used is faced with a problem which cannot readily be resolved. There is currently no method to ensure that all potential failure modes of the component are analyzed. The analyst can consider the short, open, and stuck-at-high impedance failure modes as they apply at each output pin and possible combinations of output pins. This is expected to be less than satisfactory in most cases and may be impossible where very complex devices such as micro-processors are considered due to the number of possible conditions which must be considered.

The only reasonable solution to the problem created by the lack of failure mode categorization for complex microelectronic devices is to limit the performance of FMEA to a higher level of indenture than piece-part when such devices are used. This approach may not seem ideal in terms of the depth of the analysis, but it will ensure that all potential failure modes are examined at the higher levels of indenture, thus eliminating the need for the piece part level of detail.

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCES

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Resistor, Fixed	Composition	RC RCR	MIL-R-11 MIL-R-39008	Short	.95	-	-	-	.07	-	.10	-	.50
				Open	.05	.50	.65	.50	.93	.02	.20	.90	.50
				Other	-	.50	.35	.50	-	.98	.70	.10	-
	Film	RL RLR RN RNR	MIL-R-22684 MIL-R-39017 MIL-R-10509 MIL-R-55182	Short	.40	-	.11	.10	.25	-	.01	-	.10
				Open	.60	.85	.78	.30	.75	.24	.09	.90	.30
				Other	-	.15	.11	.60	-	.76	.90	.10	.60
	Power Film	RD	MIL-R-11804	Short	-	-	.11	.10	-	-	.01	-	.10
				Open	-	.85	.78	.30	1.0	-	.09	.90	.30
				Other	-	.15	.11	.60	-	-	.90	.10	.60
	Network, Film	RZ	MIL-R-83401	Short	.20	-	-	-	-	-	-	-	-
				Open	.80	-	-	-	-	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-
Resistor, Thermistor	Wirewound, Accurate	RB RBR	MIL-R-93 MIL-R-39005	Short	.85	-	-	-	.09	-	.01	-	-
				Open	.15	1.0	.82	.80	.91	-	.09	.95	-
				Other	-	-	.18	.20	-	-	.90	.05	-
	Wirewound, Power	RW RWR	MIL-R-26 MIL-R-39007	Short	.85	-	-	-	-	-	.01	-	-
				Open	.15	1.0	.96	.80	1.0	.25	.70	.95	.80
				Other	-	-	.04	.20	-	.75	.29	.05	.20
	Wirewound, Power Chassis Mount	RE RER	MIL-R-18546 MIL-R-39009	Short	.85	-	-	-	-	-	.01	-	-
				Open	.15	1.0	.96	.80	1.0	.25	.70	.95	.80
				Other	-	-	.04	.20	-	.75	.29	.05	.20
	Bead, Disk and Rod	RTH	MIL-T-23648	Short	-	-	-	.85	-	-	-	-	.85
				Open	.90	-	.50	.15	-	-	-	.40	.15
				Other	.10	-	.50	-	-	-	-	.60	-

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCE (Continued)

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Resistor, Variable	Wirewound, Lead Screw Actuated	RT	MIL-R-27298	Short	.85	-	.02	-	.22	-	.01	-	.10
		RTR	MIL-R-39015	Open	.15	1.0	.91	-	.78	.25	.19	-	.35
				Other	-	-	.09	-	-	.75	.80	-	.50
	Precision Wirewound	RR	MIL-R-12934	Short	-	-	.02	-	.22	-	.01	-	.10
				Open	-	-	.91	-	.78	.25	.19	-	.35
				Other	-	-	.07	-	-	.75	.80	-	.50
	Wirewound, Semiprecision	RA	MIL-R-19	Short	-	-	.02	-	.22	-	.01	-	.10
		RK	MIL-R-39002	Open	-	-	.91	-	.78	.25	.19	-	.35
				Other	-	-	.07	-	-	.75	.80	-	.50
	Wirewound, Power	RP	MIL-R-22	Short	-	-	.02	-	.22	-	.01	-	.10
				Open	-	-	.91	-	.78	.25	.19	-	.35
				Other	-	-	.07	-	-	.75	.80	-	.50
Coils, Fixed and Variable	Nonwirewound Trimmer	RJ	MIL-R-22097	Short	-	-	-	-	-	-	.01	-	.10
		RJR	MIL-R-39035	Open	-	-	-	-	-	-	.19	-	.35
				Other	-	-	-	-	-	-	.80	-	.50
	Composition Low Precision	RV	MIL-R-94	Short	-	-	.14	-	-	-	.01	-	.10
				Open	-	-	.76	-	-	-	.19	-	.35
				Other	-	-	.10	-	-	-	.80	-	.50
	Nonwirewound Precision	RQ	MIL-R-39023	Short	-	-	-	-	-	-	.01	-	.10
		RVC	MIL-R-23285	Open	-	-	-	-	-	-	.19	-	.35
				Other	-	-	-	-	-	-	.80	-	.50
	RF	-	MIL-C-15305	Short	-	-	.07	-	.18	.06	.30	.50	-
			MIL-C-39010	Open	1.0	-	.86	1.0	.82	.45	.50	.50	1.0
				Other	-	-	.07	-	-	.49	.20	-	-
Transformer	Audio	TF	MIL-T-27	Short	.20	-	.22	-	.61	.61	.25	.40	-
				Open	.80	-	.59	-	.43	.36	.70	.60	-
				Other	-	-	.19	-	-	.03	.05	-	-

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCE (Continued)

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Transformer (cont.)	Power	TF	MIL-T-27	Short	.20	-	.26	.95	.57	-	.25	.40	.95
				Open	.80	-	.61	.05	.43	-	.70	.60	.05
				Other	-	-	.13	-	-	-	.05	-	-
	High Power Pulse	TF	MIL-T-27	Short	.20	-	.15	.34	.57	-	.25	.40	.50
				Open	.80	-	.80	.66	.43	-	.70	.60	.50
				Other	-	-	.05	-	-	-	.05	-	-
	Low Power Pulse	TP	MIL-T-21038	Short	.20	-	.15	.34	.57	-	.25	.40	.50
				Open	.80	-	.80	.66	.43	-	.70	.60	.50
				Other	-	-	.05	-	-	-	.05	-	-
Capacitor, Fixed	IF, RF, and Discriminator	-	MIL-T-55631 MIL-T-55631	Short	.20	-	.15	-	.57	.61	.25	.40	-
				Open	.80	-	.80	-	.43	.36	.70	.60	-
				Other	-	-	.05	-	-	.03	.05	-	-
	Paper and Plastic Film	CP CA	MIL-C-25 MIL-C-12889	Short	-	.95	.67	.30	.40	.80	.50	.20	.30
				Open	-	.05	.22	.70	.60	.10	.02	.75	.70
				Other	-	-	.11	-	-	.10	.48	.05	-
	Metalized	CZ	MIL-C-11693	Short	-	-	.67	-	.67	.02	-	.20	-
				Open	-	-	.22	-	.33	.12	-	.75	-
				Other	-	-	.11	-	-	.86	-	.05	-
	Paper and Plastic Film	CPV CQR	MIL-C-14157 MIL-C-19978	Short	.90	.95	.67	-	.40	.80	.50	.20	.30
				Open	.10	.05	.22	-	.60	.10	.02	.15	.70
				Other	-	-	.11	-	-	.10	.48	.05	-
	Metalized Paper	CH CHR	MIL-C-18312 MIL-C-39022	Short	.30	-	.67	-	.67	.02	-	.20	-
				Open	.70	-	.22	-	.33	.12	-	.75	-
				Other	-	-	.11	-	-	.86	-	.05	-

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCE (Continued)

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Capacitor, Fixed (cont.)	Metalized Plastic	CFR	MIL-C-55514	Short	-	-	.67	-	.65	-	.50	.20	-
				Open	-	-	.22	-	.35	-	.02	.75	-
				Other	-	-	.11	-	-	-	.48	.05	-
	Super-Metalized Plastic	CHR	MIL-C-83421	Short	-	-	.67	-	-	-	.50	.20	-
				Open	-	-	.22	-	-	-	.02	.75	-
				Other	-	-	.11	-	-	-	.48	.05	-
	Mica	CM CMR	MIL-C-5 MIL-C-39001	Short	-	.30	.15	.75	.65	.08	.30	.50	.75
				Open	-	.70	.80	.25	.35	.87	0	.25	.25
				Other	-	-	.05	-	-	.05	.70	.25	-
	Button Mica	CB	MIL-C-10950	Short	-	-	.15	-	.65	.08	.30	.50	.75
				Open	-	-	.80	-	.35	.87	0	.25	.25
				Other	-	-	.05	-	-	.05	.70	.25	-
	Glass	CY CYR	MIL-C-11272 MIL-C-23269	Short	.30	.30	.05	.80	.65	-	-	.50	.80
				Open	.70	.70	.80	.20	.35	-	-	.25	.20
				Other	-	-	.15	-	-	-	-	.25	-
	Ceramic, General Purpose	CK CKR	MIL-C-11015 MIL-C-39014	Short	.50	.30	.75	.75	.50	.44	.30	.60	.75
				Open	.50	.70	.25	.25	.50	.44	.05	.10	.25
				Other	-	-	-	-	-	.12	.65	.30	-
	Ceramic, Temp Compensating	CC CCR	MIL-C-20	Short	.50	.30	.75	.75	-	.44	.30	.60	.75
				Open	.50	.70	.25	.25	-	.44	.05	.10	.25
				Other	-	-	-	-	-	.12	.65	.30	-
	Tantalum, Electrolytic (Solid)	CSR	MIL-C-39003	Short	.95	.90	.85	-	.71	.04	.80	.35	.50
				Open	.05	.05	.15	-	.29	.84	.05	.35	.20
				Other	-	.05	-	-	-	.12	.15	.10	.30

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCE (Continued)

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Capacitor, Fixed (cont.)	Tantalum, Electrolytic (Non-solid)	CL	MIL-C-3965	Short	.80	.05	.10	-	.83	.12	.10	.20	.50
		CLR	MIL-C-39006	Open	.20	.05	.90	-	.17	.12	.40	.10	.20
				Other	-	.90	-	-	-	.76	.50	.70	.30
Capacitor Variable	Aluminum Oxide, Electrolytic	CU	MIL-C-39018	Short	-	-	-	-	.33	-	-	-	-
				Open	-	-	-	-	.67	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-
	Aluminum, Dry Electrolyte	CE	MIL-C-62	Short	-	-	-	-	.80	-	-	-	-
				Open	-	-	-	-	.20	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-
	Ceramic	CV	MIL-C-81	Short	-	-	-	-	-	-	-	-	-
				Open	-	1.0	-	-	-	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-
	Piston Type Tubular Trimmer	PC	MIL-C-14409	Short	-	-	-	-	-	-	-	-	-
				Open	-	1.0	-	-	-	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-
Switch	Air Trimmer	CT	MIL-C-92	Short	-	-	.87	1.0	-	-	-	-	1.0
				Open	-	1.0	.13	-	-	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-
	Vacuum or Gas	CG	MIL-C-23183	Short	-	-	-	-	-	-	-	-	-
				Open	-	1.0	-	-	-	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-
	Snap Action, Toggle, or Pushbutton	-	MIL-S-3950 MIL-S-8805	Short	-	-	-	.50	.18	.50	-	.10	.50
				Open	-	-	-	.50	.82	.50	-	.90	.50
				Mech Fail	-	-	-	-	-	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCE (Continued)

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Switch (cont.)	Basic Sensitive	-	MIL-S-8805	Short	-	-	-	-	-	-	-	-	-
				Open	-	-	-	-	-	-	-	-	-
				Mech Fail	-	-	-	-	-	-	-	-	-
				Other	-	-	-	-	-	-	-	-	-
	Rotary	-	MIL-S-3786	Short	-	-	-	-	-	.15	-	-	-
				Open	-	-	-	.92	.29	.85	-	.75	.92
				Mech Fail	-	-	-	.08	.71	-	-	.25	.08
				Other	-	-	-	-	-	-	-	-	-
Connectors	Rack and Panel, and Circular	-	MIL-C-23408	Open	1.0	-	.9	.88	-	.93	.60	.90	.12
				Contact	-	-	.1	.12	-	.07	-	.10	.88
				Short	-	-	-	-	-	-	.40	-	-
				Other	-	-	-	-	-	-	-	-	-
	Power	-	MIL-C-3767	Open	1.0	-	.9	.88	-	.93	.60	-	.12
				Contact	-	-	.1	.12	-	.07	-	-	.88
				Short	-	-	-	-	-	-	.40	-	-
				Other	-	-	-	-	-	-	-	-	-
	RF, Coaxial	-	MIL-C-3607	Open	-	-	.9	.88	-	.93	.60	-	.12
				Contact	-	-	.1	.12	-	.07	-	-	.88
				Short	-	-	-	-	-	-	.40	-	-
				Other	-	-	-	-	-	-	-	-	-

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCE (Continued)

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Diode	General Purpose	-	MIL-S-19500	Short	.70	.30	.39	.75	.50	.10	.70	.20	.75
				Open	.30	.10	.42	.25	.50	.10	.30	.65	.25
				Drift	-	.60	.19	-	-	.80	-	.15	-
	Zener	-	MIL-S-19500	Short	.70	.30	-	.08	.75	.15	.50	.20	.08
				Open	.30	.10	-	.92	.25	.03	.30	.40	.92
				Drift	-	.60	-	-	-	.82	.20	.40	-
	Thyristor	-	MIL-S-19500	Short	-	-	-	-	.67	-	.65	.30	-
				Open	-	-	-	-	.33	-	.25	.60	-
				Other	-	-	-	-	-	-	.10	.10	-
	Microwave Mixers and Detectors	-	MIL-S-19500	Short	-	-	.11	-	-	-	-	-	-
				Open	-	-	.15	-	-	-	-	-	-
				Other	-	-	.74	-	-	-	-	-	-
	Varactor, Pin, Impatt, Step Recovery, Tunnel & Gunn	-	MIL-S-19500	Short	-	-	-	.59	-	-	-	-	.59
				Open	-	-	-	.41	-	-	-	-	.41
				Other	-	-	-	-	-	-	-	-	-
Transistor	General Purpose	-	MIL-S-19500	Junction	.50	.08	.36	.66	63	.15	.40	.20	.66
				Short	.50	.20	.52	.34	37	.20	.55	.55	.34
				Open	-	.72	.12	-	-	.65	.05	.25	-
	Field Effect	-	MIL-S-19500	Junction	-	-	-	-	75	-	.60	.60	-
				Short	-	-	-	-	25	-	.40	.10	-
				Open	-	-	-	-	-	-	-	.30	-

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCE (Continued)

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Transistor (cont.)	Unijunction	-	MIL-S-19500	Junction	-	-	-	-	-	-	.30	.05	-
				Short	-	-	-	-	-	-	.40	.55	-
				Open	-	-	-	-	-	-	.30	.40	-
Opto Electronic	Microwave	-	MIL-S-19500	Other	-	-	-	-	-	-	-	-	-
				Short	-	-	-	-	-	-	-	-	-
				Open	-	-	-	-	-	-	-	-	-
	Light Emitting Diode	-	MIL-S-19500	Other	-	-	-	-	-	-	-	-	-
				Short	-	-	-	-	-	-	-	-	-
				Open	-	-	-	-	-	-	-	-	-
Crystal Units	Coupler	-		No Output	-	-	-	-	-	-	-	-	-
	Alpha-Numeric Display	-											
	Phototransistor	-											
	Photodiode	-											
		-											
		-											
Relays		-		Short	-	-	.11	.98	-	-	-	-	.98
		-		Open	-	-	.67	.02	1.0	-	-	-	.02
		-		No Output	1.0	-	.22	-	-	-	-	-	-
		-		Coil Open	-	-	-	-	.44	.24	-	.12	.30
		-		Coil Short	-	-	-	-	-	-	-	.06	-
		-		Contact Open	.70	-	.95	.70	.56	.73	-	.60	.70

TABLE 4. HIGH USAGE COMPONENT FAILURE MODES AND PERCENTAGES OF OCCURRENCE (Continued)

Component Type	Description	Style	MIL-Spec	Failure Mode	A	B	C	D	E	F	G	H	I
Relays				Contact Short (Stuck)	.30	-	.05	.30	-	-	-	.22	-
				Short	-	-	.30	.50	-	-	-	-	.50
Delay Line				Open	-	-	.60	.50	-	-	-	-	.50
				Drift	-	-	.10	-	-	-	-	-	-
Filters				Short	-	-	.45	.05	-	-	-	-	.05
				Open	-	-	.50	.95	-	-	-	-	.95
				Drift	-	-	.05	-	-	-	-	-	-
Lamp				Open	-	-	-	.90	-	.70	.95	-	.90
				Low Light Out	-	-	-	.10	-	.30	-	-	.10
Tubes				Other	-	-	-	-	-	-	.05	-	-
				Low Emis-sion	-	-	-	.80	-	-	-	-	.80
Motors				Open Filament	-	-	-	.20	-	-	-	-	.20
				Short	-	-	-	.55	-	-	-	.05	.55
				Open Mechanical	-	-	-	.45	-	-	-	-	.45
Transducers	Pressure			Short	-	-	-	-	-	-	-	.95	-
				Open	-	-	-	-	-	-	-	-	.10
	Temperature			Other	-	-	-	-	-	-	-	-	.70
				Short	-	-	-	-	-	-	-	-	.20
				Open	-	-	-	-	-	-	-	-	.20
				Other	-	-	-	-	-	-	-	-	.80

SECTION 5

GENERAL FMEA CONSIDERATIONS

This section provides a general discussion of some FMEA related topics of a general type. The topics discussed are independent of the specific technique utilized in performing the FMEA and do not provide specific information on areas related to the application of the standardized technique.

An FMEA is a hardware-based analysis of the effects of failure on an end item equipment or system at each successive level of hardware indenture. The analysis proceeds concurrent with the hardware design program becoming increasingly complex as the specific design detail becomes available. The final analysis is a bottom-up evaluation of the effects of each discrete possible failure at every level of hardware indenture. The analysis has traditionally been limited to single point failures.

A carefully performed FMEA provides the necessary information to support a wide range of engineering specialty disciplines. The FMEA has traditionally been used to provide reliability and safety information during the design process. The analysis can also support maintainability analysis in accordance with MIL-HDBK-472, Procedure 5, built-in-test effectiveness evaluations, testability evaluation, and provide an information source for evaluating the logistics supportability of the design. The use of an FMEA as a baseline for multi-discipline analyses requires that one or more highly skilled analysts perform the FMEA. The analyst performing the FMEA will need to either be skilled in design engineering, reliability, safety, maintainability, human factors, and integrated logistics or have access to and support from individuals with the necessary technical background.

5.1 FMEA PROGRAM PHASING

The performance of an FMEA concurrent with the design program is crucial. The analysis needs to produce continuous interim results which can cause design changes at an optimum point during the design. An FMEA which is performed at the conclusion of a design program may have little impact. Incorporating the results of a late FMEA can be cost-prohibitive for all but the most severe problems discovered by the analysis.

An FMEA should almost never be the analysis of choice for existing systems and equipment. The mandated performance of an FMEA on an existing equipment under a Government contract can potentially produce a biased document. The FMEA may be used either to justify the already made design decisions or as justification for a redesign contract at a profit for the contractor. An FMEA should be considered for an existing equipment only when the equipment history indicates that a major redesign program is required. The FMEA can be used in these cases to provide scope and direction to the redesign program...

5.1.1 PROGRAM PHASES

The program phases discussed in this section are presented in terms of a military procurement. There should be a one-to-one correspondence between a commercial program and a military procurement. The major differences are: (1) there are no formal dividing points between program phases and (2) the equipment is usually designed in response to the demands of the marketplace rather than to a formal specification issued by the end user. The four phases of the normal military procurement cycle are discussed below.

5.1.1.1 Conceptual Phase

During the conceptual phase of a design program, equipment needs or requirements in overall terms are decided. Decisions such as whether to use an aircraft or a missile for a specific defined mission requirement are resolved along with the development of general capabilities requirements for the selected equipment. An FMEA does not have any general applicability during this phase.

5.1.1.2 Validation Phase

During the validation phase, the general requirements defined during the conceptual phase are further refined to produce specific system and subsystem

requirements. This phase may include some limited hardware design to assess the feasibility of requirements with respect to existing technology. The validation phase will result in detailed system and subsystem specifications to be utilized in designing hardware during the Full-Scale Engineering Development (FSED) phase.

An FMEA is not generally applicable during the validation phase. The analysis can, however, be used to help assess the safety and reliability features of the limited hardware design which sometimes occur during the validation phase.

There are numerous tradeoffs in design options which occur during this phase. While an FMEA is not directly applicable to these tradeoffs, the FMEA requirements of a program can be significantly impacted. During the validation phase the information necessary to identify items or functions which are inherently safety critical should be determined.

5.1.1.3 Full-Scale Engineering Development Phase

The FSED phase of a design program is characterized by the development of detailed hardware design solutions to the system, subsystem, and equipment requirements defined during the validation phase of a program. The FSED phase progresses from conceptual, block diagram approaches to detailed hardware designs and the development and test of engineering prototype equipment.

The FSED phase has several major program milestone points uniquely associated with it:

- Preliminary Design Review (PDR) - The PDR milestone is usually held at a relatively early point in the design process. The purpose of the PDR is to review conceptual design approach at a block diagram level to ensure that the conceptual approach selected is capable of achieving the necessary performance requirements.
- Critical Design Review (CDR) - The CDR milestone typically is scheduled at the end of the conceptual or paper design time frame. The purpose of the CDR is to review the detailed design approaches used to satisfy the equipment performance requirements. Engineering prototype equipment is not usually available; however, most of the hardware solutions presented have been at least partially validated in engineering breadboard configurations.

- **Qualification Testing** - Qualification testing of engineering prototype equipment occurs during the final segment of the FSED phase. One or more prototype equipments are subjected to the appropriate testing to ensure that the final, integrated hardware design will perform adequately in its intended environment.

The FSED phase concludes with the successful completion of qualification testing. The hardware design has been proven and is ready to enter production.

The FSED phase is usually the period of the most intense FMEA activity. The analysis is iteratively performed during this period. The analysis proceeds in increasing detail as the hardware design progresses. The ongoing analysis is used as an information source to provide design feedback on the reliability, safety, maintainability, and testability impacts of the design approaches taken. The timely performance of an FMEA during FSED is important to ensure maximum design impact. An FMEA performed late in the FSED phase of a program can result in an expensive CDRL item which contributes little to the design itself due to the high cost of implementing design changes.

5.1.1.4 Production Phase

The production phase of a program is the final phase, where production hardware is produced for delivery to a customer. The basic design of an equipment remains fairly constant throughout this phase but is subject to modification to provide better productivity, easier assembly, better availability of parts, and some performance enhancements. The early production period is usually characterized by frequent changes. The number of changes gradually reduces as production continues and an optimal producibility point is approached.

The primary FMEA activity (if any) during the production phase of a program consists of updating for design changes. The FMEA which was produced during the FSED phase can be continually updated to reflect design changes allowing use as a baseline document to assess the reliability, maintainability, safety, and testability impact of proposed changes.

5.2 FMEA ACTIVITY OVERVIEW

FMEA activity usually starts in the very late validation phase or early PSED phase and continues as an integrated program element throughout the design program. It can then be used until production is complete as shown in Figure 2. This requires various approaches to the FMEA be used which are compatible with the design program phase.

The FMEA effort during late validation phase should focus on the identification and tradeoff of inherently critical functions for design control. The identification of inherently critical functions is a part of the system engineering process and involves an iterative tradeoff process with respect to all areas of designs. The task of determining criticality for subsystems is often not straightforward and usually involves a number of compromises between various subsystem elements with respect to performance versus redundancy. As an example:

During the initial design of an aircraft, it is decided to use TACAN for area navigation information. The TACAN is to supply range and bearing information to an on-board computer for use in position determination and aircraft guidance control over a redundant serial bus structure in digital format. Erroneous aircraft position determination is an inherently critical item. The failure of a single navigation aid is not generally critical as other equipments supply redundant information. The design approach to position determination (TACAN) allows several different approaches which




Figure 2. Development Program Time Line

will effect the severity classification of failures of the on-board equipment which is being designed.

- Approach No. 1: Install one TACAN on board the aircraft which is in direct dialog with the computer. The TACAN is then backed up by an additional navigation aid (non-TACAN) which can be used by the pilot to determine position. This approach requires that the TACAN built-in-test circuitry be extremely effective. It has the potential to adversely impact cost and schedule. This also requires that built-in-test failures be treated as inherently critical by the TACAN manufacturer during design.
- Approach No. 2: Install more than one TACAN and compare the range and bearing outputs in a voting arrangement. This approach will effectively prohibit the acceptance of incorrect information due to TACAN failures eliminating the need for an inordinately effective built-in-test arrangement. The inherent disadvantage of this approach is that multiple TACANs must be purchased at an increased cost and the space for additional avionics packages may not be available.
- Approach No. 3: Install one TACAN with a fairly effective Built-In-Test (BIT) capability and perform a computer check on the range and bearing information received with respect to the last data received. The comparison of readings would allow the on-board computer to effectively perform a BIT which would be capable of detecting gross failures. Gross failures normally produce range or bearing differentials which exceed the aircraft performance capabilities. The inherent disadvantage of this approach is that temporary transients which affect the TACAN readings would potentially have to be treated as failures, causing a high false alarm rate.

The results of each system engineering tradeoff will determine the inherent level of severity for the various subsystem functions. These severity/safety considerations will then effect the FMEAs performed at the system level and at each succeeding level of hardware indenture. In the example given, Approach No. 2 would effectively preclude the need for a TACAN FMEA, while Approach No. 1 would require that an FMEA, potentially to a piece-part level of detail, be performed for the TACAN.

The results of these system engineering decisions must be available to an engineer who is performing an FMEA for determination of failure severity. The necessary system design tradeoff information is best transferred to subsystem design groups through conference approach between the responsible system engineering group (often a Government agency or major contractor) and the responsible subsystem design group (often a subcontractor). The initial conference should take place at the end of the validation phase or at the start of the FSED phase and prior to the start of detailed hardware design for the system and subsystems. This will allow an early identification of critical areas for design control and will allow FMEA to focus on those design attributes which are inherently safety related.

5.3 FMEA ACTIVITY IN FULL-SCALE ENGINEERING DEVELOPMENT

Formal FMEA activity should commence concurrent with the start of hardware design. This is normally the beginning of the FSED phase. FMEA activity during the FSED should be fairly intensive and closely follow the ongoing design program. The accomplishment of FMEA activity coincident with the design process is extremely important if maximum benefit is to be gained from the activity.

During the early FSED phase which occupies the time frame from the start of FSED until a PDR time frame, FMEA efforts should proceed at a block diagram level. Design guidelines and criteria identifying the system and/or subsystem failure modes which are inherently of severity Category I (catastrophic) or Category II (critical) should be issued as early as possible. As the tentative system/subsystem partitioning is identified, individual guidelines for avoiding Category I and II failure effects should be tailored for each of the identified hardware subdivisions. The hardware design identifies the approach which will be taken at a block diagram level. The FMEA should be performed at this level, and the results should be used to judge the acceptability of the proposed approach with respect to resolving the inherent potential for Category I and II failures. Additionally, initial guidelines on indicators, test points, and BIT should be generated as a part of the FMEA activity, so that testability and failure

detectability are considered an integral part of the design. The results of the early FMEA activity and proposed solutions to any problems should be presented at the PDR.

During the PDR or a closely coincident time frame, an FMEA conference should be held. This conference will allow a thorough review of early FMEA activity and a tailoring of further FMEA effort to be agreed upon. The conference should produce an agreement on basic failure criticality considerations and allow the transfer of needed information between the responsible FMEA engineer and the customer's organization. It is not unusual for subsystem and equipment manufacturers to have a very limited knowledge of the larger system into which the equipment will be installed. This can result in potentially hazardous failure conditions being overlooked. On Government programs, the information necessary to make failure categorization decisions based on system effect may be classified. A PDR time frame conference provides an appropriate forum for the transfer of such classified information while allowing a need to know to be firmly established.

During the period between PDR and CDR, the majority of formal FMEA occurs. The FMEA should be performed at successive levels of indenture coincident with the hardware design development. In general, the FMEA should be performed at as high an indenture level as is possible while ensuring that any potential Category I or II failures are identified and eliminated or controlled to the maximum extent possible. This will usually require that circuits which can potentially experience Category I or II failures be analyzed to the piece-part level; however, this level of detail should not generally be required for circuitry whose failure can cause only Category III or IV failure effects. If the FMEA is to be accomplished in a cost-effective manner the guidance of MIL-STD-785B should be followed:

"FOR BASIC RELIABILITY, DO NOT ANALYZE BELOW THE LEVEL AT WHICH A FAILURE WILL CAUSE A DEMAND FOR MAINTENANCE, REPAIR, OR LOGISTICS SUPPORT. FOR MISSION RELIABILITY, DO NOT ANALYZE BELOW THE LEVEL NECESSARY TO IDENTIFY MISSION CRITICAL FAILURES."

The only time that an FMEA at a piece-part level of detail is justified for an entire equipment is when either all the circuitry being analyzed has the potential for causing Category I and II failure effects or when a sufficiently high percentage of the circuitry being analyzed requires piece-part level analysis. This makes analysis at a piece-part level of the remaining circuitry a cost-effective alternative to supplementing

the FMEA with other analysis methods of generating maintainability, reliability, and testability information.

The FMEA which is performed during the FSED phase between PDR and CDR should also be used to optimize the maintainability and testability of the design. The ambiguity information required for maintainability analysis in accordance with MIL-HDBK-472 Procedure 5 should be available as a part of the analysis.

At CDR or at a conference held in a corresponding time frame, the final FMEA should be reviewed for accuracy and completeness. The final resolution of all potential Category I and II failures should be reviewed, and an agreement on the safety and fitness of the final design should be reached. The failure modes and effects data can then become a baseline document to be used in assessing the impact of proposed changes to the system reliability, maintainability, safety, and testability characteristics. Formal data delivery, if required, should be scheduled for the period following CDR.

During the qualification test period, the FMEA can be used for assessing design changes in response to observed test failures. The FMEA can be updated to reflect any design changes which are implemented as a result of the testing. Additionally, the results of qualification testing failures can be used to validate the results of the paper FMEA analysis. When formal data delivery has been required on a contract, an update of the FMEA document can be required at the completion of all qualification testing. The final FMEA update completes the FMEA requirements for the FSED phase and provides an analysis baseline for the production equipment.

5.4 FMEA ACTIVITY DURING PRODUCTION

During the production phase of a program the FMEA can be used as a baseline document for evaluating the reliability, maintainability, safety, and testability impact of proposed changes. When the FMEA is used as a baseline document, the data should be updated periodically to reflect any implemented design change activity. As a minimum the FMEA should be formally updated on Government programs concurrent with the implementation of any Class I engineering change proposal.

5.5 FMEA PROCUREMENT APPROACH

An FMEA is usually specified as a formal, deliverable item only on Government procurements. The current methods used to specify the analysis have the potential for producing less than optimum results in terms of both analysis cost and benefit received.

An FMEA is usually specified by the Government within the contractual Statement of Work (SOW). The most common method used is to specify the FMEA in accordance with a Contract Data Requirements List (CDRL) item and at a specific level of detail, often piece-part. The specification of level of detail for an FMEA prior to the point where some design visibility is available can result in a worst case level of detail being specified to ensure that the analysis is performed at an adequate level of detail. This can result in large increases in FMEA cost without a matching increase in analysis benefit. The FMEA is normally required to be a review topic at design reviews. Formal data delivery in accordance with the CDRL is usually 30 to 90 days after critical design review. The procurement process needs to ensure that the FMEA cannot be treated primarily as a CDRL item instead of a design analysis tool.

A refinement of the procurement techniques currently in use can help ensure maximum benefit from the analysis while controlling cost. The primary changes suggested are to specify that the final level of detail for the analysis will be decided at approximately a PDR time frame and to include a guidance conference and at least one review conference as a part of the FMEA process. Two conferences should provide the minimum guidance and review necessary to help ensure that an optimum cost benefit point is achieved.

The initial guidance conference should be scheduled for a PDR time frame. This conference will allow any needed information to be provided and allows the necessary level of analysis detail to be determined after some hardware design visibility is available. The later specifications of level of detail can be used to help ensure that the analysis is tailored to achieve the necessary program requirements while controlling the costs which can be incurred if the required level of detail is over specified. The PDR time frame conference also allows for review of early FMEA efforts and results. This should reduce the potential for the analysis being treated strictly as a CDRL item.

A review conference should be scheduled in a CDR time frame. This conference will allow FMEA progress and results to be monitored early enough in the program to be effective. Final hardware design approach approval usually occurs following the CDR.

The implementation of changes based on the FMEA after design approach approval is difficult.

If a conference approach to FMEA specification and control is used, it needs to be structured to prevent abuses by contractor organizations. This will require that any FMEA be bid as a part of the proposal process, during the competitive part of the procurement process. The FMEA bid submitted as a part of a proposal where a conference type approach is used will need to be more detailed than has traditionally been required. The initial bid can then be used during the initial guidance conference as a basis for cost recovery by the Government. The contractor should be precluded from changing his baseline bid or negotiating the contract value upward as a result of the technical decisions made during the guidance conference. The inclusion of the necessary controls in the SOW and contract should not impose any unusual difficulty.

The use of guidance and in-process conferences would be new to the FMEA process but not to Government procurement practices. A very similar set of conferences is routinely used for provisioning, technical manuals, and logistics support analysis with positive results.

5.6 FAILURE SEVERITY CATEGORIZATION

The assignment of severity classifications to the failures considered during an FMEA can be difficult. The assignment of correct classification to an equipment failure requires that the analyst be thoroughly familiar with the equipment, the system into which it will be installed, possible missions and conditions under which the equipment may be used, and the potential for human error contribution. There is not always universal agreement between analysts as to the proper categorization of each failure. As a general rule, if the analyst is unable to determine which of two possible failure classifications is correct for a given failure, the more severe classification should be used. The failure severity classifications provided by MIL-STD-1629 are:

- Category I - Catastrophic - A failure which may cause death or weapon system loss (i.e., aircraft, tank, missile, ship, etc.).
- Category II - Critical - A failure which may cause severe injury, major property damage, or major system damage which will result in mission loss.

- **Category III - Marginal** - A failure which may cause minor injury, minor property damage, or minor system damage which will result in delay or loss of availability or mission degradation
- **Category IV - Minor** - A failure not serious enough to cause injury, property damage, or system damage, but which will result in unscheduled maintenance or repair.

An FMEA is usually not performed below the level of detail necessary to ensure that a given circuit can only produce Category III or IV failures. The FMEA generally is continued to a piece-part level of detail for Category I and II failures. The Category I and II failures comprise three basic types:

- **Direct Physical Hazard** - This type of failure causes a direct physical hazard upon its occurrence. The types of hazards and the necessary controls are defined in MIL-STD-454, Requirement 1
- **Functionally Inherent Hazards** - This type of failure causes a significant hazard by failing in a basic function of its purpose. This is characteristically a failure of a control or guidance function involved in an inherently safety-related process.
- **Human Error Contributory Hazard** - This type of failure presents a potentially hazardous situation where human recognition and/or response is critical to the degree of hazard actually occurring as a result of the failure.

Those failures which constitute the direct physical hazard type are generally easy to recognize and to design adequate compensation for. The degree of hazard represented by the functionally inherent and human error contributory types of hazards are more difficult to recognize and provide compensation for.

Any failure which causes the loss of a functionally critical equipment parameter should be analyzed thoroughly for possible system safety impact. All single point failures which can cause a Category I or II failure of a functionally inherent type should be designed out of the equipment through the use of selective redundancy, or by ensuring that the failure is automatically detected by BIT circuitry and that adequate compensation has been provided. The FMEA analyst should ensure that any BIT circuitry used to detect functionally inherent hazards has been designed to fail in an alarm condition (fail-safe).

The number of human error contributory type failures should be minimized by design, and the use of automatic compensation for these failure types should be considered wherever practical. When the use of automatic compensation is not practical, the FMEA analyst should ensure that the proposed design is carefully analyzed by human engineering specialists and that their recommendations are incorporated into the design so that an optimum man-machine interface results. Additionally, the analyst should ensure that all relevant material concerning the hazard is included in all training courses and technical manuals. A discussion of the potential hazard should be included in the FMEA document and be discussed at design reviews and FMEA conferences. In assigning failure classification to this type of failure the analyst should assume that the human will make a worst case error.

5.7 MAINTAINABILITY AND TESTABILITY INFORMATION

A significant amount of the information necessary to perform maintainability analysis in accordance with MIL-HDBK-472 Procedure 5 and to assess the testability adequacy of an equipment is developed as a part of the FMEA. This information, while available in an FMEA, is usually not easy to extract from the documented results. This difficulty is caused by both the format of the information presented and by the information itself.

In order to allow the maximum useability of the FMEA results for maintainability and testability analysis, the equipment indicators and accessible test points need to be considered as distinct outputs during the analysis. The maintainability and testability information which can then be extracted from the analysis is in the form of failure symptoms available at each level of indenture. The most critical parameter to be considered for maintainability and testability purposes is the level of ambiguity which exists at each maintenance level with respect to the failure effect under consideration. This results in a tracking of the failure symptomology as it is shown in meters, indicators, alarms, accessible test points, and possible causes. This information can then be used to recommend additional indicators, test points, etc. where they are necessary to allow isolation between possible causes.

If sufficient accessible test points, indicators, etc. are used in a piece of equipment to isolate a given failure effect or symptom to the failed LRU, then that failure effect has an ambiguity level of one with respect to LRU isolation. If the same failure effect or symptom is isolatable to two possible SRUs, then the failure effect has

an ambiguity level of two with respect to SRU isolation. This would indicate the need for additional test points which are accessible to the maintenance technician for SRU isolation. An ambiguity level of two or greater usually results in increased maintenance labor hour requirements, and increased demands on the logistic support systems.

The extraction of maintainability and testability data from the FMEA at the piece-part level is generally not productive. Piece-part repair is accomplished at depot maintenance facilities using specialized test fixturing. Also, depot level technicians can usually access component mounting pads directly which eliminates the need for additional test points. However, if the equipment under analysis contains depot repaired SRUs which are modules containing multiple circuit cards, the ability to isolate to the failed circuit card utilizing test points should be evaluated.

When an FMEA is performed in a time frame consistent with a design program, the maintainability and testability information being developed as a part of the process should be used to ensure the inclusion of needed test points, indicators, etc. in the final design. This will help ensure that the finished design has adequate testability characteristics with minimum maintenance manhour and logistic support requirements.

5.8 HUMAN ENGINEERING CONSIDERATIONS

The evaluation of the human factors adequacy of a proposed design is an integral part of the FMEA process for most equipment. Almost all large systems require one or more man-machine interfaces. The adequacy of these interfaces can be a significant factor in the severity of a failure. An FMEA analyst needs to be aware of the system man-machine interfaces even when the analysis is being performed at a subsystem or black box level.

The human factors considerations which need to be considered during an FMEA comprise three broad categories:

- Effectiveness of failure alarms and indicators
- Effectiveness of failure compensation devices
- Impact of BIT design.

Failure alarms and indicators need to be evaluated for adequacy in terms of alerting human operators that a failure has occurred. The type of indicator, placement within the system, and brightness need to be evaluated. The effectiveness of audible

versus visual alarm usage needs to be analyzed. Additionally, the potential safety impact of a defective failure indicator needs to be considered.

The effectiveness and adequacy of human activated failure compensation devices or procedures should also be considered as a part of a thorough FMEA. An evaluation of the ability of an operator to actuate compensation devices under the initial effects of a given failure needs to be performed. This evaluation is particularly critical for high performance systems, such as fighter aircraft, which can subject the operator to extreme environmental conditions (e.g., high speed turns, etc.) upon equipment failure. The potential for incorrect action and the overall skill level of the likely operator of the system need to be carefully considered in these evaluations.

The impact of built-in-test circuitry decisions needs to be evaluated as it impacts the man-machine interface. The ability of an operator to recognize and compensate for failures which are not detected by BIT can be more important than the direct percentage of failures detected. The overall effectiveness of automatically detecting failures which are easily recognized by the operator must be analyzed with respect to the increased equipment failure rate and false alarm rate associated with increased BIT capability.

The FMEA analyst needs to ensure that the results of all evaluations are available to training departments, safety engineering, and technical publications. Any requirements for special skills or training which may be needed to ensure adequate operator response to a failure occurrence needs to appear in all relevant technical material, even when initial training is contracted through the manufacturer. Many products which are produced for a relatively short number of years have a service lifetime of twenty years or more.

5.9 FMEA PRESENTATION FORMATS

The FMEA results can be presented in several different formats. The format chosen should be based on a combination of the equipment under analysis, and the intended use of the data. An example of the most prominently used formats are shown in Figures 3, 4, and 7. Each of the three commonly used formats has unique characteristics which may recommend its use under certain circumstances. Table 5 provides a comparison of the most significant features of these three formats.

FAILURE MODE AND EFFECTS ANALYSIS

SYSTEM _____
INDENTURE LEVEL _____
REFERENCE DRAWING _____
MISSION _____

[illegible]

Figure 3. Typical FMEA Tabular Format (MIL-STD-1629A)

FAILURE MODES AND EFFECTS ANALYSIS

FMEA WORKSHEET FOR _____		
FMEA IDENTIFICATION NUMBER _____		
DATE: _____	PREPARED BY: _____	APPROVED BY: _____
SCHEMATIC DIAGRAM _____	REVISION: _____	
BLOCK DIAGRAM: _____	REVISION: _____	
PARTS LIST: _____	REVISION: _____	
MISSION: _____		
MISSION PHASE: _____		
ITEM PART NUMBER: _____	FSCM: _____	INDENTURE: _____
ITEM NOMENCLATURE: _____	REF. DESIGNATOR: _____	
FAILURE MODE: _____ SEVERITY: _____		
CAUSE (s): _____		
FAILURE EFFECT (s): _____		
LOCAL: _____		
NEXT HIGHER ASSEMBLY: _____		
SYSTEM: _____		
CAN THE OPERATOR DETECT THIS FAILURE? _____		
HOW? _____		
CAN THE OPERATOR COMPENSATE FOR THIS FAILURE? _____		
HOW? _____		
FAILURE MODE PROBABILITY: _____	FAILURE EFFECT PROBABILITY (BETA): _____	
_____ SOURCE _____	FAILURE MODE RATIO (ALPHA): _____	
MIL-HDBK-217	FAILURE RATE (LAMBDA-P): _____	
	OPERATING HOURS (T): _____	
	FAILURE MODE CRITICALITY NUMBER (CM): _____	
	ITEM CRITICALITY NUMBER (CR): _____	
REMARKS: _____		

ITEM FUNCTION:

Figure 4. Typical FMEA Single Sheet Format

TABLE 5. FMEA FORMAT COMPARISON

Comparison Parameter	Tabular	Format Single Sheet	Matrix
Specification Compliance - Format can be used to satisfy MIL-STD-1629A requirements	E	G	G
Ease of Use by Analyst - Format is easy to use and update	G	F	E
Ease of Data Extraction - Format allows easy extraction of needed data by all users	F	P	E
Overall Clerical Load - Format minimizes clerical requirements imposed on analyst	F	P	E
Completeness - Format allows failure effects at each indenture level to be seen without referencing other areas of the document	G	G	P
Compactness - Format presents data in a compact form	F	P	E
Commentary Material - Format allows easy inclusion of commentary material	G	G	F
Multiple Analyst - Format does not present difficulty if more than one analyst is assigned	F	F	E

E = Excellent, G = Good, F = Fair, P = Poor

The format used should be based on the particular analysis, however, for most analyses the matrix format has several advantages. This is particularly true with respect to obtaining multidiscipline use of the analysis results. The matrix format is relatively easy to understand for non-specialists and allows easy extraction of data in the reverse order for maintainability and testability use. The matrix format should be considered for standardized use in most analyses.

5.10 BACKGROUND OF THE FMEA ANALYST

The performance of an FMEA requires that the assigned analyst either individually have expertise in a wide range of engineering disciplines or have access to individuals who can provide any needed supplemental expertise. The assignment of an analyst who possesses all the necessary skills to perform the FMEA without assistance is usually not possible. It is normally a better approach to use the skills available in several engineering specialty areas to review the FMEA and interface with the assigned analyst on an ongoing basis.

The analyst selected to perform an FMEA should ideally possess a background in design, reliability, maintainability, testability, safety, human factors, and logistics engineering. There are a few individuals with all the required areas of expertise, and their availability is limited. This results in a need to select an individual to perform the FMEA who possesses less than the ideal range of skills. A design engineering background in the analyst selected must be considered the most crucial criteria. A competent design engineer can perform the analysis even though he may not possess all the necessary complementary skills required to properly assess all failure effects. The additional expertise can be provided by specialty engineers on an as-required basis. It is generally more difficult to compensate for weaknesses in the design background of an analyst selected from a specialty engineering group.

5.11 FMEA USE LIMITATIONS

The FMEA is an extremely accurate and thorough analysis which produces a wide range of information useable by the specialty engineering disciplines to help ensure that their design requirements are met. The analysis is a particularly effective safety analysis tool. The analysis produces information needed by reliability, maintainability, safety, testability, and logistics engineers. When a program has requirements imposed in all or most of these specialty areas, the FMEA may be relatively cost-effective if duplication of effort is minimized. The analysis can be very expensive and may not be the most effective means of producing the needed data when primarily used to document the achievement of safety-related requirements.

When the program safety requirements will allow the FMEA to be performed at a reduced level of detail, the use of other, less formal techniques to produce any additional data needed by specialty engineering groups should be considered. The FMEA will not produce all the data needed, thus some supplementary analyses will always be required. The use of less formal techniques will help keep program costs to a minimum, while producing the required information.

SECTION 6 STANDARDIZED FMEA TECHNIQUE

6.1 INTRODUCTION

Section 6 provides an overview and detailed coverage of the advanced matrix FMEA technique. Various aspects of the technique and appropriate FMEA activities are discussed by program phase. The reader should complete Section 6 in its entirety prior to applying the technique for the first time.

The advanced matrix technique, as defined for the purposes of this study, is a standardized methodology or approach to a MIL-STD-1629A FMEA. Through this standardization of approach, a maximum benefit is obtained from the labor expended in the FMEA. This is accomplished by identifying the appropriate efforts for each program phase, and by allowing the use of multiple analysts without the coordination problems inherent in a tabular MIL-STD-1629A analysis. The advanced matrix technique provides a framework for the presentation of circuit analysis results which is defined and can be approved in advance when data item delivery is required.

6.2 TECHNIQUE OVERVIEW

The need for a standardized FMEA technique is well recognized. FMEA is an expensive analysis which needs to be used as cost-effectively as possible. Additionally, an FMEA, to achieve maximum effectiveness, should be completed in a time frame which is consistent with the ongoing design process. An FMEA which is completed late in a program may have little impact. A standardized technique, to be of value, needs to provide both a cost-effective and time-effective methodology, and the advanced matrix technique is effective in both of these areas.

The advanced matrix technique can be applied at any phase of product development. An FMEA using the advanced matrix technique, as with any FMEA technique, is most effective when started at the earliest stage of product development. The approach required is bottom-up piecewise. That is, the analysis progresses downward through the design detail one level of indenture at a time (top-down). The analysis for the given level is performed inductively. This is not a significant change to

the method by which thorough FMEAs have always been performed. The FMEA has traditionally been considered a bottom-up, or inductive, analysis. Since design information becomes available in a top-down sequence, the performance of a true, bottom-up FMEA would require the analysis to be started at the close of the design process rather than at the start of design. This would result in an ineffective FMEA, completed too late to have much impact on the design process.

The advanced matrix technique is particularly well designed to provide for the performance of FMEA in concert with an ongoing design program in a cost-effective manner. When the advanced matrix technique automation (described in Section 7), is used to aid the analyst in performing the FMEA, the analysis is particularly effective. The design of both the advanced matrix technique and the complementary automation has specifically been tailored to allow for the atmosphere of almost constant change which is a normal part of the equipment design and development process.

6.2.1 ADVANCED MATRIX TECHNIQUE PHASING

The performance of an FMEA utilizing the advanced matrix technique is accomplished in four phases: FMEA planning, initial FMEA activity, intermediate or block diagram level activity, and detail or piece-part level activity. The relationship between the design program phases and the FMEA activity is shown in Figure 5. The




Figure 5. FMEA Activity By Program Phase

FMEA planning and the initial FMEA activity can be begun as early in the program as the late design validation phase. Specific design knowledge of the equipment to be analyzed is not required during these phases of FMEA activity. The interim and detail level of activities are dependent on specific, detailed hardware design information and are completed in concert with the hardware design. This often requires that more than one analyst work on the FMEA at a time due to the multiple design personnel assigned. This is allowed by the structure of the advanced matrix technique. Each analyst works only on the specific area (e.g. assembly, unit, etc.) assigned to him and does not need to reference or deal with higher level effects. The activities of the various analysis personnel assigned are generally coordinated and led by a senior analyst. The senior analyst is usually assigned responsibility for the FMEA planning and the initial FMEA activity phases. During these early FMEA phases, the use of multiple analysts, while not impossible, is somewhat difficult.

Each iterative level of FMEA activity requires that specific information be available to the analyst allowing the analysis to produce specific outputs. Figure 6 shows the outputs expected during each phase of FMEA activity. The outputs shown represent all of those available within the structure of the technique. It is possible to perform the FMEA utilizing the technique without requiring all of the outputs to be assembled.

FMEA activity begins with the planning phase. The planning phase, which is primarily an administrative task, is used to provide scope and direction to the overall FMEA effort while minimizing the duplication of effort within a program. FMEA planning for content, depth of analysis, analyses needed, and scheduling required are developed based on the contractual requirements for safety, reliability, maintainability, and logistics. Detailed hardware design information is not needed for FMEA planning purposes. However, the analyst assigned to the FMEA planning should possess a background in systems similar to the one to be analyzed. This helps assure that initial decisions on FMEA depth of analysis are based on the type of hardware to be analyzed and its use environment.

Initial FMEA activity consists of the development of the technical baseline for the hardware FMEA which will be performed. This phase of activity produces an FMEA specification, initial design guidelines, initial system interface level FMEA, and serves as a baseline to finalize the FMEA planning which was previously accomplished. The amount of design information required for the initial FMEA activity is minimal. A system specification must exist. Hardware design information is not required. However, the analyst performing the initial analysis needs to be thoroughly familiar with the

design and use of systems similar to the one to be analyzed in order to understand the severity impact of system functional failures.


Intermediate FMEA activity begins the direct, hardware analysis traditionally associated with FMEA activity. Intermediate analysis is performed using circuit block failures. The outputs of the intermediate analysis process include traditional MIL-STD-1629 FMEA information, maintainability test point information, and built-in-test analysis information. The intermediate level of analysis requires that final system and equipment specifications, initial system partitioning, and block diagrams of equipment circuitry be available to the analyst. The intermediate level of analysis will usually satisfy the analysis depth which is required to review circuitry which is not capable of causing MIL-STD-1629A severity category one or two failures.

The detail level of FMEA activity is the piece part FMEA analysis. The detail activity provides the most comprehensive FMEA and is the most costly level of analysis. This level of activity is usually limited to circuits which can cause MIL-STD-1629A severity category one or two failures, or for those cases where FMEA at the piece part level of detail is the most cost effective means of developing the information needed to support maintainability or logistics analyses. A comprehensive set of design information including specifications, schematics, hardware drawings, and parts lists must be available to allow detailed FMEA activity.

6.2.2 ADVANCED MATRIX TECHNIQUE STRUCTURE

The advanced matrix technique has a structure which is similar to that of the original matrix technique. A matrix grid is used to hold the analysis information. This matrix provides good visibility of FMEA results and excellent traceability to higher and lower levels of indenture. The traceability provided by the matrix eliminates the need for the redundant, clerical entries of higher level effects, which are required by tabular methods.

Figure 7 shows a typical matrix structure which is used at the piece-part level of detail. The top of the matrix is formed by the outputs of the assembly under analysis, the test points of the assembly being analyzed, a comments and remarks reference column, a severity-level column, and a built-in-test detection column. The side of the matrix is formed by the inputs to the assembly being analyzed with the appropriate failure modes for the inputs, and by the parts contained on the assembly being analyzed with their failure modes.



ASSY: _____		OUTPUT 1	OUTPUT 2	•	OUTPUT N	TEST POINT 1	TEST POINT 2	•	TEST POINT N	INDICATOR 1	INDICATOR 2	•	INDICATOR N	BIT DETECTED	COMMENTS/REMARKS	SEVERITY	FAILURE RATE	MODE PERCENTAGE
INPUT 1	MODE 1																	
	MODE 2																	
	•																	
INPUT 2	MODE N																	
	MODE 1																	
	MODE 2																	
INPUT N	•																	
	MODE N																	
	MODE 1																	
PART 1	MODE 2																	
	•																	
	MODE N																	
PART 2	MODE 1																	
	MODE 2																	
	•																	
PART 3	MODE N																	
	MODE 1																	
	MODE 2																	
PART 4	•																	
	MODE N																	
	MODE 1																	
	MODE 2																	
	•																	
	MODE N																	

1. REMARK/COMMENT NO. 1
2. REMARK/COMMENT NO. 2

Figure 7. Typical Matrix Structure

The matrix is completed by inserting the appropriate failure effect code at the intersection between all effected outputs and test points and the failure mode being analyzed. If comments or remarks are needed, the number of the remark is placed at the intersection between the failure mode and the remarks column. If the BIT detects this failure at the level under analysis, an X should be marked in the BIT DETECTED column. If the severity of the failure at the level under analysis is other than a severity class 4, the appropriate severity level for the failure should be entered at the intersection of the SEVERITY column and the failure mode being analyzed.

The inherent traceability of the matrix structure makes it ideal for automation. Additionally, this traceability allows information to be readily extracted from the analysis in a reverse organization. The reverse extraction of analysis data is crucial if maintainability analyses are going to be supported.




Figure 8. Traceability Between Hardware Indenture Levels in a Matrix FMEA

6.2.3 MIL-STD-1629A COMPLIANCE

The advanced matrix technique is compliant with the intent of MIL-STD-1629A but is not letter for letter compliant with the specification. MIL-STD-1629A specifies five FMEA tasks:

- Task 101 - Failure Modes and Effects Analysis
- Task 102 - Criticality Analysis
- Task 103 - FMECA Maintainability Information
- Task 104 - Damage Modes and Effects Analysis
- Task 105 - Failure Mode, Effects, and Criticality Plan.

The advanced matrix technique provides the information needed to comply with the intent of tasks 101, 102, 103 and 105. Task 104 is not supported by the advanced matrix technique. This is not, however, considered a severe limitation, as damage modes and effects are seldom applied to electronic equipment and almost never at the level of detail (block diagram and piece-part) at which FMEA is normally performed.

Table 6 provides a cross reference between the information provided by the advanced matrix technique and MIL-STD-1629A requirements. In most cases the necessary information is available but the format of the information is usually different.

TABLE 6. ADVANCED MATRIX TECHNIQUE MIL-STD-1629A COMPLIANCE

Criteria	MIL-STD-1629A Task #	Remarks
ID #	101, 102, 103	Provided by mnemonic of assembly under analysis and reference designators
Item/Functional ID	101, 102, 103	Provided by mnemonic of assembly under analysis and reference designators
Function	101, 102, 103	Provided at assembly level by assembly mnemonics (see 6.3.2.4)
Failure Mode and Causes	101, 102, 103	Failure mode is coded throughout matrix - cause is not provided
Mission Phase/ Operating Mode	101, 102	Provided by the failure mode to operating mode by effect matrix
Failure Effects - Local, NHA, End	101, 103	Provided by the matrix at all levels of indenture

**TABLE 6. ADVANCED MATRIX TECHNIQUE MIL-STD-1629A
COMPLIANCE (Continued)**

Criteria	MIL-STD-1629A Task #	Remarks
Failure Detection Method (Operator)	101	Provided indirectly by including indicators and BIT in matrix
Compensating Provisions	101, 102	Provided by including an ability to include remarks
Severity Class	101, 102, 103	Provided directly
Remarks	101, 102, 103	Provided directly
<u>Failure Probability</u>		
Failure Rate Data Source	102	Not provided within the technique. The typical failure rate data source for electronic equipment is MIL-HDBK-217. Other sources would need to be defined in the introductory material.
Failure Effect Probability	102	The advanced matrix technique assumes $\beta = 1$
Failure Mode Ratio	102	This ratio can be used in criticality calculations once the correct ratios are established
Failure Rate	102	The failure rate entered in the matrix is used in criticality calculations
Operating Time	102	The operating time ratio is provided by the operating mode percentage list
Criticality #	102	Can be calculated from information provided within the technique
Item Criticality #	102	Can be calculated from information provided within the technique
System/Subsystem Description	103	Usually provided as a part of the descriptive material included in an FMEA report - not included on analysis sheets in technique

**TABLE 6. ADVANCED MATRIX TECHNIQUE MIL-STD-1629A
COMPLIANCE (Continued)**

Criteria	MIL-STD-1629A Task #	Remarks
Failure Detection Method	103	Provided indirectly as a part of test point summary
Minimum Equipment List	103	Not provided within the technique

6.3 ADVANCED MATRIX TECHNIQUE DETAIL

This section and its several subsections provide a detailed description of the advanced matrix technique. The section is organized in the order of occurrence of the various phases of the technique as presented in Section 6.2.1. Each subsection describes the information necessary to allow the phase of analysis being discussed to proceed, and the outputs which are available from the FMEA phase. Figure 6 provides a summary of the types of outputs available at each phase.

The advanced matrix technique allows multiple analysts to be used with a minimum of conflict. However, coordination between all analysts working on an FMEA remains important. This coordinating function usually requires that a chief analyst be appointed to serve as a focal point for analysis efforts and to control mnemonics. He would be expected to complete the FMEA planning phase without assistance. The chief analyst could also complete the initial FMEA activity without assistance for all but very large FMEAs. The ability of a single analyst to complete all early FMEA activity is important. The use of one analyst to structure all initial FMEA activity provides a coherent baseline for all more detailed FMEA activity. When more than one analyst is used to structure the initial FMEA material, care must be used to ensure that all efforts are completely coordinated.

Several analysis outputs discussed in this section on the advanced matrix technique are difficult or time consuming to obtain by manual methods although the necessary activities are described. This is particularly true of criticality analysis, built-in-test analysis, and test point information. The advanced matrix technique is only marginally better than tabular methods when this information must be manually assembled. The matrix technique is significantly better than tabular methods once the automation tool is in use. The overall structure and use of the technique together with the automation is discussed in Section 7.

The terms system, equipment, and system/equipment are used throughout the discussion which follows. The terms should be considered interchangeable references to the top level of FMEA analysis. FMEA is generally limited in application to the equipment level due to an inherent inability to handle multiple failure modes and human interfaces well. This does not strictly preclude the analysis from being used at the system level. The FMEA retains effectiveness at the system level when the interfaces are automated, particularly when the human interface is minimal or non-existent.

6.3.1 FMEA PLANNING

The advanced matrix technique usage depends on planning the FMEA as an integral part of the total logistics analysis to be performed during equipment development. Planning the FMEA as a part of an overall analysis package allows duplication of effort to be avoided while allowing the purpose of the FMEA to be completely defined. Once the exact purpose and usage of the FMEA has been defined, the analysis can be uniquely tailored to provide the needed outputs in a cost- and time-effective manner.

Adequate FMEA planning will define the level of detail within the analysis and the duration of the analysis. All FMEA planning should be documented, even when task 105 of MIL-STD-1629A has not been specifically invoked. An FMEA plan which is compliant with MIL-STD-1629A task 105 is ideal for documenting the planning so long as all the required information is included.

FMEA planning should be the task of the individual who will be assigned as chief analyst for the FMEA. The chief analyst is expected to have the seniority and experience to determine the FMEA analysis needs with respect to the total design program. Considering the FMEA in the context of the total program allows an initial determination of the level of detail required for the analysis. This will allow the analysis to be tailored to optimally fit the design and logistics programs. Seven fundamental questions need to be answered in order to determine the appropriate level of analysis:

- What is the primary purpose(s) of the FMEA?

What is the reason for performance of the FMEA? The FMEA can be used to support the reliability analysis, safety analysis, maintainability analysis, testability analysis, and logistics support analysis individually or in any combination. The FMEA is usually begun or required once a specific potential problem area has been recognized. This area of concentration is then the primary purpose of the FMEA.

- **What level of detail will be used for maintenance and logistics planning?**
The overall maintenance and logistics support concepts for the equipment should be examined. The type of maintenance which will be done at each level (i.e., shop, depot, flight line) should be identified. The skill level of personnel at each maintenance level should also be determined. The test equipment which will be used/available at each maintenance level should also be identified. How much FMEA information, and what level of detail is necessary to support maintenance analysis should be determined based on the support concepts and constraints which are identified.
- **Is criticality analysis required?**
If criticality analysis is required, which reliability calculations will need to be performed at the piece-part level. The need for detail in the criticality analysis may require greater overall detail in the FMEA.
- **Are the analysis results to be provided to the end item user as a data item?**
If data item preparation is required, the appropriate schedule points should be developed. These schedule points can then be used to determine what level of FMEA detail will be available at each scheduled delivery point.
- **Is built-in-test analysis required on the program?**
Built-in-test evaluation requires that a very detailed analysis be performed. The exact implementation of BIT should be evaluated to determine its impact on the level of FMEA detail.
- **Is maintainability analysis (if required) to be performed in accordance with Procedure 5 of MIL-HDBK-472.**
Maintainability analysis in accordance with MIL-HDBK-472 Procedure 5 requires that the ambiguity of each failure at each maintenance level be determined. The determination of ambiguity at a given level can require that an analysis be performed at one level of detail below the level being assessed. The level of maintenance analysis detail needed should be assessed for impact on FMEA detail.
- **What level of detail is contractually required?**
When an FMEA is contractually required, with the required level of detail specified, the analysis needs to be performed at the specified detail level of detail as a minimum. A greater level of detail may be used. This is appropriate when the greater FMEA detail provides the most cost-effective

baseline for related analyses in safety, maintainability, logistics, and/or testability.

The output of the FMEA planning process should be a complete description of the analysis required in fundamental detail. As a minimum the analyst should be able to determine the criteria required to complete an FMEA planning sheet as shown in Figure 9. Once the chief analyst has determined the amount of detail and the types of analyses which will be required, initial FMEA activity can begin. The FMEA planning, however, remains subject to change until the analysis is complete. This is to allow adequate detail to identify the causes of all severity classification Category I and II failures.

1. LEVEL OF FMEA DETAIL	
A. SYSTEM	☐
B. EQUIPMENT	☐
C. CIRCUIT CARD/MODULE	☐
D. DETAILED BLOCK DIAGRAM	☐
E. PIECE-PART	☐
2. TYPE OF ANALYSIS TO BE INCLUDED	
A. FAILURE MODES AND EFFECTS	☐
B. SEVERITY CLASSIFICATION	☐
C. TEST POINT	☐
D. BIT DETECTION INFORMATION	☐
E. CRITICALITY CALCULATIONS	☐
3. TYPE OF FMEA TO BE REPORTED TO CUSTOMER	
A. SYSTEM LEVEL	☐
B. EQUIPMENT LEVEL	☐
C. CIRCUIT CARD/MODULE LEVEL	☐
D. DETAILED BLOCK DIAGRAM LEVEL	☐
E. PIECE PART LEVEL	☐

42829-1AD

Figure 9. FMEA Planning Sheet

6.3.2 INITIAL FMEA ACTIVITY

Initial FMEA activity consists of the development of nine interrelated items. These are the FMEA specification, operational mode definitions, fundamental input and output definitions, preliminary mnemonics, preliminary failure effect list, failure mode to operating mode by effect matrix, failure mode to operating mode by severity matrix, design guidelines, and revised FMEA planning. Two of these activities, the failure mode to operating mode by severity matrix and the design guidelines are optional but highly recommended. Figure 10 shows the flow of and interrelationship between the various initial FMEA activities.

The initial FMEA material can be prepared as soon as the FMEA planning is complete. The information required to allow the initial analysis to proceed is minimal. The analyst must be capable of defining the required equipment characteristics and all necessary interfaces completely. If an equipment specification or a similar requirements document exists, an analyst who is experienced with the type of equipment being analyzed should be capable of completing the initial FMEA activity. The initial FMEA activity should begin with the development of the FMEA specification.

6.3.2.1 Specification Development

As the first step in the initial FMEA activity, the analyst must develop a specification for the FMEA. The FMEA specification is not necessarily the same as the system or equipment specification, if one exists. The FMEA specification needs to reflect the operational requirements of the system or equipment being specified.

The FMEA specification should be developed from the appropriate system or equipment specification when one exists. When no formal specification exists, the marketing criteria, or other guidelines which are used by design to determine required system or equipment performance should be used to guide preparation of the FMEA specification.

Once the analyst has obtained a baseline for the development of the FMEA specification through acquiring either the appropriate equipment specification or marketing criteria, preparation can proceed. The analyst should proceed in a step-by-step process to identify and list relevant performance parameters similar to those shown in Figure 11. The development of the performance parameter list is usually




Figure 10. Initial FMEA Activity Flow

PERFORMANCE PARAMETER	EQUIPMENT SPEC LIMIT		FMEA LIMIT		SIGNAL TYPE	SIGNAL MNEMONIC
	UPPER	LOWER	UPPER	LOWER		
1. SIGNAL LEVEL A	+1.15V	+0.85V	+1.5V	+0.5V	ANALOG	
2. SIGNAL FREQUENCY A	995 Hz	1005 Hz	950 Hz	1050 Hz	ANALOG	
3. SIGNAL TO NOISE A	50 dB	—	35 dB	—	ANALOG	
4. SIGNAL LEVEL B	4.5V	5.5V	4.5	5.5	DIGITAL	

PAGE ____ OF ____

Figure 11. FMEA Specification

straightforward. Similarly, the extraction of the equipment specification limits will not usually represent a problem. The development of the performance limits which will be used for FMEA criteria is somewhat subjective.

The subjective nature of the FMEA specification requires that the analyst have an extensive background in the type of equipment and/or system which is under analysis. Additionally, the analyst will need to coordinate the developed specification with hardware design engineering and with any disciplines which will interface with the FMEA results (i.e., safety, maintainability, testability, etc.). The specification will need to be coordinated across multiple disciplines to ensure that the performance limits established for FMEA reflect accurate, traceable values. When built-in-test circuitry will be designed into an equipment, the FMEA limits established should generally be the same as the limits which will be used in the built-in-test design. Once the specification is developed, it may be necessary to coordinate the FMEA limits established with the procurement office if the FMEA is being performed under Government contract with associated data delivery requirements.

6.3.2.2 Operational Mode Definition

After the FMEA specification has been developed, the analyst should define the basic equipment operating modes. The operating mode definitions should be as concise as possible without producing an unmanageable number of modes to be analyzed. If criticality analysis is to be performed as a part of the FMEA, the analyst should also determine the amount of time which will be spent in each mode. This time, as a percentage figure, will be used in criticality calculations.

The operational mode definitions consist of a master listing of the operational modes and percentage of time spent in each (Figure 12) and a detailed description of each mode. The detailed descriptions of each mode need to provide sufficient information to uniquely describe each mode. Figure 13 provides a sample form for operating mode definition. This would generally be supplemented by additional descriptive writings, logic flow diagrams, and such other additional information as may be required to completely define the operating mode.

A complete and comprehensive definition of each operating mode is essential to both customer understanding of an FMEA and to the ability to use multiple analysts

OPERATING MODE	PERCENTAGE
1. MODE A	XX %
2. MODE B	YY %
3. MODE C	ZZ %

Figure 12. Operational Modes Master List

OPERATING MODE DEFINITION	
	MODE: _____
FUNCTION: _____	
INDICATIONS TO OPERATOR: _____	
INITIATED BY: _____	
TERMINATED BY: _____	
POSSIBLE FAILURES: _____	

Figure 13. Operating Mode Definition Form

during the intermediate and detailed FMEA analysis stages. Additionally, the operating mode definitions help focus the analyst on the FMEA in a controlled manner.

6.3.2.3 Define Fundamental Inputs and Outputs

After the operating mode definitions have been completed, the analyst should define the fundamental inputs and outputs (I/O) of the equipment under analysis. The fundamental inputs and outputs consist of those input and output functions which define the basic purpose of the device under analysis and which form the external interfaces of

the equipment. The fundamental inputs and outputs may involve various types of input and output quantities such as mechanical motion, electrical signals, audible signals, visual signals, etc. The fundamental inputs are those which provide the signals required by the equipment under analysis from the external sources. The fundamental outputs are those outputs which interface between the equipment under analysis and the next higher level of indenture (system level).

The fundamental inputs and outputs should be tabularized, and accompanied by a brief description of each similar to Figure 14. This will allow all analysts assigned to the FMEA to work from a common baseline set of definitions. When special conditions such as backup power, etc. exist, they should be noted on the definition sheet along with the I/O description.

FUNDAMENTAL INPUT DEFINITIONS EQUIPMENT: <u>EXAMPLE</u>	
<u>INPUT</u>	<u>CHARACTERISTICS</u>
SYNC PULSE A	PROVIDES A DIGITAL SYNCHRONIZATION SIGNAL TO ALLOW TIMING OF OUTPUT A IN A MANNER WHICH IS COHERENT WITH UNIT C OF THE SYSTEM
MAIN POWER	PROVIDES PRIMARY POWER TO SYSTEM UNDER NORMAL CONDITIONS. NOTE: 20 MINUTE BATTERY BACKUP POWER EXISTS

FUNDAMENTAL OUTPUT DEFINITIONS EQUIPMENT: <u>EXAMPLE</u>	
<u>OUTPUT</u>	<u>CHARACTERISTICS</u>
SERIAL DIGITAL OUTPUT	PROVIDES DIGITAL RANGE INFORMATION TO PROCESSING ELEMENT

Figure 14. Fundamental Inputs and Outputs

6.3.2.4 Mnemonics

The analyst should begin assigning mnemonics to the FMEA as soon as the necessary information becomes available. Mnemonics can be assigned to the fundamental inputs and outputs as soon as they are identified. The use of mnemonics within the advanced matrix technique is mandatory. The mnemonics used as a part of the technique have the form:

FROM - SIGNAL - TO

The exact number of characters assigned to each position in the mnemonic is arbitrary and can be decided based on the complexity of the equipment being analyzed. For the purposes of discussion a 3-4-3 structure will be assumed. That is, three characters each assigned to the from and to portions of the mnemonic, and a four character signal identifier.

As a part of the mnemonic development and assignment process, two cross reference lists, similar to those shown in Figure 15 are developed to provide traceability between signal or assembly title and function and the assigned mnemonic. One list is for mnemonics assigned for assembly (from/to) use. The other list is for signal mnemonics. The descriptions provided in each cross reference list should be sufficiently detailed to allow the function of the signal or assembly to be described. When assigning assembly mnemonics, this will generally require that a detailed assembly description be developed to assure compliance with MIL-STD-1629A. These assembly descriptions may either be included as a part of the cross reference table or in the FMEA report with adequate referencing to the assembly mnemonics cross reference table. Functional descriptions of signals will usually be much shorter than those required for assemblies and can be included directly in the cross reference table.

The mnemonics list should be started as soon as the analyst identifies and defines the fundamental inputs and outputs. The analyst needs to identify the mnemonics of the fundamental I/Os both to begin the mnemonic lists and to provide traceability for the top levels of the analysis. In most cases, either the from or to part of the mnemonic will not be capable of being identified at the earliest stages of the analysis. This will not retard the progress of the analysis. The information required to identify the from and/or to portion of the mnemonic should be available prior to a need for the information.

Mnemonic Assignment - Mnemonics may be assigned by any method which is convenient. The codes are usually assigned either in sequence or keyed to the signal or assembly titles. The assignment of mnemonic codes which are keyed to signal or assembly title has the advantage of providing a built-in reference which aids the analyst in remembering the function of the referenced signal without continuous reference to the master mnemonic lists. The disadvantage of the keyed mnemonic assignment method is that it is very easy to assign the same alphanumeric code to more than one signal. Avoiding the multiple assignment problem usually requires the use of a sortable computer file, a 3 x 5 card index file or some similar method which allows rapid

identification of previously assigned mnemonics. Sequentially assigning mnemonics avoids the multiple assignment problems, but does not provide the analyst with the means to readily identify the signal function without a reference list.

Figure 15 shows examples of assigned mnemonic set lists. The lists shown demonstrate mnemonics which have been sequentially assigned. Using Figure 15, the full mnemonic for the signal High Speed Select Logic which is an output from the Digital Decoder Assembly and an input to the Frequency Synthesizer Assembly is AACAAABAAB. The full mnemonic identifies all relevant information about the signal with respect to the FMEA purposes. The example mnemonic also clearly demonstrates the problem with sequentially assigned codes. The mnemonic does not provide any clues to the analyst as to its meaning, making a reference list necessary at all times.

When assigning mnemonic codes, the analyst needs to reserve one from/to and several signal mnemonic codes for special use. The from/to code should be used to

ASSEMBLY MNEMONICS		ASSEMBLY
MNEMONIC		
AAA		ANALOG AMPLIFIER CIRCUIT CARD ASSY
AAB		FREQUENCY SYNTHESIZER ASSY
AAC		DIGITAL DECODER ASSY
AAD		
AAE		
AAF		

SIGNAL MNEMONICS		SIGNAL
MNEMONIC		
AAAA		MASTER 10 MHz CLOCK
AAAB		HIGH SPEED SELECT LOGIC
AAAC		ANALOG AM
AAAD		DIGIT
AAAE		
AAAF		
AAAG		

Figure 15. Example of Mnemonic Assignment Lists

identify sources and destinations which are outside the equipment under analysis. This allows the fundamental inputs and outputs to be recognized throughout the analysis. The special use signal mnemonics are used to identify digital bus lines.

The digital bus represents a special case where a signal can have multiple sources. In order to provide traceability within the analysis, a special code is assigned to each bus structure, and a separate list of bus attachment points is maintained. This separate list is then used to provide the needed traceability.

Once the mnemonics necessary for the fundamental inputs and outputs have been assigned, the analyst can begin developing the failure mode lists which will be needed in developing high level matrices for the analysis. These are the Failure Mode to Operating Mode by Effect matrix and the Failure Mode to Operating Mode by Severity matrix.

6.3.2.5 Failure Effects Lists

The development of the initial, high-level, FMEA requires that potential failure effects for the equipment/system outputs be identified. The failure effects which are possible at the top level will be largely dependent on the type of equipment under analysis and the nature of the output.

The analyst should develop a failure effect listing which is peculiar to the equipment being analyzed and relevant to the identified outputs by signal type. The analyst will need to take extreme care in the development of the failure effect list to ensure completeness while minimizing duplication. Figure 16 provides a standardized listing of signal failure effects by signal type. The failure effects list shown is general and should not be considered all inclusive at the top level of analysis. The failure modes and effects should be considered as based on the previously developed specification except where the meaning is well defined. The failure mode "open" is self explanatory. A failure mode "distorted" needs to be defined in the specification as a universal meaning for the mode does not exist.

EFFECT/MODE \ SIGNAL TYPE							
	ANALOG ELECTRICAL SIGNAL	DIGITAL ELECTRICAL SIGNAL	POWER, SIGNAL, ELECTRICAL	MECHANICAL OUTPUTS	VISUAL OUTPUTS, INDICATORS	METERS/ INDICATIONS	DIGITAL BUS
SHORT	S	S	S				
OPEN OR DISCONNECTED	O	O	O				
NO OUTPUT OR MISSING	N		N	N		N	
WEAK OR LOW OUTPUT	L		L	L		L	
OUTPUT LEVEL HIGH	H		H			H	
ACTIVATES/DEACTIVATES AT WRONG TIME	T	T	T	T		T	T
ERRATIC OUTPUT	E		E	E	E	E	
OSCILLATES	R						
INCORRECT FREQUENCY	F						
DISTORTED	D						
STUCK-HIGH (ON)		1			1		1
STUCK-LOW (OFF)		0			0		0
STUCK AT HIGH IMPEDANCE		Z					Z
INCORRECT WORD ON BUS							W
PATTERN (XX.....X) ON BUS							P

42029-21P

Figure 16. Standard Failure Effects List

6.3.2.6 Development of the Top-Level Matrices

The final step in the very early FMEA activity is the preparation of the two top-level FMEA matrices. This step can be accomplished once a detailed knowledge of the hardware's intended function is available but prior to any detailed hardware design.

Top-Level Block Diagram - The first essential step in the development of the top-level matrices is the top-level block diagram. The top-level block diagram is simply the pictorial representation of the total FMEA workup to this point in the analysis.

Figure 17 provides a general example which can be used on any system/ equipment. The top-level block diagram uses only the direct signal mnemonic when initially prepared. Adequate room should be left on the diagram for the addition of from and to information when the information becomes available later in the design program.

Failure Mode to Operating Modes by Effect Matrix (FMOMEM) - This matrix is one of the two top-level FMEA matrices. The FMOMEM displays the relationship between the ultimate failure modes of the defined fundamental outputs and the effect on the defined




Figure 17. Top-Level Block Diagram

operational modes. The matrix construction is unique to the two top-level matrices as the input signals to the equipment and any component parts are not used in the formation of the top-level matrices. The appropriate input signals are used in all other matrices. The purpose of the two top-level matrices is to provide for ultimate failure effects and for criticality calculation. The FMOMEM is usually created using only the defined output signal mnemonics. The addition of the "from" part of the signal mnemonic should be accomplished once the necessary information becomes available.

Figure 18 provides an example of the form of a FMOMEM. It should be noted that the mnemonics for the various defined outputs are used on an actual FMOMEM and that the various failure effects are represented by their single alphanumeric codes.

		OPERATING MODE 1	OPERATING MODE 2	OPERATING MODE 3	OPERATING MODE 4	OPERATING MODE N					REMARKS
OUTPUT 1	FAILURE MODE 1	1									1
	FAILURE MODE 2	2									
	FAILURE MODE N	1									
OUTPUT 2	FAILURE MODE 1		3								2
	FAILURE MODE 2		1								
	FAILURE MODE N		1								
OUTPUT 3	FAILURE MODE 1				5						3
	FAILURE MODE 2				5						4
	FAILURE MODE N				5						
OUTPUT N	FAILURE MODE 1		1	1	1						5
	FAILURE MODE 2		1	1	1						
	FAILURE MODE N		4	4	4						N
REMARKS: 1. CAN BE COMPENSATED FOR BY.....											
2. FAILURE IS NOT GENERALLY DETECTED BUT											
N. MAY NOT ALWAYS BE CRITICAL											

Figure 18. Failure Mode to Operating Mode by Effect Matrix (FMOMEM) Example

The single digit codes used within the sample matrix have the following meanings:

1. The failure causes a complete loss of operating mode.
2. The failure severely degrades the operating mode.
3. The failure causes the operating modes to be degraded slightly - the failure can be compensated for or the degradation is so slight that the condition is tolerable.
4. The failure will cause damage to system, equipment, or related system elements. The operating mode is also completely inoperative.
5. The failure is an indicator failure. It will be noticed by the operator but does not in and of itself represent a loss of equipment function.

The top-level matrix can also be used to key in commentary or explanatory material which cannot easily be contained within a matrix technique. The information contained in the FMOMEM should all be available prior to the beginning of detailed design. The necessary information is dependent on the analyst possessing a thorough understanding of the intended purpose and functioning of the proposed equipment. Additionally, the analyst will need a complete knowledge of the system into which the equipment under analysis will be integrated. It should be noted that indicators and test points are outputs.

Failure Mode to Operating Mode by Severity Matrix (FMOMSM) - This is the second top-level matrix which needs to be developed by the analyst to support the ongoing FMEA. If criticality and severity information is not required, this matrix is optional. The FMOMSM duplicates the FMOMEM (Figure H) in structure except that the severity class is used to complete the matrix rather than the failure effects codes. The severity numbers which are used within the matrix have the following meaning:

1. Catastrophic - A failure which may cause death or weapon system loss
2. Critical - A failure which may cause severe injury, major property damage, or major system damage which will result in mission loss
3. Marginal - A failure which may cause minor injury, minor property damage or minor system damage or which will result in delay or loss of availability or mission degradation
4. Minor - A failure not serious enough to cause injury, property damage, or system damage, but which will result in unscheduled maintenance or repair.

The severity classification definitions are taken directly from MIL-STD-1629A and thus are consistent with MIL-STD-882. These basic categories are usually used without change. The analyst has the ability to add severity categories between the listed categories to help refine the process but this should not generally be required.

The completion of the two high-level matrices concludes the assemblage of fundamental FMEA data. The data which has been assembled up to this point provides a complete and coherent picture of the basic system structure under which the equipment will be designed and under which the FMEA will be performed. The information which has been assembled is, however, independent of a hardware specific design. This top-level material is now to be used in several ways:

- Design guidelines - If the FMEA has been started as a part of a new design process, design guidelines providing guidance as to possible critical design failures, although optional, should be issued. The design guidelines will usually be restricted to safety concerns at this point by necessity
- Revised FMEA planning - The original FMEA Planning can now be finalized. The analyst should be able to determine which areas of the proposed equipment will require in-depth analysis with respect to the original planning
- Controlling the ongoing FMEA - Since the FMEA needs to continue in step with the design program, it will often be necessary to assign multiple analysts to the FMEA. The top-level FMEA material provides a consistent baseline for all analysts. A central control over mnemonic use will still be needed, however. If additional personnel are required for the analysis, they can be assigned at this point.

6.3.2.7 Initial Activity Completion

The initial FMEA activity is complete with the preparation and release of design guidelines and revision of the FMEA planning as required. The completion of the initial FMEA activity can occur very early in a program, often as early as the end of the validation program phase. This allows the results of the initial FMEA activity to be available for review prior to the start of full-scale engineering development. On Government procurements, the initial FMEA activity should be required for review in a

time frame concurrent with any preliminary design review or with a separate FMEA conference when appropriate.

6.3.3 INTERMEDIATE FMEA ACTIVITY

Intermediate or block diagram level FMEA activity can begin as soon as the initial FMEA activity has been completed and the design of hardware has commenced. This usually occurs at approximately a Preliminary Design Review time frame but can occur as early as the start of Full-Scale Engineering Development. The intermediate level and detail levels (piece-part) of FMEA activity usually occur in tandem. This is due to the inherent differences in the rate of design progress for different areas of the circuitry. While some parts of the circuitry have been defined to the piece-part level, other parts of the circuitry under development will only have been designed to a block diagram level of detail.

The analysis should proceed at the level of detail which is available for a given section of the design. This often requires that several analysts be assigned to the FMEA during the intermediate and detail levels of analysis due to the volume of design information being developed. It is important that the analysis keep pace with the design progress so that a maximum benefit is obtained from the analysis.

The intermediate level of FMEA analysis has several purposes. The intermediate analysis is used to evaluate equipment reliability potential, safety characteristics, and the safety and testability adequacy of the design. The basic activities which are a part of the intermediate level of FMEA activity are shown in Figure 19. The results of the initial FMEA activity, along with an expanded mnemonics list and a revised or reviewed failure modes/effects list are used to allow the development of an intermediate level FMEA matrix analysis. The analysis then allows preliminary evaluations of test point, and built-in-test adequacy to be performed. Additionally, a preliminary identification of severity classification 1 and 2 failures can be made and a revised (more directed) set of design guidelines can be issued. The evaluations are preliminary at the intermediate level of detail; however, most design problems will become apparent at this level of detail and can be resolved prior to the start of piece-part design.




Figure 19. Intermediate FMEA Activity

6.3.3.1 Mnemonics

The assignment of mnemonics will continue throughout the period of intermediate FMEA activity. As each subdivision of the developing hardware structure is identified, it should be assigned a mnemonic which will serve as its reference throughout the analysis. Similarly, the signals which are identified should be assigned a mnemonic reference as early as possible.

If more than one analyst is being used to perform the FMEA, one of the analysts will need to be assigned the responsibility of assigning or issuing mnemonics for all of the FMEA activity. It will be necessary to limit the assignment responsibility to one individual to prevent duplication of mnemonic assignment. It is relatively easy to end up

with either two mnemonics assigned to one signal or assembly or to assign one mnemonic to two assemblies or signals. The accurate assignment of mnemonics is crucial to assuring the traceability of the FMEA information which is developed. The mnemonics are used to provide the means of tracing from the output of one assembly to the input of the assembly at the next highest level of indenture.

The assignment of mnemonics is generally concluded as a part of the intermediate FMEA activity. All hardware subdivisions and interface signals are usually identified prior to the start of detailed, piece-part design. It is often necessary, however, to assign at least some mnemonics fairly late in the design process due to circuitry changes which occur as the result of testing and perhaps the FMEA itself.

6.3.3.2 Signal Failure Modes/Effects

The signal failure modes/effects which were previously established during the initial FMEA phase should be reviewed for adequacy and revised as needed to allow the analysis to proceed. The number of changes which are necessary at this point will depend on the specific equipment and analyst. Normally very few changes should be required. Often, the entire analysis can be performed without modifying the standard list (given in Figure 16).

The use of the standard signal failure modes generally over-identifies the number of failure modes which are actually possible in the finished design. As design detail becomes available some of the failure modes will be excluded as a function of the design methodology used. This is not a drawback as it allows the analyst to identify those failure modes which have the potential for contributing to catastrophic failures very early in the design process. This can allow the failure mode to be deliberately designed out. It is necessary, however, for the analyst to review the developed matrix analysis, as the level of design detail increases, and to remove those modes of failure which have been designed out of the equipment at lower levels, from the higher level analyses.

6.3.3.3 Intermediate Matrix Analysis Development

After the development of adequate mnemonics and signal failure modes to support the analysis of a given section of circuitry, the analyst can begin to develop the

intermediate level matrix. The matrix analysis at the intermediate level is an iterative analysis. The matrix can be expected to undergo a considerable amount of change due to the results of the analysis and the ongoing design process. It will ordinarily be necessary to modify the test point and built-in-test information as the analyst helps guide the design toward providing an adequate diagnostic capability with a minimum of ambiguity.

Intermediate Matrix Structure - The basic construction of the matrix at the intermediate level is shown in Figure 20. The example matrix shown is based on the block diagram shown in Figure 21. This matrix is similar in structure to the example matrix of Figure 7. The most significant change is the replacement of the piece-parts along one side of the matrix with circuitry block designators. In practice, when performing a matrix FMEA of this type by hand it is advisable to use one matrix to contain both the piece-part and block diagram levels of detail. This keeps the analyst from having to develop and complete a separate matrix form at each level of analysis. When using the automated technique, the block diagram level of detail matrix is gradually replaced by the piece-part level of detail matrix as the design detail becomes available.

Intermediate Matrix Completion - The analyst completes the intermediate level FMEA matrix by analyzing the proposed design approach to determine the effect of each failure mode of an incoming signal or circuitry block on the subassembly outputs. The analyst then places the letter code representing the appropriate failure effect at the intersection point of the failure mode and the appropriate output. This process is continued until all the incoming signals and circuit blocks have been analyzed for all potential failure modes and the appropriate failure effects have been logged against the effected outputs. The analyst must also enter the effect of the failure on any appropriate identified test points as a part of the analysis. Additionally, if the failure could be expected to activate any built-in-test monitors which are a part of the circuitry of the subassembly under analysis, the built-in-test column of the matrix should have a "Y" entered. If the failure being analyzed has a severity effect above a classification of 4, at this assembly level, the severity column should be completed with the appropriate severity level number. When remarks are necessary, a reference number to the appropriate comment should be marked and the comment included below the matrix.

Figure 20. Example Intermediate Level Matrix

Figure 20. Example Intermediate Level Matrix (Continued)

Figure 20: Example Intermediate Level Matrix (Continued)

BDC-06

[illegible]

Figure 20. Example Intermediate Level Matrix (Continued)




Figure 21. Example of Intermediate-Level Block Diagram

Test Point Evaluation - The analyst fills in the effects on identified test points as a part of the development of the intermediate level matrix. These effects are not necessarily the same as the effects on the appropriate circuit outputs. The analyst should enter the effect as it is seen at the test point, not the effect on the measured signal. The analyst must consider test point effects with some care. A failure which changes a test point to a value which may be within the range of measurement variance for the equipment population, or for the test equipment which will be used, should be considered as having no effect. Basically, the analyst should enter test point failure effects with respect to the expected ability of a technician in the field to locate a failure using readily available test equipment on the basis of the symptoms available at the test points. The skill levels of the expected operators and maintenance personnel should be considered in all cases. This results in a somewhat subjective evaluation being performed; however, a partially subjective analysis is preferable to identifying test point effects which cannot be actually detected in the field use environment.

Built-In-Test - The built-in-test (BIT) column of the matrix should be marked with a "Y" if the failure mode being analyzed activates a built-in-test monitor circuit on this subassembly. The BIT column should be left blank if the failure is not detected by built-in-test or if the built-in-test detection occurs at some other hardware level of indenture. This will allow a complete picture of the overall diagnostic capability of the built-in-test circuits to be developed. When the built-in-test information is combined with the test point information, a complete evaluation of the diagnostic adequacy of the design is possible.

Failure Severity - The analyst should judge the effects of the failure being analyzed for severity class. If the failure causes an effect with a severity classification of 1, 2, or 3, then the analyst should enter that severity classification number at the junction of the SEVERITY column and the appropriate failure mode row. A failure severity classification of 4 is ordinarily considered a default and need not be entered.

6.3.3.4 Intermediate Analysis Outputs

The intermediate level of FMEA analysis can be used for several purposes. The basic reliability characteristics of the equipment can be defined at the intermediate analysis level. The analyst can also identify the sources of potentially catastrophic failures at an early enough design stage to allow identified problems to be easily resolved without increasing design costs or impacting schedules. Initial evaluations of test point and built-in-test adequacy are also possible at the intermediate level of analysis.

Matrix Outputs - The completed intermediate level matrices yield a reasonably complete assessment of the equipment reliability potential. The analyst should be able to ascertain which low-level failure modes produce significant failure effects and which low-level failure modes do not have significant reliability impact. This will help assure that the reliability of the equipment is correctly evaluated and that a best case design tradeoff is obtained. It is usually not possible to exactly quantify the reliability of the equipment under analysis at this stage as the needed piece-part detail may not be available. The intermediate analysis will provide the necessary information for reliability evaluation to proceed once reliability calculations can be achieved at the component level. It is not usually necessary to extend the FMEA itself to a piece-part level of detail to assure correct reliability evaluation.

Test Point and Indicator Adequacy Assessment - The adequacy of equipment test points and indicators can be evaluated at the intermediate level of FMEA analysis. The evaluation is somewhat subjective and is only valid in assessing adequacy with respect to the flight line and intermediate levels of maintenance. This is not usually a drawback as depot technicians tend to have specialized test equipment available which will not be defined as early in a program as an FMEA is performed. Thus, accurate depot level test point assessment is usually difficult or impossible during an FMEA. If the FMEA is not going to be performed at the piece-part level of detail, the analyst should follow the procedure given for the test point adequacy assessment under Section 6.3.4.3, detailed analysis.

Built-In-Test Evaluation - The numerical evaluation of built-in-test adequacy proceeds in a manner which duplicates that given under the detailed analysis Section 6.3.4.2. The

analyst proceeds as though performing the full-scale analysis except that the level of detail of the reliability calculations is less than optimum and thus the overall confidence in the calculation accuracy is reduced. The block diagram results are, however, adequate for almost all programs.

Criticality Analysis - Criticality calculations can proceed in accordance with the MIL-STD-1629A requirements for the detailed analysis (Section 6.3.4.3). The level of detail accuracy is reduced somewhat but should be completely adequate for most programs. If the analysis has not identified any severity category 1 or 2 failures, the analyst should consider eliminating criticality calculations from the analysis outputs. The exercise would be largely non-productive if no catastrophic failure modes have been identified.

Design Guidelines - As the analyst completes the analysis of each successive equipment subsection he should revise the design guidelines which were produced during the initial FMEA activity to assure that the necessary guidance to identify and eliminate any potentially catastrophic failures is included. This sometimes requires that guidelines be developed which are peculiar to each assembly or subassembly. The update to the design guidelines should occur even when the analysis is not going to progress below the intermediate level.

6.3.3.5 Completion of Intermediate FMEA Analysis

Once the intermediate FMEA is completed, the analyst should evaluate the necessity to proceed to the piece-part level of detail. Even in equipment with numerous catastrophic failure modes, it should only be necessary to analyze those sections of the equipment which have been identified as contributors to the catastrophic failures, to the piece-part level of detail. Almost all the potential benefits of the FMEA process can be obtained at the intermediate level of analysis while keeping the cost of the analysis much lower. There is, however, probably no effective way to keep the FMEA level of detail above the detailed block diagram level without sacrificing significant benefits from the analysis.

6.3.4 DETAIL LEVEL FMEA ACTIVITY

Once the block diagram or intermediate level of analysis is complete for an assembly and the necessary design detail is available, the analysis can be performed at the detail or piece-part level. The detail level of analysis is the most accurate and thorough FMEA which can be performed. This level of detail requires a significant expenditure in both time and cost to complete. The level of detail involved in piece-part level analysis is necessary in cases where the potential for catastrophic failure modes exists. However, the analyst should carefully consider the benefits to be gained before expending the effort required to perform piece-part analysis.

When piece-part analysis is required, it may be advantageous to assign the task to the cognizant design engineer for the piece-part detail. The circuit designer is usually the individual with the greatest working understanding of the circuit under analysis, thus minimizing the labor expenditure required to complete the analysis. When the circuit designer is assigned to perform the piece-part level or detail FMEA, he will normally require the assistance of a knowledgeable specialty engineer. The use of circuit design engineers to assist in the piece-part level FMEA is especially attractive when using the automated tool. The automation package helps to minimize the clerical impact which has traditionally been associated with the analysis.

6.3.4.1 Detail Level Matrix Development

The detail matrix analysis is performed on assemblies and subassemblies once the necessary level of design detail is available. The analysis is performed separately on each subsection of the equipment, allowing the analysis to remain in phase with the equipment design at all times.

The analyst needs to carefully consider the hardware breakdown structure being utilized for the analysis. The structural breakdown used for FMEA purposes should duplicate the physical hardware structure whenever possible. When the physical hardware structures are too large or complex to be analyzed as a single unit, alternative analysis structuring schemes can be used. In all cases, the analyst should ensure that the selected structures do not cross physical hardware partitions. An FMEA breakdown

structure which crosses hardware partitions, such as a structure which consists of circuitry which is contained partially on two cards, prohibits accurate test point analysis for maintainability use within the technique.

Detail Matrix Structure - The structure of the matrix used for detailed level analysis exactly duplicates that shown in Figure 7. The top of the matrix is formed by the substructure outputs, test points, indicators, BIT detected, comment, severity, failure rate, and failure mode percentage columns. The side of the matrix is formed by the substructure inputs, parts, and their appropriate failure modes. It is sometimes desirable to include parts detail, where needed, on the same forms used for intermediate level analysis. This is an acceptable practice; however, the analyses are separate and should not be allowed to influence each other. The analysis at each level should be an exercise in inductive logic. The inclusion of parts level detail on the same form as block diagram level information is not advantageous or possible when using the automation package.

Detailed Matrix Completion - The matrix is completed in the same manner as was used for the intermediate level FMEA matrix. The analyst examines the finished design for the effect of each possible failure of each input signal and each part on the outputs of the assembly being analyzed. The effect code which is representative of the effect of the failure is then entered at the intersection of the affected output signal and the failure mode being analyzed. The analyst also enters the appropriate effect code under any effected test points, indicates built-in-test activation if appropriate, indicates failure severity (if greater than 4), provides a numeric key to any needed comments, and enters the appropriate part failure rate and mode percentage. The appropriate part failure rates should be calculated in accordance with MIL-HDBK-217. Input signals are assigned a failure rate of zero as the failure rate associated with the fundamental cause of any input signal failure would be assessed on the assembly where the failure occurred. The fundamental inputs can be assigned a failure rate, which is appropriate, as no information on the rate of failure cause is available within the FMEA.

Component Failure Modes - The potential effects of the various component failure modes on the circuit being analyzed need to be assessed and recorded within the matrix. Each of the individual component failure modes can potentially have a different effect

on the circuit outputs. Also, the various failure modes can have a different rate of occurrence, which will impact criticality calculations. The relative frequency of occurrence of the various possible component failure modes can also be expected to vary with the anticipated environmental exposure for the equipment. The analyst performing a piece-part level analysis should use sources of component failure mode data which correspond to the type of equipment under analysis when such sources are available. When this information is not available to the analyst, the failure mode treatment of the following paragraphs is suggested.

Two Terminal Devices - The failure modes of two terminal devices can be limited to the treatment of open and shorted devices. While this does not represent all possible failure modes for the wide variety of devices available, it does allow the most common, and catastrophic failures to be analyzed. The failure modes being considered have been limited to short and open with each failure mode being assessed a percentage of 50 percent. Less common failure modes, such as tolerance drift, are more properly a part of a worst case analysis.

Relays - The failure modes to be considered for relays are constrained to analysis of a coil open condition, a coil shorted condition, and stuck open and stuck closed for each of the discrete contact set. Combined failure modes which would involve contacts which become electrically conductive to the relay coil or to other relay contact sets should be considered too unlikely to require analysis. The failure mode probabilities should be assessed as 50 percent coil failures and the remaining fifty percent equally assigned between the contact sets.

Connectors - Connectors are not assessed failure modes as a part of the advanced matrix technique. The individual signals which pass through the connector will have numerous failure effects associated with them, including shorts and opens. The mode of failure during operation which is dominant for connectors is one of an open connection. Since the impact of the open connection will have already been assessed as a function of the failure mode open for the relevant signal, there is no reason to duplicate the analysis for the connector. There is one type of induced failure associated with connectors which is not included in FMEA using the advanced matrix technique. Bent connector pins which short to adjacent pins are not considered. This type of failure,

which is induced by maintenance instead of being caused by component breakdown, results in effects which can violate the signal paths designed into the system under analysis. This results in failure effects which are not traceable using the advanced matrix technique. The analysis of bent connector pins can be handled as a separate, tabular, FMEA.

Discrete Semiconductors - Transistors are assessed failure modes on the basis of shorts and opens between the device terminals. The common transistor would be assessed the failure modes of shorted B-E, open B-E, shorted B-C, open B-C, shorted C-E, and open C-E. Other multi-terminal semiconductor devices should be assessed open and short conditions which are appropriate for the specific device.

Microcircuits - The broad category of components which comprises microcircuits requires a specialized treatment. The approach is to assess the impact of potential failures as accurately as possible without attempting to assess so many cases as to extend the analysis unreasonably. The microcircuits are considered to belong to one of four basic categories with respect to the FMEA piece-part analysis. The categories are the discrete digital function devices, discrete analog devices, the bus structured devices, and the microcomputer functional devices.

The discrete digital function devices are those microcircuits which provide a discrete digital functional output on a pin. Devices which are a part of this grouping include NAND gates, AND gates, OR gates, flip flops, etc. These devices should be assessed for stuck at zero, and stuck at one failures at each function output pin. Devices which are three state logic should also be assessed for stuck at high impedance failures. The failure mode percentages should be assumed to be evenly distributed unless the analyst has a source of failure mode data for the part being analyzed which indicates a different distribution.

The discrete analog devices include all analog functions including the D to A converter. Devices which are a part of this grouping include operational amplifiers, three terminal regulators, voltage comparators, D to A converters, and specialized or custom microcircuits which produce a discrete analog output. The failure modes which should be assessed with respect to the analog discrete devices are stuck at high output limit and stuck at low output limit. The devices would be assumed to acquire the value of the appropriate incoming power supply limit. The two failure modes can be assumed to be equally likely for computing failure mode probabilities.

The bus structured microcircuits include those digital microcircuits whose outputs are functionally related to one another. These are devices where a failure can be reasonably expected to effect more than one pin at a time in at least some cases. The output pins of such devices must be treated as a functional entity. These devices are assessed the failure modes of incorrect word output and each discrete output pin stuck at one, stuck at zero, and for three state devices, stuck at high impedance.

Microcomputer functional devices are generally assessed as a part of a microcomputer system structure and not at the piece-part level. The devices which are included in this classification include microprocessors, microcomputers, RAMs, ROMs, peripheral interface adapters, etc. When such devices are used outside of a microprocessor or microcomputer structure they should be treated as bus structured microcircuits. When used in the context of a microprocessing structure they should not be assessed at the piece-part level due to the number of possible states which must be analyzed.

Microcomputer and Modern Digital Architectures - The complexity of the modern digital circuitry represents a significant challenge to the ability to perform FMEA. The complexity of modern digital piece parts can exceed that of entire systems which were produced under older technologies. The ability to analyze this circuitry at the piece part level is constrained by the tremendous number of individual failures which may have to be considered. A modern microprocessor architecture provides an illustration.

As an example a sample microprocessor application based on the 8080A is considered in Figure 22.

The complexity of assessing microprocessor and support circuitry failure modes is evident. Within the system shown several broad categories of failures are possible which effect the total system operation:

- Microprocessor failures
- System controller failures
- Memory failures (ROM or RAM)
- Interrupt circuitry errors
- I/O errors
- Timing and clock errors

If we consider some of the possible types of failures, some concept of the problem can be gained. Failures of any microcircuit connected to the address bus can cause any one of 65,536 failure conditions (2^{16} for a 16 bit-wide bus structure). Similarly, failures on the control bus provide another 2^6 possible conditions, while the data bus




Figure 22. Microcomputer System (Typical)

can provide another 2^8 possibilities. Each of the possible conditions must be analyzed with respect to microprocessor state and software and to the state of circuitry external to the microprocessor system.

The method of handling microprocessor based equipment which is used within the standardized technique relies on a higher level of treatment of the output. Consider that the 8080 is an eight-bit microprocessor, which is small by the current industry standards. The implementation of 16- and 32-bit architecture processors has begun. The assessment of failure condition for a 32-bit bus structure requires that approximately four billion possible states be examined. This is clearly outside the realm of reasonable possibility, yet 32-bit architectures are likely to become very common in military hardware which is developed in the next ten years.

The method of handling microprocessor type failures within the advanced matrix technique is to analyze the failure possibilities at a higher level of analysis. The microcomputer structure failure is dealt with at the outputs of the system structure. The entire microprocessor or microcomputer subsystem is treated as though it were one component piece-part of the bus structured type. The bus is then assumed to have the failure modes of wrong word on the output bus and of each individual line stuck-at-zero, stuck-at-one, and for tri-state devices, stuck-at-high impedance.

Software FMEA is a relatively new analysis and is not yet well defined in technique or application. The methods necessary to allow software FMEA are expected to be developed over the next several years as software and firmware based systems become more prevalent. The Advanced Matrix Technique does not provide a methodology for software analysis. Microprocessor based systems are analyzed at a level above piece part analysis. This method, while not assessing the probability of software induced failure effects, should at least allow identification of the potential of some hardware/software failure mix causing a catastrophic failure effect when such an effect is possible. The degree of control over the potential failure and the probability of the failure remain undefined.

6.3.4.2 Built-In-Test Assessment

The development of built-in-test information is possible as part of the FMEA process; however, this is a somewhat tedious process using manual methods. The development of this information, using the automated aid described in Section 7, is relatively simple.

The analyst should begin the BIT analysis effort by completing a form similar to that shown in Figure 23 for each assembly and subassembly in the FMEA. The form lists the circuit designator of each potential failed component along with the failure mode, component failure rate, and appropriate mode rate percentage. The previously completed FMEA matrix is then referenced to determine whether the failure is BIT detected or not. For most components this is simply extracted from the assembly matrix. Some component failures, though, will require that the analyst trace the failure upward through the hardware indentured matrices to determine where or if BIT detection occurs.

Once the assembly level forms are completed, the analyst should complete a system summary level form similar to that shown in Figure 24. The completion of the summary level form will provide a comprehensive picture of the effectiveness of the designed-in-test capabilities of the equipment under analysis.

The BIT analysis can be performed at either the intermediate or detailed levels of analysis. For intermediate level analysis, circuitry block failures are used instead of components. The numerical results will probably be somewhat less accurate at the intermediate level of analysis; however, the potential for influencing the ongoing design is enhanced during the period of a design program when piece-part level design is not yet completed.

6.3.4.3 Criticality Analysis

The advanced matrix technique provides no particular advantage over tabular methods for the development of criticality numbers, category 1 and 2 failure modes lists, or any other single point failure lists which may be demanded in an FMEA specified under contract. The analyst should prepare the contractually necessary lists in accordance with the relevant paragraphs of MIL-STD-1629A. Serious consideration should be given to the use of at least some automated aids for the necessary informational sorts. When these separate lists are contractually required, they should be performed as the last item in the FMEA activity.

170-67074

DATE: _____

111

[illegible]

Figure 24. Sample System-Level BIT Summary Form

6.3.4.4 Test Point and Indicator Assessment

The assessment of test point and indicator adequacy of designs being analyzed is an important part of the FMEA process. The matrix FMEA is particularly well structured to allow the necessary tracing between hardware indenture levels. But the task of tracing out the needed information is lengthy and tedious when manual methods are used. The automation package described in Section 7 provides a means to produce various test point and indicator outputs which make the task of assembling the needed information considerably less arduous.

As a part of the Advanced Matrix FMEA development, the analyst indicates the effect of the failure being considered on the test points and indicators found at the various levels of hardware indenture. The information is located on several different matrices for a typical component failure, and has been developed slowly as the hardware design definition has progressed. This information on test point and indicator effects can now be used to provide the information base and analysis criteria for several tasks. Test point and indicator information supports an assessment of the equipment or system maintainability in accordance with Procedure 5 of MIL-HDBK-472. This information is also needed to allow the basic adequacy of the test points and indicators for operations and maintenance use to be assessed. Additionally, the test point and indicator information provides a direct source of troubleshooting criteria for technical manual and training course use.

Assessment Development - Cost-effective development of test point and indicator information requires that the analyst direct the information gathering activity to obtain only that information needed to complete the intended analysis. The analyst should determine what maintenance philosophy is being used on a program and how it is going to be implemented. This will allow the information gathering activities to focus on only those test points and indicators which are actually intended for use by the maintenance or operations level which is under analysis.

Once the analyst has determined which test points and indicators are of interest, he should develop a Test Point/Indicator Effects Summary similar to that shown in Figure 25. The form shown in this figure shows only test points being considered, but indicators are treated exactly the same as test points and are also placed across the top of the matrix when appropriate. The top or horizontal part of the matrix consists of all the test points and indicators which are associated with the maintenance level under

Figure 25. Example Test-Point/Indicator Summary

consideration. The matrix is then completed by tracing each failure in the equipment/assembly/subassembly under analysis upward through the various levels of hardware indenture to determine the effect (if any) on the test points of interest.

The completion of the matrix for test point and indicator information, while not technically difficult, is both time consuming and tedious when manual methods are used. Consideration should be given to assigning this task to a junior member of the analysis staff. The technically difficult analysis has been completed during the development of the matrix FMEA. The test point effects summary matrix is simply a reordering of the developed data to allow the adequacy of the test points to be evaluated. This is a clerical task which can be assigned to an individual of somewhat lower technical skills than the original FMEA analyst.

Analysis Uses - After the matrix of test points has been developed, the analyst can begin to assess the adequacy of the design with respect to the test points and indicators. The analyst should judge the degree of symptom ambiguity represented by the test points and indicators used in the design, and should produce recommendations for additional or changed test points where needed to minimize ambiguity for the maintenance level under analysis. The minimization of ambiguity between failure symptomology is an important consideration if adequate diagnostic capability is going to be designed into the hardware.

After the adequacy of the test points has been assessed, the analyst can use the information about remaining ambiguity to help develop maintainability analysis in accordance with Procedure 5 of MIL-HDBK-472. The assessment of appropriate maintenance times to be expected requires that the degree of ambiguity present in the diagnostics be known. Additionally, this ambiguity information should be used in the development of technical manual and training course materials.

The overall assessment of the adequacy of the proposed test points and indicators for a design is an important part of the FMEA process and can have a major impact on the overall supportability of the finished design. The advanced matrix technique is uniquely designed to allow this assessment in a straightforward manner. This assessment is, however, relatively time consuming and clerical in nature. The use of the automated FMEA tool is recommended. If manual methods must be used, the assessment should be minimized in scope and the actual organization of the data should be assigned to an individual of somewhat lower technical skill than the original analyst.

SECTION 7

AUTOMATED TECHNIQUE

7.1 INTRODUCTION

The Failure Effects Analysis and Data Synthesis (FEADS) Program, developed as a part of this study, is a comprehensive tool to minimize the clerical impact on the FMEA analyst while providing the greatest possible multi-discipline useability of the information. The descriptions of the FMEA automation package provided within the framework of this report will be at the summary level. That is, the direct operation of the tool as it interfaces with the analyst will be described in limited detail. The primary purpose of Section 7 is to provide an overall description of the program. Additionally, the limiting factors of the program are discussed along with why those limits became necessary or were inherent in the automation technique selected.

7.1.1 AUTOMATION PURPOSE

The FEADS program developed during the FMEA study is specifically designed to be an accompaniment to the Advanced Matrix Technique described in the previous section. The FEADS program allows an easy means of data storage while providing a standardized method for documenting and reproducing FMEA results produced using the advanced matrix technique. Additionally, the computer aid allows a rigid standardization of the output reports of the FMEA process without requiring additional effort on the part of the analyst. The FEADS automation package also provides for ease of updating FMEA results in response to design changes.

7.1.2 AUTOMATION DEVELOPMENT GROUNDRULES AND ASSUMPTIONS

As a part of the automation development process a set of groundrules and assumptions were established for the FEADS program. These groundrules were followed as closely as the automation process permitted. Specific initial groundrules included the following.

7.1.2.1 Fortran Based

The FEADS program was written exclusively in FORTRAN. The FORTRAN language usage was required under contract. This restriction was, however, extended to assume that any version-specific or machine-specific FORTRAN options needed to be avoided to the maximum extent practical while allowing for a cost-effective program development. Where possible, all routines were written in non-version-specific FORTRAN code. The program does use some machine based, non-FORTRAN-based routines. These have been limited to routines which should be common to all computer facilities, such as sort packages.

7.1.2.2 User Friendliness

The FEADS program was designed with user friendliness as a specific objective. The degree of user friendliness which could be achieved was expected to significantly affect the ease of industry acceptance of the automation package. The FEADS program was expected to be used by experienced analysts, circuit design engineers, and possibly lower skill level individuals which had been assigned various peripheral tasks in a large FMEA. The potential users were expected to include individuals with very limited computer backgrounds.

The user friendliness goals for the FEADS program were achieved through a combination of built in guidance and users manual. The FEADS program guides the user with question and answer and menu driven type approaches throughout the automation package. The FMEA matrix is developed using an interactive screen approach. Additionally, for those items where a question and answer type approach would become overly repetitive for experienced users, a users manual is provided.

7.1.2.3 User Interactive

The FEADS program was designed to be directly user interactive since this also enhances user friendliness. The user communicates with the program through the use of

various input screens which are specifically designed for user interaction. Figures 26, 27, and 28 are the primary matrix input screens. The user communicates to the program, the effects on outputs (Figure 26), and test points (Figure 27) of failures and includes appropriate remarks (Figure 28). This type of interactive technique is ideally suited to facilities where direct, on line computer services can be provided at 9600 baud or greater speed. Acceptable performance can be obtained at slower terminal speeds; however, a noticeable delay in the updating of the users screen occurs. In addition to allowing an understandable, straightforward user input, the interactive screens provide many of the needed codes and ancillary information to the analyst for easy reference at the terminal. Also, default values which remove the need for tedious entry of redundant information have been used where appropriate. This has resulted in a user friendly, interactive entry technique which significantly enhances the FEADS program useability.

7.1.2.4 Complement Advanced Automated Technique

The FEADS automation package was specifically designed as a complement to the Advanced Automated Technique. The program replaces any need for the development of the matrix FMEA on paper. The program is usable at all phases of FMEA development except the planning phases. The program provides various FMEA outputs which are consistent with the Advanced Matrix Technique. A matrix output is provided, along with the capability for a single page output per failure (see Section 7.2.3). Outputs which provide BIT summaries and test point and indicator information are also available from the FEADS program. The test point and indicator output and BIT output provide a substantial reduction in the effort required to produce these analyses when compared to manual methods.

7.1.2.5 Quick Response For Assembly Level Outputs

The automation package is designed to allow the user to rapidly obtain matrix outputs at the assembly level. A relatively rapid response time is considered to be important since these outputs will be used to validate work currently in process. This

42829-3AP

INSTRUCTIONS:		CODES FOR FAILURE EFFECTS	
* LOCATE CURSOR * USING SPACE BAR, PLACE CURSOR UNDER DESIRED OUTPUT * ENTER CODE FOR THE RELATED EFFECT * CONTINUE UNTIL END OF LINE, PRESS (RETURN) * REPEAT FOR FOLLOWING LINES	0 = STUCK AT ZERO 1 = STUCK AT ONE M = MISSING O = OPEN S = SHORT TO GROUND		T = TIMING OFF Z = STUCK AT HIGH SPEED = =
	***** *OUTPUTS* *****		
	***** TEST POINTS *****		
	***** REMARKS *****		
PARTS/INPUTS		E 0 0 0 0 0 R U U U U U I T T T T T T 0 1 2 3 4 Y	
REFDES OR SIGNAL	FAILURE MODE		
R10	OPEN		
R10 C23	SHORT OPEN		

Figure 26. User Interactive CRT Display – Outputs Screen

INSTRUCTIONS:		CODES FOR FAILURE EFFECTS	
*LOCATE CURSOR *USING SPACE BAR, PLACE CURSOR UNDER DESIRED OUTPUT *ENTER CODE FOR THE RELATED EFFECT *CONTINUE UNTIL END OF LINE, PRESS (RETURN) *REPEAT FOR FOLLOWING LINES		E = ERRATIC	O = OPEN
		F = OFF FREQUENCY	S = SHORT TO GROUND
		H = HIGH OUTPUT/VOLTAGE	
		L = LOW OUTPUT/VOLTAGE	
		M = MISSING	
PARTS/INPUTS		B	***** OUTPUTS *****
		I	***** TEST POINTS *****
		T	***** REMARKS *****
REFDES OR SIGNAL	FAILURE MODE	D	T T
		S	S S
		T	T T
		P	P P
		T	T T
		?	1 2

R10	OPEN		
R10	SHORT		
C23	OPEN		

42829-35P

Figure 27. User Interactive CRT Display – Test Points Screen

42829-36P

INSTRUCTIONS:		CODES FOR FAILURE EFFECTS	
* LOCATE CURSOR * USING SPACE BAR, PLACE CURSOR UNDER DESIRED OUTPUT * ENTER CODE FOR THE RELATED EFFECT * CONTINUE UNTIL END OF LINE, PRESS (RETURN) * REPEAT FOR FOLLOWING LINES		= = = = =	= = = = =
PARTS/INPUTS		R E M A R K	* * * * * * OUTPUTS * * * * * * * TEST POINTS * * * * * * * REMARKS *
REFDES OR SIGNAL	FAILURE/MODE		#
PLEASE ENTER THE CORRECT REMARK CODE			
R10	OPEN	4	

Figure 28. User Interactive CRT Display – Remarks Screen

allows the analyst using the program to obtain needed hard copy feedback in a timely manner.

7.1.2.6 Minimum Training Requirement

The FEADS package and its accompanying documentation have been specifically tailored to minimize the training required to use the program. The user interactive program package and its accompanying user's manual are expected to provide a documentation package to allow operation of the program. Specialized training should not be required.

7.1.2.7 Easy To Update

The FEADS automation package has been designed to allow updates to occur with a minimum of effort. The program contains special routines to recognize file changes and to direct the analyst to these change activities when appropriate. This was considered a high priority item within the program development due to the rapid rate of change which is normally a part of the electronic equipment design and development process.

7.1.2.8 Computer Resource Requirements

The program development effort was conducted without considering computer resources as a limiting requirement. The using organization is responsible for providing the needed resources.

7.1.2.9 System Output Response Time

The automation development assumed that system level outputs such as complete FMEAs, BIT summaries, and test point and indicator summaries would not be required on an immediate output basis. These reports are requested using an interactive mode; however, the routines required and the size of the information base which may be printed may preclude quick response outputs for extremely large systems. These outputs can be

requested at the end of a normal working shift or at such times when significant computer resources can be dedicated to the FMEA in process, if the available computer resources are overloaded by the requested program output. The potential for this problem is dependent on the size of the system being analyzed and the available computer resources.

The groundrules and assumptions which were utilized in the development of the FEADS program have resulted in a flexible, user oriented FMEA automation package which should significantly reduce the labor required for an FMEA.

7.2 AUTOMATION PACKAGE OVERVIEW

7.2.1 PROGRAM DESCRIPTION

The FEADS automation package is a set of FORTRAN based routines specifically designed to be used for FMEAs being performed utilizing the Advanced Matrix Technique. The program consists of one main and 33 subroutines developed utilizing a structured programming approach. The FEADS automatic package has been structured to allow a maximum of user comfort when using the program while demanding a minimum of training.

The user environment provided by the FEADS program is one of continuous interaction with the program in an on-line basis to create the files which contain the analysis results. These matrix files are then used to create the various reports which the analyst requires to document the FMEA process and to provide hard copy working information for design evaluation. The program interfaces with the user through a set of interactive screens which are updated in response to user actions. The user is provided with the capability to direct the program to any desired action quickly and with a minimum potential for error.

The program is structured to provide two interrelated but separate sections. A basic overview of the program construction is shown in Figure 5. The user can enter either of two possible program environments, assembly or system. Upon entering the assembly level environment the user can create, update, or change an assembly matrix file. The user can also print selected assembly level outputs once a file has been created. Upon entering the system level environment the user can provide the program with a system definition, delineate or update the systems operation mode file, or request any one of several available system level outputs for hard copy print. Changing between the system and assembly environments within the program as well as between the various subsections is permitted.

The assembly use environment is designed to allow the creation and modification of matrix files containing the FMEA circuit analysis results. An overview of the assembly environment showing file usage and available outputs is given in Figure 30. The program user has three possible options. He may create an entirely new matrix file to hold FMEA results for a new assembly, he may change the entries presently in an existing file to correct previous errors in an update process, or the analyst can add or subtract individual circuit parts in a matrix, usually in response to design changes. The program is dependent on the existence of several user supplied files and of some files which are normally system resident files but are user modifiable. The files required to operate the program are discussed in Section 7.2.2.

The system use environment is designed to allow the creation of the top level matrix file, the creation of the system definition file, and the assembling and printout of the available system level FMEA outputs. An overview of the system environment structure showing file usage and available outputs is given in Figure 31. The program user has the option of creating, updating or changing the operation modes matrix in a manner similar to that described in the paragraph above. The user can also select from several available outputs. Some of these outputs are quite large and can provide the entire FMEA documentation. The input files required are discussed in Section 7.2.2. The available outputs are discussed in Section 7.2.3.

The overall automation package is expected to significantly reduce the labor required to document an FMEA which is performed utilizing the advanced matrix technique. The FEADS package is especially valuable in allowing a maximum value to be received from the FMEA information which has been developed. The program provides both a BIT and a test point and indicator output which are useable in evaluating the




Figure 29. FEADS Program Macro Flow Chart




Figure 30. FEADS Assembly File Usage and Outputs




Figure 31. FEADS System File Usage and Outputs

diagnostic capability of the design. These outputs are very difficult to assemble by hand due to the volume of information which the analyst must reorganize. Both outputs can be easily requested from the automation package.

7.2.2 PROGRAM FILES

The FEADS program package requires the existence of various files for proper operation (see Table 7). The files which are used by the program fall into three categories; user created and FMEA dependent, user modifiable system information files, and program used temporary files. Each of these file types may be in use on any given program operation. A detailed description of the content and format of all FEADS program files is provided as a part of the program users guide.

The user created files comprise those files which are dependent on the individual system under analysis. These files are created by the analyst either offline or through the use of the FEADS program package. Files of this type are the most numerous as three files for each assembly must be created.

The user modifiable system information files are those files which supply general information to the automation package. The user can access and modify these files through the use of an on-line edit package (not a part of FEADS). Generally the user will not need to access these files as they provide information which will generally not change from program to program. These files need to be changed with some care as the changes have the potential of affecting stored FMEA results which may need to be accessed and printed at a later time. Responsibility for maintaining the system information files should generally be assigned to one individual to maintain control over the impact of changes.

The temporary program files are inaccessible to and transparent to the user of the FEADS automation package. These are files which the program creates, uses, and deletes while it is running. These files are mentioned here in that they can consume considerable storage resources within the computer facility. Data processing professionals which have been tasked with installing the FEADS package should consult the programmer's notes section of the user's manual for further information. The temporary files are not discussed in Table 7.

TABLE 7. FEADS PROGRAM FILES

Ref No. (1)	Title	Description
1	Assembly File	This is the assembly parts file. The program user must create one of these files off-line ⁽²⁾ for each assembly in the FMEA. The file contains information on the parts making up the assembly, their failure rate, appropriate test points, inputs, and outputs. This is a user created, FMEA dependent file.
2	Outputs Failure Effects File	This file provides the program with a list of possible output failure effect codes for display to the program user in the user interface screens. This is a user modifiable, system information file which has been created off-line ⁽²⁾ prior to program use.
3	Test Point Effects File	This file is similar to the Output Failure Effects File. The only difference is that the effects contained within the file relate to test points.
4	Part Failure Modes File	This file supplies the automation package with the appropriate failure modes and occurrence percentages for the various electronic part types. This is a user modifiable, system information file.
5	Signal Failure Modes File	This file provides the program with the appropriate failure modes for each signal type. This is a user modifiable, system information file.
6	Old Matrix File	This is a designation of the existing assembly matrix file when it is being used to facilitate update or change routines. This is a user created (using FEADS), FMEA dependent file.
7	Output Signal File	This is a file which contains a list of assembly level outputs for program use. The file is created by the program.

TABLE 7. FEADS PROGRAM FILES (Continued)

Ref No.	Title	Description
8	New Matrix File	This is the assembly matrix file created by the assembly level matrix programs during the create, update and change assembly file routines. This is a program created, FMEA dependent file.
9	System Definition File	This file contains the information necessary to define the system in terms of matrix files to the program. The file also contains the information needed to allow completion of some parts of the single sheet output forms. This is a user created (using FEADS), FMEA dependent file.
10	Remarks File	This file holds the remarks to be printed with the various assembly level files. These remarks are held in this common file for all assemblies. The file is created by the program user utilizing FEADS during the creation of the matrix files (#8).

- (1) The reference number given to each program file in Table 7 is the reference number used in Figures 30 and 31. These numbers do not relate to the program code.
- (2) "off-line" refers to the activities which occur separate from the FEADS program. A file which is created "off-line" is one which has been prepared using a text editor or a similar system utility.

7.2.3 PROGRAM OUTPUTS

The FEADS automation package has been structured to provide a wide range of output formats which enhance the cross discipline useability of the FMEA material. Each of the available outputs is discussed in Table 8. A sample of each output format is provided in Figures 32 through 42. The various available system level outputs depend on having all the necessary information developed. In general, the analyst will find it difficult to receive some of the outputs until all FMEA activity at a given level of design detail is completed.

TABLE 8. AVAILABLE PROGRAM OUTPUTS

Title	Description
ASSEMBLY LEVEL OUTPUTS	
FMEA Matrix	This is an output of the created FMEA matrix for use by the analyst in checking for errors and as a record of the data entered. Figure 32 provides a sample FMEA matrix output.
Criticality Summary	This is a listing of the assembly failures as recorded by the analyst in order of their severity classification and by criticality number. Figure 33 provides a sample severity listing output.
BIT Summary	This output consists of a listing of the possible assembly level failures with their BIT detectability listed. Figure 34 provides a sample assembly level BIT summary.
Single Sheet	This output provides the FMEA for the assembly level in a single sheet format which complies with the intent of MIL-STD-1629A. Figure 35 provides a sample assembly level single sheet output.
SYSTEM LEVEL OUTPUTS	
Mission Phases	This is a system level summary of the operating phases or modes, provided to the program by the analyst, which the program uses in preparing the FMEA. Figure 36 provides a sample mission phases output.
FMEA Worksheets	This output option provides a complete set of single sheet type, MIL-STD-1629A outputs for the entire system structure. This output is very similar to the assembly level output except that the effects of failure at the next two higher levels of hardware indenture are included. Figure 37 provides a sample system level FMEA worksheet output.
Part Failure Mode Dictionary	This output is essentially a printout of the information contained in the part failure mode files. Figure 38 provides a sample failure mode dictionary output.
Signal Failure Mode Dictionary	This output provides a printout of the data contained in the signal failure mode file. Figure 39 provides a sample failure failure mode output.
Severity Summary	The Severity Summary output provides a listing of all single point failures within the system in order of their severity classification and criticality number. Figure 40 provides a sample severity summary output.

TABLE 8. AVAILABLE PROGRAM OUTPUTS (Continued)

Title	Description
BIT Summary	The BIT Summary output consists of a listing of all the failures which are possible within a system, organized by module, and their location (if any) of BIT detection. Summary information is provided for each module and for the system, including a measure of BIT effectiveness. Figure 41 provides a sample of the output format for the BIT summary.
Maintainability Information	The maintainability information output provides a listing of failures which have an effect on user designated test points. The output is useable in determining the adequacy of the various test points and indicators of the equipment being analyzed at each level of maintenance. An example of the test point and indicators output is provided in Figure 42.

7.3 USING FEADS FOR ADVANCED AUTOMATED TECHNIQUE FMEAS

The FEADS automation package has been specifically designed to aid in the performance of FMEA utilizing the advanced matrix technique. The primary advantage provided by the FEADS program is a reduction in clerical effort and the ability to easily access the developed data in the needed arrangement for optimum useability. The program also provides a means of generating formal, report oriented, documentation. This documentation is suitable for data delivery when such requirements are imposed contractually.

7.3.1 FMEA PLANNING

The FEADS automation package is not directly useable during the FMEA planning activity required by the Advanced Automated Technique. The planning phase activity is designed to provide guidance to the analyst with respect to the proper depth and focus for the FMEA. The FEADS program is designed to record analysis results and to provide analysis documentation. The program has not been designed for creating any planning documentation. The FMEA planning activity should be used to provide initial guidance in the file organization conventions and procedures as they relate to the use of the automation package. The organization and control of file names is not likely to represent a major concern for small systems; however, file naming conventions become

FMEA Matrix for FIRST ASSEMBLY									
Prepared on: WED. MAR 14, 1984 Page: 1									
REF	DES	PART NUMBER	FAILURE MODE	SEVERITY	DESIGN	TEST POINTS	OUTPUTS	TEST POINTS	TEST POINTS
NO	NO	NO	NO	NO	NO	NO	NO	NO	NO
R10	RLR07C1142GR	OPEN	0	4	Y	0	0	Y	0
R10	RLR07C1142GR	SHORT	1	4	Y	1	1	Y	1
C23	CK05R123K	OPEN	2	4	V	3	3	V	3
C23	CK05R123K	SHORT	3	4	V	3	3	V	3
CRI	IN4414	OPEN	4	4	V	1	1	V	1
CRI	IN4414	SHORT	5	4	V	1	1	V	1
U1	CMPO58Z	OPEN	6	4	V	1	1	V	1
U1	CMPO58Z	SHORT	7	4	V	1	1	V	1
U1	CMPO58Z	OPEN	8	4	V	1	1	V	1
U1	CMPO58Z	SHORT	9	4	V	1	1	V	1
U2	54LS197	OPEN	10	4	V	1	1	V	1
U2	54LS197	SHORT	11	4	V	1	1	V	1
U2	54LS197	OPEN	12	4	V	1	1	V	1
U2	54LS197	SHORT	13	4	V	1	1	V	1
U2	54LS197	OPEN	14	4	V	1	1	V	1
U2	54LS197	SHORT	15	4	V	1	1	V	1
U2	54LS197	OPEN	16	4	V	1	1	V	1
U2	54LS197	SHORT	17	4	V	1	1	V	1
U2	54LS197	OPEN	18	4	V	1	1	V	1
U2	54LS197	SHORT	19	4	V	1	1	V	1
U2	54LS197	OPEN	20	4	V	1	1	V	1
U2	54LS197	SHORT	21	4	V	1	1	V	1
U2	54LS197	OPEN	22	4	V	1	1	V	1
U2	54LS197	SHORT	23	4	V	1	1	V	1
U2	54LS197	OPEN	24	4	V	1	1	V	1
U2	54LS197	SHORT	25	4	V	1	1	V	1
U2	54LS197	OPEN	26	4	V	1	1	V	1
U2	54LS197	SHORT	27	4	V	1	1	V	1
U2	54LS197	OPEN	28	4	V	1	1	V	1
U2	54LS197	SHORT	29	4	V	1	1	V	1
U2	54LS197	OPEN	30	4	V	1	1	V	1
U2	54LS197	SHORT	31	4	V	1	1	V	1
U2	54LS197	OPEN	32	4	V	1	1	V	1
U2	54LS197	SHORT	33	4	V	1	1	V	1
U2	54LS197	OPEN	34	4	V	1	1	V	1
U2	54LS197	SHORT	35	4	V	1	1	V	1
U2	54LS197	OPEN	36	4	V	1	1	V	1
U2	54LS197	SHORT	37	4	V	1	1	V	1
U2	54LS197	OPEN	38	4	V	1	1	V	1
U2	54LS197	SHORT	39	4	V	1	1	V	1
U2	54LS197	OPEN	40	4	V	1	1	V	1
U2	54LS197	SHORT	41	4	V	1	1	V	1
U2	54LS197	OPEN	42	4	V	1	1	V	1
U2	54LS197	SHORT	43	4	V	1	1	V	1
U2	54LS197	OPEN	44	4	V	1	1	V	1
U2	54LS197	SHORT	45	4	V	1	1	V	1
U2	54LS197	OPEN	46	4	V	1	1	V	1

Figure 32. Example FMEA Matrix Output Assembly

42829-41P

Criticality Summary

CLS	REFDES	PART NO/DESCRIPT	PIN#	FAIL MODE	CRITICALITY#
4	POWER1	+5VDC	0	MISSING	.5495E-07
4	POWER1	+5VDC	0	SHORT-GND	.5495E-07
4	POWER2	-15VDC	0	MISSING	.5495E-07
4	POWER2	-15VDC	0	SHORT-GND	.5495E-07
4	POWER1	+5VDC	0	LOW OUTPUT	.4396E-07
4	POWER2	-15VDC	0	LOW OUTPUT	.4396E-07
4	U2	54LS197	2	STUCK @ 0	.3497E-07
4	U2	54LS197	2	STUCK @ 1	.3497E-07
4	U2	54LS197	9	STUCK @ 0	.3497E-07
4	U2	54LS197	9	STUCK @ 1	.3497E-07
4	U2	54LS197	12	STUCK @ 0	.3497E-07
4	U2	54LS197	12	STUCK @ 1	.3497E-07
4	POWER1	+5VDC	0	OPEN	.2198E-07
4	POWER2	-15VDC	0	OPEN	.2198E-07
4	POWER1	+5VDC	0	HI OUTPUT	.1099E-07
4	POWER2	-15VDC	0	HI OUTPUT	.1099E-07
4	POWER1	+5VDC	0	ERRATIC	.5495E-08
4	POWER2	-15VDC	0	ERRATIC	.5495E-08
4	R10	RLR07C1142GR	0	OPEN	.4557E-08
4	R10	RLR07C1142GR	0	SHORT	.4557E-08
4	U2	54LS197	2	STUCK @HIZ	.2809E-09
4	U2	54LS197	9	STUCK @HIZ	.2809E-09
4	C23	CK05R123K	0	OPEN	.6170E-10
4	C23	CK05R123K	0	SHORT	.6170E-10
4	CR1	1N4414	0	OPEN	.6160E-11

Figure 33. Example Assembly Criticality Summary

BIT Detectability Analysis (Assembly)

IND	SIGNAL	DESCRIPTIO	TOTAL FAILURE RT	BIT DETECT FAILURE RT	BIT %
0	OUT0	SHORT-GND	.4557E-08	.4557E-08	100.0
0	OUT0	STUCK @ 0	.2683E-06	.4557E-08	1.7
0	OUT0	STUCK @HIZ	.6160E-11	.6160E-11	100.0
0	OUT0	TIMING OFF	.1210E-06	.1234E-09	.1

Figure 34. Example Assembly BIT Summary

FMEA Worksheet for FIRST ASSEMBLY

FMEA Identification Number: AAAA

FMEA Date:	PREP	APPR
WED, MAR 14, 1984	BY R. DAVIS	BY P. GODDARD

Schematic Diagram:	1-3	Revision: A
Block Diagram:	1-1	Revision: A
Parts List:	1-2	Revision: A

Item Part Number:	RLR07C1142GR	Indenture: 8
Reference Mnemonic:	R10	

Failure Mode: SHORT

Local Effect(s)

Outputs:

OUT0 SHORT-GND Severity: 4 BIT Detected ? Y

Test Points:

Failure Effect Probability (Beta):	1.000
Failure Mode Ratio (Alpha):	.500
Failure Rate (Lambda-p):	.9114E-08
Operating Hours (t):	1.0

Failure Mode Criticality Number (Cm):	.4557E-08
Item Criticality Number (Cr):	.9114E-08

Remarks: This failure is detected by the master cycle of BIT, which occurs once every minute. Upon detecting this, the CPU shuts down.

Figure 35. Example Assembly Single Sheet Output

42829-43P

```

FFFFF  EEEEE  A   DDDD  SSS  Mission Phases Summary
F      E      A A  D  D  S      for
FFF    EEE    A  A  D  D  SSS
F      E      AAAAA D  D  S  ** FEADS Demonstration **
F      EEEEE  A   A  DDDD  SSS

```

* * * * * OPERATIONAL MODE * * * * *			FAILURE	
MNEMONIC	DESCRIPTION	USAGE	SEVERITY CLASS	OCCURENCE RATE
ACPWR	POWERED BY AC	.950	1	.7423E-09
			2	.5675E-08
			3	.0000E+00
			4	.5685E-08
BATPWR	POWERED BY BATRY	.050	1	.0000E+00
			2	.6417E-08
			3	.0000E+00
			4	.5685E-08

Figure 36. Example Mission Phases Summary

FMEA Worksheet for TESTING VERSION 1.1 Page: 11

Assembly Identification Number: DDDA

FMEA Date:	PREP	APPR
SAT, AUG 4, 1984	BY R. DAVIS	BY P. GODDARD

Schematic Diagram: 1-3	Revision: A
Block Diagram: 1-1	Revision: A
Parts List: 1-2	Revision: A

Reference Mnemonic: CR1

Item Part Number/Signal Description: 720604-24

Failure Mode: OPEN BIT Detectable Here ? Y

This failure falls into Severity Class 3

Failure Effect Probability (Beta):	1.000
Failure Mode Ratio (Alpha):	.500
Failure Rate (Lambda-p):	.3875E-09
Operating Hours (t):	1.0

Failure Mode Criticality Number (Cm):	.1937E-09
Item Criticality Number (Cr):	.3875E-09

Remarks: This causes all DC output voltages to be erratic due to breakdown in the full-wave rectifier.

Figure 37A. Example System FMEA Work Sheet Output (Page 1 of 3)

Local Effect(s): Page: 11a

Signals:

PW1	ERRATIC
PW2	ERRATIC
PW3	ERRATIC
STAT	STUCK @ 0

Test Points:

TP1	STUCK @ 0
-----	-----------

Figure 37B. Example System FMEA Work Sheet Output (Page 2 of 3)

Effect(s) at Higher Levels:

Page: 11b

Level + 1:

Level + 2:

DDDC CNTR TIMING OFF

DDDH BEAM TIMING OFF

DDDD DIR ERRATIC

DDDG ALARM3 ERRATIC

DDDH BEAM ERRATIC

DDDD DIR ERRATIC

DDDG ALARM3 ERRATIC

DDDB TEMP ERRATIC

DDDC CNTR TIMING OFF

DDDG ALARM1 ERRATIC

DDDB PRES ERRATIC

DDDC CNTR TIMING OFF

DDDG ALARM2 ERRATIC

DDDE TOR ERRATIC

DDDF ALARM ERRATIC

DDDG ALARM1 ERRATIC

DDDG ALARM2 ERRATIC

DDDG ALARM3 ERRATIC

DDDF ALARM STUCK OFF

Figure 37C. Example System FMEA Work Sheet Output (Page 3 of 3)

Part Failure Mode Dictionary

Date: MON, APR 30, 1984

42829-46P

Part Type	Part Sub-Type	Failure Mode	Failure Mode Probability
1	1	STUCK @ 0	.498
1	1	STUCK @ 1	.498
1	1	STUCK @HIZ	.004
1	2	STUCK @ 0	.498
1	2	STUCK @ 1	.498
1	2	STUCK @HIZ	.004
1	3	STUCK @ 0	.498
1	3	STUCK @ 1	.498
1	3	STUCK @HIZ	.004
1	4	STUCK @ 0	.498
1	4	STUCK @ 1	.498
1	4	STUCK @HIZ	.004
1	5	STUCK @ 0	.498
1	5	STUCK @ 1	.498
1	5	STUCK @HIZ	.004
1	6	STUCK @ 0	.498
1	6	STUCK @ 1	.498
1	6	STUCK @HIZ	.004
1	7	STUCK @ 0	.498
1	7	STUCK @ 1	.498
1	7	STUCK @HIZ	.004
1	8	STUCK @ 0	.498
1	8	STUCK @ 1	.498
1	8	STUCK @HIZ	.004
1	9	STUCK @ 0	.498
1	9	STUCK @ 1	.498
1	9	STUCK @HIZ	.004
1	10	STUCK @ 0	.498
1	10	STUCK @ 1	.498
1	10	STUCK @HIZ	.004
2	1	OPEN B/C	.167
2	1	OPEN B/E	.167
2	1	OPEN C/E	.167
2	1	SHORT B/C	.167
2	1	SHORT B/E	.167
2	1	SHORT C/E	.167
2	2	OPEN B/C	.167
2	2	OPEN B/E	.167
2	2	OPEN C/E	.167
2	2	SHORT B/C	.167
2	2	SHORT B/E	.167
2	2	SHORT C/E	.167
2	3	OPEN B/C	.167
2	3	OPEN B/E	.167
2	3	OPEN C/E	.167
2	3	SHORT B/C	.167
2	3	SHORT B/E	.167
2	3	SHORT C/E	.167
2	4	OPEN B/C	.167
2	4	OPEN B/E	.167
2	4	OPEN C/E	.167
2	4	SHORT B/C	.167
2	4	SHORT B/E	.167
2	4	SHORT C/E	.167
2	5	OPEN B/C	.167

Figure 38. Example Part Failure Mode Dictionary

Signal Failure Mode Dictionary

Date: MON, APR 30, 1984

Signal Type	Signal Sub-Type	Failure Mode	Symbol	Failure Mode Probability
21	1	DISTORTED	D	.005
21	1	ERRATIC	E	.045
21	1	HI OUTPUT	H	.100
21	1	LOW OUTPUT	L	.100
21	1	MISSING	M	.500
21	1	OFF FREQ	F	.005
21	1	OPEN	O	.200
21	1	OSCILLATES	R	.005
21	1	SHORT-GND	S	.005
21	1	TIMING OFF	T	.050
22	1	OPEN	O	.005
22	1	SHORT-GND	S	.005
22	1	STUCK @ 0	0	.450
22	1	STUCK @ 1	1	.450
22	1	STUCK @HZ	Z	.050
22	1	TIMING OFF	T	.050
23	1	ERRATIC	E	.050
23	1	HI OUTPUT	H	.100
23	1	LOW OUTPUT	L	.400
23	1	MISSING	M	.500
23	1	OPEN	O	.200
23	1	SHORT-GND	S	.500
24	1	ERRATIC	E	.100
24	1	HI OUTPUT	H	.200
24	1	LOW OUTPUT	L	.200
24	1	MISSING	M	.400
24	1	TIMING OFF	T	.100
25	1	ERRATIC	E	.333
25	1	STUCK ON	1	.333
25	1	STUCK OFF	0	.333
26	1	ERRATIC	E	.100
26	1	HI OUTPUT	H	.200
26	1	LOW OUTPUT	L	.200
26	1	MISSING	M	.400
26	1	TIMING OFF	T	.100
27	1	PATTERN BD	P	.200
27	1	STUCK @ 0	0	.200
27	1	STUCK @ 1	1	.200
27	1	STUCK @HZ	Z	.200
27	1	TIMING OFF	T	.500
27	1	WRONG WORD	W	.200

Figure 39. Example Signal Failure Mode Dictionary

Severity Summary

CLS	ASSY	REFDES	PART NO/DESCRIPT	PIN#	FAIL MODE	CRITICALITY#
1	ZZZZ	FIRE	FIRE ENABLE	0	TIMING OFF	.6170E-19
1	ZZZZ	FIRE	FIRE ENABLE	0	STUCK @ 1	.5553E-18
2	DDDA	ZD1	RD24E(B3)	0	SHORT	.2819E-08
2	DDDF	BPOWER	RESERVE POWER	0	MISSING	.0000E+00
2	DDDF	BPOWER	RESERVE POWER	0	OPEN	.0000E+00
2	DDDF	BPOWER	RESERVE POWER	0	SHORT-GND	.0000E+00
3	DDDA	CR1	720604-24	0	OPEN	.1938E-09
3	DDDA	CR1	720604-24	0	SHORT	.1938E-09
3	DDDA	CR2	720604-24	0	OPEN	.1938E-09
3	DDDA	CR2	720604-24	0	SHORT	.1938E-09
3	DDDA	CR3	720604-24	0	OPEN	.1938E-09
3	DDDA	CR3	720604-24	0	SHORT	.1938E-09
3	DDDA	CR4	720604-24	0	OPEN	.1938E-09
3	DDDA	CR4	720604-24	0	SHORT	.1938E-09
3	DDDA	ZD1	RD24E(B3)	0	OPEN	.2819E-08
3	ZZZZ	ACGND	GROUND	0	ERRATIC	.6170E-13
3	ZZZZ	PWRIN	115VAC	0	ERRATIC	.6170E-13
3	DDDF	3POWER	RESERVE POWER	0	LOW OUTPUT	.0000E+00
4	DDDB	DAC1	DAC0800	2	STUCK @ 0	.8884E-09
4	DDDB	DAC1	DAC0800	2	STUCK @ 1	.8884E-09
4	DDDB	DAC1	DAC0800	4	STUCK @ 0	.8884E-09
4	DDDB	DAC1	DAC0800	4	STUCK @ 1	.8884E-09
4	ZZZZ	FIRE	FIRE ENABLE	0	STUCK @HIZ	.6170E-19
4	DDDB	SW3	3113-03	0	OPEN	.4689E-09
4	DDDB	SW3	3113-03	0	SHORT	.4689E-09
4	DDDF	PTRANS	195000-86	0	OPEN	.4431E-09
4	DDDF	PTRANS	195000-86	0	SHORT	.4431E-09
4	DDDB	RTH	3011-04	0	OPEN	.3892E-09
4	DDDB	RTH	3011-04	0	SHORT	.3892E-09
4	DDDE	R1	710894-01	0	OPEN	.3867E-09
4	DDDE	R1	710894-01	0	SHORT	.3867E-09
4	DDDB	SW5	3113-05	0	OPEN	.3782E-09
4	DDDB	SW5	3113-05	0	SHORT	.3782E-09
4	DDDC	U0	74166	13	STUCK @ 0	.3365E-09
4	DDDC	U0	74166	13	STUCK @ 1	.3365E-09
4	DDDC	U1	74166	13	STUCK @ 0	.3365E-09
4	DDDC	U1	74166	13	STUCK @ 1	.3365E-09
4	DDDC	U3	7411	6	STUCK @ 0	.3360E-09
4	DDDC	U3	7411	6	STUCK @ 1	.3360E-09
4	DDDA	STAT	ON/OFF	0	STUCK @ 1	.3356E-09
4	DDDB	SW8	3113-08	0	OPEN	.3337E-09
4	DDDB	SW8	3113-08	0	SHORT	.3337E-09
4	DDDA	S1	184500-09	0	OPEN	.3326E-09
4	DDDA	S1	184500-09	0	SHORT	.3326E-09
4	DDDD	H1	700138-5	0	OPEN	.3119E-09
4	DDDD	H1	700138-5	0	SHORT	.3119E-09
4	DDDD	H2	700138-5	0	OPEN	.3119E-09
4	DDDD	H2	700138-5	0	SHORT	.3119E-09
4	DDDD	H3	700138-5	0	OPEN	.3119E-09
4	DDDD	H3	700138-5	0	SHORT	.3119E-09

Figure 40. Example System Severity Summary Output

FFFFF EEEEE A DDDD SSS BIT Detectable Failure List
 F E A A D D S for
 FFF EEE A A D D SSS
 F E AAAAA D D S ** FEADS Demonstration **
 F EEEEE A A DDDD SSS

Assembly: DDDA

Page: 1

REFDES	PIN #	FAILURE MODE	DEST
CR1	0	OPEN	DDDA
CR1	0	SHORT	DDDA
CR2	0	OPEN	DDDA
CR2	0	SHORT	DDDA
CR3	0	OPEN	DDDA
CR3	0	SHORT	DDDA
CR4	0	OPEN	DDDA
CR4	0	SHORT	DDDA
GND	0	MISSING	DDDB
GND	0	MISSING	DDDD
GND	0	MISSING	DDDF
GND	0	MISSING	DDDG
GND	0	MISSING	DDDH
GND	0	OPEN	DDDB
GND	0	OPEN	DDDC
GND	0	OPEN	DDDD
GND	0	OPEN	DDDE
GND	0	OPEN	DDDF
GND	0	OPEN	DDDG
GND	0	OPEN	DDDH
PW1	0	MISSING	DDDC
PW1	0	MISSING	DDDD
PW1	0	MISSING	DDDH
PW1	0	OPEN	DDDC
PW1	0	OPEN	DDDD
PW1	0	OPEN	DDDH
PW1	0	SHORT-GND	DDDC
PW1	0	SHORT-GND	DDDD
PW1	0	SHORT-GND	DDDH
T1	1	OPEN	DDDA
T1	1	SHORT	DDDA
T1	2	OPEN	DDDA
T1	2	SHORT	DDDA
T1	3	OPEN	DDDA
T1	3	SHORT	DDDA
T1	4	OPEN	DDDA
T1	4	SHORT	DDDA
ZD1	0	OPEN	DDDA

Figure 41. Example System Level BIT Summary

FFFF	EEEE	A	DDDD	SSS	OPTION	USER	Prepared	MON	APR	30	1984	Page	1A
FFF	EEE	A A	D D	S									
F	EE	A A	D D	SSS									
F	EE	AAAA	D D	SSS									
F	EEEE	A A	DDDD	SSS									
Maintainability Information for XX FEADS Demonstration XX													
CAUSE													
ASSY	REFDES	P T	N	FAILURE MODE	CRIT	0							
ZZZZ	ACGND	0	ERRATIC	6170E-13									
DDDF	BPOWER	0	SHORT-GND	0000E+00	1	S							
DDDA	S1	0	SHORT	3325E-09	1								
DDDF	BPOWER	0	MISSING	0000E+00	1								
DDDF	BPOWER	0	OPEN	0000E+00	1								
DDDA	CR1	0	OPEN	1937E-08	0								
DDDA	CR1	0	SHORT	1937E-08	0								
DDDA	CR2	0	OPEN	1937E-08	0								
DDDA	CR2	0	SHORT	1937E-08	0								
DDDA	CR3	0	OPEN	1937E-08	0								
DDDA	CR3	0	SHORT	1937E-08	0								
DDDA	CR4	0	OPEN	1937E-08	0								
DDDA	CR4	0	SHORT	1937E-08	0								
DDDA	S1	0	OPEN	3325E-09	0								
DDDA	T1	1	SHORT	1140E-08	0								
DDDA	T1	2	OPEN	1140E-08	0								
DDDA	T1	2	SHORT	1140E-08	0								
DDDA	T1	3	OPEN	1140E-08	0								
DDDA	T1	3	SHORT	1140E-08	0								
DDDA	T1	4	OPEN	1140E-08	0								
DDDA	T1	4	SHORT	1140E-08	0								
DDDA	ZD1	0	OPEN	2819E-08	0								
DDDA	ZD1	0	SHORT	2819E-08	0								
ZZZZ	PMWIN	0	ERRATIC	6170E-13	0								
ZZZZ	PMWIN	0	LOW OUTPUT	4936E-12	0								

Figure 42. Example Maintainability Information Output

very important for large system FMEAs where several analysts may be used. The initial planning of these file conventions is appropriate during the FMEA planning phase.

7.3.2 INITIAL FMEA ACTIVITY

The period of initial FMEA activity produces nine distinct outputs (as shown in Figure 6, page 69). The FEADS automation package is used to provide two of the outputs. The other seven possible outputs of the initial activity are not produced by the program, although the program will require the information generated by some of the activities.

The program will allow the analyst to store the results of developing the operating mode to percent list and the preliminary signal failure modes/effects list. The automation package is used to create the operation modes matrix, which is the automated equivalent of the FMOMEM and FMOMSM matrices. Additionally, the analyst should finalize any necessary planning of file conventions to be used during the analysis as a part of the initial FMEA activity.

The FEADS program will not assist the analyst in developing the design guidelines, the revised FMEA planning, FMEA specification, preliminary mnemonics, or the fundamental I/O definitions.

7.3.3 INTERMEDIATE AND DETAIL FMEA ACTIVITIES

The FEADS program is used extensively during both the intermediate and detail levels of FMEA activity. The analyst utilizes the program package to develop the FMEA documentation in a matrix format. The program is then used to produce the various outputs described in Section 7.2. The program is particularly effective in producing the BIT and test point and indicator outputs. These outputs are very tedious to assemble by manual methods. The ability to obtain the various program outputs is dependent on the existence of sufficient information within the computer. The analyst can request the various assembly level outputs as soon as the analysis of the assembly in question is complete. The ability to obtain system reports is dependent on the entire equipment under analysis having been analyzed to a given level. The preparation of system level reports which reflect the design analysis at the intermediate level of detail requires that all assemblies be analyzed at the intermediate level of detail and input to

the program prior to requesting the output for the level. It is possible to obtain results from the FEADS program without completing the FMEA for all assemblies if the system files are constrained to exclude all undefined assemblies and signals. This should not generally represent a problem; however, the ability to obtain some types of information may be paced by the speed of the slowest individual when multiple analysts are used on a large FMEA. This requires the chief analyst to ensure that his available resources are being effectively used if the needed information is going to be obtained in a timely manner.

7.4 PROGRAM LIMITATIONS

The FEADS program package has been developed with a minimum of inherent limitations. The computer resources available will be the only limiting factor for most program functions. Where such limits may be encountered, the analyst should consult the facility manager at the installation where the program is resident.

The primary restrictions which are inherent in the program design are the limits on input field sizes for the assembly matrices, restrictions on the number of test points and indicators which may be simultaneously analyzed for the test point and indicators output and the handling of next higher assembly effects for worksheet outputs.

Assembly matrices are limited to a maximum of twenty-five outputs and twenty-five test points. This is expected to be sufficiently large to accommodate most assemblies. When the number of outputs or the number of test points exceeds twenty-five, the analyst will be required to further sub-divide the hardware under analysis for FMEA purposes.

The number of test points and indicators which can simultaneously be considered for a given maintainability information output (Figure 42) is one hundred and twenty. This is expected to be sufficient for virtually all analysis. When more than one hundred and twenty test points must be considered, successive test point and indicator runs may be necessary. This should not represent an unusual difficulty as the user merely specifies that a second set of test points be considered on the succeeding program run.

The worksheet outputs at the system level of program execution provide next higher assembly effects at the two levels of hardware indenture above the one at which failure has been postulated. The program does not directly provide failure effects at the system level for each postulated failure, although this information can be directly

obtained within the report set and is easily traceable. This is not actually a program limitation per se, but reflects the judgment of the program development engineers that effects at the two nearest levels of hardware indenture being available on one sheet was preferable to one level of hardware indenture effects and system level effects.

SECTION 8

RECOMMENDATIONS FOR FURTHER STUDY

The advanced matrix technique provides a methodology which ensures maximum usability of FMEA results while minimizing the overall clerical workload imposed on the analyst. The technique has not, however, solved all the technical difficulties which currently exist for FMEA. This creates a need for further refinements in FMEA technology to assure that the analysis remains viable for hardware using modern technology. The specific recommendations for further study fall into three categories. The area of components remains unresolved with respect to failure modes and their associated rates of occurrence. The technical approach which is needed to do detailed FMEAs for software and for microprocessor circuitry at the piece part level of detail is undetermined. Additionally, the topic of cost-effective automated tools needs to be reviewed periodically to identify those automation tools which have become cost-effective due to changes in technology.

8.1 COMPONENTS

The recommended study effort for components divides into two categories of effort similar to those used during this study. The collection of failure mode data for high usage piece-parts (eg. resistors, capacitors, etc.) is possible and may be desirable if numerical accuracy in criticality analysis is considered sufficiently important. Further study of the types of complex microelectronic device failures being experienced by industry and Government may be needed. The lack of adequate data on complex microelectronic device failures is a limiting factor for piece-part FMEAs.

8.1.1 HIGH-USAGE PIECE-PARTS

The development of a standard listing of potential failure modes for high usage piece-parts does not represent an overwhelming technical challenge. The primary effort would be one of data collection. The data collection could be accomplished by requiring appropriate reports on several large Government programs or by initiating special data collection efforts at U.S. military depot maintenance locations. This data, once

compiled, should provide an accurate listing of the various types of failures being experienced by each component type. This information could then be used to provide the FMEA engineer with the appropriate failure modes to consider when performing the analysis.

The identification of the appropriate rates of occurrence for the various failure modes of high usage components is possible but may not be achievable within a cost-benefit ratio which is attractive. The establishment of the rates of occurrence for each identified failure mode will require a large data base. The data base required may equal or exceed in size the data base used to establish the failure rates and models used in MIL-HDBK-217.

The relative frequency of occurrence of individual component failure modes needs to be identified to ensure numerical accuracy for criticality analysis at the piece-part level. The primary use of the data is to identify the hazard level of single point, piece-part failures which cannot be designed out. Correct assessment of the hazard level requires that failure mode occurrence rates be known and that the rates accurately reflect the final equipment use environment. This requires that the relative frequencies assigned be based on field experience instead of factory data unless the factory data can be shown to have a one-to-one correspondence with the field information. The majority of factory data available does not have this one-to-one correspondence.

The available factory data falls into several categories. Most of this data cannot be used to determine the relative failure mode occurrence rate with the accuracy desired. Typical failure mode data available includes:

- Component Manufacturers
 - Initial lot rejection results
 - Lot rejection results during any screening
- Equipment Manufacturers
 - Incoming inspection reject results
 - Component screening reject results
 - Failure information from equipment subassembly
 - Failure information from equipment burn-in
 - Failure information from final equipment acceptance tests
 - Failure information from production reliability testing.

The total amount of component failure mode data which could be derived from these sources is potentially adequate to allow determination of the relative frequency of each failure mode. But this will require a substantial expenditure of time and cost to collect the data. Additionally, the data does not necessarily correlate well to the use environment. The failure mode data gathered during the time frame up to and including equipment burn-in is likely to be biased. The equipment and components are deliberately subjected to environmental screening designed to detect and cause prominent potential failure modes to occur during this period. This results in failure mode information measuring the efficiency of the screening imposed with respect to a given component failure mode being provided rather than data on what should be expected from fielded equipment. This data is probably adequate to determine which failure modes are possible, but is not adequate to determine their appropriate rates of occurrence.

The only factory data which can be expected to correlate well with fielded equipment is the data collected from production reliability testing. This data, while relevant to expected field data, is not necessarily sufficient to provide the large data base needed to determine the appropriate rates of occurrence accurately. There appears to be a need for a data source, based on large numbers of deployed equipment, which provides piece-part failure mode data. The depot maintenance facilities of the U.S. military organizations do not currently provide the required level of detail. A data collection effort started at the U.S. military depot maintenance facilities could, however, provide the needed data.

The collection of an adequate amount of data would allow the determination of appropriate rates of occurrence for the various failure modes. The cost would probably be prohibitively high.

8.1.2 COMPLEX MICROCIRCUITS

For piece-part FMEA, the appropriate failure modes and rates of occurrence for complex microelectronic devices remains undetermined. The primary problem is that the analyst is without guidance as to the failure modes which should be considered during the analysis. The lack of such guidance effectively precludes meaningful analysis at the piece-part level of circuitry employing complex microelectronic devices. This is not necessarily a significant limitation to the value and accuracy of the analysis if all the potential types of failure occurrences are identified and analyzed at a higher level of

hardware indenture. The performance of an FMEA analysis at a level of hardware indenture above the piece-part level is somewhat more difficult to review for thoroughness and accuracy, but the overall expense of the analysis should be somewhat less than the cost of the same analysis at the piece-part level of indenture.

The problems inherent in identifying and categorizing the failure modes of complex microelectronic devices are discussed in Section 3.1. These difficulties should not preclude periodic efforts to obtain data on the failures of complex microelectronic devices. The expanding use of these devices in an ever increasing number and type of products may eventually allow the proper failure modes to be established in a meaningful way. The use of various types of complex microelectronic devices by the automotive industry may provide a data base which is adequately large for the purpose of identifying appropriate failure modes. A periodic investigation into the current availability of data sources should be considered.

8.2 FMEA TECHNIQUES

The advanced matrix FMEA technique provides a framework for performing and recording the circuit analysis required as a part of the FMEA process. It does not, however, resolve two technical issues which are potentially important with respect to the performance of the FMEA. The recommended means for treating complex microelectronic device based circuitry need to be expanded if piece-part analysis of such circuitry is to be considered viable. Additionally, the methods to be used in assessing the impact of software and/or firmware failures within the FMEA process need to be investigated.

The development of techniques to assess the piece-part failure effects within circuitry employing complex microelectronic devices needs to be pursued if piece-part level analysis is to be valid. The initial problem is that the failure modes of these devices are not defined. Defining and categorizing these failure modes is necessary prior to the development of an accurate methodology to assess their failure effects within equipment. The recommended study effort to define these failure modes is described in Section 4.1.2. Once the appropriate failure effects have been determined, the methodology for an efficient and effective analysis of these failure modes needs to be developed.

Modern electronic equipment increasingly utilizes microprocessor-based control. This results in the impact of any failure being a function of both the hardware and the software design and implementation. Therefore the problem of software failure may need to be considered as a part of the FMEA. The techniques necessary to allow software FMEA assessment need to be developed if FMEA is to remain a valid and valuable tool for electronic equipment. There is a need for extensive work in the area of software/firmware failure analysis and the application of that analysis to the FMEA process.

8.3 FMEA AUTOMATION

This study has concluded that the standardization and automation of circuit analysis for FMEA in a manner similar to that used for reliability predictions in MIL-HDBK-217 is not feasible. The lack of ability to provide this type of standardization is expected to continue indefinitely. The validity of the study conclusion, that the development of one integrated, comprehensive circuit analysis tool for FMEA use is not feasible, may change as the availability of computer resources and analysis tools evolves. The issue of developing a cost-saving circuit analysis tool which is adequately fast and inexpensive, should be investigated periodically as electronic and computer technologies evolve.

REFERENCES

- 1 Barlow, R.E. et al; Introduction to Fault Tree Analysis; University of California, Berkeley, December 1973 (AD 774072).
- 2 Rasmuson, D.M., et al; Common Cause Failure Analysis Techniques: A Review and Comparative Evaluation; EG&G. Idaho, September 1979 (TREE-1349).
- 3 Yellman, T.W.; Event Sequence Analysis versus the Fault Tree; 1981 Proceedings, Annual Reliability and Maintainability Symposium.
- 4 Yellman, T.W.; Event Sequence Analysis; 1975 Proceedings, Annual Reliability and Maintainability Symposium.
- 5 Perason, K.L., Babin, R.S.; Integrated Reliability and Safety Analysis of the DC-10 All Weather Landing System; 1973 Proceedings, Annual Reliability and Maintainability Symposium.
- 6 Bjoro, E.G.; Safety Analysis of an Advanced Energy System Facility; 1982 Proceedings, Annual Reliability and Maintainability Symposium.
- 7 Lance, J.R., Mutone, G.A., Bjoro, E.G.; Safety Analysis of an Advanced Energy System Facility; 1980 Proceedings, Annual Reliability and Maintainability Symposium.
- 8 Hedin, F., Le Coquiec, A., LeFloch, C., Llory, M., Villemeur, A.; The Failure Combination Method; 1981 Proceedings, Annual Reliability and Maintainability Symposium.
- 9 Edwards, G.W.; Fault Tolerance Analysis for STS Payloads; 1982 Proceedings, Annual Reliability and Maintainability Symposium.
- 10 Wild, A.; Simple Fault Tree Handling System for Safety Analysis of Nuclear Power Plants; 1981 Proceedings, Annual Reliability and Maintainability Symposium.
- 11 Magee, D., Refsum, A.; Resin, A Desktop-Computer Program for Finding Cut-Sets; IEEE Transactions on Reliability, Vol. R-30, No. 5, December 1981.
- 12 Bass, L., Wynholds, N.W., Porterfield, W.R.; Fault Tree Graphics; 1975 Proceedings, Annual Reliability and Maintainability Symposium.
- 13 Pande, P.K. et al; Computerized Fault Tree Analysis; TREEL and MISCUP; University of California, Berkeley, April 1975 (AD-A010146).
- 14 Fussell, J.B.; Henry, E.B., Marshal, N.H.; MOCUS-A Computer Program to Obtain Minimal Sets From Fault Trees; Aerojet Nuclear Company, August 1974 (ANCR-1156).

- 15 Barbour, G.L.; Failure Modes and Effects Analysis by Matrix Methods; 1977 Proceedings, Annual Reliability and Maintainability Symposium.
- 16 Legg, J.M.; Computerized Approach for Matrix-Form FMEA; IEEE Transactions on Reliability, Vol. R-27, No. 4, October 1978.
- 17 Legg, J.M.; Fume Computer Users Documentation; NAPS Document Number 03247, April 1978.
- 18 Pliska, T.F., et al; Maintainability Prediction and Analysis Study; Hughes Aircraft Company, July 1978 (AD/A-059753).
- 19 Herrin, S.A.; Maintainability Applications Using the Matrix FMEA Technique; IEEE Transactions on Reliability, Vol. R-30, No. 3, August 1981.
- 20 Conley, G.A.; Digital System Diagnostics - Design/Evaluation; 1980 Proceedings, Annual Reliability and Maintainability Symposium.
- 21 Kenyon, R.L., Newell, R.J.; FMEA Technique for Microcomputer Assemblies; 1980 Proceedings, Annual Reliability and Maintainability Symposium.
- 22 Bertdino, L., Grefsrud, L.E.; Failure Analysis of Digital Systems Using Simulation; 1977 Proceedings, Annual Reliability and Maintainability Symposium.
- 23 AMCP-706-196, Engineering Design Handbook, Design for Reliability; Department of the Army, January 1976.

MISSION of Rome Air Development Center

RADC plans and executes research, development, test and selected acquisition programs in support of Command, Control, Communications and Intelligence (C³I) activities. Technical and engineering support within areas of technical competence is provided to ESD Program Offices (POs) and other ESD elements. The principal technical mission areas are communications, electromagnetic guidance and control, surveillance of ground and aerospace objects, intelligence data collection and handling, information system technology, ionospheric propagation, solid state sciences, microwave physics and electronic reliability, maintainability and compatibility.

END

FILMED

7-85

DTIC