

2

AD-A161 667



F100 FUEL SAMPLING ANALYSIS

L. Q. Maurice
Fuels Branch
Fuels and Lubrication Division

September 1985

Final Report for Period May 1983 - April 1984

Approved for Public Release; Distribution Unlimited.

DTIC FILE COPY

DTIC
SELECTED
NOV 27 1985
S D


AERO PROPULSION LABORATORY
AIR FORCE WRIGHT AERONAUTICAL LABORATORIES
AIR FORCE SYSTEMS COMMAND
WRIGHT-PATTERSON AIR FORCE BASE, OHIO 45433-6563

NOTICE


When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data, is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture use, or sell any patented invention that may in any way be related thereto.

This report has been reviewed by the Office of Public Affairs (ASD/PA) and is releasable to the National Technical Information Service (NTIS). At NTIS, it will be available to the general public, including foreign nations.

This technical report has been reviewed and is approved for publication.




LOURDES Q. MAURICE
Fuels Branch
Fuels and Lubrication Division
Aero Propulsion Laboratory



ARTHUR V. CHURCHILL, Chief
Fuels Branch
Fuels and Lubrication Division
Aero Propulsion Laboratory

FOR THE COMMANDER



ROBERT D. SHERRILL, Chief
Fuels and Lubrication Division
Aero Propulsion Laboratory

"If your address has changed, if you wish to be removed from our mailing list, or if the addressee is no longer employed by your organization, please notify AFWAL/POSF, Wright-Patterson AFB OH 45433-6563 to help us maintain a current mailing list."

Copies of this report should not be returned unless return is required by security considerations, contractual obligations, or notice on a specific document.

AD-A161 667

REPORT DOCUMENTATION PAGE

1a REPORT SECURITY CLASSIFICATION UNCLASSIFIED		1b RESTRICTIVE MARKINGS			
2a SECURITY CLASSIFICATION AUTHORITY		3 DISTRIBUTION/AVAILABILITY OF REPORT Approved for Public Release; Distribution Unlimited.			
2b DECLASSIFICATION/DOWNGRADING SCHEDULE					
4 PERFORMING ORGANIZATION REPORT NUMBER(S)		5. MONITORING ORGANIZATION REPORT NUMBER(S) AFWAL-TR-85-2045			
6a NAME OF PERFORMING ORGANIZATION Aero Propulsion Laboratory USAF	6b. OFFICE SYMBOL (If applicable) AFWAL/POSF	7a. NAME OF MONITORING ORGANIZATION Aero Propulsion Laboratory (AFWAL/POS) Air Force Wright Aeronautical Laboratories (AFSC)			
6c. ADDRESS (City, State and ZIP Code) Wright-Patterson Air Force Base OH 45433- 6563		7b. ADDRESS (City, State and ZIP Code) Wright-Patterson Air Force Base OH 45433- 6563			
8a. NAME OF FUNDING/SPONSORING ORGANIZATION	8b. OFFICE SYMBOL (If applicable)	9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER			
8c. ADDRESS (City, State and ZIP Code)		10. SOURCE OF FUNDING NOS.			
		PROGRAM ELEMENT NO.	PROJECT NO.	TASK NO.	WORK UNIT NO.
11 TITLE (Include Security Classification) F100 Fuel Sampling Analysis		62203F	3048	05	91
12. PERSONAL AUTHOR(S) L.Q. Maurice					
13a TYPE OF REPORT Final Technical Rpt.	13b TIME COVERED FROM May 83 TO Apr 84	14 DATE OF REPORT (Yr., Mo., Day) September 1985	15. PAGE COUNT 136		
16 SUPPLEMENTARY NOTATION (American Society of Testing and Materials)					
17 COSATI CODES			18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUB GR.	Fuels F100 Engine MIL-T-5624L Fuel Speci- Fuel Properties; JP-4 Fuel fication. ASTM Test Methods; Petroleum Fuel; Cavitation ←		
21	04				
21	05				
19. ABSTRACT (Continue on reverse if necessary and identify by block number) Fuel pump cavitation problems experienced with the F100 engine used in the F-15/F-16 aircraft have led to an extensive fuel analysis program to identify fuel properties that might be contributing to fuel pump failures. This report analyzes the chemical and physical properties of twenty-one JP-4 fuel samples obtained from United States Air Force Bases. The fuels analyzed met specifications in all but a few isolated cases, and had no unusual properties. If the fuel used is causing fuel pump failure, it must be the result of a fuel property not being measured. The fuels are as good or better than the specification prescribes. It is concluded that the F100 fuel pump cavitation problems are most likely associated with the mechanical complexity built into the design, rather than the result of the fuel used. <i>Keywords:</i>					
20. DISTRIBUTION/AVAILABILITY OF ABSTRACT UNCLASSIFIED/UNLIMITED <input type="checkbox"/> SAME AS RPT. <input type="checkbox"/> DTIC USERS <input checked="" type="checkbox"/>			21. ABSTRACT SECURITY CLASSIFICATION UNCLASSIFIED		
22a. NAME OF RESPONSIBLE INDIVIDUAL LOURDES Q. MAURICE		22b TELEPHONE NUMBER (Include Area Code) (513) 255-3138	22c. OFFICE SYMBOL AFWAL/POSF		

FOREWORD

This F100 Fuel Samples Analyses program was conducted by the Fuels Branch of the Aero Propulsion Laboratory, Air Force Wright Aeronautical Laboratories, Air Force Systems Command, Wright-Patterson Air Force Base, Ohio. The work was performed under Work Unit 30480591. Ms Lourdes Q. Maurice was the project engineer.

This report presents physical and chemical analyses of aviation turbine fuel used in F100 engines at United States Air Force Bases. Attempts are made to correlate fuel properties to fuel pump cavitation problems.

The author wishes to extend gratitude to Ms Tina Allen and Ms Carole Carter for their assistance in preparing portions of this report. Mr Tim Dues' valuable technical advice is also appreciated. The efforts of the Air Force Quality Control Laboratory, SA-ALC/SFTLA, in providing fuel analysis are also gratefully acknowledged.

Accession For	
NTIS CRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A-1	



TABLE OF CONTENTS

SECTION	PAGE
I INTRODUCTION	1
II BACKGROUND	2
III EXPERIMENTAL/DISCUSSION	7
A. Specification Tests	7
B. Lubricity Test	12
C. Characterization Tests	15
IV CONCLUSIONS	22
V RECOMMENDATIONS	24
APPENDIX A SPECIFICATION ANALYSES	25
APPENDIX B CHARACTERIZATION ANALYSES	60
REFERENCES	124

LIST OF ILLUSTRATIONS

FIGURE		PAGE
1	Lubricity Results	14
A1	Total Acid Number	28
A2	Volume Percent Aromatics	30
A3	Volume Percent Olefins	32
A4	Mercaptan Sulfur	34
A5	Total Sulfur	36
A6	API Gravity	44
A7	Heat of Combustion	48
A8	Smoke Point	50
A9	Hydrogen Content	52
A10	Thermal Stability	55
A11	Existent Gum	57
A12	Fuel System Icing Inhibitor	59
B1-B18	Viscosity vs Temperature Plots	68-85
B19-B20	Thermal Conductivity vs Temperature Plots	88-89
B21-B41	Distillation Curves	92-112

LIST OF TABLES

TABLE		PAGE
1	United States Bases Participating in Fuel Sampling Program	3
2	Results of Questionnaire	4
3	Summary of Specification Test Failures	9
4	Comparison of Average JP-4's	10
5	Lubricity Analyses	13
A1	Saybolt Color Analyses	26
A2	Total Acid Number Analyses	27
A3	Volume Percent Aromatics Analyses	29
A4	Volume Percent Olefins Analyses	31
A5	Mercaptan Sulfur Analyses	33
A6	Total Weight Percent Sulfur Analyses	35
A7	Boiling Range Distribution Specs	37
A8	Simulated Distillation Analyses	38
A9	Vapor Pressure Analyses	42
A10	API Gravity Analyses	43
A11	Freezing Point Analyses	45
A12	Viscosity Analyses	46
A13	Heat of Combustion Analyses	47
A14	Smoke Point Analyses	49
A15	Hydrogen Content Analyses	51
A16	Copper Strip Corrosion Analyses	53
A17	Thermal Stability Analyses	54
A18	Existent Gum Analyses	56
A19	Vol % Fuel System Icing Inhibitor Analyses	58
B1	Physical Properties as a Function of Temperature	60
B2	Comparison of Typical JP-4 and Averaged F100 Samples Vapor Pressure as a Function of Temperature	67
B3	Comparison of Typical JP-4 and Averaged F100 Samples Kinematic Viscosity as a Function of Temperature	86
B4	Comparison of Typical JP-4 and Averaged F100 Samples Density as a Function of Temperature	86
B5	Comparison of Typical JP-4 and Averaged F100 Samples Surface Tension as a Function of Temperature	87
B6	Thermal Conductivity Analyses	87

LIST OF TABLES (Concluded)

TABLE		PAGE
B7	Comparison of Typical JP-4 and Averaged F100 Samples Thermal Conductivity	89
B8	Specific Heat Analyses	90
B9	Comparison of Typical JP-4 and Averaged F100 Samples Specific Heat as a Function of Temperature	91
B10-B30	Distillation Analyses	92-112
B31	Hydrocarbon Type Analyses	113
B32	Correlations Between Distillation Data and Hydrocarbon Type Analyses	118
B33	GC Normal Paraffin Analyses	119

LIST OF ABBREVIATIONS

AB	Air Base
AFB	Air Force Base
AFWAL/POSF	Aero Propulsion Laboratory's Fuels Branch
API	American Petroleum Institute
ASD/YZF	Tactical Engines Program Office
ASTM	American Society for Testing and Materials
BOC	Ball-on-Cylinder
$^{\circ}\text{C}$	degrees Celsius
cm	centimeter
CONUS	Continental United States
DFSC	Defense Fuel Supply Center
Δ	Delta, mathematical change
$^{\circ}\text{F}$	degrees Fahrenheit
FIA	Fluorescent Indicator Adsorption
FSII	fuel system icing inhibitor
ft^3	cubic feet
g	grams
GC	gas chromatography
H_2SO_4	sulfuric acid
Hg	mercury
JFTOT	Jet Fuel Thermal Oxidation Tester
kPa	kilo pascal
max	maximum
min	minute
mm	millimeter
NO_x	nitrogen oxides

LIST OF ABBREVIATIONS (Concluded)

P	pressure
PDC	preheater deposit code
%	percent
ppm	part per million
psi	pounds per square inch
rpm	revolution per minute
SA-ALC/SFTLA	Quality Control Laboratory
sec	second
SO ₂	sulfur dioxide
SO ₃	sulfur trioxide
vol %	volume percent
WSD	wear scar diameter
wt %	weight percent

SUMMARY

Fuel pump cavitation problems experienced in the F-15/F-16 aircraft led to the initiation of an intensive effort to analyze fuels used in these aircraft. Twenty-one fuel samples were collected from United States F-15/F-16 Air Force Bases in order to identify any fuel characteristics that could contribute to increased fuel pump cavitation.

The analyses included specification tests, as well as lubricity and special chemical and physical characterization tests.

Only a few fuels failed to meet specifications prescribed by Military Specification MIL-T-5624L. Fuels from Langley Air Force Base and Aviano Air Base did not meet thermal stability specifications. Fuels from Hill Air Force Base and Luke Air Force Base failed Reid vapor pressure tests. The fuel from Tyndall Air Force Base failed the fuel system icing inhibitor (FSII) content test. In addition, seven fuels (Eglin Air Force Base, Camp New Amsterdam Air Base, Zaragoza Air Base, Torrejon Air Base, Osan Air Base, Clark Air Base, and Anderson Air Base) did not meet simulated distillation specifications, although these results were not repeatable.

Thermal stability and FSII failures are not indicative of fuels likely to contribute to fuel pump failure. Simulated distillation and vapor pressure failures are indicative of the volatility of fuels. According to Perry's "Chemical Engineers' Handbook," (Reference 1), a fuel with lower volatility would be theoretically more likely to cause fuel pump cavitation at sea level conditions. However, both tests were conducted in two laboratories, and in no case did a fuel fail twice. Since the failures were not repeatable, for identical samples drawn from different containers, it is reasonable to presume that poor fuel handling techniques resulted in the loss of fuel front end, light boiling constituents. This in turn would lower vapor pressure and increase simulated distillation temperatures, as noted.

One of the most critical tests of this program was the lubricity test. Poor lubricity is often associated with fuel pump failure. However, all the fuels analyzed had excellent lubricating qualities.

Chemical and physical characterization test results showed no indication of properties likely to cause fuel pump failure.

Overall, all the fuels analyzed met specifications in all but a few isolated cases, and had no unusual properties. The fuels are as good or better than the specification prescribes. If the fuel is causing a fuel pump problem on the F100 fuel pump, it must be the result of a fuel property not limited by the specification, such as surface tension or viscosity.

It is therefore concluded that the F100 fuel pump cavitation problems are most likely associated with the mechanical complexity built into the design, rather than the result of the fuel used.

SECTION I

INTRODUCTION

This report summarizes the analyses performed on twenty-one fuel samples from F-15 and F-16 bases, and bases that often refuel this aircraft to identify any fuel characteristics that might be contributing to increased fuel pump cavitation and fuel pump failure. The data was collected between May 1983 and May 1984. The report contains five sections.

Section I is the introduction.

Section II is a discussion of the fuel pump cavitation problem and a summary of the samples involved in the analyses.

Section III describes tests performed, and discusses test results.

Section IV summarizes conclusions.

Section V offers recommendations.

SECTION II

BACKGROUND

As a result of fuel pump cavitation problems experienced in the F-15/F-16 aircraft, the Tactical Engines Program Office (ASD/YZF) and the Aero Propulsion Laboratory's Fuels Branch (AFWAL/POSF) jointly initiated a program to analyze aviation fuels used in those aircraft. The objective of the Fuel Analysis Program was to thoroughly analyze fuel samples from all F-16 and F-15 bases, as well as bases that often refuel these aircraft, in order to identify any fuel characteristics that might induce fuel pump cavitation.

The Fuel Analysis Program was divided into two phases. During Phase I, fuel samples provided by 21 Air Force Bases were analyzed, and the results are presented in this report. A list of the bases participating in this phase of the program is shown in Table 1. During Phase II of this program, 16 fuel samples provided by Foreign National bases will be analyzed, and the results will be published under a separate cover.

In order to obtain reliable data from which sound conclusions could be derived, it was necessary to minimize any contamination of the fuel samples, thus several measures were taken to ensure sample purity. AFWAL/POSF provided each Air Force Base with special shipping containers, along with detailed sampling procedures. Each base was also asked to complete a questionnaire providing additional information regarding fuel suppliers, additives, and sampling techniques. This information was requested to possibly provide explanations for any unusual characteristics noted in any of the fuel samples. The results of the questionnaire are tabulated in Table 2.

Each of the participating bases provided two gallons and one pint of fuel sample. The fuel was distributed by AFWAL/POSF to various organizations for detailed analyses. The Quality Control Laboratory, SA-ALC/SFTLA, performed a series of specification tests, Monsanto Research Corporation under Air Force contract was responsible for several characterization tests, and AFWAL/POSF performed lubricity as well as characterization tests.

TABLE 1

UNITED STATES BASES PARTICIPATING IN FUEL SAMPLING PROGRAM

BASE	FUEL TYPE	SAMPLE CODE
West		
Hill AFB (UT)	JP-4	83-POSF-1006
Luke AFB (AZ)	JP-4	83-POSF-1073
Holloman AFB (NM)	JP-4	83-POSF-1084
Elmendorf AFB (AK)	JP-4	83-POSF-1085
Edwards AFB (CA)	JP-4	83-POSF-1086
Nellis AFB (NV)	JP-4	83-POSF-1158
Southeast		
Langley AFB (VA)	JP-4	83-POSF-1074, 83-POSF-1350
Tyndall AFB (FL)	JP-4	83-POSF-1075
MacDill AFB (FL)	JP-4	83-POSF-1076
Shaw AFB (SC)	JP-4	83-POSF-1077
Eglin AFB (FL)	JP-4	83-POSF-1273
Europe		
Hahn AB (Germany)	JP-4	83-POSF-1157
Birzburg AB (Germany)	JP-4	83-POSF-1159
Aviano AB (Italy)	JP-4	83-POSF-1253, 83-POSF-1298
Zaragoza AB (Spain)	JP-4	83-POSF-1259
Camp New Amsterdam (The Netherlands)	JP-4	83-POSF-1283
Torrejon AB (Spain)	JP-4	83-POSF-1287
Far East		
Osan AB (Korea)	JP-4	83-POSF-1181
Clark AB (Philippines)	JP-4	83-POSF-1272
Anderson AB (Guam)	JP-4	83-POSF-1284
Kadena AB (Japan)	JP-4	83-POSF-1297

TABLE 2
RESULTS OF QUESTIONNAIRE

BASE	SAMPLING PROCEDURE	SUPPLIERS	ADDITIVES USED
Hill	Samples drawn from a sampling point between a truck fillstand and a filter separator.	American Oil Co. Chevron Oil Co. Phillips Oil Co.	No information available
Luke	Samples drawn from quick disconnect with metal flex hose.	Southern Pacific Pipe-Line Co.	No information available
Holloman	Samples drawn from sample connection downstream of truck fillstand underflow.	Standard Transpipe Corp.	FSII ASA-3 STADIS 450 conductivity additive Corrosion inhibitor
Elmendorf	Rotated 4,000 gallons thru bottom loader and samples were taken on single point nozzle under full flow conditions thru the bypass line on the in-line sampler.	DFSC Anchorage Terminal, DIO 172nd INF BDE Petroleum Division	No information available
Edwards	Samples drawn from sampling point downstream of a filter separator.	Mobil Oil Co., CA Powine Oil Co., CA	FSII Conductivity
Nellis	Samples drawn from R-9 refueler thru manhole cover.	Calnev Pipeline Co.	STADIS 450 FSII
Langley (1074)	Rotated 500 gallons, then sample drawn from regular in-line sampling point.	Government owned stock	No information available
(1350)	Used in-line sampler at sampling point on R-9 refueler.	Government owned stock	No information available

TABLE 2 (Cont'd)
RESULTS OF QUESTIONNAIRE

BASE	SAMPLING PROCEDURE	SUPPLIERS	ADDITIVES USED
Tyndall	Samples drawn from an R-9 refueler by using sip nozzle hooked to bottom loader at full flow conditions.	No information available	No information available
MacDill	Samples drawn through quick disconnect coupler on filter separator #4 in pumphouse W.	Spartan Oil Co.	ASA-3 STADIS 450
Shaw	Samples drawn from R-9 refueler while the unit was being recirculated through the in-line sampler connection in the can box.	Continental Service Co.	No information available
Eglin	Samples drawn from refueling unit using in-line sampler with continuous flow.	Chevron USA, Inc.	ASA-3 Conductivity Additive FSII
Hahn	Samples drawn with top half of in-line sampler, downstream on a hydrant filter separator.	NATO Pipeline	No information available
Bitburg	Samples drawn from Type IV hydrant downstream of filter separator.	NATO Pipeline	No information available
Aviano (1253)	Samples drawn from fillstand #1, area F bulk storage. Sample was obtained from a 1/2 inch pipe welded to the side of the fillstand pipe.	NATO Pipeline	FSII
(1298)	Samples drawn from fillstand #2, area F bulk storage. Sample was obtained from a 1/2 inch pipe welded to the side of the fillstand pipe.	NATO Pipeline	FSII ASA-3

TABLE 2 (Concluded)
RESULTS OF QUESTIONNAIRE

BASE	SAMPLING PROCEDURE	SUPPLIERS	ADDITIVES USED
Zaragoza	Samples drawn from hydrant cart thru the in-line sampler.	Campas Fuels (National Fuel Co.)	ASA-3
Camp New Amsterdam	Samples drawn from unit 81L-167 using the metal portion of the in-line sampler while the fuel was rotating thru the unit.	Royal Netherlands Air Force	ASA-3
Torrejon	Samples drawn from hydrant section.	Campas	ASA-3
Osan	Samples drawn using the top portion of the in-line sampler with the valve on the test position allowing fuel to flow directly into the can.	United States Army Petroleum Distributions Systems Korea (USA PCSK)	ASA-3 FSII
Clark	Samples drawn from the sampling stub on unit 81L337 using the top portion of the in-line sampler in the "test" position.	Sea Lift Command through Subic Naval Station	ASA-3 STADIS 450
Anderson	Fuel samples drawn from refueler 756-676 sample cock downstream of filter separator using the bypass hose of the in-line sampler.	Naval Supply Depot Guam, M.I.	FSII ASA-3
Kadena	Fuel samples drawn using the in-line sampler downstream of the filter separator on refueling unit 81L-148 R-9.	US Army Petroleum System, Okinawa Japan	STADIS 450

SECTION III

EXPERIMENTAL/DISCUSSION

A. SPECIFICATION TESTS

The Air Force Quality Control Laboratory (SA-ALC/SFTLA, Wright-Patterson Air Force Base, Ohio) performed a series of 19 specification tests on all 21 fuel samples. The results of these tests can be found in Appendix A.

All specification tests were performed using American Society of Testing & Materials (ASTM) test methods and applicable Federal Test Methods prescribed by Military Specification MIL-T-5624L for JP-4. These test methods are documented in Reference 2.

Results of these tests were compared to the physical and chemical requirements prescribed by MIL-T-5624L. With a few minor exceptions, all fuel samples analyzed were well within the specification limits.

Two fuel samples showed thermal stability problems. The sample from Langley AFB passed the thermal stability test (Jet Fuel Thermal Oxidation Tester or JFTOT) at the Air Force Quality Control Lab, but failed it at Pratt & Whitney Aircraft with a Preheater Deposit Code (PDC) of 3. The Fuels Branch repeated the analysis and also failed the fuel with a PDC of 3. A second fuel sample was requested from Langley AFB for further testing, and this time the sample passed with $\Delta P=0$ and PDC=1.

The Aviano Air Base sample failed JFTOT at SFTLA and Pratt & Whitney Aircraft. The second Aviano sample requested also failed with a PDC of 4.

It is important to note that the Aviano sample had a worse copper strip corrosion than any of the other samples (1B). Also, both the Langley and Aviano samples had higher than typical existent gum (1.0 mg/100 ml and 1.2 mg/100 ml, respectively). These properties confirm that these two samples could have a thermal stability problem.

It appears that the thermal stability failure of the Langley fuel sample was an isolated incident, since the second fuel sample from that base met specification. The failure might have been caused by poor sampling techniques. However, the Aviano fuel appears to have consistently poor thermal stability qualities.

Two fuel samples failed the Reid Vapor Pressure Test. The fuel from Hill AFB had a vapor pressure of 1.7 psi and the sample from Luke AFB had a vapor pressure of 1.5. The specification limits vapor pressure test failures among a widespread sample of fuels from the field. It is very difficult for a technician in the flight line to follow sampling procedures precisely, thus the loss of light end components is common. Furthermore, the fuel samples analyzed by Monsanto from a different container showed no vapor pressure problems.

The fuel from Tyndall AFB failed the fuel system icing inhibitor (FSII) test. The specification limits FSII to 0.15 vol % and the fuel had an FSII content of 0.17 vol %.

Two fuel samples failed the 90% recovered simulated distillation test at Monsanto Research Corp., those from Eglin AFB, and Camp New Amsterdam AB. Seven fuels also failed the end point specification, those from Eglin AFB, Zaragoza AB, Camp New Amsterdam AB, Torrejon AB, Osan AB, Clark AB and Anderson AB.

However, all these fuels met simulated distillation specifications at the Air Force Quality Control Lab. It is reasonable to assume that the failures were caused by the loss of the fuel's front end components from the field to the laboratory. The Quality Control lab analyzed samples obtained directly from the field. Monsanto's samples were drawn from the container received from the field by the Fuels Branch; thus they had a better chance to lose highly volatile front end components.

A summary of specification test failures is found in Table 3.

Results of specification tests were also compared to the average specification properties of JP-4 determined in 1980/81 (Reference 3). The average properties of the F100 study JP-4s are compared to the 1980/81 average JP-4 in Table 4.

Out of 13 properties, four worsened, five improved, and four remained unchanged. The four worsened properties were aromatic content, vapor pressure, smoke point, and hydrogen content. The average aromatic content of the F100 samples was higher than 1980/81 JP-4. This is a negative trend because aromatics tend to increase visible smoke and contribute to shorter life spans for combustor liners.

The average vapor pressure of the F100 fuels was considerably lower than the average vapor pressure of 1980/81 JP-4. Fuels with low vapor pressure do not vaporize

TABLE 3
SUMMARY OF SPECIFICATION TEST FAILURES

Test	Spec Limit	Sample Code	Value of Property
Thermal Stability (ASTM D 3241)	$\Delta P=25\text{mm Hg max}$ PDC < 3	Langley 1 ⁽¹⁾	1 PDC
"	"	Langley 2 ⁽²⁾	3 PDC
"	"	Langley 1 ⁽³⁾	3 PDC
"	"	Langley 2 ⁽³⁾	1 PDC
"	"	Aviano 1 ⁽¹⁾	4
"	"	Aviano 1 ⁽²⁾	4
"	"	Aviano 2 ⁽³⁾	4
Reid Vapor Pressure (ASTM D 323)	2 psi min 3 psi max	Hill	1.7 psi
"	"	Luke	1.5 psi
Fuel System Icing Inhibitor (FSID 791 5327)	0.10 vol % min 0.15 vol % max	Tyndall	0.17 vol %
Simulated Distillation ASTM D 2887 End Point 90% Recovered	245°C	Eglin ⁽⁴⁾	252°C
"	"	Zaragoza ⁽⁴⁾	252°C
Simulated Distillation ASTM D 2887	320°C	Eglin ⁽⁴⁾	333°C
"	"	Zaragoza ⁽⁴⁾	370°C
"	"	Camp New Amsterdam ⁽⁴⁾	333°C
"	"	Torrejon ⁽⁴⁾	330°C
"	"	Osan ⁽⁴⁾	330°C
"	"	Clark ⁽⁴⁾	342°C
"	"	Anderson ⁽⁴⁾	334°C

- (1) Values determined by the Air Force Quality Control Laboratory.
(2) Values determined by Pratt & Whitney Aircraft.
(3) Values determined by the Fuels Branch.
(4) Values determined by Monsanto Research Corporation.

TABLE 4
COMPARISON OF AVERAGE JP-4s

Property	1980/81 Study Average JP-4	F100 Study Average JP-4
Total Acid Number	0.005 mg KOH/g	0.005 mg KOH/g
Vol % Aromatics	12.6	14.0
Vol % Olefins	0.8	0.7
Wt % Mercaptan Sulfur	0.0004	0.0002
Wt % Total Sulfur	0.04	0.02
Vapor Pressure	2.6	2.29
API Gravity	54.2	53.9
Net Heat of Combustion	43.5	43.5
Smoke Point	27	25
Hydrogen Content	14.3	14.2
Thermal Stability, PDC	< 3	< 2
Thermal Stability, ΔP	1mm Hg	2mm Hg
Existent Gum	0.8 mg/100 ml	0.4 mg/100 ml
Vol % FSII	0.13	0.13

readily, which could lead to difficult starting at low temperatures. Also, fuel vapor pressure is inversely proportional to fuel pump cavitation. Thus, lower fuel vapor pressures would tend to increase fuel pump cavitation.

Smoke point and hydrogen content are closely related, and they were lower which is an unfavorable trend. High hydrogen content/smoke point fuels have good combustion properties, lead to longer combustor life and result in less smoke emissions.

The five improved properties were: volume percent olefins, weight percent total sulfur and mercaptan sulfur, API gravity and existent gum.

The samples analyzed had lower than 1980/81 average JP-4 olefin content. Lower olefins will reduce thermal stability problems caused by the thermal instability and gum forming tendencies of olefins.

The mercaptan sulfur of the F100 samples was considerably lower. This is a favorable trend because some sulfur compounds attack elastomers, and solubilize trace metals such as copper, which can cause thermal stability problems.

The lower sulfur content of the F100 fuels is also favorable because when sulfur is combusted, SO_2 and SO_3 are formed, which corrode certain fuel system components. Water vapor is also a combustion product, and it may combine with SO_2 and SO_3 to yield H_2SO_4 , which attacks the turbine blades of an engine. In addition, sulfur contributes to thermal stability problems.

The increase in API gravity of the F100 fuel samples is a positive trend, because it marks a tendency towards denser fuels. This increases volumetric heat of combustion, and in turn increased volume-limited aircraft range.

Large quantities of gum in a fuel are indicative of contamination of higher boiling oils or particulate matter. Turbine engines that use prevaporizer fuel tubes are known to be sensitive to existent gum. Thus, the lower average existent gum found in the F100 fuels is a definite improvement.

The four properties that remained unchanged were thermal stability, total acid number, net heat of combustion and volume percent FSII.

B. LUBRICITY TEST

This test evaluates the lubricity characteristics of a fuel sample. In recent years, turbine fuel specifications have become increasingly restrictive, in particular with respect to thermal stability and cleanliness. The demand for turbine fuel has also increased, and new processes have been introduced to satisfy both demand and quality. However, production of cleaner fuels has tended to remove some of the compounds that make fuel a good lubricating agent. Fuel is depended upon to lubricate certain components of the fuel system, particularly fuel pumps and fuel controls. Poor lubricity can affect the life cycle of these components, and even result in fuel pump failure.

The lubricity of the fuel samples was evaluated using the modified Furey Ball-on-Cylinder (BOC) Test Rig (Reference 4). The test consists of contacting a stationary, perpendicular loaded test ball with a rotating cylinder. The cylinder and ball are located in a rectangular test cell, and the cylinder is immersed approximately 1/3 in the test fluid. The remaining portion of the cylinder and the ball are exposed to a controlled environment which consists of air having a moisture content of less than 20 ppm. The standard operating conditions for the test are: 1000 gm load, 240 rpm cylinder speed, dry air environment with 0.5 ft³/min indirect purging and 77°F fuel temperature. The lubricity of the fuel is evaluated by measuring the wear scar on the ball generated by the rotating cylinder. Based on data obtained for fuel samples known to be good lubricating agents, a fuel's lubricity is considered acceptable if the average diameter of the wear scar is less than .45 mm.


The results of lubricity tests for the 21 fuel samples analyzed are presented in Table 5. A fuel lubricity problem would be one of the most likely ways in which a fuel would cause fuel pump failure, thus these data were thoroughly studied.

Besides testing each fuel sample in duplicate to ensure accurate results, a "standard" sample known to have good lubricating qualities was tested along with each fuel sample to qualify the acceptability of the test sample.

The wear scars of the 21 F100 fuel samples ranged between 0.29 mm and 0.44 mm, with an average wear scar of 0.38 mm diameter. All wear scars were within the acceptability criteria, as well as smaller than wear scars generated using "standard" samples as illustrated in Figure 1. The fuels from CONUS Western bases had lower wear scar diameters (0.36 mm average). However, no unusual fuel lubricity characteristics that might cause fuel pump problems were observed in any of the samples.

TABLE 5
LUBRICITY ANALYSES

FUEL SAMPLE	AVERAGE WSD (mm)
Hill	0.38
Luke	0.30
Holloman	0.32
Elmendorf	0.40
Edwards	0.37
Nellis	0.38
Langley	0.36
Tyndall	0.43
MacDill	0.43
Shaw	0.35
Eglin	0.43
Hahn	0.40
Bitburg	0.39
Aviano	0.44
Zaragoza	0.37
Camp New Amsterdam	0.39
Torrejon	0.39
Osan	0.38
Clark	0.39
Anderson	0.35
Kadena	0.37



FUEL SAMPLE	AVERAGE WSD (mm)
HILL	0.38
LUKE	0.30
HOLLOMAN	0.32
ELMENDORF	0.40
EDWARDS	0.37
NELLIS	0.38
LANGLEY	0.36
TYNDALL	0.43
MACDILL	0.43
SHAW	0.35
EGLIN	0.43
HAHN	0.40
BITBURG	0.39
AVIANO	0.44
ZARAGOZA	0.37
CAMP NEW AMSTERDAM	0.39
TORREJON	0.39
OSAN	0.38
CLARK	0.39
ANDERSON	0.35
KADENA	0.37

Figure 1. Lubricity Results

C. CHARACTERIZATION TESTS

1. Description: Monsanto Research Corporation performed a series of characterization tests (Reference 5). These tests were not necessarily specification tests, and tended to provide more information about the fuel samples than simple specification tests. The tests performed were:

Physical properties as a function of temperature:

True Vapor Pressure

Kinematic Viscosity

Density

Surface Tension

Simulated Distillation by ASTM D 2887

Hydrocarbon Type by ASTM D 2789-71 and Monsanto 21-PQ-38-36

Gross Heat of Combustion by ASTM D 240

Thermal Conductivity

Specific Heat

a. Physical Properties as a Function of Temperature

The physical properties specification tests performed by the Quality Control Laboratory are generally performed at one specific condition and the results are evaluated according to the pass/fail criteria provided by MIL-T-5624L. The tests show whether fuel samples pass the specification criteria, but they do not show the behavior of the fuel over a wide temperature range. The fuels analyzed for the F100 sampling program were suspected of possibly contributing to pump failure, and this it was desired to study the physical properties of the samples over a wide temperature range to possibly identify any fuel characteristics that might contribute to fuel pump failure.

The true vapor pressure was measured using ASTM D 2551. The method consists of introducing a fuel sample of known volume into an evacuated, temperature controlled vessel. The pressure in the chamber is read with a mercury manometer attached to the apparatus. The pressure read is the sum of the vapor pressure and the partial pressure due to any dissolved air in the sample; therefore, the vapor pressure measurement is preceded by an operation to degas the sample. This operation

does not lead to any vapor losses. The vapor pressure was measured at 32, 70, 100 and 140°F and fitted to an equation of the form:

$$\log P = A - B/T$$

where:

P = vapor pressure

T = temperature

A, B = constants

The equation can then be used to determine vapor pressures at various temperatures.

The kinematic viscosity of the various samples was measured at -20, -4, 32, 70, 100 and 140°F using ASTM D 445. The test method has been previously described in Reference 2. Viscosity was measured at the various temperatures and the results were plotted on standard ASTM viscosity temperature charts which serve to determine kinematic viscosities at other temperatures.

The density of the fuel samples was measured at -20, 32, 59, 70, 100 and 140°F using a pyrex dilatometer. The method consists of introducing a fuel sample into a dilatometer, then bringing the sample up to the desired temperature by immersing the dilatometer in a constant temperature bath. After temperature equilibrium was established, the dilatometer scale was read with a cathemometer (Reference 5). The density was then plotted as a function of temperature.

The surface tension was measured at 32, 70, 100 and 140°F using the capillary rise method (Reference 5). The surface tension was calculated using the following expression:

$$\frac{rhdg}{2\cos\theta}$$

d = density of liquid, g/cm³

h = height of the column of liquid, cm

g = acceleration of gravity, cm/sec²

r = radius of the capillary, cm

θ = contact angle, degrees

The data obtained was plotted to obtain a relationship between surface tension and temperature.

b. Simulated Distillation

The boiling range distribution was determined by Monsanto Research Corporation using ASTM D 2887. The significance of this test was previously discussed in this report. In addition to results for specification temperatures, Monsanto provided detailed analysis of the entire boiling range.

c. Hydrocarbon Type Analysis

This test identifies hydrocarbon types in fuel samples. Information provided includes weight percent paraffins, cycloparaffins, dicycloparaffins, alkylbenzenes, indans, and tetralins, indenes and dihydronaphthalenes, and naphthalenes. Paraffins are the most chemically inert compounds present in turbine engine fuel, thus they are more stable in storage and under thermal stresses. These compounds also have a minimum solvent and swelling effect on elastomers. Cycloparaffins are similar to straight chained paraffins, although their properties are slightly less desirable. Aromatics do have a high heating content per unit volume, but they do not burn cleanly and have a high solvent and swelling effect on elastomers. Hydrocarbon types were determined by mass spectrometry using both a modification of ASTM 2789 (Reference 2) and Monsanto 21-PQ-38-63 (Reference 6). Both of these analyses are based on summing characteristic mass spectral lines for each compound type, and constructing a matrix of n equations relating each of the n hydrocarbon types to the summed peak values. The simultaneous equations are then solved to provide a quantitative measure of each compound type present in the fuel sample.

d. Electrical and Thermal Conductivity

Monsanto Research Corporation measured the electrical conductivity of fuel samples. Electrical conductivity is essential to allow any static charge that may build up within the fuel to rapidly bleed to ground. However, electrical conductivity must be controlled because an excessive amount will affect the accuracy of some fuel level indicators.

The thermal conductivity of six of the 21 fuel samples was determined using a transient hot wire apparatus built by Monsanto Research Corporation. The method consists of applying a constant heating current to a resistant wire immersed in fuel. The change in temperature of the wire is obtained from the voltage drop across the wire and known resistance-temperature characteristics (Reference 5). The remaining 15 fuel samples were not analyzed by this method because the procedure is rather lengthy and time consuming and does not provide information that is vital to identify fuel properties that may cause pump cavitation.

e. Specific Heat

The specific heat of the samples was measured with a Perkin-Elmer differential scanning calorimeter, Model DSC-1. The calorimeter is used to measure the heat flow into a sample whose temperature is linearly programmed. The specific heat is calculated by comparing the rate of heat from the sample with the rate of heat flow from a standard whose specific heat is known.

The specific heat of the fuel samples was determined by this test. The heat capacity of a fuel is directly proportional to the types of hydrocarbons that make up the fuel. The variations in specific heat between different fuels is usually in the range of $\pm 7\%$, which could lead to a difference of 30 to 40°C in peak temperature of fuel emerging from the fuel system heat exchangers. Thus, a higher specific heat will result in improved thermal stability (Reference 6).

2. Results: Characterization test results can be found in Appendix B.

a. Physical Properties

(1) Vapor Pressure

Monsanto evaluated vapor pressure as a function of temperature for all 21 fuel samples. The vapor pressure of the samples as a function of temperature was compared to the typical vapor pressure of JP-4 as a function of temperature (Reference 7). Monsanto reported vapor pressure data in units of mm Hg, while the typical JP-4 data was available in KPa. For easy comparison, the typical vapor pressures of JP-4 at the temperatures at which Monsanto determined the vapor pressure of the F100 samples were converted to mm Hg.

Generally, the F100 samples had higher typical vapor pressure at 32^oF, and 100^oF and lower than normal at 70^oF and 40^oF. However, the Camp New Amsterdam fuel sample had extremely low vapor pressure. Overall, the data indicate that the F100 samples have higher vapor pressures than typical JP-4. Theoretically, the higher vapor pressures would lead to decreased pump cavitation at sea level conditions. However, this relation may not hold true at higher altitudes. Also, the more volatile fuel would be more difficult to handle.

(2) Kinematic Viscosity

Monsanto also calculated the kinematic viscosity as a function of temperature of the F100 samples. There are no specifications against which to judge the viscosity of JP-4, but the data obtained was compared to typical JP-4 kinematic viscosity measurements (Reference 7).

The average F100 sample has lower kinematic viscosity at low temperatures than typical JP-4. The samples from Elmendorf, Clark, Anderson, and Kadena have exceptionally low kinematic viscosity, while the sample from Camp New Amsterdam has higher than typical kinematic viscosity at low temperatures. On the other hand, the F100 samples have higher than typical kinematic viscosity at higher temperatures. High kinematic viscosity affects fuel pumpability more at the lower temperature range than at the higher temperature range. Thus, with the exception of the Camp New Amsterdam sample, the F100 examples have better than typical pumpability, which makes them less likely to cause fuel pump failures.

(3) Density

The average density of the F100 samples is equal to the average density of JP-4. No problems were noted in regards to density with any of the samples.

(4) Surface Tension

Low surface tension favors the atomization and ignition of fuel droplets (Reference 7). Monsanto measured the surface tension of the F100 samples versus temperature, and results were compared with typical JP-4 surface tension at varying temperatures.

The average surface tension of the 21 F100 samples is higher than the typical surface tension of JP-4. The F100 fuels would tend to negatively impact ignition characteristics as compared to typical JP-4. However, the differences are of such low magnitude that no noticeable loss of performance is likely to occur.

b. Thermal Properties

(1) Thermal Conductivity Analyses

Thermal conductivity analyses were only performed on nine of the 21 fuel samples. The results were compared to the typical thermal conductivity values of JP-4. No unusual characteristics were noted.

(2) Specific Heat

The specific heat as a function of temperature of the F100 samples were calculated and compared to typical JP-4 specific heat at various temperatures. The F100 samples had lower specific heat than typical JP-4. The lower specific heat would indicate a tendency towards poorer thermal stability, but no increased fuel pump problems.

c. Chemical Composition

(1) Boiling Point Distribution

The simulated distillation data obtained by Monsanto for the 21 F100 fuel samples were plotted to obtain distillation curves.

No abnormalities are noted in the distillation curves, with the exception of the curves for the Eglin and Camp New Amsterdam fuel samples. These two samples failed the boiling point distribution specifications, and their distillation shows higher than normal JP-4 distillation curves.

(2) Hydrocarbon Type Analyses

Hydrocarbon type analyses were performed by both modified ASTM and Monsanto methods. To determine which test method was more applicable to the F100 samples, the average carbon number of the samples was measured by mass spectrometry. The average carbon numbers were in the 7 to 9 range which indicates that the samples are more compatible with the modified ASTM test method.

Hydrocarbon types measured included paraffins, cycloparaffins, dicycloparaffins, alkylbenzenes, indans, and tetralins and naphthalenes.

The average paraffin content was 53.5%, with values ranging from 39.6% for the Nellis sample to 66% for the Tyndall sample. The cycloparaffin content ranged between 39.5% for the Elmendorf sample to 13.7% for the Tyndall sample. The

average cycloparaffin content was 27.4%. The dicycloparaffin content was low, ranging from 1.3% for the Elmendorf sample to 8.1% for the Nellis sample. The average dicycloparaffin content was 4.01%. The average sample had an 84.9% average paraffin/cycloparaffin content, and none of the samples deviated from the average by more than three percent.

The average alkybenzene content was 12.8%, with values ranging from 9.8% for the Torrejon sample to 15.9% for the Holloman and Elmendorf samples. The indenes and tetralins content was low, averaging 1.5%. Values ranged from 0.2% for the Hill sample to 2.9% for the Nellis sample. The naphthalene content was also low. The average naphthalene content was 0.8%, with values ranging from 0.3% for the Aviano sample to 1.2% for the Shaw sample. The total aromatic content ranged from 18.3% for the Tyndall sample to 12% for the Torrejon sample. The average total aromatics content was 15%. Again, samples from the CONUS Western bases had higher than average total aromatics content and the samples from European bases had lower than average aromatic content. These deviations are easily explained by processing practices.

No unusual trends were noted in the hydrocarbon type analyses. All the samples fit the description of "typical JP-4" and should not contribute to fuel pump failure.

Attempts were made to correlate hydrocarbon type to final boiling point. Although hydrocarbon types do influence boiling point distribution, no specific correlations were found. The samples that did fail boiling point specifications did have a larger average carbon number than the remaining samples.

3. Normal Paraffin Analyses

AFWAL/POSF analyzed the normal paraffin fraction of the 21 F100 fuel samples by Gas Chromatography. A high content of long chained normal paraffins would tend to give the fuels a "waxy", less pumpable character, possibly contributing to fuel pump failure.

The longest normal paraffin found in the F100 samples was normal C-17, and this was only found in the Holloman fuel sample. The longest normal paraffin found in most of the samples was C-16, and seven samples only had normal paraffins as long as C-15. These analyses revealed no abnormalities that would cause the F100 fuels to contribute to increased fuel pump failure.

Attempts were made to correlate total normal paraffin content and long chained normal paraffin content to simulated distillation data, but no correlations were noted.

SECTION IV

CONCLUSIONS

Due to fuel pump cavitation problems experienced in the F-15/F-16 aircraft, fuel samples from 21 F-15 and F-16 air bases were thoroughly analyzed to possibly identify fuel properties that might contribute to increased fuel pump cavitation and/or fuel pump failure. The analysis performed did not yield any conclusive results that would indicate that the fuels being presently used in US Air Force Bases have any inherent characteristics that contribute to pump cavitation or failure.

Only four areas resulted in fuels not meeting specification requirements: thermal stability (2 failures), simulated distillation (7 failures), vapor pressure (2 failures) and FSII (1 failure).

Thermal stability and FSII content failures are not indicative of characteristics likely to cause fuel pump failure. The observed failures were isolated cases and generally not repeatable by second laboratories. Simulated distillation and fuel vapor pressure are closely related. The vapor pressure and simulated distillation failures could indicate a tendency for the fuel to increase fuel pump cavitation, since cavitation is inversely proportional to vapor pressure at sea level conditions. However, these failures were not repeatable. It is felt that the failures were the result of poor sampling techniques that led to the loss of light end fuel components, which decreases vapor pressure and increases simulated distillation temperatures.

The characterization tests showed no unusual fuel properties that might lead to fuel pump problems. Vapor pressure, kinematic viscosity, surface tension and density as a function of temperature were comparable to typical JP-4. Hydrocarbon type analyses also revealed no unusual trends.

Lubricity tests indicated that all the samples had adequate lubricating qualities. Poor fuel lubricity is often blamed for fuel pump failures, but all the F100 samples are considered acceptable.

Overall, the JP-4 fuels analyzed for the F100 fuel sampling program were well within specifications. The fuels were also comparable, or generally better than "typical" JP-4.

From this analyses program, it can be concluded that it is unlikely that extensive analyses of fuel samples not directly involved in isolated aircraft fuel pump failures will provide explanations for such incidents. In general, fuel used in the field is of very high quality, and such analyses as the F100 sampling program attest to assurances that specifications used by the Air Force are as viable as they were when the chemical and physical properties of JP-4 for 1980-1981 was published (Reference 3).

SECTION V

RECOMMENDATIONS

Since analyzing fuel samples has not offered any clues to the fuel pump cavitation problem, it is recommended that the cavitation problem be studied in a more fundamental level. Fuel pump tests should be conducted to determine if any fuel characteristics, not limited by the specification such as viscosity and surface tension, can be causing fuel pump failures.

This analyses is an excellent survey of operational fuels. However, if the fuel is causing a fuel pump problem on the F100 fuel pump, it must be the result of a fuel property not being measured, or one that has never been related to pump failure before. It is more likely that the F100 fuel pump cavitation problems are associated with the mechanical complexity build into the design, rather than the result of the fuel used. A different approach must be taken to resolve the F100 fuel pump failure problem.

APPENDIX A
SPECIFICATION ANALYSES

APPENDIX A
SPECIFICATION ANALYSESTABLE A1
SAYBOLT COLOR

Spec Limits: No Limit

<u>Fuel</u>	<u>Saybolt Color</u>
1. Hill	27
2. Luke	22
3. Holloman	28
4. Elmendorf	30
5. Edwards	12
6. Nellis	10
7. Langley	17
8. Tyndall	10
9. MacDill	17
10. Shaw	18
11. Eglin	14
12. Hahn	22
13. Bitburg	25
14. Aviano	22
15. Zaragoza	22
16. Camp New Amsterdam	28
17. Torrejon	26
18. Osan	27
19. Clark	22
20. Anderson	14
21. Kadena	29

Mean: 21 ± 6


TABLE A2
TOTAL ACID NUMBER ANALYSES

Spec: 0.015 mg KOH/g maximum

"Average" from 1980/81 JP-4 Study: 0.005 mg KOH/g

<u>Fuel</u>	<u>Total Acid</u> <u>(mg KOH/g)</u>
1. Hill	.004
2. Luke	.009
3. Holloman	.005
4. Elmendorf	.007
5. Edwards	.006
6. Nellis	.007
7. Langley	.004
8. Tyndall	.004
9. MacDill	.002
10. Shaw	.006
11. Eglin	.003
12. Hahn	.007
13. Bitburg	.004
14. Aviano	.007
15. Zaragoza	.003
16. Camp New Amsterdam	.003
17. Torrejon	.005
18. Osan	.006
19. Clark	.003
20. Anderson	.002
21. Kadena	.006

Mean: .005 ± 0.002



FUEL SAMPLE	TOTAL ACID (mg KOH/g)
HILL	.004
LUKE	.009
HOLLOMAN	.005
ELMENDORF	.007
EDWARDS	.006
NELLIS	.007
LANGLEY	.004
TYNDALL	.004
MACDILL	.002
SHAW	.006
EGLIN	.003
HAHN	.007
BITBURG	.004
AVIANO	.007
ZARAGOZA	.003
CAMP NEW AMSTERDAM	.003
TORREJON	.005
OSAN	.006
CLARK	.002
ANDERSON	.002
KADENA	.006

Figure A1. Total Acid Number


TABLE A3
VOLUME PERCENT AROMATICS ANALYSES

Spec: 25% maximum

"Average" from 1980/81 JP-4 Study: 12.6%

<u>Fuel</u>	<u>Vol % Aromatics</u>
1. Hill	14.1
2. Luke	14.3
3. Holloman	19.7
4. Elmendorf	16.2
5. Edwards	15.9
6. Nellis	14.3
7. Langley	11.3
8. Tyndall	15.6
9. MacDill	17.2
10. Shaw	13.9
11. Eglin	15.2
12. Hahn	12.4
13. Bitburg	12.3
14. Aviano	11.4
15. Zaragoza	12.2
16. Camp New Amsterdam	12.6
17. Torrejon	11.7
18. Osan	12.8
19. Clark	13.7
20. Anderson	13.3
21. Kadena	13.0

Mean: 14.0 ± 2.1



<u>FUEL SAMPLE</u>	<u>VOLUME PERCENT AROMATICS (volume percent)</u>
HILL	14.1
LIKE	14.3
HOLLOMAN	19.7
ELMENDORF	16.2
EDWARDS	15.9
NELLIS	14.3
LANGLEY	11.3
TYNDALL	15.6
MACDILL	17.2
SHAW	13.9
EGLIN	15.2
HAHN	12.4
BITBURG	12.3
AVIANO	11.4
ZARAGOZA	12.2
CAMP NEW AMSTERDAM	12.6
TORREJON	11.7
OSAN	12.8
CLARK	13.7
ANDERSON	13.3
KADENA	13.0

Figure A2. Volume Percent Aromatics


TABLE A4
VOLUME PERCENT OLEFINS ANALYSES

Spec: 5% maximum

"Average" from 1980/81 JP-4 Study: 0.8%

<u>Fuel</u>	<u>Vol % Olefins</u>
1. Hill	0.3
2. Luke	0.7
3. Holloman	0.8
4. Elmendorf	0.3
5. Edwards	0.9
6. Nellis	0.7
7. Langley	0.7
8. Tyndall	1.2
9. MacDill	0.7
10. Shaw	0.7
11. Eglin	1.4
12. Hahn	0.7
13. Bitburg	0.7
14. Aviano	0.5
15. Zaragoza	0.5
16. Camp New Amsterdam	0.5
17. Torrejon	0.5
18. Osan	0.5
19. Clark	0.5
20. Anderson	0.5
21. Kadena	0.9

Mean: 0.7 ± 0.3



FUEL SAMPLE	VOLUME PERCENT OLEFINS (vol %)
HILL	0.3
LUKE	0.7
HOLLOMAN	0.8
ELMENDORF	0.3
EDWARDS	0.9
NELLIS	0.7
LANGLEY	0.7
TYNDALL	1.2
MACDILL	0.7
SHAW	0.7
EGLIN	1.4
HAHN	0.7
BITBURG	0.7
AVIANO	0.5
ZARAGOZA	0.5
CAMP NEW AMSTERDAM	0.5
TORREJON	0.5
OSAN	0.5
CLARK	0.5
ANDERSON	0.5
KADENA	0.9

Figure A3. Volume Percent Olefins


TABLE A5
 MERCAPTAN SULFUR ANALYSES

Spec: .001 wt% maximum

"Average" from 1980/81 JP-4 Study: 0.0004

<u>Fuel</u>	<u>Mercaptan Sulfur Wt %</u>
1. Hill	0.0003
2. Luke	0.0003
3. Holloman	0.0002
4. Elmendorf	0.0002
5. Edwards	0.0002
6. Nellis	0.0002
7. Langley	0.0002
8. Tyndall	0.0003
9. MacDill	0.0006
10. Shaw	0.0004
11. Eglin	0.0005
12. Hahn	0.0002
13. Bitburg	0.0001
14. Aviano	0.0001
15. Zaragoza	0.0002
16. Camp New Amsterdam	0.0001
17. Torrejon	0.0001
18. Osan	0.0001
19. Clark	0.0003
20. Anderson	0.0002
21. Kadena	0.0002

Mean: 0.0002 + .0001



FUEL SAMPLE	MERCAPTAN SULFUR WT % (WT %)
HILL	0.0003
LUKE	0.0003
HOLLOMAN	0.0002
ELMENDORF	0.0002
EDWARDS	0.0002
NELLIS	0.0002
LANGLEY	0.0002
TYNDALL	0.0003
MACDILL	0.0006
SHAW	0.0004
EGLIN	0.0005
HAHN	0.0002
BITBURG	0.0001
AVIANO	0.0001
ZARAGOZA	0.0002
CAMP NEW AMSTERDAM	0.0001
TORREJON	0.0000
OSAN	0.0001
CLARK	0.0003
ANDERSON	0.0002
KADENA	0.0001

Figure A4. Mercaptan Sulfur


TABLE A6
TOTAL WEIGHT PERCENT SULFUR ANALYSES

Spec: 0.40 wt % maximum

"Average" from 1980/81 JP-4 Study: 0.04 wt %

<u>Fuel</u>	<u>Wt % Sulfur</u>
1. Hill	0.01
2. Luke	0.02
3. Holloman	0.04
4. Elmendorf	0.01
5. Edwards	0.03
6. Nellis	0.04
7. Langley	0.00
8. Tyndall	0.02
9. MacDill	0.04
10. Shaw	0.03
11. Eglin	0.02
12. Hahn	0.03
13. Bitburg	0.03
14. Aviano	0.03
15. Zaragoza	0.01
16. Camp New Amsterdam	0.02
17. Torrejon	0.00
18. Osan	0.01
19. Clark	0.01
20. Anderson	0.02
21. Kadena	0.01

Mean: 0.02 ± 0.01



FUEL SAMPLE	WEIGHT PERCENT SULFUR (WT %)
HILL	0.01
LUKE	0.02
HOLLOMAN	0.04
ELMENDORF	0.01
EDWARDS	0.03
NELLIS	0.04
LANGLEY	0.00
TYNDALL	0.02
MACDILL	0.04
SHAW	0.03
EGLIN	0.02
HAHN	0.03
BITGURG	0.03
AVIANO	0.03
ZARAGOZA	0.01
CAMP NEW AMSTERDAM	0.02
TORREJON	0.00
OSAN	0.01
CLARK	0.01
ANDERSON	0.02
KADENA	0.01

Figure A5. Total Sulfur

TABLE A7
BOILING RANGE DISTRIBUTION SPECS

	ASTM D 2887	ASTM D 86
SPECS:	20% recovered - 130°C max	145°C max
	50% recovered - 185°C max	190°C max
	90% recovered - 250°C max	245°C max
	FBP - 320°C max	270°C max

"AVERAGE" FROM 1980/81 JP-4 STUDY (ASTM D 86)

1BD	61°C
10%	94°C
20%	107°C
50%	143°C
90%	205°C
FBP	238°C

TABLE A8
SIMULATED DISTILLATION ANALYSES

Fuel	IBP °C		10% °C		20% °C	
	SFTLA	MONSANTO	SFTLA	MONSANTO	SFTLA	MONSANTO
1. Hill	0	29	73	78	94	99
2. Luke	24	30	70	73	92	91
3. Holloman	25	27	75	77	98	98
4. Elmendorf	24	34	73	79	89	91
5. Edwards	24	27	75	74	97	97
6. Nellis	1	27	76	83	101	101
7. Langley	24	29	66	66	90	89
8. Tyndall	2	27	68	87	102	117
9. MacDill	24	29	68	67	97	95
10. Shaw	24	29	66	62	90	87
11. Eglin	23	28	90	92	118	119
12. Hahn	10	27	69	60	98	96
13. Bitburg	23	27	69	71	94	98
14. Aviano	1	26	76	87	102	107
15. Zaragoza	22	29	68	55	97	93
16. Camp New Amsterdam	25	29	83	82	99	100

TABLE A8 (Continued)
SIMULATED DISTILLATION ANALYSES

Fuel	IBP °C		10% °C		20% °C	
	SFTLA	MONSANTO	SFTLA	MONSANTO	SFTLA	MONSANTO
17. Torrejon	23	28	74	73	99	100
18. Osan	22	10	67	64	96	95
19. Clark	25	28	82	72	99	98
20. Anderson	25	31	70	73	93	97
21. Kadena	25	29	85	84	99	99
					Mean:	97 98

TABLE A8 (Continued)
SIMULATED DISTILLATION ANALYSES

Fuel	50% °C		90% °C		FBP	
	SFTLA	MONSANTO	SFTLA	MONSANTO	SFTLA	MONSANTO
1. Hill	146	141	216	195	278	262
2. Luke	144	135	231	221	284	291
3. Holloman	149	159	234	245	280	318
4. Elmendorf	120	116	214	215	281	303
5. Edwards	147	142	238	238	291	305
6. Nellis	159	159	246	244	297	296
7. Langley	147	142	236	233	279	275
8. Tyndall	147	147	239	229	284	283
9. MacDill	166	163	245	244	284	288
10. Shaw	168	172	244	244	284	304
11. Eglin	143	145	239	252	291	333
12. Hahn	160	160	229	228	275	288
13. Bitburg	162	170	233	235	271	295
14. Aviano	143	141	219	216	264	257
15. Zaragoza	160	165	226	240	265	370
16. Camp New Amsterdam	169	173	235	252	285	333
17. Torrejon	157	167	229	238	270	330

TABLE A8 (Concluded)
SIMULATED DISTILLATION ANALYSES

Fuel	50% °C		90% °C		FRP	
	<u>SFTLA</u>	<u>MONSANTO</u>	<u>SFTLA</u>	<u>MONSANTO</u>	<u>SFTLA</u>	<u>MONSANTO</u>
18. Osan	160	166	228	234	288	330
19. Clark	131	134	204	222	276	342
20. Anderson	132	139	206	246	282	334
21. Kadena	126	126	215	220	300	311
Mean	149	151	229	233	291	307

TABLE A9
VAPOR PRESSURE ANALYSES

Spec: 2 psi minimum; 3 psi maximum

"Average" from 1980/81 JP-4 Study: 2.6 psi

<u>Fuel</u>	Vapor Pressure (psi) <u>SFTLA</u>
1. Hill	1.7
2. Luke	1.5
3. Holloman	2.5
4. Elmendorf	2.3
5. Edwards	2.5
6. Nellis	2.1
7. Langley	2.2
8. Tyndall	2.1
9. MacDill	2.2
10. Shaw	2.1
11. Eglin	2.9
12. Hahn	2.1
13. Bitburg	2.4
14. Aviano	2.3
15. Zaragoza	2.4
16. Camp New Amsterdam	2.1
17. Torrejon	2.3
18. Osan	2.4
19. Clark	2.5
20. Anderson	2.8
21. Kadena	2.6

Mean 2.29 ± .38


TABLE A10
API GRAVITY ANALYSES

Spec Limits: 45.0 and 57.0

"Average" from 1980/81 JP-4 Study: 54.2

<u>Fuel</u>	<u>API Gravity</u>
1. Hill	54.9
2. Luke	53.5
3. Holloman	51.5
4. Elmendorf	54.9
5. Edwards	52.6
6. Nellis	50.2
7. Langley	55.7
8. Tyndall	55.7
9. MacDill	52.7
10. Shaw	53.7
11. Eglin	54.7
12. Hahn	54.5
13. Bittburg	54.2
14. Aviano	55.8
15. Zaragoza	54.5
16. Camp New Amsterdam	52.8
17. Torrejon	54.4
18. Osan	54.5
19. Clark	54.8
20. Anderson	51.4
21. Kadena	55.9

Mean: 53.9 ± 1.6



FUEL SAMPLE	API GRAVITY
HILL	54.9
LUKE	53.5
HOLLOMAN	51.5
ELMENDORF	54.9
EDWARDS	52.6
NELLIS	50.2
LANGLEY	55.7
TYNDALL	55.7
MACDILL	52.7
SHAW	53.7
EGLIN	54.7
HAHN	54.5
BITBURG	54.2
AVIANO	55.8
ZARAGOZA	54.5
CAMP NEW AMSTERDAM	52.8
TORREJON	54.4
OSAN	54.5
CLARK	54.8
ANDERSON	54.4
KADENA	55.9

Figure A6. API Gravity

TABLE A11
FREEZING POINT ANALYSES

Spec Limit: -58°C maximum

"Near Spec Limit": -60.6°C maximum

<u>Fuel</u>	<u>Freezing Point (°C)</u>
1. Hill	-73
2. Luke	-69
3. Holloman	-66
4. Elmendorf	-73
5. Edwards	-66
6. Nellis	-63
7. Langley	-66
8. Tyndall	-67
9. MacDill	-58
10. Shaw	-60
11. Eglin	-59
12. Hahn	-67
13. Bitburg	-64
14. Aviano	-73
15. Zaragoza	-63
16. Camp New Amsterdam	-60
17. Torrejon	-62
18. Osan	-66
19. Clark	-73
20. Anderson	-73
21. Kadena	-73

TABLE A12
 VISCOSITY ANALYSES

Spec Limits: No Limit

<u>Fuel</u>	<u>Viscosity (CS) (-20°C)</u>	
	SFTLA	Monsanto
1. Hill	1.6	1.5
2. Luke	1.6	1.5
3. Holloman	1.8	1.8
4. Elmendorf	1.3	1.3
5. Edwards	1.9	1.7
6. Nellis	2.1	1.9
7. Langley	1.6	1.6
8. Tyndall	1.8	1.5
9. MacDill	1.9	1.8
10. Shaw	2.0	1.8
11. Eglin	1.9	1.7
12. Hahn	1.9	1.8
13. Bitburg	1.9	1.8
14. Aviano	1.7	1.5
15. Zaragoza	1.9	1.8
16. Camp New Amsterdam	2.2	1.9
17. Torrejon	2.0	1.8
18. Osan	1.8	1.7
19. Clark	1.6	1.4
20. Anderson	1.5	1.4
21. Kadena	1.5	1.4

Mean: 1.8 ± .2

1.6 ± .2

TABLE A13
HEAT OF COMBUSTION ANALYSES


Spec: 42.8 MJ/kg minimum

"Average" from 1980/81 JP-4 Study: 43.5 MJ/kg

<u>Fuel</u>	<u>Heat of Combustion (MJ/kg)</u>	
	SFTLA	MONSANTO
1. Hill	43.5	43.6
2. Luke	43.5	43.4
3. Holloman	43.2	43.2
4. Elmendorf	43.4	43.5
5. Edwards	43.4	43.4
6. Nellis	43.4	43.2
7. Langley	43.7	43.5
8. Tyndall	43.6	43.5
9. MacDill	43.4	43.5
10. Shaw	43.5	43.5
11. Eglin	43.6	43.5
12. Hahn	43.6	43.5
13. Bitburg	43.6	43.5
14. Aviano	43.6	43.5
15. Zaragoza	43.6	43.5
16. Camp New Amsterdam	43.6	43.6
17. Torrejon	43.6	43.5
18. Osan	43.5	43.4
19. Clark	43.5	43.4
12. Anderson	43.5	43.4
21. Kadena	43.6	43.5

Mean: 43.5 ± .11

Mean: 43.5 ± .10



FUEL SAMPLE	HEAT OF COMBUSTION (MJ/KG)
HILL	43.5
LUKE	43.5
HOLLOMAN	43.2
ELMENDORF	43.4
EDWARDS	43.4
NELLIS	43.4
LANGLEY	43.7
TYNDALL	43.6
MACDILL	43.4
SHAW	43.5
EGLIN	43.6
HAHN	43.6
BITBURG	43.6
AVIANO	43.6
ZARAGOZA	43.6
CAMP NEW AMSTERDAM	43.5
TORREJON	43.6
OSAN	43.6
CLARK	43.5
ANDERSON	43.5
KADENA	43.6

Figure A7. Heat of Combustion


TABLE A14
SMOKE POINT ANALYSES

Spec: 20 mm minimum

"Average" from 1980/81 JP-4 study: 27

<u>Fuel</u>	<u>Smoke Point</u>
1. Hill	24.0
2. Luke	25.0
3. Holloman	23.0
4. Elmendorf	26.0
5. Edwards	22.0
6. Nellis	20.0
7. Langley	30.0
8. Tyndall	28.0
9. MacDill	26.0
10. Shaw	27.0
11. Eglin	26.0
12. Hahn	24.0
13. Bitburg	25.0
14. Aviano	27.0
15. Zaragoza	26.0
16. Camp New Amsterdam	25.0
17. Torrejon	28.0
18. Osan	26.0
19. Clark	25.0
20. Anderson	25.0
21. Kadena	24.0

Mean: 25 ± 2



FUEL SAMPLE	SMOKE POINT (mm)
HILL	24.0
LUKE	25.0
HOLLOMAN	23.0
ELMENDORF	26.0
EDWARDS	22.0
NELLIS	20.0
LANGLEY	30.0
TYNDALL	28.0
MACDILL	26.0
SHAW	27.0
EGLIN	26.0
HAHN	24.0
BITGURG	25.0
AVIANO	27.0
ZARAGOZA	26.0
CAMP NEW AMSTERDAM	25.0
TORREJON	28.0
OSAN	26.0
CLARK	25.0
ANDERSON	25.0
KADENA	24.0

Figure A8. Smoke Point

TABLE A15
HYDROGEN CONTENT ANALYSES

Spec: 13.6 wt % minimum


"Average" from 1980/81 JP-4 Study: 14.3

<u>Fuel</u>	<u>SFTLA</u> <u>Wt % H₂</u>	<u>POSF</u> <u>Wt % H₂</u>
1. Hill	14.3	14.2
2. Luke	14.2	14.0
3. Holloman	14.0	13.9
4. Elmendorf	14.2	14.0
5. Edwards	14.1	14.1
6. Nellis	14.1	13.9
7. Langley	14.5	14.4
8. Tyndall	14.4	14.3
9. MacDill	14.1	14.1
10. Shaw	14.3	14.3
11. Eglin	14.3	14.3
12. Hahn	14.4	14.4
13. Bitburg	14.4	14.4
14. Aviano	14.5	14.4
15. Zaragoza	14.4	14.4
16. Camp New Amsterdam	14.4	14.2
17. Torrejon	14.4	14.5
18. Osan	14.4	14.3
19. Clark	14.3	14.2
20. Anderson	14.3	14.1
21. Kadena	14.4	14.3

Mean: 14.3 ± .1

Mean: 14.2 ± .2

% Difference over Spec Min 4 %



FUEL SAMPLE	SFTLA WT % H ₂	POSF WT % H ₂
HILL	14.3	14.2
LUKE	14.2	14.0
HOLLOMAN	14.0	13.9
ELMENDORF	14.2	14.0
EDWARDS	14.1	14.1
NELLIS	14.1	13.9
LANGLEY	14.5	14.4
TYNDALL	14.4	14.3
MACDILL	14.1	14.1
SHAW	14.3	14.3
EGLIN	14.3	14.3
HAHN	14.4	14.4
BITBURG	14.4	14.4
AVIANO	14.5	14.4
ZARAGOZA	14.4	14.4
CAMP NEW AMSTERDAM	14.4	14.2
TORREJON	14.4	14.5
OSAN	14.4	14.3
CLARK	14.3	14.2
ANDERSON	14.3	14.1
KADENA	14.4	14.3

Figure A9. Hydrogen Content

TABLE A16
COPPER STRIP CORROSION ANALYSES


Spec Limit: 1B maximum

<u>Fuel</u>	<u>Copper Strip Corrosion</u>
1. Hill	1A
2. Luke	1A
3. Holloman	1A
4. Elmendorf	1A
5. Edwards	1A
6. Nellis	1A
7. Langley	1A
8. Tyndall	1A
9. MacDill	1A
10. Shaw	1A
11. Eglin	1A
12. Hahn	1A
13. Bitburg	1A
14. Aviano	1B
15. Zaragoza	1A
16. Camp New Amsterdam	1A
17. Torrejon	1A
18. Osan	1A
19. Clark	1A
20. Anderson	1A
21. Kadena	1A

TABLE A17
THERMAL STABILITY ANALYSES

Spec: $\Delta P = 25$ mm Hg maximum PDC < 3

<u>Fuel</u>	<u>P mm Hg</u>	<u>PDC</u>
1. Hill	0	1
2. Luke	0	1
3. Holloman	0	1
4. Elmendorf	0	1
5. Edwards	0	1
6. Nellis	0	1
7. Langley	0, 16.5, 0	1, 3, 1
8. Tyndall	0	1
9. MacDill	0	1
10. Shaw	0	1
11. Eglin	0	1
12. Hahn	0	1
13. Bitburg	0	1
14. Aviano	0, 0.2	4, 4
15. Zaragoza	0	1
16. Camp New Amsterdam	0	1
17. Torrejon	0	1
18. Osan	0	1
19. Clark	0	1
20. Anderson	0	1
21. Kadena	0	1



FUEL SAMPLE	DELTA P (mm hg)
HILL	0
LUKE	0
HOLLOMAN	0
ELMENDORF	0
EDWARDS	0
NELLIS	0
LANGLEY	0, 16.5
TYNDALL	0
MACDILL	0
SHAW	0
EGLIN	0
HAHN	0
BITBURG	0
AVIANO	0, 0.2
ZARAGOZA	0
CAMP NEW AMSTERDAM	0
TORREJON	0
OSAN	0
CLARK	0
ANDERSON	0
KADENA	0

Figure A10. Thermal Stability


TABLE A18
EXISTENT GUM ANALYSES

Spec: 7 mg/100 ml maximum

"Average" from 1980/81 JP-4 Study: 0.8 mg/100 ml

<u>Fuel</u>	<u>Existent Gum</u>
1. Hill	0.4
2. Luke	0.6
3. Holloman	0.0
4. Elmendorf	0.0
5. Edwards	0.6
6. Nellis	0.6
7. Langley	1.0
8. Tyndall	0.0
9. MacDill	0.0
10. Shaw	0.2
11. Eglin	0.8
12. Hahn	0.0
13. Bitburg	0.6
14. Aviano	1.2
15. Zaragoza	0.6
16. Camp New Amsterdam	0.6
17. Torrejon	0.4
18. Osan	0.2
19. Clark	0.8
20. Anderson	0.6
21. Kadena	0.4

Mean: 0.5 ± .04



FUEL SAMPLE	EXISTENT GUM (mg/ml)
HILL	0.4
LUKE	0.6
HOLLOMAN	0.0
ELMENDORF	0.0
EDWARDS	0.6
NELLIS	0.6
LANGLEY	1.0
TYNDALL	0.0
MACDILL	0.0
SHAW	0.2
EGLIN	0.8
HAHN	0.0
BITBURG	0.6
AVIANO	1.2
ZARAGOZA	0.6
CAMP NEW AMSTERDAM	0.6
TORREJON	0.4
OSAN	0.2
CLARK	0.8
ANDERSON	0.6
KADENA	0.4

Figure A11. Existent Gum


TABLE A19
VOL % FUEL SYSTEM ICING INHIBITOR ANALYSES

Spec: 10 minimum; 15 maximum

"Average" from 1980/81 JP-4 Study: 0.13 Vol %

<u>Fuel</u>	<u>Vol % FSII</u>
1. Hill	0.12
2. Luke	0.13
3. Holloman	0.12
4. Elmendorf	0.13
5. Edwards	0.11
6. Nellis	0.13
7. Langley	0.14
8. Tyndall	0.17
9. MacDill	0.11
10. Shaw	0.10
11. Eglin	0.14
12. Hahn	0.14
13. Bitburg	0.15
14. Aviano	0.11
15. Zaragoza	0.12
16. Camp New Amsterdam	0.11
17. Torrejon	0.14
18. Osan	0.12
19. Clark	0.13
20. Anderson	0.14
21. Kadena	0.12

Mean 0.13 ± 0.02



FUEL SAMPLE	FSII (vol %)
HILL	0.12
LUKE	0.13
HOLLOMAN	0.12
ELMENDORF	0.13
EDWARDS	0.11
NELLIS	0.13
LANGLEY	0.14
TYNDALL	0.17
MACDILL	0.11
SHAW	0.10
EGLIN	0.14
HAHN	0.14
BITBURG	0.15
AVIANO	0.11
ZARAGOZA	0.12
CAMP NEW AMSTERDAM	0.11
TORREJON	0.14
OSAN	0.12
CLARK	0.13
ANDERSON	0.14
KADENA	0.12

Figure A12. Fuel System Icing Inhibitor

APPENDIX B
CHARACTERIZATION ANALYSES

TABLE B1
PHYSICAL PROPERTIES AS A FUNCTION OF TEMPERATURE

	Vapor pressure (mm Hg)	Kinematic viscosity (centi- stokes)	Density (g/cm ³)	Surface tension (dynes/cm)
Hill				
-30.1°F	-	2.013	-	-
-20°F	8 ^a	1.785	0.7936	28.1 ^b
-4°F	-	1.512	-	-
32°F	33	1.139	0.7718	25.4
59°F	-	-	0.7589	-
70°F	74	0.863	0.7546	23.4
100°F	133	0.720	0.7409	21.9
140°F	270	0.583	0.7230	19.8
Luke				
-30.1°F	-	2.010	-	-
-20°F	8 ^a	1.798	0.7998	28.2 ^b
-4°F	-	1.514	-	-
32°F	32	1.135	0.7767	25.4
59°F	-	-	0.7653	-
70°F	76	0.862	0.7608	23.4
100°F	134	0.719	0.7471	21.8
140°F	290	0.582	0.7296	19.7
Holloman				
-30.1°F	-	2.345	-	-
-20°F	7 ^a	2.072	0.8051	28.4 ^b
-4°F	-	1.755	-	-
32°F	32	1.283	0.7850	25.9
59°F	-	-	0.7738	-
70°F	78	0.9660	0.7689	24.0
100°F	145	0.7694	0.7555	22.6
140°F	305	0.6359	0.7369	20.6

^aValue determined by extrapolation of Log P versus 1/T vapor pressure relationship.

^bObtained by linear regression extrapolation of data.

TABLE B1 (Continued)
 PHYSICAL PROPERTIES AS A FUNCTION OF TEMPERATURE

	Vapor pressure (mm/Hg)	Kinematic viscosity (centistokes)	Density (g/cm ³)	Surface tension (dynes/cm)
Elmendorf				
-30.1°F	-	1.629	-	-
-20°F	7 ^a	1.471	0.7928	27.8 ^b
-4°F	-	1.277	-	-
32°F	32	0.9676	0.7710	25.1
59°F	-	-	0.7583	-
70°F	76	0.7587	0.7539	23.2
100°F	140	0.6375	0.7398	21.2
140°F	288	0.5201	0.7214	19.5
Edwards				
-30.1°F	-	2.188	-	-
-20°F	6 ^a	1.942	0.8023	28.3 ^b
-4°F	-	1.653	-	-
32°F	26	1.224	0.7815	25.6
59°F	-	-	0.7695	-
70°F	66	0.9254	0.7644	23.6
100°F	125	0.7620	0.7507	22.0
140°F	270	0.6153	0.7326	19.8
Nellis				
-30.1°F	-	2.603	-	-
-20°F	7 ^a	2.262	0.8143	29.2 ^b
-4°F	-	1.917	-	-
32°F	30	1.391	0.7936	26.6
59°F	-	-	0.7811	-
70°F	70	1.028	0.7761	24.8
100°F	128	0.8430	0.7628	23.3
140°F	265	0.6703	0.7444	21.4

^aValue determined by extrapolation of Log P versus 1/T vapor pressure relationship.

^bObtained by linear regression extrapolation of data.

TABLE B1 (Continued)
 PHYSICAL PROPERTIES AS A FUNCTION OF TEMPERATURE

	Vapor pressure (mm/Hg)	Kinematic viscosity (centistokes)	Density (g/m ³)	Surface tension (dynes/cm)
Shaw				
-30.1°F	-	2.404	-	-
-20°F	6 ^a	2.116	0.7971	27.7 ^b
-4°F	-	1.761	-	-
32°F	29	1.284	0.7745	25.1
59°F	-	-	0.7642	-
70°F	71	0.969	0.7592	23.2
100°F	137	0.797	0.7457	21.7
140°F	282	0.639	0.7293	19.6
Eglin				
-30.1°F	-	2.242	-	-
-20°F	8.9 ^a	2.061	0.7944	27.6 ^b
-4°F	-	1.703	-	-
32°F	35	1.256	0.7730	25.2
59°F	-	-	0.7606	-
70°F	77	0.941	0.7588	23.2
100°F	133	0.776	0.7424	21.9
140°F	265	0.630	0.7256	20.0
Hahn				
-30.1°F	-	2.373	-	-
-20°F	6 ^a	2.088	0.7939	28.9 ^b
-4°F	-	1.796	-	-
32°F	28	1.295	0.7722	26.2
59°F	-	-	0.7615	-
70°F	68	0.972	0.7565	24.3
100°F	128	0.799	0.7433	22.6
140°F	265	0.644	0.7259	20.4

^aValue determined by extrapolation of Log P versus 1/T vapor pressure relationship.

^bObtained by linear regression extrapolation of data.

TABLE B1 (Continued)
 PHYSICAL PROPERTIES AS A FUNCTION OF TEMPERATURE

	Vapor pressure (mm/Hg)	Kinematic viscosity (centistokes)	Density (g/cm ³)	Surface tension (dynes/cm)
Langley				
-30.1°F	- ^a	2.120	-	-
-20°F	7 ^a	1.876	0.7899	27.4 ^b
-4°F	-	1.580	-	-
32°F	32	1.174	0.7678	24.7
59°F	-	-	0.7557	-
70°F	74	0.887	0.7512	22.8
100°F	138	0.740	0.7377	21.2
140°F	285	0.596	0.7199	19.2
Tyndall				
-30.1°F	- ^a	2.048	-	-
-20°F	7 ^a	1.818	0.7895	27.8 ^b
-4°F	-	1.521	-	-
32°F	30	1.149	0.7681	25.1
59°F	-	-	0.7563	-
70°F	70	0.872	0.7513	23.2
100°F	125	0.719	0.7378	21.6
140°F	255	0.587	0.7206	19.6
MacDill				
-30.1°F	- ^a	2.464	-	-
-20°F	7 ^a	2.185	0.8014	28.1 ^b
-4°F	-	1.810	-	-
32°F	30	1.334	0.7806	25.4
59°F	-	-	0.7690	-
70°F	71	0.981	0.7643	23.5
100°F	130	0.806	0.7508	21.8
140°F	268	0.647	0.7327	19.8

^aValue determined by extrapolation of Log P versus 1/T vapor pressure relationship.

^bObtained by linear regression extrapolation of data.

TABLE B1 (Continued)
 PHYSICAL PROPERTIES AS A FUNCTION OF TEMPERATURE

	Vapor pressure (mm/Hg)	Kinematic viscosity (centistokes)	Density (g/cm ³)	Surface tension (dynes/cm)
Bitburg				
-30.1°F	-	2.372	-	-
-20°F	8 ^a	2.084	0.7966	28.2 ^b
-4°F	-	1.775	-	-
32°F	37	1.304	0.7726	25.8
59°F	-	-	0.7627	-
70°F	78	0.9729	0.7579	24.0
100°F	140	0.7998	0.7444	22.6
140°F	290	0.6423	0.7276	20.8
Aviano				
-30.1°F	-	2.128	-	-
-20°F	10 ^a	1.818	0.7904	28.4
-4°F	-	1.549	-	-
32°F	39	1.163	0.7672	25.7
59°F	-	-	0.7562	-
70°F	85	0.879	0.7512	23.8
100°F	148	0.733	0.7378	22.1
140°F	284	0.594	0.7202	20.2
Zaragoza				
-30.1°F	-	2.514	-	-
-20°F	6.4 ^a	2.225	0.7950	28.3 ^b
-4°F	-	1.825	-	-
32°F	29	1.334	0.7732	25.5
59°F	-	-	0.7619	-
70°F	71	0.999	0.7571	23.5
100°F	135	0.829	0.7438	21.8
140°F	288	0.660	0.7272	19.7

^aValue determined by extrapolation of Log P versus 1/T vapor pressure relationship.

^bObtained by linear regression extrapolation of data.

TABLE B1 (Continued)
 PHYSICAL PROPERTIES AS A FUNCTION OF TEMPERATURE

	Vapor pressure (mm/Hg)	Kinematic viscosity (centistokes)	Density (g/cm ³)	Surface tension (dynes/cm)
Camp New Amsterdam				
-30.1°F	-	2.628	-	- ^b
-20°F	4.9 ^a	2.326	0.8019	27.9 ^b
-4°F	-	1.901	-	-
32°F	23.5	1.382	0.7812	25.5
59°F	-	-	0.7688	-
70°F	59	1.024	0.7639	23.8
100°F	114	0.848	0.7507	22.2
140°F	245	0.664	0.7336	20.5
Torrejon				
-30.1°F	-	2.516	-	- ^b
-20°F	5.2 ^a	2.238	0.7946	28.4 ^b
-4°F	-	1.839	-	-
32°F	25	1.357	0.7742	25.7
59°F	-	-	0.7617	-
70°F	65	1.005	0.7569	23.6
100°F	124	0.829	0.7437	22.1
140°F	270	0.662	0.7265	20.0
Osan				
-30.1°F	-	2.325	-	- ^b
-20°F	8.1 ^a	2.054	0.7955	28.8 ^b
-4°F	-	1.731	-	-
32°F	33	1.282	0.7723	26.1
59°F	-	-	0.7617	-
70°F	76	0.958	0.7568	24.0
100°F	138	0.791	0.7434	22.4
140°F	278	0.640	0.7264	20.4

^aValue determined by extrapolation of Log P versus 1/T vapor pressure relationship.

^bObtained by linear regression extrapolation of data.

TABLE B1 (Concluded)
 PHYSICAL PROPERTIES AS A FUNCTION OF TEMPERATURE

	Vapor pressure (mm/Hg)	Kinematic viscosity (centistokes)	Density (g/cm ³)	Surface tension (dynes/cm)
Clark				
-30.1°F	-	1.908	-	-
-20°F	6.1 ^a	1.687	0.7940	29.3 ^b
-4°F	-	1.440	-	-
32°F	28	1.091	0.7722	26.0
59°F	-	-	0.7599	-
70°F	69	0.850	0.7550	23.6
100°F	130	0.701	0.7412	21.7
140°F	276	0.569	0.7238	19.2
Anderson				
-30.1°F	-	1.868	-	-
-20°F	6.8 ^a	1.702	0.7956	28.4 ^b
-4°F	-	1.429	-	-
32°F	32	1.085	0.7746	25.5
59°F	-	-	0.7616	-
70°F	75	0.834	0.7566	23.3
100°F	140	0.695	0.7429	21.5
140°F	300	0.578	0.7253	19.4
Kadena				
-30.1°F	-	1.809	-	-
-20°F	6.6	1.636	0.7886	28.2 ^b
-4°F	-	1.389	-	-
32°F	32	1.062	0.7675	25.4
59°F	-	-	0.7552	-
70°F	76	0.814	0.7502	23.4
100°F	135	0.681	0.7369	21.8
140°F	276	0.576	0.7190	19.6

^aValue determined by extrapolation of Log P versus 1/T vapor pressure relationship.

^bObtained by linear regression extrapolation of data.

TABLE B2
COMPARISON OF TYPICAL JP-4 AND AVERAGED F100 SAMPLES
VAPOR PRESSURE AS A FUNCTION OF TEMPERATURE

Temperature °F (°C)	Vapor Pressure (mm Hg)	
	Typical JP-4	F100 Samples
-20 (-28.9)	no data	7
32 (0)	23.25 ^a	30.8
70 (21.1)	81.01	72.6
100 (37.8)	126	133
140 (60)	283.5	276.9

^aObtained by extrapolation




Figure B1. Temperature/Viscosity Plot for Hill Fuel Sample




Figure B2. Temperature/Viscosity Plot for Luke Fuel Sample




Figure B3. Temperature/Viscosity Plot for Holloman Fuel Sample




Figure B4. Temperature/Viscosity Plot for Elmendorf Fuel Sample




Figure B5. Temperature/Viscosity Plot for Edwards Fuel Sample




Figure B6. Temperature/Viscosity Plot for Langley Fuel Sample




Figure B7. Temperature/Viscosity Plot for Tyndall Fuel Sample




Figure B8. Temperature/Viscosity Plot for MacDill Fuel Sample




Figure B9. Temperature/Viscosity Plot for Shaw Fuel Sample




Figure B10. Temperature/Viscosity Plot for Eglin Fuel Sample




Figure B11. Temperature/Viscosity Plot for Aviano Fuel Sample




Figure B12. Temperature/Viscosity for Zaragoza Fuel Sample




Figure B13. Temperature/Viscosity Plot for Camp New Amsterdam Fuel Sample




Figure B14. Temperature/Viscosity Plot for Torreon Fuel Sample




Figure B15. Temperature/Viscosity Plot for Osan Fuel Sample




Figure B16. Temperature/Viscosity Plot for Clark Fuel Sample




Figure B17. Temperature/Viscosity Plot for Anderson Fuel Sample




Figure B18. Temperature/Viscosity Plot for Kadena Fuel Sample

TABLE B3
COMPARISON OF TYPICAL JP-4 AND AVERAGED F100 SAMPLES
KINEMATIC VISCOSITY AS A FUNCTION OF TEMPERATURE

Temperature °F (°C)	Kinematic Viscosity Cs	
	Typical JP-4	F100 Samples
-30.1 (-34.5)	2.3	2.21
-20 (-28.8)	2.1	1.96
-4 (-20)	1.70	1.65
32 (0)	1.23	1.22
70 (21.1)	.56	.932
100 (37.8)	.44	.762
140 (60)	.40	.616

TABLE B4
COMPARISON OF TYPICAL JP-4 AND AVERAGED F100 SAMPLES
DENSITY AS A FUNCTION OF TEMPERATURE

Temperature °F (°C)	Density (g/cm ³)	
	Typical JP-4	F100 Samples
-20 (-28.8)	.797	.796
32 (0)	.775	.774
59 (15)	.764	.763
70 (21.1)	.758	.759
100 (37.8)	.698 ^a	0.745
140 (60)	not avail.	.727

^aObtained by extrapolation

TABLE B5
COMPARISON OF TYPICAL JP-4 AND AVERAGED F100 SAMPLES
SURFACE TENSION AS A FUNCTION OF TEMPERATURE

Temperature °F (°C)	Surface Tension (dyne/cm)	
	Typical JP-4	F100 Samples
-20 28.8	25.9	28.3
-4 (-20)	25.2	25.6
70 (21.1)	21.7	23.6
100 (37.8)	20.3	22.0
140 (60)	18.4	20.0

TABLE B6
THERMAL CONDUCTIVITY ANALYSES

Sample	Thermal Conductivity (Watt/meter° Kelvin)		
	0°C	20°C	40°C
Hill	0.123 ± 2.12%	0.117 ± 2.69%	0.110 ± 2.92%
Luke	0.123 ± 4.05%	0.116 ± 2.40%	0.113 ± 2.49%
Langley	0.123 ± 1.26%	0.116 ± 1.34%	0.114 ± 2.55%
Tyndall	0.123 ± 1.50%	0.118 ± 1.88%	0.114 ± 1.71%
MacDill	0.122 ± 3.11%	0.119 ± 3.65%	0.111 ± 3.05%
Shaw	0.122 ± 1.62%	0.117 ± 1.62%	0.113 ± 1.80%
Holloman	0.123 ± 1.75%	0.119 ± 5.44%	0.113 ± 1.50%
Elmendorf	0.121 ± 1.89%	0.115 ± 1.39%	0.111 ± 1.27%
Edwards	0.120 ± 1.34%	0.115 ± 1.23%	0.110 ± 1.06%
Toluene (standard)	0.140 ± 3.71%	0.1317 ± 2.12%	0.1253 ± 3.05%
Toluene (literature value ^a)	0.1366	0.1308	0.1250

^aLiterature values from Venart & Mani, Can. J. Chem. 49, 2468 (1971).

^bStandard deviation of 6-8 measurements made at each temperature.




Figure B19. Thermal Conductivity Versus Temperature




Figure B20. Thermal Conductivity Versus Temperature

TABLE B7
COMPARISON OF TYPICAL JP-4 AND AVERAGED F100 SAMPLES
THERMAL CONDUCTIVITY

Temperature (°C)	Thermal Conductivity (watt/meter °K)	
	Typical JP-4	F100 Samples
0	.1188	.122
20	.1155	.117
40	.1118	.112

TABLE B8
SPECIFIC HEAT ANALYSES

Sample	Specific Heat (cal/g/°C)					
	35°C	45°C	55°C	65°C	75°C	85°C
Hill	0.489 ± .002	0.500 ± .002	0.511 ± .003	0.520 ± .003	0.529 ± .003	0.538 ± .002
Luke	0.499 ± .005	0.512 ± .002	0.522 ± .003	0.534 ± .007	0.542 ± .006	0.551 ± .003
Langley	0.504 ± .002	0.512 ± .003	0.523 ± .005	0.534 ± .003	0.543 ± .002	0.554 ± .001
Tyndall	0.516 ± .007	0.526 ± .006	0.537 ± .006	0.549 ± .009	0.558 ± .009	0.566 ± .007
MacDill	0.499 ± .007	0.509 ± .006	0.520 ± .005	0.533 ± .009	0.540 ± .009	0.549 ± .007
Shaw	0.505 ± .013	0.517 ± .008	0.526 ± .009	0.536 ± .013	0.546 ± .013	0.555 ± .013
Holloman	0.501 ± .011	0.511 ± .009	0.521 ± .011	0.533 ± .013	0.542 ± .012	0.550 ± .014
Elmendorf	0.487 ± .009	0.497 ± .008	0.510 ± .007	0.522 ± .010	0.531 ± .010	0.543 ± .009
Edwards	0.493 ± .006	0.503 ± .005	0.516 ± .004	0.527 ± .007	0.536 ± .007	0.546 ± .006
Diphenylether (Standard)	0.382	0.388	0.395	0.398	0.405	0.412
Diphenylether ^a (Literature Value)	0.382	0.388	0.394	0.401	0.407	0.414

^aDiphenylether literature values interpolated from D.C. Ginnings and G.T. Furukawa, J. Amer. Chem. Soc. 75, 522 (1953).

TABLE B9
COMPARISON OF TYPICAL JP-4 AND AVERAGED F100 SAMPLES
SPECIFIC HEAT AS A FUNCTION OF TEMPERATURE

Temperature (°C)	Specific Heat (cal/g °C)	
	Typical JP-4	F100 Samples
35	.507	.499
45	.517	.510
55	.528	.521
65	.538	.532
75	.547	.541
85	.559	.550

TABLE B10
SIMULATED DISTILLATION DATA FOR HILL SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	29	84
1.0	31	87
5.0	58	137
10	78	172
20	99	209
30	112	233
40	127	261
50	141	286
60	152	305
70	164	327
80	175	347
90	195	383
95	213	416
99	251	483
99.5	262	503

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR HILL SAMPLE




Figure B21. Distillation Curves

TABLE B11
SIMULATED DISTILLATION DATA FOR LUKE SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	30	86
1.0	32	90
5.0	59	139
10	73	163
20	91	196
30	102	216
40	118	244
50	135	275
60	150	303
70	168	335
80	191	376
90	221	430
95	239	463
99	270	518
99.5	281	537

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR LUKE SAMPLE




Figure B22. Distillation Curves

TABLE B12
SIMULATED DISTILLATION DATA FOR HOLLOMAN SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	27	80
1.0	28	82
5.0	58	137
10	77	170
20	98	209
30	116	241
40	136	277
50	159	317
60	180	356
70	202	396
80	222	432
90	245	472
95	260	501
99	305	581
99.5	318	604

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR HOLLOMAN SAMPLE




Figure B23. Distillation Curves

TABLE B-13
SIMULATED DISTILLATION DATA FOR ELMENDORF SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	34	93
1.0	37	98
5.0	66	150
10	79	175
20	91	196
30	100	212
40	109	228
50	116	241
60	124	255
70	135	274
80	152	306
90	225	419
95	249	479
99	289	552
99.5	303	577




Figure B24. Distillation Curves

TABLE B14
SIMULATED DISTILLATION DATA FOR EDWARDS SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	27	80
1.0	28	82
5.0	59	138
10	74	166
20	97	207
30	114	238
40	127	261
50	142	287
60	160	319
70	181	358
80	209	409
90	238	460
95	258	496
99	293	559
99.5	305	580




Figure B25. Distillation Curves

TABLE B-15
SIMULATED DISTILLATION DATA FOR NELLIS SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	27	80
1.0	28	83
5.0	65	149
10	83	181
20	101	213
30	121	250
40	139	282
50	159	317
60	177	350
70	198	388
80	220	428
90	244	471
95	260	500
99	288	550
99.5	296	565

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR NELLIS SAMPLE




Figure B26. Distillation Curves

TABLE B16
SIMULATED DISTILLATION DATA FOR LANGLEY SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	29	83
1.0	35	95
5.0	56	134
10	66	150
20	89	193
30	112	233
40	124	256
50	142	288
60	163	326
70	186	367
80	209	408
90	233	451
95	247	477
99	269	516
99.5	275	527




Figure B27. Distillation Curves

TABLE B17
SIMULATED DISTILLATION DATA FOR TYNDALL SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	27	81
1.0	28	83
5.0	59	138
10	87	189
20	117	243
30	126	259
40	136	277
50	141	286
60	145	293
70	164	328
80	196	385
90	229	444
95	249	479
99	273	524
99.5	283	542

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION TYNDALL SAMPLE




Figure B28. Distillation Curves

TABLE B18
SIMULATED DISTILLATION DATA FOR MACDILL SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	29	84
1.0	35	95
5.0	57	135
10	67	152
20	95	203
30	117	243
40	139	282
50	163	326
60	187	369
70	206	402
80	224	435
90	244	470
95	255	491
99	279	534
99.5	288	550

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR MACDILL SAMPLE




Figure B29. Distillation Curves

TABLE B19
SIMULATED DISTILLATION DATA FOR SHAW SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	29	84
1.0	34	94
5.0	56	133
10	62	144
20	87	189
30	111	232
40	142	288
50	172	341
60	189	373
70	206	402
80	223	433
90	244	470
95	257	495
99	291	556
99.5	304	579

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR SHAW SAMPLE




Figure B30. Distillation Curves

TABLE B20
SIMULATED DISTILLATION DATA FOR EGLIN SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	28	82
1.0	29	84
5.0	62	143
10	92	198
20	119	246
30	132	269
40	141	285
50	145	293
60	168	334
70	198	388
80	225	437
90	252	486
95	271	520
99	321	610
99.5	333	632

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR EGLIN SAMPLE




Figure B31. Distillation Curves

TABLE B21
SIMULATED DISTILLATION DATA FOR HAHN SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	27	81
1.0	32	90
5.0	35	95
10	60	141
20	96	205
30	118	244
40	141	286
50	160	320
60	175	346
70	192	378
80	208	406
90	228	443
95	244	471
99	276	529
99.5	288	550




Figure B32. Distillation Curves

TABLE B22
SIMULATED DISTILLATION DATA FOR BITBURG SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	27	81
1.0	30	85
5.0	57	135
10	71	160
20	98	208
30	124	255
40	149	301
50	170	338
60	185	366
70	200	392
80	216	421
90	235	456
95	252	485
99	285	545
99.5	295	563

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR BITBURG SAMPLE




Figure B33. Distillation Curves

TABLE B23
SIMULATED DISTILLATION DATA FOR AVIANO SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	26	79
1.0	27	81
5.0	56	133
10	87	189
20	107	225
30	118	244
40	130	266
50	141	286
60	150	302
70	165	329
80	186	367
90	216	421
95	232	450
99	253	487
99.5	257	495

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR AVIANO SAMPLE




Figure B34. Distillation Curves

TABLE B24
SIMULATED DISTILLATION DATA FOR ZARAGOZA SAMPLE

<u>% Recovered</u>	<u>Temperature</u>	
	<u>°C</u>	<u>°F</u>
0.5	29	84
1.0	35	95
5.0	37	98
10	55	131
20	93	199
30	121	250
40	145	293
50	165	330
60	181	357
70	197	387
80	217	422
90	240	463
95	270	517
99	351	664
99.5	370	698




Figure B35. Distillation Curves

TABLE B25
SIMULATED DISTILLATION DATA FOR CAMP NEW AMSTERDAM SAMPLE

<u>%</u> <u>Recovered</u>	<u>°C</u>	83-POSF-1283	<u>°F</u>
0.5	29		84
1.0	34		94
5.0	66		151
10	82		179
20	100		212
30	127		260
40	152		305
50	173		344
60	189		371
70	205		401
80	226		439
90	252		486
95	282		539
99	351		663
99.5	373		703




Figure B36. Distillation Curves

TABLE B26
SIMULATED DISTILLATION DATA FOR TORREJON SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	28	82
1.0	34	93
5.0	58	137
10	73	163
20	100	213
30	126	258
40	149	300
50	167	332
60	183	361
70	199	391
80	217	423
90	238	460
95	259	498
99	313	595
99.5	330	626




Figure B37. Distillation Curves

TABLE B27
SIMULATED DISTILLATION DATA FOR OSAN SAMPLE

<u>% Recovered</u>	<u>Temperature</u>	
	<u>°C</u>	<u>°F</u>
0.5	10	50
1.0	28	83
5.0	50	122
10	64	147
20	96	205
30	123	253
40	148	298
50	166	331
60	180	356
70	195	383
80	214	417
90	234	453
95	253	487
99	317	603
99.5	330	626




Figure B38. Distillation Curves

TABLE B28
SIMULATED DISTILLATION DATA FOR CLARK SAMPLE

<u>% Recovered</u>	<u>Temperature</u>	
	<u>°C</u>	<u>°F</u>
0.5	28	82
1.0	29	84
5.0	54	129
10	72	162
20	98	209
30	110	229
40	119	247
50	134	274
60	146	296
70	165	330
80	188	370
90	222	432
95	252	486
99	325	617
99.5	342	647

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR CLARK SAMPLE




Figure B39. Distillation Curves

TABLE B29
SIMULATED DISTILLATION DATA FOR ANDERSON SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	31	88
1.0	33	92
5.0	60	140
10	73	163
20	97	207
30	110	230
40	124	255
50	139	282
60	154	310
70	173	343
80	200	391
90	246	475
95	283	541
99	322	611
99.5	334	634

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR ANDERSON SAMPLE




Figure B40. Distillation Curves

TABLE B30
SIMULATED DISTILLATION DATA FOR KADENA SAMPLE

<u>% Recovered</u>	Temperature	
	<u>°C</u>	<u>°F</u>
0.5	29	85
1.0	31	87
5.0	67	152
10	84	183
20	99	211
30	108	226
40	118	245
50	126	259
60	139	282
70	151	305
80	180	355
90	220	427
95	248	478
99	293	559
99.5	311	591

SIMULATED DISTILLATION BOILING POINT
DISTRIBUTION FOR KADENA SAMPLE




Figure B41. Distillation Curves

TABLE B31
HYDROCARBON TYPE ANALYSES

	Hill		Luke		Holloman		Elmendorf		Edwards	
	ASTM ^a	Monsanto	ASTM	Monsanto	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b
Paraffins	51.4	43.1	42.8	37.1	44.7	37.7	42.5	36.0	43.7	36.5
Cycloparaffins	30.5	- ^c	37.9	- ^c	32.6	- ^c	39.5	- ^c	37.4	- ^c
Dicycloparaffins	2.9	- ^c	2.9	- ^c	4.4	- ^c	1.3	- ^c	5.4	- ^c
Total cyclo- paraffins	33.4 ^d	36.1	40.8 ^d	39.9	37.0 ^d	37.2	40.8 ^d	40.9	42.8 ^d	45.4
Alkylbenzenes	14.3	20.8	14.6	22.1	15.9	22.8	15.9	23.1	10.4	15.2
Indans and tetralins	0.2	0	1.0	0.6	1.5	1.4	0.3	0	2.2	2.5
Indenes and di- hydronaphthalenes	- ^c	0	- ^c	0	- ^c	0	- ^c	0	- ^c	0
Naphthalenes	0.7	0	0.8	0.3	0.9	0.9	0.5	0	0.9	0.4
Average carbon no.	8.2		8.3		8.8		7.8		8.5	

^aModification of ASTM Method D 2789, values converted from volume percent using relative densities.

^bMonsanto Method 21-PQ-38-63.

^cDash indicates method does not provide information on this specific compound category.

^dSum of two preceding values.

TABLE B31 (Continued)
HYDROCARBON TYPE ANALYSES

	Nellis		Langley		Tyndall		MacDill		Shaw	
	ASTM ^a	Monsanto ^b	ASTM	Monsanto	ASTM	Monsanto	ASTM	Monsanto	ASTM	Monsanto
Paraffins	39.6	33.2	60.2	54.1	66.0	59.2	56.0	48.0	57.6	50.9
Cycloparaffins	37.4	-	22.3	- ^c	13.7	- ^c	21.5	- ^c	21.4	- ^c
Dicycloparaffins	8.1	-	4.2	- ^c	3.0	- ^c	5.7	- ^c	5.8	- ^c
Total cycloparaffins	45.5 ^d	46.3	26.5 ^d	28.1	16.7 ^d	16.1	27.2 ^d	27.6	27.2 ^d	27.0
Alkylbenzenes	11.0	16.0	10.5	15.9	15.8	23.9	12.9	19.8	11.6	17.4
Indans and tetra- lins	2.9	3.5	1.8	1.9	1.0	0.8	2.8	3.3	2.4	2.7
Indenes and dihydro- naphthalenes	- ^c	0	- ^c	0	- ^c	0	- ^c	0	- ^c	0
Naphthalenes	1.0	1.0	1.0	0	0.5	0	1.1	1.3	1.2	1.1
Average carbon no.	9.0		8.5		8.9		9.1		8.9	

^aModification of ASTM Method D 2789, values converted from volume percent using relative densities.

^bMonsanto Method 21-PQ-38-63.

^cDash indicates method does not provide information on these specific compound categories.

^dSum of two preceding values.

TABLE B31 (Continued)
HYDROCARBON TYPE ANALYSES

	Eglin		Hahn		Bitburg		Aviano		Zaragoza	
	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b
Paraffins	64.6	57.7	57.9	51.6	57.0	50.7	56.1	49.4	58.3	52.2
Monocycloparaffins	16.3	- ^c	24.4	- ^c	24.6	- ^c	28.3	- ^c	24.7	- ^c
Dicycloparaffins	4.1	- ^c	3.9	- ^c	4.4	- ^c	3.2	- ^c	4.1	- ^c
Total cycloparaffins	20.4 ^d	20.6	28.3	29.4	29.0 ^d	30.1	31.5 ^d	33.1	28.8 ^d	30.1
Alkylbenzenes	12.7	19.6	11.6	17.5	11.2	16.9	11.2	16.7	10.7	16.2
Indans and tetralins	1.5	1.6	1.5	1.4	1.9	2.0	0.9	0.8	1.5	1.5
Indenes and dihydro- naphthalenes	- ^c	0	- ^c	0	- ^c	0	- ^c	0	- ^c	0
Naphthalenes	0.8	0.5	0.7	0.1	0.9	0.3	0.3	0	0.7	0
Average carbon no.	9.1		8.7		8.7		8.7		8.7	

^aModification of ASTM Method D2789, values converted from volume percent using relative densities.

^bMonsanto Method 21-PQ-38-63.

^cDash indicates method does not provide information on these specific compound categories.

^dSum of two preceding values.

TABLE B31 (Continued)
HYDROCARBON TYPE ANALYSES

	Camp New Amsterdam		Torrejon		Osan		Clark	
	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b	ASTM ^a	Monsanto ^b
Paraffins	54.3	49.1	57.5	51.9	58.5	52.5	50.7	43.1
Monocycloparaffins	25.4	- ^c	26.2	- ^c	22.8	- ^c	30.6	- ^c
Dicycloparaffins	5.4	- ^c	4.3	- ^c	4.1	- ^c	2.6	- ^c
Total cycloparaffins	30.8 ^d	30.2	30.5	31.4	26.9 ^d	27.4	33.2 ^d	35.0
Alkylbenzenes	12.1	17.9	9.8	14.8	12.3	18.6	14.5	21.8
Indans and tetralins	2.0	2.1	1.6	1.7	1.6	1.5	0.8	0.1
Indenes and dihydro-	- ^c	0	- ^c	0	- ^c	0	- ^c	0
naphthalenes								
Naphthalenes	0.8	0.7	0.6	0.2	0.7	0	0.8	0
Average carbon no.	9.1		8.9		8.7		8.1	

^aModification of ASTM Method D-2789, values converted from volume percent using relative densities.

^bMonsanto Method 21-PQ-38-63.

^cDash indicates method does not provide information on these specific compound categories.

^dSum of two preceding values.

TABLE B31 (Concluded)
HYDROCARBON TYPE ANALYSES

	Anderson		Kadena		Monsanto	
	ASTM ^a	Monsanto ^b	ASTM	Monsanto	ASTM	Monsanto
Paraffins	49.5	41.5	55.2	49.4	55.2	49.4
Monocycloparaffins	31.0	- ^c	27.4	- ^c	27.4	- ^c
Dicycloparaffins	2.3	- ^c	2.2	- ^c	2.2	- ^c
Total cycloparaffins	33.3	34.5	29.6	29.6	29.6	29.6
Alkylbenzenes	15.7	24.0	13.7	20.9	13.7	20.9
Indans & Tetralins	0.7	0	0.6	0.1	0.6	0.1
Indenes & dihydronaphthalenes	- ^c	0	- ^c	0	- ^c	0
Naphthalenes	0.8	0	0.9	0	0.9	0
Average carbon number	8.2	0	8.3	0	8.3	0

^aModification of ASTM Method D 2789, values converted from volume percent using relative densities.

^bMonsanto Method 21-PQ-38-63.

^cDash indicates method does not provide information on these specific compound categories.

^dSum of two preceding values.

TABLE B32
CORRELATIONS BETWEEN DISTILLATION DATA AND HYDROCARBON TYPE ANALYSES

Correlation	Correlation Coefficient
FBP vs Paraffins	.07
FBP vs Cycloparaffins	-.09
FBP vs Dicycloparaffins	.28
FBP vs Total Cycloparaffins	-.04
FBP vs Indans & Tetralins	.10
FBP vs Naphthalenes	.08
FBP vs Average Carbon Number	.20

TABLE B33
GC NORMAL PARAFFIN ANALYSES

	Hill		Luke		Holloman	
	% of Total	% of n-paraffin	% of Total	% of n-paraffin	% of Total	% of n-paraffin
C-5	1.391	6.33	2.143	11.54	2.363	11.71
C-6	2.945	13.41	3.724	20.05	3.015	14.94
C-7	3.637	16.56	3.099	16.69	2.547	12.62
C-8	5.975	26.98	2.739	14.75	2.414	11.96
C-9	4.325	19.69	2.297	12.37	2.153	10.67
C-10	2.196	10.00	1.646	8.86	2.221	11.00
C-11	.867	3.95	1.190	6.41	2.198	10.89
C-12	.344	1.57	.935	5.03	1.759	8.71
C-13	.186	0.85	.541	2.91	1.113	5.51
C-14	.096	0.44	.186	1.00	.323	1.60
C-15	.037	0.17	.052	0.28	.051	0.25
C-16	.011	0.05	.020	0.11	.022	0.11
C-17	-	-	-	-	.007	0.03
TOTAL	21.960	100	18.572	100	20.186	100

TABLE B33 (Continued)
GC NORMAL PARAFFIN ANALYSES

	Langley		Lyndall		MacDill		Shaw	
	% of Total % of n-paraffin	% of Total % of n-paraffin	% of Total % of n-paraffin	% of Total % of n-paraffin	% of Total % of n-paraffin	% of Total % of n-paraffin	% of Total % of n-paraffin	% of Total % of n-paraffin
C-5	1.074	4.73	1.319	6.74	1.327	6.07	1.226	5.19
C-6	5.383	23.70	1.614	8.25	4.763	21.77	6.272	26.57
C-7	4.779	21.04	7.480	38.22	3.246	14.84	1.829	7.75
C-8	2.724	11.99	3.411	17.43	1.746	7.98	1.535	6.71
C-9	2.180	9.60	1.201	6.14	1.731	7.91	2.694	11.41
C-10	2.114	9.31	1.266	6.47	2.419	11.06	3.385	14.34
C-11	1.821	8.02	1.211	6.19	2.388	10.92	2.731	11.57
C-12	1.433	6.31	.980	5.01	2.080	9.51	2.024	8.57
C-13	.876	3.86	.699	3.57	1.497	6.84	1.343	5.69
C-14	.266	1.17	.257	1.31	.548	2.50	.408	1.73
C-15	.060	0.26	.061	0.31	.112	0.51	.089	0.38
C-16	-	-	.070	0.36	.020	0.09	.023	0.09
C-17	-	-	-	-	-	-	-	-
TOTAL	22.71	100	19.569	100	21.877	100	23.609	100

TABLE B33 (Continued)
GC NORMAL PARAFFIN ANALYSES

	Eglin	Hahn	Bitburg	Aviano	
	% of Total % of n-paraffin % of Total % of n-paraffin % of Total % of n-paraffin				
C-5	1.654	2.594	2.840	2.874	11.47
C-6	1.595	3.972	4.312	1.407	5.61
C-7	6.966	3.794	2.983	6.988	27.88
C-8	3.225	3.897	2.768	6.349	25.33
C-9	.943	4.340	3.885	3.071	12.25
C-10	1.410	4.054	3.757	1.582	6.31
C-11	1.417	2.943	3.088	1.455	5.81
C-12	1.204	1.700	1.980	.897	3.58
C-13	1.011	.786	.945	.365	1.46
C-14	.475	.156	.186	.065	0.26
C-15	.137	.031	.030	.011	0.04
C-16	.037	.009	-	-	-
C-17	-	-	-	-	-
TOTAL	20.074	28.276	26.774	25.064	100

TABLE B33 (Continued)
GC NORMAL PARAFFIN ANALYSES

	Zaragoza		Camp New Amsterdam		data not available		data not available	
	% of Total % of n-paraffin	% of Total % of n-paraffin	% of Total % of n-paraffin	% of Total % of n-paraffin	Torrejon	Osan	% of Total % of n-paraffin	% of Total % of n-paraffin
C-5	2.919	9.84	.938	3.87				
C-6	3.568	12.02	3.233	13.35				
C-7	3.490	11.76	2.882	11.90				
C-8	4.113	13.86	2.801	11.56				
C-9	4.828	16.27	4.243	17.52				
C-10	4.404	14.84	3.836	15.84				
C-11	3.330	11.22	2.632	10.87				
C-12	1.996	6.73	1.994	8.23				
C-13	.811	2.73	1.310	5.41				
C-14	.174	0.59	.299	1.23				
C-15	.037	0.12	.046	.19				
C-16	.007	0.02	.010	0.04				
C-17	-	-	-	-				
TOTAL	29.677	100	24.224	100				

TABLE B33 (Concluded)
GC NORMAL PARAFFIN ANALYSES

	Clark		Anderson		Kadena	
	% of Total	% of n-paraffin	% of Total	% of n-paraffin	% of Total	% of n-paraffin
C-5	1.845	9.32	2.210	10.74	1.839	8.93
C-6	2.807	14.18	3.910	19.01	3.111	15.10
C-7	5.366	27.11	3.914	19.03	7.834	38.03
C-8	3.764	19.01	3.691	17.94	3.502	17.00
C-9	2.513	12.69	2.551	12.40	1.701	8.26
C-10	1.661	8.39	1.716	8.34	1.306	6.34
C-11	1.080	5.46	1.191	5.79	.678	3.29
C-12	.481	2.43	.776	3.77	.392	1.90
C-13	.195	.99	.430	2.09	.164	0.80
C-14	.063	.32	.141	.69	.059	0.29
C-15	.021	.11	.039	.19	.014	0.07
C-16	-	-	-	-	-	-
C-17	-	-	-	-	-	-
TOTAL	19.796	100	20.569	100	20.600	100

REFERENCES

1. R.H. Perry, C.H. Chilton, Chemical Engineer's Handbook, McGraw-Hill, Inc, New York, 1973.
2. 1981 Annual Book of ASTM Standards, American Society for Testing and Materials, Philadelphia, 1981.
3. W.E. Harrison, The Chemical and Physical Properties of JP-4 for 1980-1981, Aero Propulsion Laboratory, Wright-Patterson AFB, Ohio 45433, AFWAL-TR-82-2052, June 1982.
4. J. Petrarca, Aviation Turbine Fuel Lubricity Evaluation of Corrosion Inhibitors, Air Force Aero Propulsion Laboratory, Wright-Patterson AFB, Ohio 45433, AFAPL-TR-75-47, September 1975.
5. F.N. Hodgson, E.A. Steinmetz, et al., Analysis of Aircraft Fuels and Related Materials, Aero Propulsion Laboratory, Wright-Patterson AFB, Ohio 45433, AFWAL-TR-82-2082, September 1982.
6. Maxwell Smith, Aviation Fuels, GT Foulis and 10 Ltd, Oxforshire, UK, 1970.
7. Aviation Fuel Properties, Coordinating Research Council, Atlanta, Georgia, CRC Report No. 530, 1983.