

AD-A173 276

PROPOSAL FOR RESEARCH INSTRUMENTATION(U) YALE UNIV NEW
HAVEN CT DEPT OF MECHANICAL ENGINEERING
H B LONG ET AL. DEC 85 AFOSR-TR-86-0928 AFOSR-83-0285


1/1

UNCLASSIFIED

F/G 14/2

NL





MICROCOPY RESOLUTION TEST CHART
NATIONAL BUREAU OF STANDARDS-1963-A

2

AFOSR-TR. 86-0928

AD-A173 276

DTIC
ELECTE
OCT 20 1986
S D

Final Report
to the
Air Force Office of Scientific Research

PROPOSAL FOR RESEARCH INSTRUMENTATION

Approved for public release;
distribution unlimited.

AFOSR Grant No. 83-0285

July 1, 1983 - June 30, 1984

Marshall B. Long, Richard K. Chang, Boa-Teh Chu

Principal Investigators

Yale University
Department of Mechanical Engineering and
Center for Laser Diagnostics
New Haven, Connecticut 06520

DTIC FILE COPY

December, 1985

AD-A173 276
DTIC FILE COPY
OCT 20 1986
S D

86 10 16 201

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE

AD-A17276

REPORT DOCUMENTATION PAGE

1a. REPORT SECURITY CLASSIFICATION Unclassified		1b. RESTRICTIVE MARKINGS	
2a. SECURITY CLASSIFICATION AUTHORITY		3. DISTRIBUTION/AVAILABILITY OF REPORT Approved for public release; distribution unlimited.	
2b. DECLASSIFICATION/DOWNGRADING SCHEDULE		4. PERFORMING ORGANIZATION REPORT NUMBER(S)	
4. PERFORMING ORGANIZATION REPORT NUMBER(S)		5. MONITORING ORGANIZATION REPORT NUMBER(S) AFOSR-TR. 86-0928	
6a. NAME OF PERFORMING ORGANIZATION Yale University Applied Physics & Mech. Eng.	6b. OFFICE SYMBOL (If applicable)	7a. NAME OF MONITORING ORGANIZATION DoD, Univ. Research Instrumentation Program Air Force Office of Scientific Research/NA	
6c. ADDRESS (City, State and ZIP Code) P.O. Box 2157, Yale Station New Haven, CT 06520		7b. ADDRESS (City, State and ZIP Code) Building 410 Bolling Air Force Base, DC 20332-6448	
8a. NAME OF FUNDING/SPONSORING ORGANIZATION AFOSR	8b. OFFICE SYMBOL (If applicable) NA	9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER AFOSR Grant No. 83-0285	
8c. ADDRESS (City, State and ZIP Code) Bolling AFB DC 20332-6448		10. SOURCE OF FUNDING NOS.	
11. TITLE (Include Security Classification) PROPOSAL FOR RESEARCH INSTRUMENTATION		PROGRAM ELEMENT NO. 61102F	PROJECT NO. 2308
12. PERSONAL AUTHOR(S) Marshall B. Long, Richard K. Chang, Boa-Teh Chu		TASK NO. A3	WORK UNIT NO.
13a. TYPE OF REPORT Final	13b. TIME COVERED FROM 7/1/83 TO 6/30/84	14. DATE OF REPORT (Yr., Mo., Day) December 19, 1985	15. PAGE COUNT 20
16. SUPPLEMENTARY NOTATION			
17. COSATI CODES		18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number)	
FIELD	GROUP	SUB. GR.	Rayleigh scattering, velocity, laser diagnostics, flames, temperature mapping, scalar gradient
19. ABSTRACT (Continue on reverse if necessary and identify by block number) A summary is given of the progress to date using two new laser/multichannel detection systems obtained with the DoD-University Research Instrumentation Program funding. Progress has been made in several different areas including: (1) high-speed mapping of gas concentrations in turbulent flows, (2) use of Rayleigh scattering for temperature mapping in turbulent diffusion flames, (3) measurement of the full three-dimensional scalar gradient in a plane, and (4) measurement of multipoint three-component velocities in a large volume. A summary of research in these areas is given along with a description of future studies to be carried out using the equipment acquired under this program.			
20. DISTRIBUTION/AVAILABILITY OF ABSTRACT UNCLASSIFIED/UNLIMITED <input type="checkbox"/> SAME AS RPT. <input checked="" type="checkbox"/> DTIC USERS <input type="checkbox"/>		21. ABSTRACT SECURITY CLASSIFICATION Unclassified	
22a. NAME OF RESPONSIBLE INDIVIDUAL Leonard H. Caveny		22b. TELEPHONE NUMBER (Include Area Code) (202) 467-4937	22c. OFFICE SYMBOL NA

ABSTRACT

A summary is given of the progress to date using two new laser/multichannel detection systems obtained with DoD-University Research Instrumentation Program funding. Progress has been made in several different areas including: (1) high-speed mapping of gas concentrations in turbulent flows, (2) use of Rayleigh scattering for temperature mapping in turbulent diffusion flames, (3) measurement of the full three-dimensional scalar gradient in a plane, and (4) measurement of multipoint three-component velocities in a large volume. A summary of research in these areas is given along with a description of future studies to be carried out using the equipment acquired under this program.

Accession For	
NTIS CRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By _____	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A-1	



INTRODUCTION

Researchers associated with the Yale Center for Laser Diagnostics have been using laser scattering techniques to investigate a number of different physical processes. Although several different research areas are being actively pursued at the Center, a common base for these diverse experiments has been the use of laser scattering and multichannel detection systems which enable the simultaneous measurement of scattered intensities in the spatial and/or spectral domains. Through the efforts in this area, several new diagnostic techniques in the field of turbulence and combustion have been introduced. Under the DoD-University Research Instrumentation Program, we have sought to upgrade the facilities of the Center to keep pace with major advances in both detectors and lasers. The availability of these new systems has allowed the members of the Center to embark on totally new diagnostic programs in the turbulence/combustion field. These programs should provide new information on the mixing in turbulent reacting flows and on multipoint three-component velocities in a large volume. Obtaining such information would have been considered impossible prior to these advances in high technology.

RESEARCH ACCOMPLISHMENTS

During the initial period of the grant, a study was done to determine the optimum source of the laser and detector systems that were to be purchased. Since these are rapidly developing technologies, the products available are in a constant state of flux. After determination of the vendors, the equipment was ordered and preliminary experiments were carried out with facilities existing within the Center for Laser Diagnostics.

With the funds made available through this grant, the following equipment was purchased:

1) High-speed laser/imaging system including:

High-speed two-dimensional diode array camera
Microtex Corporation
Model 7402

Two-stage microchannel plate image intensifier
ITT Electroptical Products Division
Model F414420MCP

Copper Vapor Laser System
Plasma Kinetics, Inc.
Model 451

2) Three-dimensional velocity diagnostic system:

1024 x 1280 Element High Resolution Camera
Microtex Corporation
Model 7602

Nd:YAG Oscillator/Amplifier and Dye Laser
Quanta-Ray, Inc.
Models DCR-2A and PDL-1

Following is a summary of our work in the areas of research in which the equipment has been used to date.

Temporal Development of Structures in Turbulent Flows

The importance of large-scale structures and the role they play in turbulence has prompted the development of several new experimental techniques for quantitatively measuring characteristics of these structures in two dimensions. Nozzle gas concentration distributions have been mapped out at a single instant by detecting the elastically scattered light from an aerosol laden flow.¹ In a similar way, other light scattering processes have been used for quantitative two-dimensional mapping of structures within turbulent flows, including Rayleigh scattering from gas molecules,² fluorescence,³ and Raman scattering.⁴ While the two-dimensional information offered by these techniques is valuable, the detectors used did not allow images to be recorded at a rate high enough to observe changes in the structures from one frame to the next. Thus it is difficult to study the evolution of large-scale structures utilizing these techniques.

High-speed imaging systems must be used to study the evolution of large-scale structures in a general way. The DoD-University Instrumentation program enabled investigators at the Center for Laser Diagnostics to obtain an electronically based system which is capable of high framing rates, directly quantifiable output, and real-time data display. This type of fast electro-optical data acquisition scheme holds great potential for applications in experimental fluid mechanics. By directly digitizing images consisting of a large number of points at a high repetition rate, one can extract such information

as convection velocities, the intermittency factor, or the mixing associated with a given structure as it travels downstream.

The experimental setup used for our initial high-speed imaging experiments is shown schematically in Fig. 1. The air was seeded with micron-sized aerosol particles and then passed through a 4 mm diameter axisymmetric nozzle. The nozzle was equipped with a stagnation chamber which was attached to a differential manometer for determining flow velocity.

An Ar⁺ laser operated on all lines was pulsed using an acousto-optic modulator, then focused into a sheet and used to illuminate a radial cross section of the jet. The sheet of light was formed by passing the laser beam back and forth repeatedly between two opposing cylindrical reflectors as shown in the figure.

An image frame of 14.5 x 14.5 mm² was imaged onto the photodiode array of a Reticon MC9128 camera, using two camera lenses. The Reticon camera was interfaced directly to an LSI 11/23 computer using a Microtex 7402 camera/computer interface with 1.25 Mbytes of high-speed memory. The pixel rate for this system was 8 MHz and, through software control, the user could designate the array width to be used, (i.e., number of pixels). When scanning the full 128 x 128 photodiode array, the detector could be operated at a framing rate of ~400 Hz and a total of 80 frames could be collected in one data acquisition sequence. A much higher framing rate was necessary for the flow conditions considered here. To this end, the array was operated in a 128 x 32 pixel format which allowed for storage of 320 consecutive images. The data shown in Fig. 2 were collected at




Fig. 1. Experimental configuration used for continuous two-dimensional concentration measurements at 1.136 kHz. The Ar⁺ laser is pulsed using an acousto-optic modulator (AOM) which is synchronized with a photodiode array. The beam is formed into a thin sheet and the scattered light from the jet is proportional to the nozzle gas concentration.




Fig. 2. A sequence of nozzle gas concentration measurements recorded at 1.136 kHz. The flow proceeds downstream from 4 diameters (top) to 7.5 diameters (bottom) at a rate of 3.4 m/sec.

1136 Hz. The flow velocity is 3.4 m/sec corresponding to a Reynolds number of 900. The region shown is from 4 to 7.6 nozzle diameters downstream. The pulse duration used here was 67 μ sec with the laser operating at 5 W.

The raw data as collected by the camera have been corrected for background light and nonuniformities in the response of the camera and the illumination sheet. A dark background was recorded in the absence of the seeded jet. The response of the system was recorded by filling the entire image frame with a seeded gas that was passed through a large nozzle positioned directly into the sheet of light and then averaged over several realizations. The data were then divided by this image to correct for the nonuniformities in the camera, the illumination sheet, and the collection optics. These corrections ensure that the data obtained from these experiments are a quantitative measure of the gas concentration.

For the results described above, the diode array camera could be operated in an unintensified mode because of the relatively strong signals produced by Lorenz/Mie scattering from aerosols. In the future, an intensified version of the camera will be used in conjunction with the Cu vapor laser (Plasma Kinetics 451). With the intensifier and the high repetition rate available from the pulsed Cu vapor laser, the system will be able to detect molecular scattering mechanisms such as Rayleigh scattering and fluorescence at rates greater than 1 kHz.

Because a major fraction of the cost of such a low-light-level, high-speed camera system is the microchannel plate image intensifier

and the A/D conversion electronics, the solid-state detector was not permanently attached to the intensifier. This will make it possible to take advantage of future advancements in solid-state detector technology (connected with VLSI development), as well as to change the resolution of the system by simply changing solid-state detectors.

Rayleigh Scattering Temperature Mapping

Our new, recently established capability uses Rayleigh scattering to provide an instantaneous mapping of the two-dimensional temperature distribution in a turbulent nonpremixed flame. In this work, the Rayleigh scattered light from an illuminated plane intersecting the flow field is imaged onto a computer-controlled low-light-level television camera and digitized in an 8,000 data point array. The fuel is a mixture of methane and hydrogen selected in proportions that will cause the Rayleigh cross section of the fuel gas mixture to be the same as that of the ambient coflowing air. For this fuel mixture, the Rayleigh scattered intensity will be directly proportional to the number density of molecules in the flow and, therefore, inversely proportional to the temperature.

Although Rayleigh temperature measurements have been previously reported for single-point measurements,⁵ our work represents the first time that the technique has been applied in two dimensions. In this study, particular attention has been directed toward making the data obtained in this way as accurate as possible. This involves the proper correction of the data for both background level and nonuniformities of the illumination sheet and detector gain. These

data corrections are somewhat different from those required for single-point Rayleigh measurements because of the special requirements of two-dimensional imaging. The experimental details of the work and calculated quantities based on the results have been accepted for publication.⁶

Figure 3 shows a schematic representation of the experimental configuration used for the two-dimensional mapping of temperature using Rayleigh scattering. Three instantaneous temperature measurements obtained with Rayleigh scattering from three different laser shots are presented in Fig. 4. In the figure, the vertical component of the plot represents the amplitude of the temperature at each (x,y) coordinate in the flame.

This technique can be applied to a large number of diffusion and premixed flames. The two-dimensional nature of these data makes possible the study of large-scale structures in flows and, because the data are quantitative, it is possible to calculate various statistical quantities which can be expected to provide useful information on the nature and role of large-scale structures in the flame.

Instantaneous Two-Dimensional Mapping of the Complete Three-Dimensional Scalar Gradient

While the two-dimensional measuring techniques discussed above represent significant progress in the effort to characterize structures in turbulent flows, turbulence is known to be three dimensional and even more information is needed to fully characterize the complex processes involved. For example, the joint probability




Fig. 3. Experimental apparatus used for obtaining the instantaneous two-dimensional temperature measurement of a methane-hydrogen diffusion flame.




Fig. 4. Instantaneous two-dimensional Rayleigh thermometry of a methane-hydrogen diffusion flame (a) between 21 and 29 nozzle diameters downstream, (b) between 31 and 39 nozzle diameters downstream, and (c) between 37 and 45 nozzle diameters downstream.

distribution function (pdf) of the gas concentration and the scalar dissipation is of particular interest to modelers of combustion because it is thought to give information about reaction rates in both premixed⁷ and diffusion⁸ flames. To obtain this joint pdf, instantaneous measurements of all three components of the concentration gradient vector are needed.

Using the equipment purchased with this grant, a new technique has been developed that allows calculation of all three instantaneous components of the concentration gradient vector within a cross section of a turbulent flow.⁹ This is accomplished by the simultaneous measurement of gas concentrations from two closely-spaced parallel cross sections of the flow using laser Rayleigh scattering. The x and y components of the gradient vector are calculated from data within one of the cross sections and the z component is determined from corresponding points in the two adjacent planes.

As depicted in Fig. 5, the vertically polarized second-harmonic output of a pulsed Nd:YAG laser (Quanta Ray DCR-2A) was split into two parts. Half the output was used to pump a dye laser (Quanta Ray PDL-1 using Rhodamine 6G), and the other half was apertured to produce an energy comparable to the dye laser output. The resulting Nd:YAG (532 nm) and dye beam (563 nm) energies were 4.7 and 8.8 mJ, respectively. The two beams were then directed by independent steering mirrors through the same sheet-forming optics. Adjustment of the steering mirrors controlled the angle between the two sheets, hence their separation at the nozzle. A linear photodiode array (Reticon RL 512G) was used to measure the separation and widths of the





Figure 5

two sheets. The illumination sheets were parallel to the gas flow ejected from the nozzle and intersected the flow at its center.


The Rayleigh scattered light from the two illuminated cross sections of the jet was collimated by a single collecting lens. A beam splitter then directed half the collected light to each of two focusing lenses, which imaged the jet onto two silicon intensified target (SIT) vidicon detectors (PARC OMA-2). These were controlled by a single LSI 11/23 computer which coordinated the camera scanning and data acquisition with the firing of the Nd:YAG laser. A different optical interference filter positioned directly in front of each camera ensured that each received light from only one of the two sheets. The light collection configuration was chosen to minimize the contribution of stray scattering from the surroundings to the raw signal and was similar to that used in a previous two-camera experiment.¹⁰

To demonstrate the capabilities of this technique, a jet of freon ejected into air was investigated. The Rayleigh intensity distributions from the flow field were digitized in a 65 x 78 pixel format, corresponding to resolution volumes of $90 \times 90 \times 100 \mu\text{m}^3$. The maximum separation of the two sheets was 200 μm .


Statistical quantities of interest to combustion modelers can be determined if a large number of instantaneous shots are taken. For example, Fig. 6 shows the joint and independent pdf's of mixture fraction and mixture fraction gradient from a point near the centerline of the flow 14.9 nozzle diameters downstream. Similar data for a point slightly further from the jet centerline are shown in



(a) Joint probability density function (jpdf) of the mixture fraction and its gradient magnitude, calculated from 7000 instantaneous shots at a point 14.9 d downstream from the exit nozzle (diameter $d = 3.5$ mm) of a freon jet ($Re = 3850$), and at a radial distance of $0.13 d$ from the jet centerline. Lighter shading represents a higher joint probability.



(b) Independent pdf of the mixture fraction at the same location in the jet.



(c) Independent pdf of the mixture fraction gradient magnitude. The units of the pdf ensure that the area under the curve equals the dimensionless total probability of one.


Fig. 6.

Fig. 7. In both cases, the pdf's were obtained from 7000 shots. Although the data shown here were obtained in a cold flow, the same technique can be applied to flames.


Multipoint and Multicomponent Velocity Measurements in Three-Dimensions

We are currently developing a holographic technique to use the high resolution camera (Microtex 7602) and Nd:YAG laser (Quanta-Ray DCR-2A) to measure the three-component velocity from many points within the three-dimensional volume of the flow field. If a hologram of an aerosol-seeded flow is taken at a time t , and again at a time $t + \Delta t$ later, the reconstructed double-exposure hologram can be used to determine the velocity at locations in the flow where particles were present. The Nd:YAG laser system will be used in a double-pulsed mode to provide the high intensity required to produce the hologram from the elastic scattering of the seeded particles within the flow. By modulating the intensity of the two laser pulses, it will be possible to unambiguously obtain the direction of the flow. In addition, this will make it easier to determine which two images in the hologram correspond to a single particle. Once the hologram is developed, a means of digitizing the data contained in the reconstructed image is required. The high resolution camera system is needed to obtain the particle positions (and thus the velocity) with sufficient accuracy.


We have successfully used the Nd:YAG laser system to make sideband holograms of a thickly-seeded turbulent air jet. For these



- (a) Joint probability density function (jpdf) of the mixture fraction and its gradient magnitude, calculated from 7000 instantaneous shots at a point $14.9 d$ downstream from the exit nozzle (diameter $d = 3.5 \text{ mm}$) of a freon jet ($Re = 3850$), and at a radial distance of $0.58 d$ from the jet centerline. Lighter shading represents a higher joint probability.



- (b) Independent pdf of the mixture fraction at the same location in the jet.



- (c) Independent pdf of the mixture fraction gradient magnitude. The units of the pdf ensure that the area under the curve equals the dimensionless total probability of one.

Fig. 7.

experiments, the laser was operated with the electronic line narrowing accessory (Quanta-Ray ELN-2), which gave an experimentally determined average coherence length of approximately 15 cm. This is more than adequate for the three-dimensional velocity mapping technique under development. The average energy of 50 mJ per pulse was used to form a sideband hologram of aerosols entrained in a jet of air. Examination of the reconstructed image of the jet indicated that the hologram formed with this laser is capable of resolving micron sized particles.

The problems associated with the automated digital processing of the holographic images obtained are significant. In order to minimize these difficulties, much attention is being given to producing good quality, high resolution, and high contrast images of the aerosol-seeded flow. Concurrently, we are collaborating with experts in digital signal processing to determine the best techniques for use in obtaining velocities from the holograms.

REFERENCES

1. M.B. Long, B.T. Chu, and R.K. Chang, "Instantaneous Two-Dimensional Gas Concentration Measurements by Light Scattering," *AIAA Journal* 19, 1151 (1981).
2. M.C. Escoda and M.B. Long, "Rayleigh Scattering Measurements of the Gas Concentration Field in Turbulent Jets," *AIAA Journal* 21, 81 (1983).
3. M.J. Dyer and D.R. Crosley, "A Rapidly Sequenced Pair of Two-Dimensional Images of HO Laser-Induced Fluorescence in a Flame," *Opt. Lett.* 9, 254 (1984).
4. M.B. Long, D.C. Fourquette, M.C. Escoda, and C.B. Layne, "Instantaneous Ramanography of a Turbulent Diffusion Flame," *Opt. Lett.* 8, 244 (1983).
5. R.W. Dibble and R.E. Hollenbach, "Laser Rayleigh Thermometry in Turbulent Flames," in Eighteenth Symposium (International) on Combustion (The Combustion Institute, Pittsburgh, PA, 1981), p. 1489.
6. D.C. Fourquette, R.M. Zurn, and M.B. Long, "Two-Dimensional Rayleigh Thermometry in a Turbulent Methane-Hydrogen Flame," *Combustion Sci. Tech.* 44, 307 (1985).
7. K.N.C. Bray, in Turbulent Reacting Flows, P.A. Libby and F.A. Williams, eds. (Springer-Verlag, Berlin, 1980), p. 115.
8. R.W. Bilger, in Turbulent Reacting Flows, P.A. Libby and F.A. Williams, eds. (Springer-Verlag, Berlin, 1980), p. 65.
9. B. Yip and M.B. Long, "Instantaneous Planar Measurement of the Complete Three-Dimensional Scalar Gradient in a Turbulent Jet," *Opt. Lett.*, in press.
10. M.B. Long, P.S. Levin, and D.C. Fourquette, "Simultaneous Two-Dimensional Mapping of Species Concentration and Temperature in Turbulent Flames," *Opt. Lett.* 10, 267 (1985).

PERSONNEL

In addition to the three co-principal investigators, the following graduate students have participated in the research described above:

Dominique C. Fourquette

Huey-Ming Tzeng

Michael Winter

Brandon Yip

Rena M. Zurn

END

12-86

DTIC