

Naval Research Laboratory

Washington, DC 20375-5000



NRL Memorandum Report 6513

AD-A212 756

Scaling of an 85 GHz Gyrotron to Operate at 94 GHz

G. BERGERON,* M. CZARNASKI* AND M. RHINEWINE

*Beam Physics Branch
Plasma Physics Division*

**JAYCOR, Inc.
Vienna, VA*

DTIC
ELECTE
SEP 15 1989
S D

September 6, 1989


Approved for public release; distribution unlimited.

89 9 14 057

REPORT DOCUMENTATION PAGE				Form Approved OMB No 0704-0188	
1a. REPORT SECURITY CLASSIFICATION UNCLASSIFIED			1b. RESTRICTIVE MARKINGS		
2a. SECURITY CLASSIFICATION AUTHORITY			3. DISTRIBUTION / AVAILABILITY OF REPORT Approved for public release; distribution unlimited.		
2b. DECLASSIFICATION / DOWNGRADING SCHEDULE					
4. PERFORMING ORGANIZATION REPORT NUMBER(S) NRL Memorandum Report 6513			5. MONITORING ORGANIZATION REPORT NUMBER(S)		
6a. NAME OF PERFORMING ORGANIZATION Naval Research Laboratory		6b. OFFICE SYMBOL (If applicable) Code 4790		7a. NAME OF MONITORING ORGANIZATION	
6c. ADDRESS (City, State, and ZIP Code) Washington, DC 20375-5000			7b. ADDRESS (City, State, and ZIP Code)		
8a. NAME OF FUNDING / SPONSORING ORGANIZATION Balance Technology Initiative		8b. OFFICE SYMBOL (If applicable)		9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER	
8c. ADDRESS (City, State, and ZIP Code) Washington, DC 20363-5100			10. SOURCE OF FUNDING NUMBERS		
			PROGRAM ELEMENT NO 637370	PROJECT NO	TASK NO 145
			WORK UNIT ACCESSION NO.		
11. TITLE (Include Security Classification) Scaling of an 85 GHz Gyrotron to Operate at 94 GHz					
12. PERSONAL AUTHOR(S) Bergeron,* G., Czarnaski,* M. and Rhinewine, M.					
13a. TYPE OF REPORT Memorandum		13b. TIME COVERED FROM _____ TO _____		14. DATE OF REPORT (Year, Month, Day) 1989 September 6	
15. PAGE COUNT 37					
16. SUPPLEMENTARY NOTATION *JAYCOR, Vienna, VA					
17. COSATI CODES			18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUB-GROUP			
			Gyrotron		
			Maser		
			Microwaves		
19. ABSTRACT (Continue on reverse if necessary and identify by block number)					
This paper describes how a 94 GHz, 70 kV gyrotron operating in the TE₁₃ mode was designed and built. The novel feature of the design is that it was based to a large degree on a previously built gyrotron that operated at a lower frequency. The highest efficiency achieved was 32% at 4A which agrees well with theoretical predictions. The highest power measured was 135 kW at 12 A.					
20. DISTRIBUTION / AVAILABILITY OF ABSTRACT ☒ UNCLASSIFIED/UNLIMITED ☐ SAME AS RPT ☐ DTIC USERS			21. ABSTRACT SECURITY CLASSIFICATION UNCLASSIFIED		
22a. NAME OF RESPONSIBLE INDIVIDUAL Max Rhinewine			22b. TELEPHONE (Include Area Code) (202) 767-3821		22c. OFFICE SYMBOL Code 4790

CONTENTS

I. INTRODUCTION	1
II. DESIGN CONSIDERATIONS	1
III. EXPERIMENTAL SET-UP	3
IV. EXPERIMENTAL RESULTS	4
V. DISCUSSION OF RESULTS	4
VI. SUMMARY	5
ACKNOWLEDGEMENTS	7
REFERENCES	8
DISTRIBUTION LIST	25



SCALING OF AN 85 GHZ GYROTRON TO OPERATE AT 94 GHZ

I. Introduction

The gyrotron is an effective high average power cyclotron maser whose principle of operation is to match the electron cyclotron frequency to the resonant frequency of a desired cavity mode. The ability of gyrotron cavities to operate in modes with large transverse eigennumbers is of considerable interest due to the increase in cavity cross-section and power rating compared with a fundamental mode cavity.

TE_{1n} modes are attractive candidates for high power, short wavelength operation. Studies of TE_{13} mode gyrotrons have been carried out using short electron pulses, on the order of 50 nanoseconds (Ginzberg et al 1978, Bratman et al 1981, Voronkov et al 1982, Gold et al 1988). Recently, this time has been extended to microsecond pulses (Rhinewine and Read 1986).

In this paper we describe a 94 GHz, 70 kV, TE_{13} mode gyrotron designed to operate in the microsecond range. Relatively stable operation was achieved without the necessity of slotting the cavity walls. Power was observed up to 135 kW at high current (12 A). Efficiency was 32% at low current (4 A), in agreement with the theoretically predicted value. Lower efficiencies at higher currents are measured, similar to results obtained by both Varian (K. Felch, private discussion) and M.I.T. (Kreischer et al, 1988) with their high power gyrotrons. It is speculated that this anomaly may be due to some type of beam instability.

II. Design Considerations

The design of the 94 GHz TE_{13} mode gyrotron was based on a successful predecessor, the 85 GHz TE_{13} mode gyrotron described elsewhere (Rhinewine and Read 1986).

The issues that had to be addressed were the following:

- A. Would the old electron gun work at the higher value of magnetic field and r.f. frequency.
- B. Would the electrons from this gun, operating at the new

parameters, propagate through the gyrotron without interception.

C. Would the dimensions used in the cavity design successfully in the 85GHz TE₁₃ gyrotron scale to the higher frequency.

A. The magnetron injection gun we planned to use was originally designed for use with a TE₀₁ gyrotron operating at 35 GHz with a magnetic field compression ratio of 6.7 (Seftor 1979). To determine the increase in compression ratio for operation at 94 GHz, a code based on a paper by Baird and Lawson (1986) was used. The compression ratio was found to be 15 with the same mod anode voltage as for 35 GHz operation; i.e, 0.47 of the cathode voltage, which was 70 kV.

B. Running an electron trajectory code (Herrmannsfeidt 1979), it was found that increasing the magnetic field compression ratio from 6.7 to 15 would indeed allow the electrons to get through the narrower input section, smaller cavity, etc., without interception or mirroring.

C. Utilizing cavity and efficiency codes previously run for the 85 GHz gyrotron, it was found that a cavity whose linear dimensions were scaled down from the 85 GHz cavity, i.e., in the ratio of 85/94, should oscillate at 94 GHz, have a $Q = 600$, and an axial length of 6.8 free space wavelengths. Mode conversion was calculated as approximately 15% due to the output taper of the cavity. All these parameters were similar to those of the 85 GHz gyrotron. Figure 1 shows the normalized electric field profile, $|F|$, in the cavity region. The dashed line is the wall outline, including part of the drift region, the input taper, the cavity straight wall section and the double output taper.

Using a code developed by A.W. Fliflet, the performance characteristics of the gyrotron were calculated. Figure 2 is the calculated current versus magnetic field for various values of calculated output power (the lowest curve represents the lowest possible starting current, about 2 A at 3.7T). Figure 3 shows the calculated efficiency versus current for the range of magnetic fields in which the gyrotron was expected to operate, 3.57 - 3.78 Tesla. The theoretically predicted maximum efficiency is at 12 A. Figure 4 shows the calculated power versus current for the same magnetic fields. Not surprisingly, the high powers are at

relatively high currents for the same magnetic fields.

III. Experimental Set-Up

Figure 5 is a block diagram of the 94 GHz TE₁₃ mode gyrotron. The same electron gun, cavity holder, collector and pump-out section that were used in the 85 GHz gyrotron were reused. Here the input section of the cavity holder had to be modified to accommodate the smaller copper scraper and MacorTM absorber rings used in the drift section. The new cavity section, shown in Figure 6, has the same outer dimensions as its predecessor, so no further machining of the housing was required. In order to reuse the relatively expensive pump-out waveguide which has an uptaper to the window, a downtaper had to be machined to match the new BeO window now designed for minimum reflection at 94 GHz.

To characterize the gyrotron's output parameters (microwave frequency, power, mode, efficiency) as fully as possible, it was operated over the following parameter ranges:

Voltage.....50 - 75 kV
Current.....2 - 14 A
Field.....3.6 - 3.8 T
Pulse Duration.....2 microseconds (fixed)
Pulse Repetition Frequency...1 - 30 pps

Frequency was measured using a standard wavemeter with a resolution of 200 MHz at 94 GHz. Average power was measured with a commercial laser calorimeter that has been modified for maximum absorption at 85 GHz and reflects about 10% of the incident power at 94 GHz. The calculated power measurements are not corrected for this loss, and so are a lower bound on the powers claimed. Attempts at mode identification were carried out with burn paper, liquid crystal and far field antenna pattern measurements. Efficiency was calculated from measured output average power corrected for the duty cycle and knowledge of the input voltage and collector current.

IV. Experimental Results

As can be seen from the ensuing plots, (Figures 7 through 9), microwaves were obtained over a wide range of input voltages, currents and magnetic fields. Figure 7 is a plot of the theoretical starting current versus magnetic field, with the experimental data covering a wide range of collector currents and magnetic fields. Figures 8 and 9 are repeats of the theoretical curves in Figures 3 and 4 with the experimental data appropriately plotted. The shaded portions in these two last Figures delineate the magnetic field bounds within which most of the microwaves measured were seen (i.e. $3.59 \text{ T} \leq B \leq 3.75 \text{ T}$ was where the gyrotron oscillated reliably). Figure 10 is a plot of the data showing measured frequency versus calculated electron cyclotron frequency.

Burn patterns and liquid crystal patterns showed significant power on axis. Far field antenna measurements were made with a rectangular horn connected to a crystal detector; the horn was oriented first horizontally, then vertically. Plots of the resultant curves are shown: Figure 11 is the theoretical curve for the far field antenna pattern when the horn is oriented so as to pick up waves with a vertical B field and Figure 12 shows what was actually measured. Similarly, Figures 13 and 14 show the theoretical and experimental curves when the horn is in the horizontal orientation.

V. Discussion of Results

The gyrotron operated in the 93.5 - 94.5 GHz frequency range (Figure 10), which centers around the design frequency of 94 GHz. Most stable operation was obtained in the 94.1 - 94.5 GHz range. All the higher microwave output powers (greater than 100kW) were in this frequency range.

The detuning between the electron cyclotron frequency and the measured frequency for each data point in Figure 10 is characteristic of gyrotron behavior. The average detuning goes from approximately 5% at the lower frequencies to 2% at the higher frequencies, which represents a typical range for this type of gyrotron. The theoretical plot of efficiency versus

current (Figure 3) shows highest efficiencies at 9 - 10 A, but the best measured efficiencies were in the 4 - 6 A range, with the highest, 32%, at only 4 A (Figure 8). It has been speculated that this discrepancy between theoretical and experimental efficiency at higher currents may be due to beam instability. As is evident from the plots in Figures 12 and 14, we did not achieve a pure TE_{13} mode; the radiation pattern is very skewed, which may be attributed to either a bend in the collector that was known to exist, or the additional tapers to the window, or both. The lack of sharply defined minima (except the one) might imply that there is a mixture of TE_{13} and TE_{12} modes (and probably others). Calculations with a code written by J. Levine indicate that more than 50% of the mode conversion is into the TE_{12} mode. The mode map in Figure 15 shows that there are no other TE_{1n} modes close enough in frequency to emanate from the cavity, so any TE_{12} mode content would be due to mode conversion in the tapers, window, etc. The only other modes near enough in frequency, the TE_{32} and TE_{71} , were not observed, as expected, since their start currents are higher than that of the TE_{13} mode.

VI. Summary

A gyrotron has been designed, built and tested to operate in the TE_{13} mode at 94 GHz. Stable frequency of operation was in the 94.1 - 94.5 GHz range, which is close to the design frequency. Highest power measured was 135 kW at 12 A and an efficiency of 16%; and highest efficiency was 32% at 4 A at a calculated power of 85 kW. The gyrotron was operated in a pulsed mode at a repetition frequency of 30 pps with pulse width of 2 microseconds. Although the power on axis is indicative of TE_{1n} modes, it is clear that operation in a pure TE_{13} mode was not achieved; rather, a mixture of TE_{13} and TE_{12} modes were present at the output, probably due to mode conversion after the cavity.

The present gyrotron was built as a proof of the principle that scaling from 85 GHz to 94 GHz is possible with simple scaling of cavity dimensions. However, there were several known deficiencies that were not addressed in the design of the 85 GHz gyrotron, and consequently were continuing problems in the 94 GHz gyrotron:

A. Soft seals (Viton O-rings) had to be used, both to effect a current break between the cavity section and the collector, and for the ultra-TorrTM fitting used at the window. This eliminates the possibility of a proper high temperature bake-out, and therefore operation at higher average power (i.e. higher rep-rate) causes the gyrotron to heat up, become gassy and arc.

B. The relatively soft OFHC copper collector is easily deformed and makes good alignment in the bore of the magnet virtually impossible.

Both of these issues are being addressed in an ongoing redesign: No Viton O-rings will be used (a non-trivial design problem), and a stainless steel reinforced copper collector should alleviate the second problem. An alternative solution would be to fabricate the collector from dispersion hardened copper, GlidcopTM (K. Felch, private discussion).

Acknowledgements

The authors are indebted to W. Manheimer and A. Fliflet, who made this project possible; to R. Lee and R. Fischer, who generated some of the theoretical curves shown; to R. McCowan, who wrote the code based on the Baird and Lawson paper; and to Prof. V.L. Granatstein of the University of Maryland, who read the preliminary manuscript and made many useful suggestions.

This work was supported in part by the Balanced Technology Initiative (BTI) program.

References

- BAIRD, J.M., and LAWSON, W., 1986, Magnetron injection gun (MIG) design for gyrotron applications. *International Journal of Electronics*, 61, 953 - 967.
- BRATMAN, V.L., et al., 1981, Relativistic gyrotrons and cyclotron auto-resonance masers. *International Journal of Electronics*, 51, 541 - 567.
- FLIFLET, A.W., 1985, Scaling calculations for a relativistic gyrotron. *NRL Memorandum Report 5598*, July.
- GINZBERG, N.S., et al., 1979, Experimental investigation of a high-current relativistic maser. *Soviet Physics-Technical Physics*, 24, 218 - 222.
- GOLD, S.H., et al., 1988, High peak power Ka-band gyrotron oscillator experiments with slotted and unslotted cavities. *I.E.E.E. Transactions on Plasma Science*, 16, 142 - 148.
- HERRMANNSFELDT, W.B., 1979, Electron trajectory program. *SLAC Report-226*, November.
- KREISCHER, K.E., et al., 1988, The design of megawatt gyrotrons for the Compact Ignition Tokamak. *Conference Digest: Thirteenth International Conference on IR and MM Waves*.
- LEVINE, J.S., 1984, Rippled wall mode converters for circular waveguide. *International Journal of IR and MM Waves*, 5, 937-952.
- RHINEWINE, M., and READ, M.E., 1986, A TE_{1,3} gyrotron at 85 GHz. *International Journal of Electronics*, 61, 729 - 733.

SEFTOR, J.L. et al., 1979, An investigation of a magnetron injection gun suitable for use in cyclotron resonance masers. I.E.E.E. Transactions on Electron Devices, 26, 1609 - 1616.

VORONKOV, S.N., et al., 1982, Stimulated cyclotron radiation at millimeter wavelengths from a high-power relativistic electron beam. Soviet Physics-Technical Physics, 27, 68 - 69.




Figure 1: Profile of the calculated electric field (normalized) in the cavity region. The right side, labeled R_w , refers to the actual cavity dimensions outlined by the dashed line. Z is in the axial direction at the center of the cavity.




Figure 2: Collector current versus magnetic field for various values of output power. The lowest curve, calculated at extremely low power, represents the lowest possible start current - about 2 A at 3.7 T.

TE_{1,3} ROTATING MODE 94 GHz GYROTRON OSCILLATOR




Figure 3: Efficiency versus collector current for various values of magnetic field. The highest theoretical efficiency (over 40%) should occur above 10 A.

TE_{1,3} ROTATING MODE

94 GHz GYROTRON OSCILLATOR





Figure 4: Output power versus collector current for various values of magnetic field. The powers scale roughly with current.

94 GHz, $TE_{1,3}$ GYROTRON

(NOT DRAWN TO SCALE)



VOLTAGE = 70 KV


CURRENT = 10 Amp

$\alpha = 1.5$

$\gamma = 1.137$

Figure 5:

Block diagram (not to scale) of the 94 GHz gyrotron.



$f = 94.0 \text{ GHz (TE}_{1,3}\text{)}$

$Q = 600$

$L/\lambda = 6.8$

MODE CONVERSION < 15%

Figure 6: Cavity - not drawn to scale.

START CURRENT

94 GHz GYROTRON OSCILLATOR




Figure 7: Microwaves measured at various collector currents and magnetic field. The solid line is the start current for the TE_{13} mode.

TE_{1,3} ROTATING MODE 94 GHz GYROTRON OSCILLATOR




Figure 8:

Efficiency versus collector current for the measured microwaves. The shaded region represents the magnetic field range within which most of the data points shown were measured.

TE_{1,3} ROTATING MODE 94 GHz GYROTRON OSCILLATOR




Figure 9: Power versus collector current for the measured microwaves. The shaded region represents the magnetic field range within which most of the data points shown were measured.




Figure 10: Measured microwave frequency versus the corresponding calculated electron cyclotron frequency for each data point. The straight line represents the average detuning as a function of frequency: the low end is about 5%, the high end about 2%.

THEORY - E PLANE





Figure 11: Theoretical far field mode pattern for $TE_{1,n}$ modes as a function of angle when the rectangular receiving horn is oriented vertically with respect to the direction of swing.

Far Field Pattern 94 GHz Gyrotron Oscillator




Horn orientation: vertical

Direction of sweep: horizontal

Measured frequency 94.3 GHz

Figure 12: Measured far field mode pattern as a function of horn angle. Each circle represents a 2 degree increment from -45 degrees to +45 degrees.

THEORY - E PLANE



94 GHz


$TE_{1,3}$

HORN SWUNG $\perp$ to $\vec{E}$

THETA

Figure 13: Theoretical far field mode pattern for $TE_{1,n}$ modes as a function of angle when the rectangular horn is oriented horizontally with respect to the direction of swing.

Far Field Pattern 94 GHz Gyrotron Oscillator



Horn orientation: horizontal
Direction of sweep: horizontal

Measured frequency 94.3 GHz

Figure 14: Measured far field mode pattern as a function of horn angle. Each circle represents a 2 degree increment from -45 degrees to +45 degrees.




Figure 15: Map of the cutoff frequencies of TE_{mn} modes falling between 58.7 and 128.9 GHz for the unslotted TE_{13} cavity at 94 GHz.

4793/4 DISTRIBUTION LIST

Air Force Avionics Laboratory AFWAL/AADM-1 Wright/Patterson AFB, OH 45433 Attn: Walter Friez	1 copy
Air Force Office of Scientific Research Bolling AFB Washington, D.C. 20332 Attn: H. Schlossberg	1 copy
Air Force Weapons Lab Kirkland AFB Albuquerque, NM 87117 Attn: Dr. William Baker Dr. A.H. Guenter	2 copies 1 copy
Bhabha Atomic Research Center Laser Division Bombay, India 400085 Attn: T.S. Shirsat	1 copy
Columbia University 520 West 120th Street Department of Electrical Engineering New York, NY 10027 Attn: Dr. S.P. Schlesinger A. Sen	1 copy 1 copy
Columbia University 520 West 120th Street Department of Applied Physics and Nuclear Engineering New York, NY 10027 Attn: T.C. Marshall R. Gross	1 copy 1 copy
Cornell University School of Applied and Engineering Physics Ithaca, NY 14853 Attn: Prof. Hans H. Fleischmann John Nation R. N. Sudan	1 copy 1 copy 1 copy
Creol-FEL Research Pavillion 12424 Research Parkway, Suite 400 Orlando, FL 32826 Attn: Dr. Luis R. Elias Dr. I. Kimel	1 copy 1 copy

Dartmouth College 18 Wilder, Box 6127 Hanover, NH 03755 Attn: Dr. John E. Walsh	1 copy
Defense Advanced Research Project Agency/DEO 1400 Wilson Blvd. Arlington, VA 22209 Attn: Dr. L. Buchanan	1 copy
Defense Communications Agency Washington, D.C. 20305 Attn: Dr. Pravin C. Jain Assistant for Communications Technology	1 copy
Defense Nuclear Agency Washington, D.C. 20305 Attn: Mr. J. Farber Dr. Leon Wittwer (RAAE)	1 copy 5 copies
Defense Technical Information Center Cameron Station 5010 Duke Street Alexandria, VA 22314	2 copies
Department of Energy Div. of Advanced Energy Projects Washington, DC 20545 Attn: Dr. R. Gajewski	1 copy
Department of Energy Office of Energy Research Washington, D.C. 20545 Attn: C. Finfgeld/ER-542, GTN T.V. George/ER-531, GTN D. Crandall/ER-54, GTN Dr. David F. Sutter/ER-224, GTN	1 copy 1 copy 1 copy 1 copy
Director of Research U. S. Naval Academy Annapolis, MD 21402-5021	1 copy
General Atomics 13-260 Box 85608 San Diego, CA 92138 ATTN: Dr. J. Doane Dr. C. Moeller	1 copy 1 copy

Georgia Tech. EES-EOD Baker Building Atlanta, GA 30332 Attn: Dr. James J. Gallagher	1 copy
Hanscomb Air Force Base Stop 21, MA 01731 Attn: Lt. Rich Nielson/ESD/INK	1 copy
Hughes Aircraft Co. Electron Dynamics Division 3100 West Lomita Boulevard Torrance, CA 90509 Attn: J. Christiansen J. Tancredi	1 copy 1 copy
Hughes Research Laboratory 3011 Malibu Canyon Road Malibu, CA 90265 Attn: Dr. R. Harvey Dr. R.W. Schumacher	1 copy 1 copy
KMS Fusion, Inc. 3941 Research Park Dr. P.O. Box 1567 Ann Arbor, MI 48106 Attn: S.B. Segall	1 copy
Lawrence Berkeley Laboratory University of California 1 Cyclotron road Berkeley, CA 94720 Attn: Dr. A.M. Sessler	1 copy
Lawrence Livermore National Laboratory P.O. Box 808 Livermore, CA 94550 Attn: Dr. D. Prosnitz Dr. T.J. Orzechowski Dr. J. Chase Dr. W.A. Barletta Dr. D.L. Birx Dr. R. Briggs Dr. E.T. Scharlemann	1 copy 1 copy 1 copy 1 copy 1 copy 1 copy 1 copy
Litton Electron Devices 960 Industrial Road San Carlos, CA 94070 Attn: Library	1 copy

Los Alamos National Scientific Laboratory
P.O. Box 1663, MSJ 564
Los Alamos, NM 87545
Attn: Dr. Brian Newman

Los Alamos Scientific Laboratory
P.O. Box 1663, AT5-827
Los Alamos, NM 87545
Attn: Dr. T.J.T. Kwan
Dr. L. Thode
Dr. C. Brau
Dr. R. R. Bartsch

Massachusetts Institute of Technology
Department of Physics
Cambridge, MA 02139
Attn: Dr. G. Bekefi/36-213
Dr. M. Porkolab/NW 36-213
Dr. R. Davidson/NW 16-206
Dr. A. Bers/NW 38-260
Dr. K. Kreischer
Dr. B. Danby
Dr. G.L. Johnston

Massachusetts Institute of Technology
167 Albany St., N.W. 16-200
Cambridge, MA 02139
Attn: Dr. R. Temkin/NW 14-4107

Mission Research Corporation
8560 Cinderbed Road, Suite 700
Newington, VA 22122
Attn: Dr. M. Bollen
Dr. Tom Hargreaves
Dr. J. Pasour

Naval Research Laboratory	
Addressee: Attn: Name/Code	
Code 0124 - ONR	1 copy
Code 1000 - Commanding Officer	1 copy
Code 1001 - T. Coffey	1 copy
Code 1003.9A - Computer Resources Architect	1 copy
Code 1005 - Head, Office of Mgt. & Admin.	1 copy
Code 1005.1 - Deputy Head, Off. of Mgt. & Admin.	1 copy
Code 1005.6 - Head, Directives Staff	1 copy
Code 1200 - Capt. M.A. Howard	1 copy
Code 1201 - Deputy Head, Command Support Division	1 copy
Code 1220 - Security	1 copy
Code 2000 - J. Brown	1 copy
Code 2604 - NRL Historian	1 copy
Code 2628 - TID Distribution	22 copies
Code 2634 - Cindy Sims	1 copy
Code 3000 - R. Doak	1 copy

Code 4000 - W. Ellis	1 copy
Code 4000 - D. Nagel	1 copy
Code 4700 - S. Ossakow	26 copies
Code 4700.1 - A. Ali	1 copy
Code 4790 - Branch Office	25 copies
Code 4790 - W. Black	1 copy
Code 4790 - G. Cooperstein	1 copy
Code 4790 - A. Fliflet	1 copy
Code 4790 - S. Gold	1 copy
Code 4790 - C. Hui	1 copy
Code 4790 - C. Kapetanakos	1 copy
Code 4790 - A. Kinhead	1 copy
Code 4790 - Y. Lau	1 copy
Code 4790 - W. Manheimer	1 copy
Code 4790 - M. Rhinewine	1 copy
Code 4790 - P. Sprangle	1 copy
Code 5700 - L. Cosby	1 copy
Code 6840 - S. Ahn	1 copy
Code 6840 - A. Ganguly	1 copy
Code 6840 - R. Parker	1 copy
Code 6840 - N. Vanderplaats	1 copy
Code 6850 - L. Whicker	1 copy
Code 6875 - R. Wagner	1 copy

Naval Sea Systems Command
 Department of the Navy
 Washington, D.C. 20362
 Attn: Commander, PMS 405-300

1 copy

Northrop Corporation
 Defense Systems Division
 600 Hicks Rd.
 Rolling Meadows, IL 60008
 Attn: Dr. Gunter Dohler

1 copy

Oak Ridge National Laboratory
 P.O. Box Y
 Mail Stop 3
 Building 9201-2
 Oak Ridge, TN 37830
 Attn: Dr. A. England

1 copy

Office of Naval Research
 800 N. Quincy Street
 Arlington, VA 22217
 Attn: Dr. C. Roberson

1 copy

Office of Naval Research
 1012 W 36th Street, Childs Way Bldg.
 Los Angeles, CA 90089-1022
 Attn: Dr. R. Behringer

1 Copy

Optical Sciences Center
University of Arizona
Tucson, AZ 85721
Attn: Dr. Willis E. Lamb, Jr.

1 copy

Physical Science Inc.
603 King Street
Alexandria, VA 22314
ATTN: M. Read

1 copy

Physics International
2700 Merced Street
San Leandro, CA 94577
Attn: Dr. J. Benford

1 copy

Princeton Plasma
Plasma Physics Laboratory
James Forrestal Campus
P.O. Box 451
Princeton, NJ 08544
Attn: Dr. H. Hsuan
Dr. D. Ignat
Dr. H. Furth
Dr. P. Efthimion
Dr. F. Perkins

2 copies
1 copy
1 copy
1 copy
1 copy

Raytheon Company
Microwave Power Tube Division
Foundry Avenue
Waltham, MA 02154
Attn: N. Dionne

1 copy

Sandia National Laboratories
ORG. 1231, P.O. Box 5800
Albuquerque, NM 87185
Attn: Dr. Thomas P. Wright
Mr. J.E. Powell
Dr. J. Hoffman
Dr. W.P. Ballard
Dr. C. Clark

1 copy
1 copy
1 copy
1 copy
1 copy

Science Applications, Inc.
1710 Goodridge Dr.
McLean, VA 22102
Attn: Adam Drobot
P. Vitello
D. Bacon
C. Menyuk

1 copy
1 copy
1 copy
1 copy

Science Research Laboratory
15 Ward Street
Somerville, MA 02143
Attn: Dr. R. Shefer

1 copy

SPAWAR Washington, D.C. 20363 Attn: E. Warden, Code PDE 106-3113 Capt. Fontana, PMW 145	1 copy 1 copy
Spectra Technologies 2755 Northup Way Bellevue, WA 98004 Attn: Dr. J.M. Slater	1 copy
Stanford University Dept. of Electrical Engineering Stanford, CA 94305 Attn: Dr. J. Feinstein	1 copy
Stanford University High Energy Physics Laboratory Stanford, CA 94305 Attn: Dr. T.I. Smith	1 copy
Stanford University SLAC Stanford, CA 94305 Attn: Dr. Jean Labacqz	1 copy
TRW, Inc. One Space Park Redondo Beach, CA 90278 Attn: Dr. H. Boehmer Dr. T. Romisser Dr. Z. Guiragossian	1 copy 1 copy 1 copy
University of California Physics Department Irvine, CA 92717 Attn: Dr. G. Benford Dr. N. Rostoker	1 copy 1 copy
University of California Department of Physics Los Angeles, CA 90024 Attn: Dr. A.T. Lin Dr. N. Luhmann Dr. D. McDermott	1 copy 1 copy 1 copy
University of Maryland Department of Electrical Engineering College Park, MD 20742 Attn: Dr. V. L. Granatstein Dr. W. W. Destler	1 copy 1 copy

University of Maryland
Laboratory for Plasma and Fusion
Energy Studies

College Park, MD 20742

Attn: Dr. Tom Antonsen	1 copy
Dr. John Finn	1 copy
Dr. Jhan Varyan Hellman	1 copy
Dr. W. Lawson	1 copy
Dr. Baruch Levush	1 copy
Dr. Edward Ott	1 copy
Dr. M. Reiser	1 copy

University of New Mexico
Department of Physics and Astronomy
800 Yale Blvd, N.E.
Albuquerque, NM 87131

Attn: Dr. Gerald T. Moore	1 copy
---------------------------	--------

University of Tennessee
Dept. of Electrical Engr.
Knoxville, TN 37916

Attn: Dr. I. Alexeff	1 copy
----------------------	--------

University of Utah
Department of Electrical Engineering
3053 Merrill Engineering Bldg.
Salt Lake City, UT 84112

Attn: Dr. Larry Barnett	1 copy
Dr. J. Mark Baird	1 copy

U. S. Army
Harry Diamond Labs
2800 Powder Mill Road
Adelphi, MD 20783-1145

Attn: Dr. Howard Brandt	1 copy
Dr. Edward Brown	1 copy
Dr. Stuart Graybill	1 copy
Dr. A. Kehs	1 copy
Dr. J. Silverstein	1 copy

Varian Associates
611 Hansen Way
Palo Alto, CA 94303

Attn: Dr. H. Huey	1 copy
Dr. H. Jory	1 copy
Dr. Kevin Felch	1 copy
Dr. R. Pendleton	1 copy
Dr. A. Salop	1 copy

Varian Eimac San Carlos Division
301 Industrial Way
San Carlos, CA 94070

Attn: C. Marshall Loring	1 copy
--------------------------	--------

WL/CA
Kirtland AFB, NM 87117-6008
Attn: Mr. Brendan B. Godfrey

1 copy

Yale University
Applied Physics
Madison Lab
P.O. Box 2159
Yale Station
New Haven, CN 06520
Attn: Dr. I. Bernstein

1 copy

Ken Busby

1 copy