

DTIC FILE COPY

4

AD-A224 843

Ultra-Low Loss Optical Fiber Characterization System Development

Final Report for
Naval Research Laboratory
Project Number 65-9017-88

1 June 1990

DTIC
ELECTE
JUL 25 1990
S & B D

VPI&SU Project No. 230-11 - 110f-104-352298
U.S. SFRC No. N00014-88-K-2013

Principal Investigator: Dr. R.G. Claus
Report Prepared by: R.G. May and K.D. Bennett

Fiber & Electro•Optics Research Center
Bradley Department of Electrical Engineering
Virginia Polytechnic Institute and State University
Blacksburg, VA 24061-0111

DISTRIBUTION STATEMENT A

Approved for public release;
Distribution Unlimited

98 07 19 133

1.0 Introduction.....	3
1.1 Measurements Performed by the NRL IR System 1.....	3
1.1.1 Spectral Attenuation.....	3
1.1.2 Differential Modal Attenuation.....	3
1.1.3 Numerical Aperture.....	4
1.2 System Specifications.....	4
1.2.1 Fiber Limitations.....	4
1.2.2 Detector Noise (RMS values).....	4
1.2.3 Spectral Signal-to-Noise.....	4
1.2.4 Lamp Drift.....	5
2.0 How the NRL IR System 1 differs from the Photon Kinetics FOA 2000.....	6
2.1 Monochromator.....	6
2.2 Infrared Lenses.....	7
2.3 Quartz-Tungsten Lamp.....	7
2.4 Cutoff Filters.....	7
2.5 Infrared Neutral Density Filters.....	8
2.6 Indium Antimonide Detector.....	8
2.7 Vacuum Chucks.....	8
2.8 Annular Apertures for DMA Measurements.....	8
2.9 Knife Edge Numerical Aperture Measurements.....	9
2.10 Major Changes in the FOA-2000 Software.....	9
3.0 Normal Operating Procedures.....	13
3.1 Turn-on Procedure.....	13
3.2 Software Set-up.....	13
3.3 Fiber End Preparation.....	14
3.4 Important Commands.....	14
4.0 Maintenance.....	16
4.1 Alignment Procedure for NRL IR System 1.....	16
4.1.1 Definitions.....	16
4.1.2 Main LED Beam Path.....	16
4.1.3 Input Objective Lens.....	16
4.1.4 Input Fiber Chuck.....	17
4.1.5 Launch Spot.....	18
4.1.6 Output Objective Lens.....	18
4.1.7 Output Fiber Chuck.....	18
4.1.8 Output Target.....	19
4.1.9 Lamp Path.....	19
4.1.10 Germanium Detector.....	19
4.1.11 Indium Antimonide Detector.....	20
5.0 How to get help.....	21
5.1 FOA-2000 Error Messages.....	21
5.2 Likely Problems.....	22
Appendix A. Neutral Density Filter Calibration Results.....	24
Appendix B. InSb Detector Preamp Power Supply Circuit.....	25
Appendix C. Index of Technical Reports and Publications.....	26
Appendix D. System Software Listing.....	27

STATEMENT "A" per Dr. Ishwar Aggarwal
NRL/Code 6505.2
TELECON

7/24/90

VG

Dist	Special
A-1	



y Codes
nd/or

1.0 Introduction

The NRL IR System 1 is an automated optical bench designed for the measurement of spectral attenuation, differential modal attenuation, and numerical aperture of zirconium fluoride infrared optical fiber. It was developed by the Fiber & Electro-Optics Research Center at Virginia Tech under contract to NRL, and is a specially adapted version of a commercially available FOA-2000, a silica fiber characterization system manufactured by Photon Kinetics of Beaverton, Oregon.

1.1 Measurements performed by the NRL IR System 1

1.1.1 Spectral Attenuation

The system measures spectral attenuation over the range from 600 nm to 4 μ m. Launch conditions are overfilled for multimode fibers with core diameters up to 150 μ m and with numerical apertures up to 0.24. The fiber vacuum chucks can accept fibers with outside diameters up to 200 μ m. The attenuation is derived by performing a cut-back test. *Y601*

1.1.2 Differential Modal Attenuation

The system can measure differential modal attenuation (DMA) on step-index multimode fibers. Launch conditions are restricted by manually placing apertures that restrict the launch numerical aperture (NA) to a narrow range, thereby exciting a limited mode group in the optical fiber. Attenuation values are derived by performing a cutback test. The DMA apertures and the range of NA for each aperture follows:

<u>Aperture #</u>	<u>NA Range</u>
#1	.04
#2	.08
#3	.10
#4	.13
#5	.15
#6	.18
#7	.20
#8	.04<NA<.08
#9	.08<NA<.13
#10	.11<NA<.17
#11	.14<NA<.21

DMA tests for graded-index fibers have not been implemented in the current version of the system software, but the system may be easily adapted for this test. In order to achieve the correct restricted launch for graded index fibers,

the launch spot size must be restricted as well as the numerical aperture. To restrict the spot size, an aperture of the correct diameter must be placed in the spot restrictor carriage holder (see Figures 1 and 2), and the DMA software must be changed to engage the spot restrictor. The spot restrictor aperture is demagnified 100/9 times when it is imaged onto the input fiber end. The current spot restrictor aperture (390 μm diameter) achieves a spot size of 35 μm on the end of the fiber. This represents the minimum spot achievable at 2.5 μm wavelength since it is approximately the diffraction limit for the infrared lenses at that wavelength.

1.1.3 Numerical Aperture

The system will measure the numerical aperture of step and graded-index fibers, up to a value of 0.24. Due to the low radiance of the lamp source, the measurement procedure uses a scanning knife-edge, rather than a scanning aperture in the far-field as specified in EIA FOTP #47. The knife edge technique is an adaptation of an EIA procedure for determining the mode field diameter of a single mode fiber. In this procedure, a knife edge is scanned across the far field output of the fiber, and a lens is used to collect the light passed by the knife edge and direct it to the detector. The computer reads the output of the detector at the lock-in amplifier, which is effectively the integrated power as a function of far field angle. This data is then differentiated and smoothed to yield the far field radiation pattern of the fiber. From this far field the numerical aperture is derived. A criterion of 5% of maximum intensity is used to determine the numerical aperture.

1.2 System specifications

1.2.1. Fiber limitations

The system provides overfilled launch conditions for multimode fibers with core diameters up to 150 μm and numerical apertures up to 0.24. The differential modal attenuation procedure is currently set up for step index fibers only.

1.2.2. Detector noise (RMS values)

The following values for the average detector noise were measured using the "SUB low_init_check" subroutine in the FOA-2000 QC software package.


Thermoelectrically cooled Germanium detector: 0.66 μV

Liquid nitrogen cooled Indium Antimonide detector: 0.7 μV

1.2.3. Spectral signal-to-noise

After the values for detector noise given above were determined, the FOA-2000 QC software was used to measure the spectral signal-to-noise by

running the "SUB Spec_snoise" subroutine. A one-meter piece of fluoride fiber (from NRL spool number 891019) was used to give a representative value for coupling losses into a fluoride fiber. The results are graphed below.



Graph 1. Spectral signal-to-noise ratio

1.2.4 Lamp drift

The FOA-2000 QC software subroutine titled "SUB Lamp_drift" was used to measure the drift of the lamp output as detected by both the germanium (Ge) detector and the indium antimonide (InSb) detector. This test measured the detector output every twenty seconds over a duration of 60 minutes. The test indicated that the germanium detector drifted by -0.002 dB per five minutes. The indium antimonide detector was measured to drift by 0.004 dB per five minutes when the test was performed immediately after filling the InSb dewar with liquid nitrogen. The same test was repeated 1.5 hours after filling the dewar, and the drift was reduced to 0.002 dB per five minutes, indicating the need to refill the dewar approximately 2 hours before running any critical tests.

2.0 How the IR System 1 differs from the Photon Kinetics FOA- 2000

The NRL IR System 1 differs from the commercially available Photon Kinetics FOA--2000 with the addition or substitution of several key components. They are:

- a. A three-grating monochromator, with a stepper motor to select the grating,
- b. custom design diffraction limited infrared lenses,
- c. a quartz-tungsten lamp with extended spectral window envelope,
- d. additional cutoff filters for the extended range of the monochromator,
- e. infrared neutral density filters to accommodate the range of the monochromator,
- f. a liquid nitrogen cooled indium antimonide detector for the range from 1.8 μm to 4.0 μm ,
- g. vacuum chuck V-grooves to accommodate the larger fiber diameter of the infrared fiber,
- h. special annular apertures for DMA measurements,
- i. a numerical aperture measurement technique that uses a knife edge rather than a pinhole to scan the far field,
- j. software that has been adapted to account for the differences in hardware.

2.1. Monochromator

The monochromator is a Jarrell Ash Monospec® 27 with three gratings that may be interchanged by moving a turret. The gratings are summarized as

<u>grating freq.</u>	<u>blaze Λ</u>	<u>λ range</u>	<u>avg. dispersion</u>	<u>spectral bandpass</u>
600 gr/mm	1 μm	.6 to 1.79 μm	6 nm/mm	3 nm
300 gr/mm	2 μm	1.8 to 2.69 μm	12 nm/mm	6 nm
150 gr/mm	4 μm	2.7 to 4.0 μm	24 nm/mm	12 nm

The approximate spectral bandpass figures assume that the output slit size is 0.5 mm.

The monochromator wavelength selector is automated with a stepper motor. The step angle on the motor is 1.8 degree per step, and it takes 200 steps for one complete revolution. The Monospec® 27 has an analog wavelength counter which is calibrated to the 1200 groove/mm grating. To obtain the proper wavelength for each grating, the counter reading must be multiplied by 2, 4, and 8 for the 600 groove/mm , 300 groove/mm, and 150 groove/mm

gratings, respectively. One complete revolution on the wavelength selector corresponds to 25 nm of wavelength scan for a 1200 groove/mm grating. The gear ratio between the monochromator and stepper motor is 3:1. The number of steps on the motor required to scan 1 nm using the 1200 groove/mm grating can be calculated by the formula,

$$G \cdot \frac{N_m}{W_s},$$

where N is the number of motor steps per revolution, W is the wavelength scan per revolution on selector, and G is the gear ratio between the monochromator and stepper motor. The 1200 groove / mm grating requires 24 steps for a 1 nm scan. The 600 groove / mm, 300 groove / mm, and 150 groove / mm gratings require 12 steps / nm, 6 steps / nm, and 3 steps / nm, respectively.

2.2. Infrared Lenses

The infrared lenses were designed and constructed by Infrared Optics, Inc. of Farmingdale, NY. They are multi-element lenses fabricated of barium fluoride and lithium fluoride, or zinc sulfide. The lenses were designed to correct for most spherical aberrations between 0.6 and 4.0 μm , with a spot size of 35 μm at 2.5 μm wavelength. The physical dimensions and focal lengths of the lenses were designed to be identical to the standard lenses used in the FOA--2000, in order to facilitate their replacements. The lens parameters are summarized in Figure 2.

2.3 Quartz-Tungsten Lamp

A Ushio Model no. JC12V-50W H20 G/1.0 tungsten halogen lamp is used for the white light source. This lamp utilizes a special quartz envelope which has an extended transmittance out to 4.0 μm .

2.4 Cutoff Filters

Since the Jarrell-Ash monochromator has a greater spectral range than the original FOA--2000 monochromator, it was necessary to add additional cutoff filters to eliminate second- and higher-order spectra from the longer wavelengths. The filter numbers and their cut-on wavelengths are listed below.

<u>Filter No.</u>	<u>Cut-on Wavelength</u>
1	540 nm
2	850 nm
3	1525 nm
4	2175 nm
5	3150 nm

2.5 Infrared Neutral Density Filters

The neutral density filters in the original FOA-2000 are specified only for operation over the limited spectral range of that instrument. They were replaced in the NRL IR System 1 with neutral density filters design for used in the infrared up to 4.0 μm .

The attenuation of each filter was measured over the range from 800 to 4000 nm using a modified version of the FOA-2000 QC software subroutine SUB Attn_calib. The results of the ND filter calibration tests are given in Appendix A. The attenuation is not very uniform over the spectral range. The ND filters are not used in any spectral attenuation, differential modal attenuation, or numerical aperture tests on the instrument, because of the low radiance of the lamp, eliminating the need to attenuate the output of the lamp. It is possible that the calibration values given there could be incorporated into a look-up table in the system software, such that any time a ND filter is used at some wavelength, then the measured attenuation of that filter at that wavelength is recalled for use in calculations. The original FOA-2000 software however does not easily lend itself to incorporating such a feature, so that including it would entail an effort of moderate difficulty.

2.6 InSb Detector

A liquid nitrogen-cooled indium antimonide (InSb) detector manufactured by Infrared Associates is used to cover the spectral range from 1800 to 4000 nm. The system software automatically switches between the Ge detector and the InSb detector at 1800 nm. The preamplifier used for the InSb detector is an Infrared Associates model PPA-15-IS. The schematic for the InSb detector power supply is given in Appendix B.

2.7 Vacuum Chucks for 200 μm OD fiber

The original FOA-2000 vacuum chucks can only accommodate fibers with outside diameters (OD) up to 140 μm . These chucks have been replaced with ones that can accommodate fibers with up to 200 μm OD.

2.8 Annular Apertures for Differential Modal Attenuation Measurements

Numerical aperture launch restrictors have been adapted to include annular apertures, which are used for launching high order modes in step index fibers, for differential modal attenuation tests. Launch conditions are restricted by manually placing apertures that restrict the launch numerical aperture (NA) to a narrow range, thereby exciting a limited mode group in

the optical fiber. Attenuation values are derived by performing a cutback test.

2.9 Knife edge numerical aperture measurements

Due to the low radiance of the lamp source, the measurement procedure uses a scanning knife-edge, rather than a scanning aperture in the far-field as specified in EIA FOTP #47. The knife edge technique is an adaptation of an EIA procedure for determining the mode field diameter of a single mode fiber. In this procedure, a knife edge is scanned across the far field output of the fiber, and a lens is used to collect the light passed by the knife edge and direct it to the detector. The computer reads the output of the detector at the lock-in amplifier, which is effectively the integrated power as a function of far field angle. This data is then differentiated and smoothed to yield the far field radiation pattern of the fiber. From this far field the numerical aperture is derived. A criterion of 5% of maximum intensity is used to determine the numerical aperture.

2.10 Major changes in the FOA-2000 software

2.10.1 DMA Measurement

The software has been rewritten so that multiple wavelength scans can be performed in such a way that only one cutback is required. A few new subroutines were created to enable this change in the measurement procedure. A description of their operation is included in the discussion below.

SUB Fibertest2: As with the Far Field test, the user is first queried as to the source of the data which he wishes to view. That is, he may indicate that a new test is to be performed, or that data from a previous run is to be reviewed. Previous data may either be data which was collected earlier in the day (computer on continuously) and is present in the dynamic memory buffer, or data which is stored on a diskette. This query takes place by calling the subroutine FNDatasource, which returns a 0 if a new test is desired, 1 if memory in the buffer is desired, or 2 if the routine Retrieve is to be called to access data on diskette. If either 1 or 2 are returned to Fibertest2, data is loaded into the array called "Dmaattendata", the test portion of the routine is skipped, and the data is plotted on the screen. More details about the plot are below.

SUB Dmarun: First the user is queried about which numerical aperture restrictor to use (including #0 = no restrictor). This is performed by calling the routine FNGetrestrictor, which first lists the restrictor numbers and their corresponding NA range, then uses the FNGetint to determine and return the (integer) restrictor number. The first restrictor number is stored in the (0,1) position of the array "Dmarundata" (see supplemental sheet 1), while subsequent numbers, up to 11, are stored in (0,2), (0,3), and so on.

The wavelengths to scan, and the total number of wavelengths to scan, n, are shared with this routine through the common block /Wavelength/ command. The number of wavelengths is stored in the (0,0) position of "Dmarundata." The (1,0) position of this array contains the fiber length, while the (2,0) position holds the number of DMA runs performed. The wavelength scan is then performed on the long or "run" piece of fiber, and the voltages are stored in the column beneath the restrictor number, in the row corresponding to the wavelength at which the voltage was read.

After each before-the-cutback scan, the user is asked to see if another DMA run (i.e., another NA range) is desired; if yes, the new restrictor number is requested, time given to insert the restrictor, and the program returns to the wavelength scan portion and continues as before.

If no more NA ranges are desired, the user is directed to cutback the fiber, being careful to leave the input end undisturbed. The routine Outalign is then called to align the output end. The first restrictor used before cutback is requested, and a short or "ref" fiber wavelength scan is performed. The voltage data here is now stored in columnar form in an array called "Dmarefdata," which has the same (0,0), (1,0), (2,0) entries as "Dmarundata."

It should be understood that before the first wavelength scan on the long fiber, the signal on the detector (through the fiber) is read using the LED source. This is taken as an alignment reference. After the scan for each DMA run, the alignment is again checked, and if it has varied by more than 1%, the user is informed and given the choice of re-doing that particular scan, exiting the test, or proceeding. The same type procedure is used to insure integrity of the input fiber end alignment after the cutback is performed.

SUB Dmacomp: The data from the two arrays are passed through a COM statement to this routine, where the calculation is performed to determine the spectral attenuation for each NA range (represented by respective restrictor number). This outcome of the computation is stored in an array named "Dmaattendata," while the wavelengths used for the scan are stored in the positions (1,0) - (n,0), i.e., the first column of this array. As explained in the supplemental sheet 2, the (0,0) position of this array contains both the number of wavelength scans n, and the number of DMA runs performed, m.

SUB Dmaplotprep: Next the user is queried as to which column of data he wishes to view (i.e., which restrictor). His choice column is loaded into the second column of the array Specattdata, while the wavelengths are loaded into the first column. The fiber ID number, including the restrictor number and fiber length are loaded into the string Specatt_id\$. Then the routine Specatplot is called to plot the particular column of data requested, and operates in the same way as an ordinary spectral attenuation plot as

described by Photon Kinetics in their software listing remarks. If at any point the "STORE DATA" option is entered, the program exits the plot, enters the Archive subroutine, and stores the contents of the array "Dmaattendata," and then returns the user to the main menu. To further review data, such as the loss results of other restrictors, the "Recall data" option must be chosen from the DMA menu.

2.10.2 Far Field Measurement

This test was changed to run from its own menu, and allow the user the option to smooth the data by averaging a variable number of points. The attached flow chart may aid in understanding the logic.

Presuming a new test is specified, the knife edge will scan across the collimated far field pattern, moving to gradually cut off the power reaching the detector. A normalized version of the data from this scan is held in an array called "Farfield;" it is considered the "raw" data, and is plotted against scanner position. This data can be differentiated to obtain an actual far field output pattern, or can be smoothed directly. When the Differentiate option is chosen, the raw data is first loaded into an array called "Ffrawdata." Then it is differentiated, corrected to account for a small angle approximation, renormalized, and stored in an array "Ffdiffdata," which is again plotted on screen. In addition, the routine Numaper is called to calculate the numerical aperture, which is displayed below the plot. At this point the user may smooth the differentiated data, or return to the raw data plot. If the Smooth Data option is chosen, he is asked for the number of points to average, the data smoothing routine Ffsmooth is called, and the smoothed, normalized version of the data is stored in an array called "Ffsmoothdata." This is plotted on the display, along with a recalculated value of numerical aperture. Further smoothing may then be performed on the raw, differentiated, or smoothed data, and plotted accordingly.

It may be noted that when the raw data is smoothed, at present the smoothed version may not be differentiated, only viewed. Because the "smoothed" raw data actually appeared to be less smooth than the actual raw data, and because of ambiguities introduced into the numerical aperture calculation due to smoothing, this was not further modified, though it would be relatively straightforward to do so. Furthermore, an alternate routine has been sketched out (included) by George McCabe which would fit the data to a Gaussian distribution and look for the 5% points there. In the end, this might offer a more repeatable method to obtain a value for the numerical aperture.

2.10.3 Program Organization

Lines relevant to unused tests were purged in many, but not all, places in the system software. Large blocks such as the FibertestX subroutines and

associated routines were deleted, but remnants exist in other places due to not wanting to alter the "foasetup" file and the way it is stored. All lines relevant to the Near Field test were retained.

2.10.4 Fiber Alignment

The Inalign and Outalign routines have been altered so that the first time either are called, the alignment is performed, and a counter variable is set equal to 1. At the end of the alignment, the final voltage on the Ge detector is read and held in the first position of a variable array, called Sig(1). The routine then returns and aligns the fiber a second time, and holds the new final voltage in Sig(2). These two voltage values are then compared, and if they differ by more than 1%, the user is told so, and given the option of continuing anyway, or returning to re-align. If the latter is chosen, then eventually Sig(3) and Sig(2) are compared as before and so on. At present, the maximum number of alignments that can be performed in this way is 10.

3.0. Normal Operating Procedures

This section describes the daily procedures required for proper normal operation of the system.

3.1. Turn-on procedure

The proper sequence for bringing the system up is outlined below.

- a. Turn on the FOA-2000 control panel by turning the key on the front panel.
- b. Turn on the EG&G 5207 lock-in amplifier.
- c. Turn on the red (illuminated) switch on the power supply.
- d. Check the voltage of the preamp batteries in the power supply chassis. To do this, switch the small toggle switch labeled "Meter" to either 1 or 2. There are two sets of batteries, labeled 1 and 2, respectively. One set is normally connected to the preamp while the other is held in reserve, or is being recharged. The voltage of the set in use should read greater than 11 volts. Switch the batteries on by turning the switch labeled "Preamp Batteries" to the set with the higher voltage. If the other set shows a voltage below 11 volts, connect the two battery chargers to the connectors labeled "CHARGERS" on the back of the power supply unit. The reserve batteries will be charged automatically.

Important: Switch the "Meter" switch to "off" after checking the batteries. If it is left on, the discharge of the batteries will be accelerated.
- e. Make sure that the InSb detector dewar is filled with liquid nitrogen. When refilling the dewar, it is not necessary to shield the detector from room light. The lens that covers the detector face does not transmit light of a wavelength below 1.0 μm . For minimal drift, the dewar should be filled two hours before any important measurements.
- f. Load and run the system software, as describe below.

3.2. Software set-up

Place the disk labeled "DISK #1 (AUTOBOOT)" in the left hand drive (drive 0) of the computer. Turn the monitor, disk drive, printer, and computer on. When the computer prompts, remove the autoboot disk and replace it in drive 0 with the system software disk. The system software will execute automatically, and present the user with a menu.

3.3. Fiber End Preparation

For proper use of the vacuum fiber chucks and the elastomeric fiber clamps, it is necessary to strip at least two inches of jacket from the fiber end. The best location for positioning the clamp on the fiber can be gauged by using the two short strips of black tape on the fiber shelf. The distance from the tape to the edge of the fiber shelf is the proper length of bare fiber that should extend from the fiber clamp.

3.4 Important Commands

Here we list several convenient commands that may be executed from the HP computer.

<u>Command</u>	<u>Effect</u>
Stop	To stop execution of the system software because something is wrong.
Call Menu	To access the main menu.
Call Nextwave	To have the unit set to a particular wavelength. For example, to set the wavelength to 850 nm, execute "CALL WAVELENGTH(850)". See the note "IMPORTANT" below.
Call Fibertest1	To run the spectral attenuation test directly from the keyboard without having to access it from the main menu.
Call Fibertest2	To run the differential modal attenuation test directly from the keyboard.
Call Fibertest3	To run the numerical aperture test directly from the keyboard.
Call Cleanup	Clears the GPIB bus and resets the phase on the lock-in amplifier.
Run	To reinitialize the FOA-2000 control panel. This <u>must</u> be done each and every time the control panel is turned off and on again. If the FOA-2000 control panel is turned on, then the system software must be restarted in order to reinitialize the Z-80 μ processor in the FOA-2000 control panel. In order to do this, stop the program execution (it may be necessary to hit the break

key), and then type "RUN" and press the return key. It is not sufficient to "CALL MENU." The system software must be restarted. After restarting the software, the "Equipment Preset" routine should be run.

Call F2000send ("INSB")

Connects the InSb detector to the lock-in amplifier, and sets the mirrors to direct the fiber output to the InSb detector.

Call Cleardata

To clear all data from the memory buffer. This should be called before running the first test on a new fiber if other fibers were run since the machine was turned on.

IMPORTANT: To set the monochromator to a desired wavelength, it is necessary to use the "CALL NEXTWAVE" command instead of using the front panel control. The system software will then insure that the correct grating, cutoff filter, and detector are set up. In addition, the software calculates the proper setting for the monochromator shaft and automatically sets it there. The control panel should only be used to make minor (<50 nm) adjustments in the wavelength displayed on the control panel LED display.

4.0. Maintenance

4.1 Alignment Procedure for NRL IR System 1

4.1.1 Definitions:

The x direction is perpendicular to the beam direction, and parallel to the bench surface. The y direction is perpendicular to both the beam direction and the bench surface. The z direction is parallel to the beam direction.

The IR target is an aluminum piece with cross-hair lines etched on it. Its base should just fit into the milled slots (to assure lateral consistency), and have a cross-hair marked directly over the center of the slot at a height of $1\frac{3}{8}$ inches above the surface of the bench (not the slot).

4.1.2. Main LED Beam Path.

- a. Remove lenses 1, 2, 3, 4 from the bench. Select LED on the front panel, with the launch spot out. Using the IR target, align the LED beam all the way around the bench to the camera. Start by engaging LASER 1 on the front panel. When this is done, the mirror in BS2 will switch out to allow the beam to pass through BS2. In addition, the stepper motor driving the monochromator turret will attempt to turn the shaft. This is expected, so don't be concerned by the sound. Put the IR target in the milled slot at position A, and adjust the LED lens 7 in x and y to align the LED output to the cross-hairs. Adjust the lens in z in order to collimate the beam as well as possible.
- b. Next disengage LASER 1 to bring the lower mirror in BS2 back up, directing the beam towards BS4. Again align the beam to the IR target. Now engage THRU TRANSMISSION with the output target out, and adjust BS4 lower mirror to direct the beam onto the IR target at C. Engage FIBER OR SOURCE and proceed to align to the IR target at D. It may be necessary to re-adjust the collimation by tweaking the z position of the LED lens 7. Next adjust mirror M1 to collect as much of the beam as possible, and direct it towards the target at position F. The 275 mm lens 11 should still be in place, roughly half way between M1 and M2. Finally, adjust M2 to direct the beam into the video camera. Leave the image of the LED on the right one third of the monitor, centered vertically.

4.1.3. Input Objective Lens.

- a. Center the input objective lens 5 in x, y, and z over the range of travel of the respective motors. To do this, first push the appropriate button on the front panel to engage the corresponding motor. Then turn the front panel knob until the front panel display shows four dots, indicating that the motor has reached the end of its range of travel. Then press the ZERO button to zero the

display. Next, while holding the local button down, rotate the front panel knob in the opposite direction (from the previous motion) until the four dots vanish. Release the local button and continue turning the knob until the four dots appear again, indicating the limit of travel in the opposite direction. Take the reading on the front panel display and divide by two (if the display "tripped over" to 000, be sure to add 1000 to the number before division). Hold the local button down, and rotate the knob in the opposite direction until the dots vanish. Then move the knob until the display shows the number that resulted from the division by two. Press ZERO to re-zero the display. This position is the center of travel in the appropriate axis. Repeat this procedure for the remaining two axes.

- b. Place the lens cap (with white target and mark in center) on the lens. Position the lens in x, y, and z so that the center of the LED beam strikes the center of the lens cap. Note the reading on the front panel in x and y, which displays how many units away from the center of the lens travel the LED beam is.
- c. If the reading in x or y is more than about 150 units, the brass U-shaped bracket in the opto-sensor may need to be adjusted to redefine the lens travel limits and therefore the lens travel zero. In order to do this, remove the bracket holder (x axis is underneath bench, y is above), and adjust the position either up or down slightly. Repeat steps a and b until the LED beam corresponds to the center of the x and y lens travel to within acceptable limits.
- d. Redefine the zero lens position at the center of the LED beam by pressing the ZERO button on the front control panel for each input lens motor.

4.1.4. Input Fiber Chuck.

- a. Remove the lens cap from lens 5. Make sure step 2d has been taken.
- b. Prepare a length of fiber (1-2 meters) with cleaved ends. Place one end in the input fiber chuck, and place the other end of the fiber in a power meter (Si detector).
- c. Loosen the set screws holding the vacuum chuck and adjust the vacuum chuck to maximize the power injected through the fiber, as detected by the power meter. To adjust horizontally, move the vacuum chuck horizontally. Make an effort to keep the chuck axis perpendicular to the lens. To adjust vertically, use the front panel control (input-y). To adjust longitudinally, push the fiber in and out for coarse adjustments, and use the front panel (input-z) for fine adjustments.
- d. Tighten chuck screws so that the chuck is locked firmly in place.

4.1.5. Launch Spot.

- a. Engage the BS4 lower mirror by pressing SOURCE. Replace lens 2 on the bench. Set launch spot into the beam by engaging LAUNCH SPOT. Move lens 2 along the slot (in z) to focus the spot on the monitor.
- b. Disengage the launch spot. Replace lens 1 (in the adjustable mount) on the bench and move it along the slot to focus the LED on the monitor. Adjust the lens mount in x and y to center the LED image over its previous position on the right one third of the monitor, centered vertically.
- c. Engage the launch spot again. Adjust the aperture position on the launch spot carriage in x and y to center the spot over the center of the LED image.

4.1.6. Output Objective Lens.

- a. Engage the beamsplitter mirror in the top of BS4 by pressing FIBER LOAD. Loosen the mirror and adjust it until a (probably dim) reflected image of the input fiber end is positioned over the LED image (right one third, centered vertically). This squares the position of the light reflected onto the output objective lens.
- b. Follow the procedure of Step 2 to center the output objective lens within its range of travel. Note however that because of the nature of the beamsplitter, in this case the LED beam will appear as a half-circle only. Be sure to redefine the zero lens position for each output lens motor.
- c. Re-adjust the upper beamsplitter mirror of BS4 to direct the input fiber image onto the left third of the monitor, centered vertically (over the grease pencil marks). Tighten the mirror screws to lock it into place.

4.1.7. Output Fiber Chuck.

- a. Place one end of the prepared fiber in the output chuck. Inject white light into the other end (this may be simply accomplished by placing the fiber end near the filament of an ordinary light bulb).
- b. Press THRU TRANSMISSION to allow the white light through the fiber to reach the camera. Loosen the set screws holding the output vacuum chuck and adjust the chuck horizontally to put the output fiber image over the LED image in the right one third of the screen. Center the image vertically by adjusting the front panel control (output-y). To focus the image, push the fiber in and out for coarse adjustments, and use the front panel (output-z) for

fine adjustments.

- c. Place the IR target at the position of lens 3 and check that fiber output is aligned with crosshairs. Then place IR target just after lens 11 and insure that beam is still aligned with crosshairs. If not, move the output fiber chuck angularly in x, and then reiterate steps b and c until the output fiber path lies squarely over the line between BS4 and BS5.

4.1.8. Output Target.

- a. Replace lens 4 on the bench. Engage the output target. Move lens 4 along the slot (in z) to focus the image of the output target on the monitor.
- b. Disengage the output target. Replace lens 3 (in the adjustable mount) on the bench and move it along the slot to focus the LED on the monitor. Adjust the lens mount in x and y to center the LED image over its previous position on the right one third of the monitor, centered vertically.
- c. Engage the output target again. Position the aperture on the output target carriage in x and y over the LED image.
- d. At this point the LED, output fiber, and output target should all be focussed on the same position on the right one-third of the screen, centered vertically. This position should be remarked with a grease pencil if necessary.

4.1.9. Lamp Path.

- a. Engage LED on the front panel. Switch the lamp on, if it's not on already. Put the IR target at position F in the milled slot that leads from the monochromator output and BS3. Adjust lens 8 to focus the monochromator output on the IR target. Also adjust the positioning knob on top of the lamp to maximize the amount of light into the monochromator, and onto the IR target.
- b. Engage the LAMP on the front panel. Engage the button below "LASER THREE" on the front panel. As before, BS2 will switch mirrors and the stepper motor driving the monochromator turret will attempt to turn the shaft. Put the IR target in the milled slot at position A. Adjust the mirror in BS3 to align the monochromator output to the crosshairs as well as possible. Engage LED again.

4.1.10. Ge Detector.

- a. Engage SOURCE, Ge DET, and DETECTOR on the front panel control. With

the attenuator at 0, an image of the LED reflected from the surface of the Ge detector should be visible on the monitor. Adjust lens 10 (on the detector module) in x, y, and z to roughly center and focus the image within the large area of the detector.

- b. Disengage the DETECTOR switch (upper beamsplitter mirror on BS5), and maximize the output of the Ge detector as seen on the lock-in amplifier.
- c. Re-engage DETECTOR and be sure the image of the LED is not too near the edge of the Ge detector. (The most sensitive spot on the detector appears to be near the upper left edge.) Finally, disengage the DETECTOR switch.

4.1.11. InSb Detector.

- a. In order to engage the InSb detector, the FOA-2000 System Software must have been loaded onto the HP computer. If the program is running (e.g. a menu is displayed on the HP screen), first press STOP on the keyboard. To connect the detector output to the lock-in amplifier, type the command

CALL F2000send("INSB")

- b. Adjust lens 9 on the InSb detector module in x, y, and z to maximize the output of the detector as seen on the lock-in display. Large adjustments in x and y are not recommended.

5.0. How to get help.

In the event that the system does not appear to operate correctly, or if the HP computer returns an error message, the appropriate sequence of actions is as follows:

1. Review the section below entitled "Likely Problems" to see if the fix is indicated there.
2. If the computer indicates an FOA-2000 error message, check page 12-16 of the Photon Kinetics Installation manual for an explanation of the problem.
3. If the computer indicates an HP software problem, then check the "Error Message" appendix of the HP Language Reference manual for an explanation of the error.

If the above steps do not remedy the situation, then contact Russ May or Rick Claus at the Fiber & Electro-Optics Research Center, Virginia Tech, at (703) 231-7203. Replacement parts and knowledgeable insight into the correct operation of the original, unaltered FOA-2000 may be obtained by calling Customer Support at Photon Kinetics, Beaverton, OR, at (503) 644-1960. It should be made clear to Photon Kinetics that the instrument under discussion is Serial No. E4221, which was adapted for use with fluoride fiber by Virginia Tech.

5.1 FOA-2000 Error Messages:

Occasionally the HP computer will indicate an "FOA-2000 error" together with an error number. Most often this may occur when the computer will mistakenly try to drive a stepper motor beyond its permissible range. The meaning of the error number may be found on page 12-16 of the FOA-2000 Installation manual.

Some of the system software routines poll the instrument status of the EG&G lock-in amplifier. If an error is returned by the lock-in to the HP computer, the routine will indicate an error and report the HP basic error number. A description of the error and the associated number is found in the "Error Message" appendix in the back of the HP Basic Language Reference manual.

5.2 Likely Problems

A list of likely problems, their possible causes, and remedies follow:

<u>Problem</u>	<u>Possible Cause and Remedy</u>
Computer displays "Division by zero" error; or output graphs show measurements to be very noisy.	a. Preamp power supply not turned on. b. Lamp power supply not switched on. c. Lamp bulb burned out. d. Preamp battery charge low. e. The phase lock may have been lost on the phase-lock amplifier. This appears to happen after the GPIB bus has been cleared with a "CLEAR 7" command. To reset the phase of the amplifier, type "CALL CLEARUP" and Return. If the program has been halted, then type "CALL MENU" to access the main menu. f. Tried to read archived data in from a non-existent file.
FOA Error no. 97	If the FOA-2000 control panel is turned on, then the system software must be restarted in order to reinitialize the Z-80 μ processor in the FOA-2000 control panel. In order to do this, stop the program execution (it may be necessary to hit the break key), and then type "RUN" and press the return key. It is not sufficient to "CALL MENU." The system software must be restarted. After restarting the software, the "Equipment Preset" routine should be run.
The HP computer seems to have halted or is "stuck" while trying to issue a command to the FOA-2000 unit or the lock-in amplifier. press the return key. Then type "CALL return key. This will the lock-in when a It may be possible by typing it will be and restart the	The GPIB bus may have crashed when program execution was halted while the computer was issuing a command or waiting for a status byte on the bus. To remedy, first press the "STOP" key on the computer. Then type "CLEAR 7" and CLEARUP" and the cause the phase to be reset on amplifier, which is often lost "CLEAR 7" is executed. to continue program execution "CONTINUE", but more likely necessary to "CALL MENU" test from the beginning.

Can't see the fiber end
in "FIBER LOAD" mode.

- a. Bad fiber end. Recleave.
- b. Fiber end off the screen. Put the FOA-2000 in "VIDEO OUT" mode, and peak the reading on the lock-in amp as the fiber is manually adjusted using the fiber movement controls on the FOA-2000 control panel. Then return the FOA-2000 to "FIBER OR SOURCE" mode.

During auto-alignment,
the computer consistently
returns messages indicating
that the fiber end positions
need to be adjusted.

- a. The fiber end might not be perpendicular to the fiber axis. Check the end angle using a fiber inspection scope, or recleave the fiber.
- b. The fiber alignment motors may need to be recentered. See page 13-1 of the FOA-2000 installation manual for a procedure to recenter the motors.

Grinding sound from
monochromator

In this case, the computer has lost track of actual position of the monochromator shaft, and is attempting to drive the shaft past its limits. The grinding sound results from the stepper motor slipping. To remedy, turn off the key switch on the FOA-2000 control panel immediately. Then turn on the front panel again, and type and execute "RUN" on the HP computer. Then run the "EQUIPMENT PRESET" subroutine from the main menu.

Appendix A. Neutral Density Filter Calibration Results

SPECTRAL ATTENUATION

FIBER ID: Attenuator calibration for ATTN #1 17-MAR-90 14:26:41

LENGTH: 0 km

WAVELENGTH	ATTENUATION (dB)
------------	------------------

800	-11.56
850	-11.14
900	-9.83
950	-6.91
1000	-4.89
1050	-3.55
1100	-2.69
1150	-2.11
1200	-1.76
1250	-1.65
1300	-1.45
1350	-1.49
1400	-2.07
1450	-1.87
1500	-1.96
1550	-7.06
1600	-7.41
1650	-8.43
1700	-8.39
1750	-8.21
1800	-8.21
1850	-8.17
1900	-8.11
1950	-8.03
2000	-7.98
2050	-7.92
2100	-7.87
2150	-7.82
2200	-7.75
2250	-7.71
2300	-7.66
2350	-7.60
2400	-7.54
2450	-7.48
2500	-7.42
2550	-7.34
2600	-7.32
2650	-7.24
2700	-7.23
2750	-7.12
2800	-7.11
2850	-7.11
2900	-7.11
2950	-7.09
3000	-7.07

3150	-6.97
3200	-6.93
3250	-6.88
3300	-6.85
3350	-6.82
3400	-6.81
3450	-6.77
3500	-6.76
3550	-6.73
3600	-6.70
3650	-6.66
3700	-6.63
3750	-6.60
3800	-6.59
3850	-6.55
3900	-6.55
3950	-6.52
4000	-6.49

SPECTRAL ATTENUATION

 FIBER ID: Attenuator calibration for ATTN #2 17-MAR-90 14:34:59
 LENGTH: 0 km

WAVELENGTH	ATTENUATION (dB)
------------	------------------

800	-22.56
850	-21.82
900	-20.25
950	-16.98
1000	-14.60
1050	-12.92
1100	-11.73
1150	-10.88
1200	-10.30
1250	-9.98
1300	-9.59
1350	-9.50
1400	-9.98
1450	-9.62
1500	-9.62
1550	-14.47
1600	-14.80
1650	-15.71
1700	-15.60
1750	-15.44
1800	-15.37
1850	-15.28
1900	-15.20
1950	-15.10
2000	-15.04
2050	-14.99
2100	-14.94
2150	-14.89
2200	-14.84
2250	-14.81
2300	-14.78
2350	-14.77
2400	-14.66
2450	-14.65
2500	-14.64
2550	-14.59

2700	-14.54
2750	-14.52
2800	-14.49
2850	-14.45
2900	-14.45
2950	-14.48
3000	-14.48
3050	-14.51
3100	-14.49
3150	-14.43
3200	-14.38
3250	-14.32
3300	-14.28
3350	-14.26
3400	-14.25
3450	-14.25
3500	-14.22
3550	-14.21
3600	-14.22
3650	-14.23
3700	-14.22
3750	-14.20
3800	-14.18
3850	-14.17
3900	-14.16
3950	-14.16
4000	-14.18

SPECTRAL ATTENUATION

FIBER ID: Attenuator calibration for ATTN #3 17-MAR-90 14:44:37
 LENGTH: 0 km

WAVELENGTH	ATTENUATION (dB)
------------	------------------

800	-34.31
850	-33.71
900	-32.25
950	-29.15
1000	-26.99
1050	-25.42
1100	-24.26
1150	-23.45
1200	-22.87
1250	-22.54
1300	-22.15
1350	-22.02
1400	-22.42
1450	-22.06
1500	-22.00
1550	-26.65
1600	-26.85
1650	-27.68
1700	-27.40
1750	-27.20
1800	-26.80
1850	-26.44
1900	-26.30
1950	-28.20
2000	-26.08
2050	-25.01
2100	-25.89

2300	-25.52
2350	-25.44
2400	-25.39
2450	-25.29
2500	-25.25
2550	-25.19
2600	-25.24
2650	-25.10
2700	-25.20
2750	-24.99
2800	-25.00
2850	-24.91
2900	-24.93
2950	-24.93
3000	-24.94
3050	-24.95
3100	-24.87
3150	-24.80
3200	-24.80
3250	-24.69
3300	-24.62
3350	-24.59
3400	-24.56
3450	-24.53
3500	-24.51
3550	-24.42
3600	-24.39
3650	-24.38
3700	-24.38
3750	-24.33
3800	-24.30
3850	-24.30
3900	-24.27
3950	-24.28
4000	-24.23

SPECTRAL ATTENUATION


FIBER ID: Attenuator calibration for ATTN #4 17-MAR-90 14:54:53
 LENGTH: 0 km

WAVELENGTH	ATTENUATION (dB)
------------	------------------

800	-44.20
850	-42.82
900	-40.85
950	-37.31
1000	-34.65
1050	-32.77
1100	-31.25
1150	-30.09
1200	-29.17
1250	-28.54
1300	-27.85
1350	-27.47
1400	-27.62
1450	-26.99
1500	-26.67
1550	-31.06
1600	-31.13
1650	-31.71

1750	-30.05
1800	-30.61
1850	-30.09
1900	-29.82
1950	-29.62
2000	-29.35
2050	-29.19
2100	-28.98
2150	-28.76
2200	-28.60
2250	-28.48
2300	-28.29
2350	-28.06
2400	-27.81
2450	-27.67
2500	-27.54
2550	-27.43
2600	-27.30
2650	-27.16
2700	-27.24
2750	-27.80
2800	-28.56
2850	-28.69
2900	-28.64
2950	-28.53
3000	-28.40
3050	-28.34
3100	-28.23
3150	-28.18
3200	-28.11
3250	-28.14
3300	-28.12
3350	-28.16
3400	-28.19
3450	-28.19
3500	-28.14
3550	-28.02
3600	-27.94
3650	-27.77
3700	-27.67
3750	-27.53
3800	-27.48
3850	-27.29
3900	-27.27
3950	-27.16
4000	-27.11

Appendix B. InSb Detector Preamp Power Supply Circuit



Appendix C. Index of Technical Reports and Publications

No technical reports other than this final report were generated during the administration of this contract.

There were no publications generated during the administration of this contract.

Appendix D. System Software Listing

```

10 | *****
12 |
14 | Copyright Notification:
16 |
18 |     COPYRIGHT 1985 PHOTON KINETICS, INC.
20 |     All rights reserved.
22 |     Contains trade secrets of Photon Kinetics, Inc.
24 |     Unauthorized copying, use, modification or transfer prohibited.
26 |
28 |     Extensive modifications were completed in April 1990 by K.D. Bennett
30 |     and R.G. May of Virginia Tech for the Naval Research Laboratory to
32 |     customize the system for use with IR fiber. Also towards this end,
34 |     routine INIT_FOA_CNTRL was added by C.S.S of P.K. on June 20th, 1989.
36 |
38 | OUTPUT KBD USING "*,K";"K"
40 | GCLEAR
42 | BEEP
44 | PRINT TABXY(5,8);"Copyright 1985/1989, Photon Kinetics, Inc."
46 | PRINT TABXY(16,9);"All rights reserved."
48 | WAIT 5
50 | OUTPUT KBD USING "*,K";"K"
52 | REM +*****+
54 | REM + FOA-2000 SYSTEM SOFTWARE  6/20/89      C.S.S      VERSION 2.1IRP
56 | REM + Main Program "Mainprog"
58 | REM + PURPOSE:
60 | REM + This is the main program that calls all other
62 | REM + test and utility modules. It sets up the required data
64 | REM + and calls the initialization routines that prepare the
66 | REM + FOA-2000 system for measurements. Then, it prints a menu
68 | REM + of options for the user to choose from. At present, the menu
70 | REM + contains options for running the test sequence defined by
72 | REM + the user's FIBERTEST module, setting the time and date,
74 | REM + inspecting the system set-up data, and archiving measurement
76 | REM + results. Other options can be added easily.
78 | REM +
80 | REM -*****-
82 | !
84 | ! First the common data areas are set-up. The data in these common
86 | ! areas are shared among many routines in the utility software. They
88 | ! should not be changed since many routines reference this data.
90 | !
92 | OPTION BASE 0
94 | COM /Diskdrive/ Sysdrive$(20),Arcdrive$(20)
96 | COM /Iopaths/ @Foa2000,@Egg5205,@Tek7854,@Bncdelay,Printer_add
98 | COM /Previous/ Previous$(80)
100 | COM /Egg5205/ Scales(20),Settle,INTEGER Num_aver,Range
102 | COM /Sysdata/ Serial_num$(40),Lasers(2),Filter_flag,Filters(11),Num_focus,
Focus(64,3),Cutoff,Low_wave,High_wave,Det_switch
104 | COM /Syscal/ Pin_x,Pin_y,Pin_z,Inx_step,Iny_step,Outx_step,Outy_step,Farfi
old_step,Inoise

```

```

114 COM /Frequency/ Frequency(200),Num_freqs
116 COM /Farfield/ Ffieldval(200),Fnum_points,Farfield(203,1),Ffield_id$(80)
118 COM /Fftampdata/ Ffrawdata(203,1),Ffdiffdata(203,1),Ffsmoothdata(203,1)
120 COM /Farfield_wave/ Ffwavelen
122 COM /Specrundata/ Specrundata(350,1),Specrun_id$(80)
124 COM /Specrerefdata/ Specrerefdata(350,1),Specreref_id$(80)
126 COM /Specattdata/ Specattdata(350,1),Specatt_id$(80)
128 COM /Dmadata/ Dmarundata(350,1),Dmarefdata(350,1),Dmaattendata(350,1),D
ma_id$(80)
130 COM /Directref/ Specrerefcor(350,1),Pulserefcor(1,256,2),Pulsecorwave(2),Cor
rect_flag(2)
132 COM /Pulserundata/ Pulserundata(257,2),Pulserun_id$(2)(80),Pulserunwave(2)
,Num_aves$(10),Sys_delay
134 COM /Pulserefdata/ Pulserefdata(257,2),Pulseref_id$(2)(80),Pulserefwave(2)
136 COM /Pulseresults/ Pulseresult(1,256,2),Pulseres_id$(2)(80),Pulsereswave(2
)
138 COM /Jittercor/ Jittercor(256)
140 COM /Nearfield/ Nfieldval(200),Num_points,Nearfield(200,1),Nfield_id$(80)
142 COM /Otdrdata/ Otdr(255),Otdr_id$(80),Time_div
144 COM /Cutoff/ Cutref(200,1),Cutresult(200,1),Cutoff_id$(80),Cutoff_wave,Fin
st,Last,Slope,Intercept
146 COM /Varap/ Varap_id$(80),Varap_data(1,16),Varap_sn$(40),Apcal_data(2,15),
Ap_nums(15),Num_ap6
148 COM /Addition/ Curr_wave,Gratings(10),Cur_grating,Wave_step
150 !
152 ! Next, the various devices in the system are assigned to I/O paths.
154 ! After these assignments, all references to the device are made through
156 ! the appropriate I/O path name. These path names and their character-
158 ! istics should not be changed unless a device address is changed.
160 !
162 Foaadres=5 !FOA-2000 primary address
164 Eggadres=4 !EGG-5207 primary address
166 Bncadres=15 !BNC delay primary address
168 T7854adres=10 !7854 primary address
170 ASSIGN @Foa2000 TO 700+Foaadres
172 ASSIGN @Egg5205 TO 700+Eggadres
174 ASSIGN @Bncdelay TO 700+Bncadres
176 ASSIGN @Tek7854 TO 700+T7854adres
178 DUMP DEVICE IS PRT !Address of dump device
180 Printer_add=PRT !Address of printer:PRT-701
182 PRINTER IS CRT
184 !
186 ! The scale factors for the EGG5207 are stored in a common array in
188 ! the common area called /Egg5205/. These scale factor values are
190 ! used to scale readings from the EGG5205 into volts. The array is
192 ! initialized here.
194 !
196 DATA 2.5E-3,1E-3,.5E-3,2.5E-4,1E-4,.5E-4,2.5E-5,1E-5,.5E-5,2.5E-6,1E-6,.5E
-6,2.5E-7,1E-7,.5E-7,2.5E-8,1E-8,.5E-8,2.5E-9,1E-9,.5E-9
198 READ Scales(*) !Read scale factors into an array
200 !
202 ! The disk drives are assigned device specifier names used throughout
204 ! this software when the disk drives are accessed. These drive names
206 ! are automatically derived from the current MSI. This may be inapprop-
208 ! riate for some systems where MSI's are changed to MEMORY or BUBBLE.
210 ! If this is the case then change these lines to assign these directly.
212 ! Some examples are
214 ! 9836: Sysdrive$=":INTERNAL,4,0" Arcdrive$=":INTERNAL,4,1"
216 ! 9817: Sysdrive$=":HP9122,701,0" Arcdrive$=":HP9122,700,1"
218 ! 9816: Sysdrive$=":HP8290X,701,0" Arcdrive$=":HP8290X,701,1"
220 !
222 Sys$=SYSTEM$("MSI")
224 IF POS(9)=4 THEN GOTO 225 ELSE GOTO 226

```

```

230 MASS STORAGE IS Sysdrive$
232 |
234 | If the keyboard is a 46020A keyboard then some initialization should be
236 | done on it. This is accomplished automatically below.
238 |
240 STATUS KBD,9:Key_id
242 IF BIT(Key_id,5) THEN
244     CONTROL KBD,14:0 !Set fl=f1, not f0
246     OUTPUT KBD USING "-K,%"CHR$(255)&CHR$(123) !Put function keys in USER
248 END IF
250 |
252 | If BASIC 4.0 or greater is running, then turn on the display comp-
254 | atability card if it is there.
256 |
258 IF VAL(SYSTEM$( "VERSION:BASIC" ))>=4.0 AND POS(SYSTEM$( "CRT ID" ),"B") THEN
260     CONTROL CRT,21:1
262 END IF
264 |
266 | Now the initialization routine is called to initialize the system.
268 | The system data file is read in, and previously-measured reference
270 | data is transferred from the system disk into Common.
272 |
274 Init:ON ERROR GOTO Syserror
276 CALL Sysinit
278 OFF ERROR
280 CALL Menu
282 GOTO Init
284 |
286 | We get an error when attempting to call SYSINIT if MAINPROG is
288 | run without the rest of the system software package. The loadsub
290 | module will build the complete FOA2000 file.
292 !! THIS IS FOR PHOTON KINETICS USE ONLY !!
294 |
296 Syserror:IF ERRN=7 THEN
298     OFF KEY
300     BEEP
302     DISP "Do you want to build an F2000SYSTEM file?"
304     ON KEY S LABEL " YES" GOTO Build
306     ON KEY 6 LABEL " NO " GOTO Done
308 Wait_here:GOTO Wait_here
310 Build:OFF KEY
312     DISP ""
314     GOTO Init
316 ELSE
318 Main_err:BEEP
320     DISP "MAINPROG -- "&ERRM$
322 Dead1:GOTO Dead1
324 END IF
326 Done:DISP ""
328 END
330 |
332 |
334 SUB Sysinit
336 |*****
338 | SYSTEM INITIALIZATION MODULE VERSION 2.1P
340 |*****
342 COM /Diskdrive/ Sysdrive$,Arcdrive$
344 COM /Sysdata/ Serial_num$,Laser(*),Filter_flag,Filter(*),Num_focus,Focus
346 COM /Syscal/ Pin_x,Pin_y,Pin_z,Inx_step,Iny_step,Outx_step,Outy_step,Far
348 COM /Directref/ Specrefcor(*),Pulserefcor(*),Pulsecorwave(*),Correct_flg

```

```

354 COM /Pulserundata/ Pulserundata(*),Pulserun_id$(*),Pulserunwave(*),Num_a
ves$[10],Sys_delay
356 COM /Jittercor/ Jittercor(*)
358 COM /Addition/ Curr_wave,Gratings(*),Cur_grating,Wave_step
360 DIM Filename$[40],Temp(1,256)
362 ABORT 7 !Send IFC (Interface Clear) on GPIB
364 GCLEAR
366 STATUS KBD,9;Key_id
368 !
370 ! If the number of pulse averages has not been set, default=400
372 !
374 IF Num_aves$="" THEN Num_aves$="4 0 0"
376 CALL Init_foa_ctrl !Set the FOA-2000's controller to new mono stuff
378 !
380 ! Now check to see if the user wants to load/reload user routines.
382 !
384 ON ERROR GOTO File_error
386 Load_set:OFF KEY
388 Filename$="foasetup" !Set-up file name
390 DISP ""
392 INTEGER Index
394 !
396 ! Now read the FOA-2000 set-up file called "foasetup"
398 !
400 Readsetup:ASSIGN @Setupfile TO Filename$&Sysdrives$
402 ENTER @Setupfile;Version$ !Check the setup file
404 IF NOT POS(Version$,"VERSION") THEN
406 BEEP
408 PRINT TABXY(5,10);"The set up file on this disk is the wrong version,"
410 PRINT TABXY(5,11);"sub SYSTEMDATA should be called to update it, (wave
length limits and"
412 PRINT TABXY(5,12);"machine serial number I.D. should be added)."

```

```

482 | Next, read the insertion delay.
484 |
486 Read_delay:Filename$="pulsedelay"
488 ASSIGN @Delayfile TO "pulsedelay"
490 ENTER @Delayfile;Sys_delay
492 ASSIGN @Delayfile TO *
494 Read_jitter:Filename$="jittercor"
496 ASSIGN @Jittercor TO "jittercor"
498 ENTER @Jittercor;Jittercor(*)
500 ASSIGN @Jittercor TO *
502 |
504 | Next read the variable aperture calibration data.
506 |
508 Readvarapcal:Filename$="varapcal"
510 ASSIGN @Varapfile TO Filename$&Sysdrives$
512 ENTER @Varapfile;Varap_sn$
514 ENTER @Varapfile;Apcal_data(*)
516 ASSIGN @Varapfile TO *
518 |
520 | Next, read the Spectral Attenuation direct-spot correction data
522 |
524 Readspeccor:Filename$="speccor"
526 ASSIGN @Specreffile TO Filename$&Sysdrives$
528 ENTER @Specreffile;Specreffcor(*)
530 ASSIGN @Specreffile TO *
532 |
534 | Read the Swept frequency direct-spot correction data for all 3 lasers
536 |
538 Readpulse:FOR Jindex=0 TO 2
540     Filename$="pulsecor"&VAL$(Jindex+1)
542     ASSIGN @Pulsereffile TO Filename$&Sysdrives$
544     ENTER @Pulsereffile;Temp(*)
546     ENTER @Pulsereffile;Pulsecorwave(Jindex)
548     FOR Index=0 TO 256
550         Pulsereffcor(0,Index,Jindex)=Temp(0,Index)
552         Pulsereffcor(1,Index,Jindex)=Temp(1,Index)
554     NEXT Index
556     ASSIGN @Pulsereffile TO *
558 Readpulse_1: NEXT Jindex
560 GOTO Done
562 File_error: SELECT ERRN
564     CASE 56
566         SELECT Filename$
568         CASE "foasetup"
570             BEEP
572             PRINT TABXY(1,17);"The FOA-2000 set-up file does not exist on the di
sk in the primary"
574             PRINT TABXY(1,18);"disk drive. Please insert the system software dis
k and press PROCEED."
576             ON KEY 5 LABEL "PROCEED" GOTO Ready
578 Wait_2: GOTO Wait_2
580 Ready: OFF KEY
582     GOSUB Cln_screen
584     GOTO Readsetup
586     CASE "pulsedelay"
588         Sys_delay=40
590     GOTO Read_jitter
592     CASE "jittercor"
594     GOTO Readvarapcal
596     CASE "varapcal"
598     GOTO Readspeccor
600     CASE "speccor"

```

```

060      ON KEY 5 LABEL "RE-TRY" GOTO Load_user
061      BEEP
062      DISP "The ""USER"" file was not found on this disk."
063      ON KEY 5 LABEL "RE-TRY" GOTO Load_user
064      IF BIT(Key_id,5) THEN
065          ON KEY 6 LABEL "LOAD AL-TERNATE" GOTO Try_again
066      ELSE
067          ON KEY 6 LABEL "LOAD ALTERNATE" GOTO Try_again
068      END IF
069      GOTO Wait_3
070  CASE ELSE
071      BEEP
072      DISP Filename$;" was not found."
073      ON KEY 5 LABEL "RE-TRY" GOTO Try_again
074      IF BIT(Key_id,5) THEN
075          ON KEY 6 LABEL "LOAD    DEFAULT" GOTO Default
076      ELSE
077          ON KEY 6 LABEL "LOAD DEFAULT" GOTO Default
078      END IF
079  Wait_3: GOTO Wait_3
080  Try_again: CAT Sysdrive$
081      GOTO Load_alt
082  Default: Filename$="USER"
083      GOTO Load_user
084  END SELECT
085  CASE 7
086      GOTO Skip_del
087      I Call to an undefined subprogram
088  CASE 80
089      BEEP
090      DISP "There is no disk in the disk drive. Please install the disk and
091  press proceed."
092      ON KEY 5 LABEL "PROCEED" GOTO Proceed
093  Wait_4: GOTO Wait_4
094  Proceed: SELECT Filename$
095      CASE "foasetup"
096          GOTO Readsetup
097      CASE "varapcal"
098          GOTO Readvarapcal
099      CASE "speccor"
100          GOTO Readspeccor
101      CASE "pulsecor1","pulsecor2","pulsecor3"
102          GOTO Readpulse
103      CASE "USER"&Sysdrive$
104          GOTO Load_user
105      CASE ELSE
106          GOTO Load_alt
107  END SELECT
108  CASE ELSE
109      BEEP
110      DISP "SYSINIT -- Error number "&VAL$(ERRN)
111  Dead1: GOTO Dead1
112  END SELECT
113  Cln_screen: OUTPUT KBD USING "#,K";"K"
114  RETURN
115  Done: SUBEND
116  I
117  SUB Systemdata
118  I+*****+
119  I EXAMINE/MODIFY SYSTEM DATA MODULE                                VERSION 2.1
120  I-*****-
121  I
122  I INITIALIZATION
123  I
124  I

```

```

738 DIM Filenames$(25),Titles$(200),Keys$(1:20)(16)
740 !Set key label data for 16's and 17's
742 Data16:DATA QUIT,PRINT DATA,MODIFY DATA,SHOW CAL DATA,RETURN TO MENU,PRINT C
AL DATA,CHANGE LASERS,USE MONOCHRO.  CHANGE FILTERS,USE FILTERS
744 DATA USE CUTOFF FIL,MOD/DEL CUTOFF,MOD WAVE LIMIT,ADD CORR VALUE,DEL COR
R VALUE,MOD CORR VALUE,DISPLAY DATA,FILTER WHEEL,MONOCHROMATER,CHANGE SERIAL #
746 Data17:DATA QUIT,PRINT DATA,MODIFY DATA,SHOW CALDATA,RETURN TO MENU,PRIN
T CAL DATA,CHANGE LASERS,USE MONOCHRM.,CHANGE FILTERS,USE FILTERS
748 DATA USE CUT-OFF FIL.,MOD/DEL CUTOFF,MOD WAVELIMITS,ADD CORRVALUE,DEL CO
RRVALUE,MOD CORRVALUE,DISPLAY DATA,FILTER WHEEL,MONOCHR-OMATER,CHANGE SERIAL #
750 !
752 ! If computer is a 9816/36 then read the first set of key labels otherwise
754 ! read the second set of key labels.
756 !
758 RESTORE Data16
760 STATUS KBD,9,Key_id
762 IF BIT(Key_id,5) THEN RESTORE Data17
764 READ Keys$(*)
766 !
768 ! Write_flag is set if any system data is modified, to indicate
770 ! that the foasetup file must be purged and re-written.
772 !
774 Write_flag=0 !Clear re-write foasetup flag
776 Filenames%="foasetup"&Sysdrives$ !Set-up file name
778 INTEGER Index
780 !
782 ! Display the system data on the CRT (excluding calibration data)
784 !
786 GOSUB Sys_display
788 !
790 ! Now ask the user what to do
792 !
794 Sys_menu:BEEP
796 ON KEY 1 LABEL Keys$(20) GOTO Change_sn
798 ON KEY 5 LABEL Keys$(1) GOTO Sys_done
800 ON KEY 6 LABEL Keys$(2) GOTO Print_scrn
802 ON KEY 7 LABEL Keys$(3) GOTO Call_mod
804 ON KEY 8 LABEL Keys$(4) GOTO Call_cal
806 Wait_menu:GOTO Wait_menu
808 Change_sn:OFF KEY
810 DISP ""
812 Write_flag=1
814 INPUT "Enter a serial number or new identifier: ",Serial_num$
816 GOSUB Sys_display
818 GOTO Sys_menu
820 Print_scrn:OFF KEY
822 DUMP ALPHA
824 GOSUB Clr_screen
826 GOSUB Sys_display
828 GOTO Sys_menu
830 Call_mod:OFF KEY
832 GOSUB Sys_modify
834 GOSUB Clr_screen
836 GOSUB Sys_display
838 GOTO Sys_menu
840 Call_cal:OFF KEY
842 GOSUB Sys_cal
844 GOSUB Clr_screen
846 GOSUB Sys_display
848 GOTO Sys_menu
850 Clr_screen:OUTPUT KBD USING "#,K": "K"
852 RETURN

```

```

860 Sys_display: GOSUB Clr_screen
862 DISP ""
864 PRINT TABXY(5,1);CHR$(129);" FOA-2000 SYSTEM CONFIGURATION: MACHINE SERIAL NUMBER "&Serial_num$;CHR$(128)
866 PRINT
868 PRINT CHR$(132);"Wavelength Range:";CHR$(128)&" ";VAL$(Low_wave);" nm to ";VAL$(High_wave);" nm. Detector switch at ";VAL$(Det_switch);"."
870 IF Filter_flag=1 THEN
872 PRINT CHR$(132);"
                                FILTER WHEEL WAVELENGTHS
                                ";CHR$(128)
874 PRINT CHR$(132);"Filter";CHR$(128);" ";CHR$(132);"Wavelength";CHR$(128);"
                                ";CHR$(132);"Filter";CHR$(128);" ";CHR$(132);
876 PRINT "Wavelength";CHR$(128);" ";CHR$(132);"Filter";CHR$(128);"
                                ";CHR$(132);"Wavelength";CHR$(128)
878 FOR Index=0 TO 3
880 PRINT USING "2X,2D,6X,4D,13X,2D,6X,4D,13X,2D,6X,4D";Index,Filter(Index),Index+4,Filter(Index+4),Index+8,Filter(Index+8)
882 NEXT Index
884 ELSE
886 PRINT
888 IF Filter_flag=2 THEN
890 PRINT "Monochrometer installed and cutoff filters are being used."
892 ELSE
894 PRINT "Monochrometer installed but cutoff filters not being used."
896 END IF
898 PRINT
900 END IF
902 PRINT CHR$(132);"
                                CORRECTION VALUES
                                ";CHR$(128)
904 PRINT CHR$ 13 "Wavelength X Y Z";CHR$(128);" ";CHR$(132);"Wavelength X Y Z";CHR$(128);" ";CHR$(132);
906 PRINT "Wavelength X Y Z";CHR$(128)
908 FOR Index=0 TO 21
910 PRINT USING "3X,4D,3X,3D,2X,3D,2X,4D,#";Focus(Index,0),Focus(Index,1),Focus(Index,2),Focus(Index,3)
912 PRINT USING "4X,4D,3X,3D,2X,3D,2X,4D,#";Focus(Index+22,0),Focus(Index+22,1),Focus(Index+22,2),Focus(Index+22,3)
914 IF Index<21 THEN
916 PRINT USING "4X,4D,3X,3D,2X,3D,2X,4D";Focus(Index+44,0),Focus(Index+44,1),Focus(Index+44,2),Focus(Index+44,3)
918 END IF
920 NEXT Index
922 RETURN
924
926 ! Display Calibration Data
928 !
930 Sys_cal:GOSUB Clr_screen
932 DISP ""
934 PRINT TABXY(25,1);CHR$(129);" FOA-2000 CALIBRATION CONSTANTS ";CHR$(128)
936 PRINT
938 PRINT TABXY(33,3);CHR$(132);"PINHOLE POSITION";CHR$(128)
940 PRINT TABXY(23,5);"Pin_x: ";Pin_x;" Pin_y: ";Pin_y;" Pin_z: ";Pin_z
942 PRINT TABXY(30,7);CHR$(132);"FIBER STAGE STEP SIZE";CHR$(128)
944 PRINT TABXY(8,9);"Inx_step: ";Inx_step;" Iny_step: ";Iny_step;" Outx_step: ";Outx_step;" Outy_step: ";Outy_step
946 PRINT TABXY(25,11);CHR$(132);"FAR-FIELD RESTRICTOR STEP SIZE";CHR$(128)
948 PRINT TABXY(28,13);"Farfield_step: ";Farfield_step
950 PRINT TABXY(26,15);CHR$(132);"LOW-FREQUENCY DETECTOR NOISE";CHR$(128)
952 PRINT TABXY(28,17);"Lfnoise: ";Lfnoise
954 ON KEY 5 LABEL Keys$(5) GOTO Cal_done
956 ON KEY 6 LABEL Keys$(6) GOTO Cal_print
958 Wait_cal:GOTO Wait_cal
960 Cal_print:OFF KEY

```

```

968      |
970      | Modify the System data
972      |
974 Sys_modify:GOSUB Cln_screen
976      BEEP
978      ON ERROR GOSUB Input_error
980      |
982      | Modify menu
984      |
986      ON KEY 5 LABEL Keys$(7) GOTO Mod_lasers
988      SELECT Filter_flag
990      CASE 1
992          ON KEY 6 LABEL Keys$(8) GOTO Use_mono
994          ON KEY 7 LABEL Keys$(9) GOTO Mod_filter
996      CASE 0
998          ON KEY 6 LABEL Keys$(10) GOTO Use_filter
1000         ON KEY 7 LABEL Keys$(11) GOTO Use_cutoff
1002      CASE 2
1004         ON KEY 6 LABEL Keys$(10) GOTO Use_filter
1006         ON KEY 7 LABEL Keys$(12) GOTO Mod_cutoff
1008      END SELECT
1010      ON KEY 1 LABEL Keys$(14) GOTO Add_corr
1012      ON KEY 2 LABEL Keys$(15) GOTO Del_corr
1014      ON KEY 3 LABEL Keys$(13) GOTO Mod_highlow
1016      ON KEY 4 LABEL Keys$(16) GOTO Mod_corr
1018      ON KEY 8 LABEL Keys$(17) GOTO Mod_done
1020 Wait_mod:GOTO Wait_mod
1022      |
1024      | Modify laser wavelengths
1026      |
1028 Mod_lasers:OFF KEY
1030      DISP ""
1032      Write_flag=1                      !Set flag to re-write foasetup
1034      BEEP
1036      ON KEY 5 LABEL "LASER 1" GOTO Laser_1
1038      ON KEY 6 LABEL "LASER 2" GOTO Laser_2
1040      ON KEY 7 LABEL "LASER 3" GOTO Laser_3
1042 Wait_las:GOTO Wait_las
1044 Laser_1:OFF KEY
1046      BEEP
1048      INPUT "Enter the new wavelength for laser 1 in nanometers: ",Laser(0)
1050      GOTO Check
1052 Laser_2:OFF KEY
1054      BEEP
1056      INPUT "Enter the new wavelength for laser 2 in nanometers: ",Laser(1)
1058      GOTO Check
1060 Laser_3:OFF KEY
1062      BEEP
1064      INPUT "Enter the new wavelength for laser 3 in nanometers: ",Laser(2)
1066      GOTO Check
1068 Check:DISP "Do you want to change another laser wavelength?"
1070      BEEP
1072      ON KEY 5 LABEL "YES" GOTO Mod_lasers
1074      ON KEY 6 LABEL "NO" GOTO Mod_done
1076 Wait_chk:GOTO Wait_chk
1078      |
1080      | Modify the filter flag: If set, clear it; if clear, set it.
1082      |
1084 Use_mono:OFF KEY
1086      DISP ""
1088      Write_flag=1                      !Set re-write flag to rewrite foasetup
1090      Filter_flag=0                    !Clear filter_flag (use monochromator)
1092      GOTO Mod_lasers

```

```

1000      Write_flag=1
1100      Filter_flag=1                      !Set filter_flag (use filter wheel)
1102      GOTO Mod_done
1104      Use_cutoff:OFF KEY
1106      DISP ""
1108      Write_flag=1
1110      Filter_flag=2                      !Filter_flag=2 (mono w/ cutoff filters)
1112      GOTO Mod_done
1114      Mod_highlow:OFF KEY
1116      DISP ""
1118      Write_flag=1
1120      BEEP
1122      INPUT "Enter the new low wavelength range limit: ",Low_wave
1124      INPUT "Enter the new high wavelength range limit: ",High_wave
1126      INPUT "Enter the new detector switch wavelength: ",Det_switch
1128      GOTO Mod_done
1130      Mod_cutoff:OFF KEY
1132      DISP ""
1134      Write_flag=1
1136      Cut_off:INPUT "Enter wavelength to switch the cutoff filters, (entering 0 w
all cancel cutoff): ",Cutoff1
1138      IF Cutoff1=0 THEN
1140          Filter_flag=0
1142      ELSE
1144          IF Cutoff1<Low_wave OR Cutoff1>High_wave THEN
1146              BEEP
1148              DISP "Cutoff filter switch point must be between "&VAL$(Low_wave)&"
and "&VAL$(High_wave)&" nm."
1150              WAIT 3
1152              GOTO Cut_off
1154          ELSE
1156              Cutoff=Cutoff1
1158          END IF
1160      END IF
1162      GOTO Mod_done
1164      |
1166      | Modify filter wavelengths
1168      |
1170      Mod_filter:OFF KEY
1172      DISP ""
1174      BEEP
1176      Write_flag=1                      !Set flag to rewrite foasetup
1178      INPUT "Enter the filter number (0-11) you want to change: ",Filter_num
1180      IF Filter_num>11 OR Filter_num<0 THEN GOTO Mod_filter
1182      BEEP
1184      INPUT "Enter the new wavelength: ",Filter(Filter_num)
1186      DISP "Do you want to change more filter wavelengths?"
1188      BEEP
1190      ON KEY 5 LABEL "YES" GOTO Mod_filter
1192      ON KEY 6 LABEL "NO" GOTO Mod_done
1194      Wait_fil:GOTO Wait_fil
1196      |
1198      | Modify a correction value
1200      |
1202      Mod_corr:OFF KEY
1204      DISP ""
1206      Write_flag=1                      !Set flag to rewrite foasetup
1208      Try_again:BEEP
1210      INPUT "Enter the correction wavelength you want to modify: ",Wavelen
1212      DISP ""                          !Clear error messages
1214      FOR Index=0 TO Num_focus
1216          IF Wavelen=Focus(Index,0) THEN GOTO Get_new
1218      NEXT Index
1220      BEEP

```

```

1224 OFF ERROR
1226 GOTO Sys_modify
1228 Get_new:BEEP
1230 INPUT "Enter the new X-axis correction value: ",Focus(Index,1)
1232 BEEP
1234 INPUT "Enter the new Y-axis correction value: ",Focus(Index,2)
1236 BEEP
1238 INPUT "Enter the new Z-axis correction value: ",Focus(Index,3)
1240 Focus(Index,0)=Wavelen
1242 GOTO Mod_done
1244 !
1246 ! Delete a correction value
1248 !
1250 Del_corr:OFF KEY
1252 BEEP
1254 Write_flag=1 !Set flag to rewrite foasetup
1256 INPUT "Enter the wavelength of the correction value you want to delete",
Wavelen
1258 FOR Index=0 TO Num_focus !Find the one to delete
1260 IF Wavelen=Focus(Index,0) THEN GOTO Delete
1262 NEXT Index
1264 BEEP
1266 DISP "SYSTEM DATA--The specified wavelength is not in the correction tab
le."
1268 OFF ERROR
1270 GOTO Sys_modify
1272 !
1274 ! Delete the correction entry by moving the rest down by 1
1276 !
1278 Delete:FOR Index=Index TO Num_focus-1
1280 Focus(Index,0)=Focus(Index+1,0)
1282 Focus(Index,1)=Focus(Index+1,1)
1284 Focus(Index,2)=Focus(Index+1,2)
1286 Focus(Index,3)=Focus(Index+1,3)
1288 NEXT Index
1290 Focus(Index,0)=0
1292 Focus(Index,1)=0
1294 Focus(Index,2)=0
1296 Focus(Index,3)=0
1298 Num_focus=Num_focus-1 !And decrement the count
1300 GOTO Mod_done
1302 !
1304 ! ADD A NEW CORRECTION VALUE
1306 !
1308 Add_corr:OFF KEY
1310 DISP ""
1312 IF Num_focus=19 THEN
1314 BEEP
1316 DISP "SYSTEMDATA -- The correction table is full, delete an entry firs
t."
1318 OFF ERROR
1320 GOTO Sys_modify
1322 END IF
1324 BEEP
1326 Write_flag=1 !Set flag to re-write foasetup
1328 INPUT "Enter the new correction wavelength: ",Wavelen
1330 IF Wavelen<800 OR Wavelen>1600 THEN
1332 BEEP
1334 DISP "SYSTEMDATA -- Correction wavelengths must be between 800 and 160
0."
1336 OFF ERROR
1338 GOTO Sys_modify
1340 END IF
1342 BEEP

```

```

1350 BEEP
1352 INPUT "Enter the new Z-axis correction: ",Zaxis
1354 |
1356 | Find the place to put the new correction values
1358 |
1360 FOR Index=0 TO Num_focus
1362 IF Focus(Index,0)>Wavelen THEN GOTO Add
1364 IF Focus(Index,0)=Wavelen THEN GOTO Replace
1366 NEXT Index
1368 |
1370 | Now make room for the new value by shifting up by 1
1372 |
1374 Add:FOR Ix=Num_focus+1 TO Index+1 STEP -1
1376 Focus(Ix,0)=Focus(Ix-1,0)
1378 Focus(Ix,1)=Focus(Ix-1,1)
1380 Focus(Ix,2)=Focus(Ix-1,2)
1382 Focus(Ix,3)=Focus(Ix-1,3)
1384 NEXT Ix
1386 |
1388 | Add the new value and update the count (num_focus)
1390 |
1392 Focus(Ix,0)=Wavelen
1394 Focus(Ix,1)=Xaxis
1396 Focus(Ix,2)=Yaxis
1398 Focus(Ix,3)=Zaxis
1400 Num_focus=Num_focus+1
1402 GOTO Mod_done
1404 |
1406 | If the specified wavelength already exists, replace it
1408 |
1410 Replace:Focus(Index,0)=Wavelen
1412 Focus(Index,1)=Xaxis
1414 Focus(Index,2)=Yaxis
1416 Focus(Index,3)=Zaxis
1418 Mod_done:OFF ERROR
1420 RETURN
1422 |
1424 | This code is executed if the set-up file does not exist
1426 | and the user wants to create one.
1428 |
1430 Sys_create:GOSUB Clr_screen
1432 OFF ERROR
1434 ON ERROR GOSUB Input_error
1436 OFF KEY
1438 Write_flag=2 !Set flag for creating a new foasetup
1440 BEEP
1442 INPUT "Enter the machine's serial number: ",Serial_num$
1444 BEEP
1446 INPUT "Enter the low wavelength range limit: ",Low_wave
1448 BEEP
1450 INPUT "Enter the high wavelength range limit: ",High_wave
1452 BEEP
1454 INPUT "Enter the detector switch wavelength: ",Det_switch
1456 BEEP
1458 INPUT "Enter the laser 1 wavelength: ",Laser(0)
1460 BEEP
1462 INPUT "Enter the laser 2 wavelength: ",Laser(1)
1464 BEEP
1466 INPUT "Enter the laser 3 wavelength: ",Laser(2)
1468 BEEP
1470 DISP "Does the system have a filter wheel or monochromator?"
1472 ON KEY 5 LABEL Keys$(18) GOTO Set_flag

```

```

1482 GOTO F_corr
1484 Set_flag:OFF KEY
1486 Filter_flag=1
1488 FOR Index=0 TO 11
1490 BEEP
1492 PRINT TABXY(1,18);"Enter the wavelength of filter ";Index+1;" : "
1494 INPUT Filter(Index)
1496 NEXT Index
1498 F_corr:GOSUB Clr_screen
1500 PRINT TABXY(1,18);"Do you want to create a correction table?"
1502 ON KEY 5 LABEL " YES" GOTO Yes
1504 ON KEY 6 LABEL " NO" GOTO No
1506 Wait_cor:GOTO Wait_cor
1508 Yes:OFF KEY
1510 GOSUB Clr_screen
1512 INPUT "Enter the number of correction points. ",Num_focus
1514 DISP "" !Clear error message
1516 IF Num_focus>20 THEN
1518 BEEP
1520 DISP "SYSTEMDATA -- The maximum number of correction points is 64."
1522 GOTO Yes
1524 END IF
1526 Num_focus=Num_focus-1
1528 PRINT TABXY(40,8);"NOTE"
1530 PRINT TABXY(5,9);"Correction values must be entered in ascending order f
rom"
1532 PRINT TABXY(5,10);"the lowest wavelength to the highest wavelength value
."
1534 FOR Index=0 TO Num_focus
1536 PRINT TABXY(1,18);"Enter the wavelength for correction point ";Index+1
1538 INPUT Focus(Index,0)
1540 GOSUB Clr_screen
1542 PRINT TABXY(1,18);"Enter the X-axis correction for point ";Index+1
1544 INPUT Focus(Index,1)
1546 GOSUB Clr_screen
1548 PRINT TABXY(1,18);"Enter the Y-axis correction for point ";Index+1
1550 INPUT Focus(Index,2)
1552 GOSUB Clr_screen
1554 PRINT TABXY(1,18);"Enter the Z-axis correction for point ";Index+1
1556 INPUT Focus(Index,3)
1558 GOSUB Clr_screen
1560 NEXT Index
1562 No:OFF KEY
1564 OFF ERROR
1566 ON ERROR GOTO File_error
1568 DISP ""
1570 RETURN
1572 !
1574 ! Come here if the set-up file doesn't exist.
1576 !
1578 Input_error:OFF ERROR
1580 SELECT ERRN
1582 CASE 32
1584 BEEP
1586 CASE ELSE
1588 BEEP
1590 DISP "INVALID CHARACTERS ENTERED: SYSTEMDATA -- "&ERRM$
1592 ON KEY 5 LABEL "PROCEED" GOTO Gohead1
1594 Hang_here:GOTO Hang_here
1596 Gohead1: OFF KEY
1598 END SELECT
1600 RETURN
1602 File_error:OFF ERROR

```

```

1610     DISP "The set-up file doesn't exist on this disk. Do you want to creat
& on6?"
1612     ON KEY 5 LABEL "YES" GOTO Set_create
1614     ON KEY 6 LABEL "NO" GOTO Dont_store
1616     ON KEY 8 LABEL "STORE CURRENT" GOTO Store_it
1618 Wait_create:GOTO Wait_create
1620 Dont_store:OFF KEY
1622     Write_flag=0
1624     GOTO Sys_done
1626 Set_create:OFF KEY
1628     Write_flag=3
1630     GOTO Sys_done
1632 Store_it:OFF KEY
1634     Write_flag=2
1636     CASE 54
1638         PURGE "foasetup"
1640     CASE 55
1642         BEEP
1644     DISP "The directory has overflowed. Use a different disk."
1646     ON KEY 5 LABEL "READY" GOTO Disk_change
1648 Wait_disk1:GOTO Wait_disk1
1650 Disk_change:OFF KEY
1652     DISP ""
1654     CASE ELSE
1656         BEEP
1658     DISP "SYSTEMDATA --"&ERRM$
1660 Dead_in_h20:GOTO Dead_in_h20
1662     END SELECT
1664 Sys_done:ON ERROR GOTO File_error
1666     OFF KEY
1668     IF Write_flag>0 THEN
1670         IF Write_flag=3 THEN GOSUB Sys_create
1672         IF Write_flag=1 THEN
1674             PURGE Filenames$
1676         END IF
1678         CREATE ASCII Filenames$,27
1680         ASSIGN @Setupfile TO Filenames$
1682         OUTPUT @Setupfile;"VERSION 2.1"
1684         OUTPUT @Setupfile;Serial_num$
1686         OUTPUT @Setupfile;Low_wave,High_wave
1688         OUTPUT @Setupfile;Laser(*)
1690         OUTPUT @Setupfile;Filter_flag
1692         OUTPUT @Setupfile;Filter(*)
1694         OUTPUT @Setupfile;Num_focus
1696         OUTPUT @Setupfile;F    ,(*)
1698         OUTPUT @Setupfile;Cutoff
1700         OUTPUT @Setupfile;Pin_x,Pin_y,Pin_z
1702         OUTPUT @Setupfile;Inx_step,Iny_step
1704         OUTPUT @Setupfile;Outx_step,Outy_step
1706         OUTPUT @Setupfile;Farfield_step
1708         OUTPUT @Setupfile;Lfnoise
1710         OUTPUT @Setupfile;Det_switch
1712         ASSIGN @Setupfile TO *
1714     END IF
1716     GOSUB Clr_screen
1718     DISP ""
1720 Exit:SUBEND
1722     !
1724     !
1726 SUB Timeset(OPTIONAL Timedate$)
1728 !+*****
1730 ! SET TIME/DATE MODULE
1732 ! .....

```

```

1738 DIM Mon$,Feb,MAR,MAY,JUN,JUL,AUG,SEP,OCT,NOV,DEC
1740 DIM Month$(1:12)(3)
1742 READ Month$(*)
1744 IF NPAR=1 THEN
1746   Hours=VAL(Timedate$)
1748   Minutes=VAL(Timedate$(POS(Timedate$,"")+1;2))
1750   Month=VAL(Timedate$(POS(Timedate$,"")+1;2))
1752   Timedate$=Timedate$(POS(Timedate$,"")+1,LEN(Timedate$))
1754   Day=VAL(Timedate$)
1756   Year=VAL(Timedate$(POS(Timedate$,"/")+1,LEN(Timedate$)))
1758   GOTO Set_time
1760 END IF
1762 GOSUB Cln_screen          !Clear screen
1764 Retry:PRINT TABXY(1,16);"Please enter the current time. Enter the hours and
minutes, "
1766 PRINT TABXY(1,17);"(in 24-hour format) separated by a colon. Example: 1
3:05"
1768 BEEP
1770 INPUT Hours$
1772 GOSUB Cln_screen
1774 IF POS(Hours$,":")=0 THEN
1776   BEEP
1778   PRINT TABXY(1,16);"Please enter the minutes (0-59): "
1780   INPUT Minutes$
1782   Hours=VAL(Hours$)
1784   Minutes=VAL(Minutes$)
1786 ELSE
1788   ENTER Hours$ USING "K,K";Hours,Minutes
1790 END IF
1792 GOSUB Cln_screen          ! Clear screen again
1794 Get_month:PRINT TABXY(1,16);"Please enter the month as a three-letter abbre-
viation."
1796 PRINT TABXY(1,17);"(JAN, FEB, MAR, APR, MAY, JUN, JUL, AUG, SEP, OCT, NO
V, DEC)"
1798 BEEP
1800 INPUT Mon$
1802 FOR I=1 TO 3              !Change lower case to upper case in month
1804   Mon$(I;1)=CHR$(BINAND(NUM(Mon$(I;1)),BINCMP(32)))
1806 NEXT I
1808 Month=0
1810 FOR I=1 TO 12             !Look for the month in month$
1812   IF POS(Mon$,Month$(I)) THEN Month=I
1814 NEXT I
1816 IF Month=0 THEN
1818   BEEP
1820   PRINT TABXY(1,10);"TIMESET -- You have entered an invalid month, pleas
e try again."
1822   GOTO Get_month
1824 END IF
1826 GOSUB Cln_screen
1828 BEEP
1830 PRINT TABXY(1,16);"Please enter the day of the month (1-31): "
1832 INPUT Day
1834 BEEP
1836 PRINT TABXY(1,16);"Please enter the last two digits of the year: "
1838 INPUT Year
1840 Set_time:IF Month>2 THEN
1842   Month=Month-3
1844 ELSE
1846   Month=Month+9
1848   Year=Year-1
1850 END IF
1852 Year=Year+1900

```

```

1860 Julian=Julian*86400+((3600*Hours+60*Minutes) MOD 86400)
1862 IF Julian<2.08662912E+11 OR Julian>2.143252224E+11 THEN Range_err
1864 SET TIMEDATE Julian
1866 GOTO Done
1868 Range_err:BEEP
1870 GOSUB Clr_screen
1872 PRINT "TIMESET -- The time or date entered was out of range. Please try
again."
1874 GOTO Retry
1876 Syntax_err:BEEP
1878 GOSUB Clr_screen
1880 PRINT TABXY(1,10);"TIMESET -- Syntax error. Please try again."
1882 GOTO Retry
1884 Clr_screen:OUTPUT KBD USING "#,K";"K"          ! Clear screen without scroll
1886 RETURN
1888 Done:OFF ERROR
1890 GOSUB Clr_screen
1892 DISP ""          ! Clear error messages
1894 SUBEND
1896 !
1898 !
1900 DEF FNTimedates$
1902 !+*****
1904 ! GET CURRENT TIME/DATE MODULE          VERSION 2.1
1906 !-*****
1908 DATA JAN,FEB,MAR,APR,MAY,JUN,JUL,AUG,SEP,OCT,NOV,DEC
1910 DIM Month$(1:12)(3)
1912 READ Month$(*)
1914 !
1916 ! Compute the current hours, minutes, and seconds
1918 !
1920 Time_now=INT(TIMEDATE) MOD 86400
1922 Hours=Time_now DIV 3600
1924 Minutes=Time_now MOD 3600 DIV 60
1926 Seconds=Time_now MOD 60
1928 !
1930 ! Find/Compute the current date
1932 !
1934 Julian=TIMEDATE DIV 86400-1721119
1936 Year=(4*Julian-1) DIV 146097
1938 Julian=(4*Julian-1) MOD 146097
1940 Day=Julian DIV 4
1942 Julian=(4*Day+3) DIV 1461
1944 Day=(4*Day+3) MOD 1461
1946 Day=(Day+4) DIV 4
1948 Month=(5*Day-3) DIV 153
1950 Day=(5*Day-3) MOD 153
1952 Day=(Day+5) DIV 5
1954 Year=(100*Year+Julian)-1900
1956 IF Month<10 THEN
1958 Month=Month+3
1960 ELSE
1962 Month=Month-9
1964 Year=Year+1
1966 END IF
1968 Timedates$=VAL$(Day)&"-"&Month$(Month)&"-"
1970 Year$=VAL$(Year)
1972 IF Year=0 THEN Year$="0"&Year$
1974 Hours$=VAL$(Hours)
1976 IF Hours<10 THEN Hours$="0"&Hours$
1978 Minutes$=VAL$(Minutes)
1980 IF Minutes<10 THEN Minutes$="0"&Minutes$
1982

```

```

1990 FNEND
1992 !
1994 !
1996 SUB Logtime(OPTIONAL Clrflag)
1998 !+*****+
2000 ! LOG TIME AND DATE MODULE VERSION 2.1
2002 !-*****-
2004 COM /Fiber/ Fiber_id$,Fiber_len,Log_times$
2006 IF NPAR=1 THEN
2008 Log_times$=""
2010 ELSE
2012 Log_times$=FNTimedates$
2014 END IF
2016 SUBEND
2018 !
2020 !
2022 SUB Archive(OPTIONAL File$)
2024 ! +*****+
2026 ! ARCHIVE MEASUREMENT DATA MODULE VERSION 2.1P
2028 ! -*****-
2030 COM /Diskdrive/ Sysdrive$,Arcdrive$
2032 COM /Fiber/ Fiber_id$,Fiber_len,Log_times$
2034 COM /Specattdata/ Specattdata(*),Specatt_id$
2036 COM /Dmadata/ Dmarundata(*),Dmarefdata(*),Dmaattenddata(*),Dma_id$
2038 COM /Farfield/ Ffieldval(*),Fnum_points,Farfield(*),Ffield_id$
2040 COM /Nearfield/ Nfieldval(*),Num_points,Nearfield(*),Nfield_id$
2042 !
2044 DIM Filename$(10),Temp(256,1)
2046 INTEGER Index,Log_index,Log_flag(6)
2048 !
2050 ! Initialize the log data flags
2052 !
2054 FOR Index=0 TO 6 !Leave a few extra spots for data
2056 Log_flag(Index)=0 !Log flags correspond to Fiber test #'s
2058 NEXT Index
2060 !
2062 ! Compute the required file size, and set log flags
2064 !
2066 Numrec=8 ! Initial space for file header
2068 IF Fiber_id$=Specatt_id$[1,LEN(Fiber_id$)] THEN
2070 Log_flag(1)=1 !Log spectral attenuation data
2072 Numrec=Numrec+400
2074 END IF
2076 IF Fiber_id$=Dma_id$[1,LEN(Fiber_id$)] THEN
2078 Log_flag(2)=1 !Log DMA data, 200 for wavelengths,
2080 Numrec=Numrec+200+(200*Dmarundata(2,0)) !Variable for signal data
2082 END IF
2084 IF Fiber_id$=Ffield_id$[1,LEN(Fiber_id$)] THEN
2086 Log_flag(3)=1 !Log far-field data
2088 Numrec=Numrec+440 !Fibertest 4 data stored here also
2090 END IF
2092 IF Fiber_id$=Nfield_id$[1,LEN(Fiber_id$)] THEN
2094 Log_flag(5)=1 !Log near-field data
2096 Numrec=Numrec+240
2098 END IF
2100 !
2102 ! If there's no data to write, don't go any further, just quit.
2104 !
2106 IF Numrec=8 THEN
2108 BEEP
2110 DISP "ARCHIVE -- There is no data in memory with the current fiber I.D
"
2112

```

```

2120 | Get the file name from the user and open the file.
2122 |
2124     IF NPAR>0 THEN
2126         Filename$=File$
2128         GOTO Open_file
2130     ELSE
2132         GOTO Get_name
2134     END IF
2136 Get_name: 1
2138     PRINT TABXY(1,16);"Please put the disk on which the data is to be archiv
ed in the right hand drive."
2140     PRINT TABXY(1,17);"Then enter archive data file name (10 letters max).
Press PROCEED when ready."
2142     PRINT TABXY(1,18);" "
2144     ON KEY 5 LABEL "PROCEED" GOTO Open_file
2146     WAIT 2
2148     INPUT Filename$
2150 Hang_man: GOTO Hang_man
2152 Open_file:ON ERROR GOTO File_err
2154     CREATE BDAT Filename$&Arcdrive$,Numrec,8
2156     ASSIGN @Archive TO Filename$&Arcdrive$
2158     OUTPUT KBD USING "&,K";"K"
2160     PRINT TABXY(10,1);CHR$(129)&" FOA-2000 measurement data archive utility.
"&CHR$(128)
2162     PRINT TABXY(1,3);"Archiving data for fiber: ";Fiber_id$;
2164     OUTPUT @Archive;FNTimedate$
2166     WAIT 2
2168     !
2170     ! Select data to be written from the log flags
2172     !
2174     IF Log_flag(1)=1 THEN
2176         OUTPUT @Archive;"SPECATTEN"
2178         OUTPUT @Archive;Specatt_id$
2180         OUTPUT @Archive;Specattdata(*)
2182     END IF
2184     IF Log_flag(2)=1 THEN
2186         OUTPUT @Archive;"DMA"
2188         OUTPUT @Archive;Dma_id$
2190         OUTPUT @Archive;Dmaattenddata(*)
2192     END IF
2194     IF Log_flag(3)=1 THEN
2196         OUTPUT @Archive;"FFIELD"
2198         OUTPUT @Archive;Ffield_id$
2200         OUTPUT @Archive;Farfield(*)
2202     END IF
2204     IF Log_flag(5)=1 THEN
2206         OUTPUT @Archive;"NFIELD"
2208         OUTPUT @Archive;Nfield_id$
2210         OUTPUT @Archive;Nearfield(*)
2212     END IF
2214     ASSIGN @Archive TO *
2216     GOTO Done
2218 File_err:SELECT ERRN
2220     CASE 54 !Error 54 = File name already exists.
2222         DISP "File ";Filename$;" already exists. Do you want to delete it or c
hange the name?"
2224         ON KEY 5 LABEL "YES" GOTO Yes
2226         ON KEY 6 LABEL "NO" GOTO Done
2228         ON KEY 7 LABEL "CHANGE" GOTO Chng_nm
2230 Wait_1:GOTO Wait_1
2232     CASE 53
2234         BEEP
2236         DISP "File name must be 10 characters or less with no spaces

```

```

2240      GOTO Get_name
2242      CASE 64
2244      BEEP
2246      DISP "The archive disk is full. Replace with a new disk. Initialize if
        necessary."
2248      ON KEY 5 LABEL "PROCEED" GOTO New_disk
2250 Wait_full:GOTO Wait_full
2252 New_disk:OFF KEY
2254      DISP ""
2256      GOTO Open_file
2258      CASE 80
2260      BEEP
2262      DISP "The "&Arcdrive$&" disk drive is empty. Please insert the archive
        disk."
2264      ON KEY 5 LABEL "PROCEED" GOTO Disk_ready
2266 Wait_2:GOTO Wait_2
2268 Disk_ready:DISP ""
2270      OFF KEY
2272      GOTO Open_file
2274      CASE ELSE
2276      DISP "ARCHIVE -- HP Error Number "&VAL$(ERRN)
2278      GOTO Done
2280      END SELECT
2282 Yes:OFF KEY
2284      DISP ""
2286      PURGE Filename$&Arcdrive$
2288      GOTO Open_file
2290 Chng_nm:OFF KEY
2292      DISP ""
2294      GOTO Get_name
2296 Done:OUTPUT KBD USING "#,K";"K"          !Erase the screen
2298      DISP ""
2300      OFF KEY
2302      SUBEND
2304      !
2306      !
2308      SUB Retrieve(OPTIONAL File$)
2310      !+*****+
2312      ! RETRIEVE ARCHIVED MEASUREMENT DATA MODULE                      VERSION 2.1P
2314      !-*****+
2316      COM /Diskdrive/ Sysdrive$,Arcdrive$
2318      COM /Fiber/ Fiber_id$,Fiber_len,Log_time$
2320      COM /Specattdata/ Specattdata(*),Specatt_id$
2322      COM /Dmadata/ Dmarundata(*),Dmarefdata(*),Dmaattendata(*),Dma_id$
2324      COM /Farfield/ Ffieldval(*),Fnum_points,Farfield(*),Ffield_id$
2326      COM /Nearfield/ Nfieldval(*),Num_points,Nearfield(*),Nfield_id$
2328      !
2330      DIM Filename$(30),Data_type$(70)
2332      INTEGER Index,Jindex
2334      PRINT CHR$(12)
2336      !
2338      ! Get the file name from the user
2340      !
2342      IF NPAR>0 THEN
2344          Filename$=File$
2346          GOTO Open_file
2348      ELSE
2350          GOTO Get_file
2352      END IF
2354 Get_file: !
2356      PRINT TABXY(1,16);"Please put the disk containing the archived file in t
        he right-hand drive."
2358      PRINT TABXY(1,17);"Then enter the name of the archived file. Press PROC
        ED (F5) when ready."

```

```

2366 Hang_girl: GOTO Hang_girl
2368 !
2370 Open_file: ON ERROR GOTO File_err
2372 ASSIGN @Archive TO Filename$&Arctdrive$
2374 !
2376 ! Read the archive time and date from the first line
2378 ! of the file.
2380 !
2382 ENTER @Archive:Archive_dates
2384 OUTPUT KBD USING "&K";"K" !Erase screen
2386 PRINT TABXY(1,5);"Retrieving data archived on: ";Archive_dates
2388 PRINT TABXY(1,7);"This archive file contains the following data:"
2390 PRINT
2392 !
2394 ! Read the data type header. If it's SPECATTEN, read the
2396 ! following array into Specattdata(*). If not, check the
2398 ! other data types.
2400 !
2402 ENTER @Archive:Data_types$
2404 IF Data_types$="SPECATTEN" THEN
2406 ENTER @Archive:Specatt_id$
2408 ENTER @Archive:Specattdata(*)
2410 PRINT "Spectral Attenuation Data"
2412 PRINT " for fiber: ";Specatt_id$
2414 ENTER @Archive:Data_types$
2416 END IF
2418 ! Read DMA data (if any).
2420 IF Data_types$="DMA" THEN
2422 ENTER @Archive:Dma_id$
2424 ENTER @Archive:Dmaattenddata(*)
2426 PRINT "Differential Modal Attenuation Data"
2428 PRINT " for fiber: ";Dma_id$
2430 ENTER @Archive:Data_types$
2432 END IF
2434 ! Read Far-field data (if any).
2436 IF Data_types$="FFIELD" THEN
2438 ENTER @Archive:Ffield_id$
2440 ENTER @Archive:Farfield(*)
2442 PRINT "Far-field data"
2444 PRINT " for fiber: ";Ffield_id$
2446 ENTER @Archive:Data_types$
2448 END IF
2450 ! Read Near-field data (if any).
2452 IF Data_types$="NFIELD" THEN
2454 ENTER @Archive:Nfield_id$
2456 ENTER @Archive:Nearfield(*)
2458 PRINT "Near field data"
2460 PRINT " for fiber: ";Nfield_id$
2462 ENTER @Archive:Data_types$
2464 END IF
2466 !
2468 ASSIGN @Archive TO * !Close the file
2470 GOTO Done
2472 File_err: IF ERRN=59 THEN !Error 59=End of file reached.
2474 ASSIGN @Archive TO * !Close the file
2476 GOTO Done !We're done.
2478 END IF
2480 IF ERRN=80 THEN
2482 DISP "No disk in right hand drive, please insert and try again."
2484 GOTO Get_file
2486 END IF
2488 IF ERRN=53 THEN
2490 DISP "File name contains unrecognizable characters."

```

```

2498 DISP "The archive file <"Filename$;"> isn't on this disk. Do you want
to try again?"
2500 ON KEY 5 LABEL " YES" GOTO Yes
2502 ON KEY 6 LABEL " NO" GOTO Quit
2504 Wait_here:GOTO Wait_here
2506 Yes: !
2508 OFF KEY
2510 OUTPUT KBD USING "#,K";"K" !Erase screen
2512 CAT Archdrives$
2514 GOTO Get_file
2516 END IF
2518 DISP "RETRIEVE -- HP Error Number "&VAL$(ERRN)
2520 ON KEY 5 LABEL "RETURN" GOTO Unspaced
2522 Dead_in_h20:GOTO Dead_in_h20
2524 Unspaced: OFF KEY
2526 CALL Cleardisplay
2528 GOTO Get_file
2530 Done:IF NPAR>0 THEN GOTO Quit
2532 ON KEY 5 LABEL "CONTINUE" GOTO Quit
2534 Wait_done:GOTO Wait_done
2536 Quit:OUTPUT KBD USING "#,K";"K"
2538 DISP ""
2540 OFF KEY
2542 SUBEND
2544 !
2546 !
2548 SUB Zcenter
2550 !+*****+
2552 ! Z-AXIS MOTOR CENTERING MODULE VERSION 2.1
2554 !-*****-
2556 !
2558 ! **** NOTE ****
2560 ! The FOA-2000 commands used in this module are not documented in
2562 ! the FOA-2000 manual and should be used only under direction of
2564 ! Photon Kinetics.
2566 !
2568 CALL F2000send("ALIGN INZ COUPL 3000 DARK",1)!Find edge of INZ sensor
2570 CALL F2000send("INZ ZER -900 GOTO INZ ZER",1)!Backup and stop
2572 CALL F2000send("OUTZ COUPL 3000 DARK",1)!Find edge of outz sensor
2574 CALL F2000send("OUTZ ZER -900 GOTO OUTZ ZER",1)!Backup and stop
2576 SUBEND
2578 !
2580 !
2582 SUB Rundisplay(Message$)
2584 !+*****+
2586 ! IN PROCESS DISPLAY MODULE VERSION 2.1
2588 !-*****-
2590 GINIT
2592 GCLEAR
2594 GRAPHICS ON
2596 MOVE 0,90
2598 CSIZE 5,.57
2600 LABEL Message$
2602 SUBEND
2604 !
2606 !
2608 SUB Cleardisplay
2610 !+*****+
2612 ! CLEARDISPLAY - clears both alpha and graphics
2614 !-*****-
2616 OFF KEY !Clears labels from bottom of screen
2618 DISP " " !Clears header
2620 OUTPUT KBD USING "# K";"K" !Clears alphanumeric characters

```

```

2628 |
2630 SUB F2000send(Message$,OPTIONAL Wait_flag)
2632 |*****
2634 | SEND COMMANDS TO FOA-2000 MODULE VERSION 2.1P
2636 |*****
2638 COM /Iopaths/ @Foa2000,@Egg5205,@Tek7854,@Bncdelay,Printer_add
2640 COM /Previous/ Previous$ !A place to remember the last command
2642 DIM Message$(80)
2644 INTEGER Statbyt,Busybit !Integers make better status bytes
2646 INTEGER Posn ! Used to locate "LOW" in Message$
2648 Busybit=4
2650 Message$=Message$
2652 DISP "FOA-2000: ";Message$ !Display the message we're sending
2654 Busy:Statbyt=SPOLL(@Foa2000) !Do a serial poll on FOA2000
2656 IF BIT(Statbyt,Busybit)=1 THEN GOTO Busy !If busy, poll it again
2658 GOSUB Err_chk !Any errors?
2660 IF Err_flag THEN DISP "FOA-2000: ";Message$ !If so, re-display
2662 OUTPUT @Foa2000 USING "K";Message$ !Ready, so send message
2664 Previous$=Message$ !Remember last cmd. in case of error
2666 IF NPAR=1 THEN Done !If wait_flag not specified, don't wait
2668 IF Wait_flag=0 THEN Done !If wait_flag=0, don't wait.
2670 Not_done:WAIT .1 !Give FOA2000 a chance to assert busy
2672 Statbyt=SPOLL(@Foa2000)
2674 GOSUB Err_chk !Check for errors
2676 IF BIT(Statbyt,Busybit)=1 THEN GOTO Not_done
2678 GOSUB Err_chk !Check for errors
2680 GOTO Done
2682 Err_chk:Err_flag=0 !Clear the error flag
2684 IF Statbyt>96 AND Statbyt<100 THEN
2686 Err_flag=1 !Got an error, set the flag
2688 BEEP
2690 IF Statbyt=99 THEN
2692 PRINT TABXY(1,15);"FOA-2000 ERROR NUMBER: "&VAL$(Statbyt)&" "&Previous$
2694 PRINT TABXY(1,16);"Motor error. Probably caused by fiber misalignm
ent or a bad fiber end."
2696 PRINT TABXY(1,17);"First try focussing the fiber end on the screen,
and press PROCEED."
2698 CALL F2000send("ALIGN")
2700 ELSE
2702 PRINT TABXY(1,15);"FOA-2000 ERROR NUMBER: "&VAL$(Statbyt)&" "&Previous$
2704 END IF
2706 LOCAL @Foa2000 !Put the foa2000 in local mode
2708 ON KEY 5 LABEL "PROCEED" GOTO Proceed
2710 Wait_here:GOTO Wait_here
2712 Proceed:DISP "FOA2000: ";Previous$ !Display the command
2714 OUTPUT @Foa2000 USING "K";Previous$
2716 WAIT .01 ! ** TEMPORARY--Give the foa2000 time to get busy ** !
2718 Busy!:Statbyt=SPOLL(@Foa2000) !Serial poll the instrument
2720 IF BIT(Statbyt,Busybit)=1 THEN Busy! !Keep trying till not busy
2722 GOTO Err_chk !Check for errors once more
2724 END IF
2726 RETURN
2728 Done:DISP " "
2730 SUBEND
2732 |
2734 |
2736 SUB Preset
2738 |*****
2740 | SYSTEM PRESET MODULE VERSION 2.1P
2742 |*****
2744 COM /Iopaths/ @Foa2000,@Egg5205,@Tek7854,@Bncdelay,Printer_add

```

```

2140 COM /align_param; alignment;
2750 OUTPUT KBD USING "#,K";"K" ! Clear alpha screen
2752 CALL Rundisplay(" Initializing system equipment.")
2754 CALL F2000send("3. ATTENUAT CHOP-ON LAMP-ON LED-ON. GERMAIN")
2756
2758 | Center the FOA-2000 focus motors.
2760
2762 PRINT TABXY(1,16);"Centering the FOA-2000 focus motors."
2764 CALL Zcenter
2766
2768 | Now wait for the operator to confirm warm-up
2770
2772 BEEP
2774 PRINT TABXY(1,16);"Please check that all equipment is ON. The FOA-2000 m
ust be allowed to warm"
2776 PRINT TABXY(1,17);"up for 5 minutes before proceeding. Press the PROCEE
D key (f5) when ready."
2778 ON KEY 5 LABEL "PROCEED" GOTO Proceed
2780 Here:GOTO Here !Wait for them to press the key
2782 Proceed:OFF KEY
2784 OUTPUT KBD USING "#,K";"K"
2786
2788 CALL F2000send("LED LED-ON ILLUMIN VOUT TARGET-OUT SPOT-OUT FF-OUT 3 ATT
ENUAT",1)
2790
2792 | Check chopper operation by looking at reference status on EGG
2794
2796 Eggstatus=SPOLL(@Egg5205)
2798 IF BIT(Eggstatus,3)=1 THEN
2800 Retry:OUTPUT KBD USING "#,K";"K" !Clean up screen from error
2802 OFF KEY
2804 PRINT TABXY(1,16);"Waiting for the FOA-2000 chopper to stabilize."
2806 CALL F2000send("CHOP-OFF CHOP-ON",1)
2808 Starttime=TIMEDATE
2810 Wait_loop:WAIT 2
2812 Eggstatus=SPOLL(@Egg5205)
2814 IF BIT(Eggstatus,3)=0 THEN GOTO Chop_ready
2816 IF TIMEDATE-Starttime>30 THEN
2818 BEEP
2820 DISP "The FOA-2000 Chopper is inoperative, or the lock-in amplifier
reference channel is disconnected."
2822 ON KEY 5 LABEL " Retry" GOTO Retry
2824 ON KEY 6 LABEL " Stop" GOTO Quit
2826 Wait_key:GOTO Wait_key
2828 Quit: OFF KEY
2830 Dead!: GOTO Dead!
2832 END IF
2834 GOTO Wait_loop
2836 Chop_ready:WAIT 10 ! Wait 10 more seconds
2838 END IF !Skip the whole thing if REF LOW bit is not set
2840
2842 | Initialize EGG 5205/7 settings, sending selected device clear (SDC).
2844
2846 PRINT TABXY(1,16);"Setting up the EGG5207 Lock-in Voltmeter."
2848 CLEAR @Egg5205
2850
2852 | Set the EGG5207 phase (twice, for assured precision)
2854
2856 CALL E5205comm("A2 1")
2858 CALL E5205comm("A2 1")
2860
2862 | Set the EGG5207 to a known range
2864

```

```

PROCEED Key (F6).
2872 PRINT TABXY(1,17),"In this case, BE SURE THAT THE LAMP IS TURNED ON before
processing."
2874 PRINT TABXY(1,18),"To skip this step, press the SKIP key (F6)."
2876 ON KEY 5 LABEL "PROCEED" GOTO Mono_cal
2878 ON KEY 1 LABEL "SKIP" GOTO Skipped
2880 Hang_out: GOTO Hang_out
2882 !
2884 Mono_cal: OFF KEY
2886 OUTPUT KBD USING "#,K";"K"
2888 CALL F2000send("0 ATTENUAT",1)
2890 IF Filter_flag=1 THEN GOTO Done
2892 CALL F2000send("0 FILTER LAMP SOURCES 1TO1 0SEEK WAV COUPL",1)
2894 LOCAL @Foa2000
2896 PRINT TABXY(1,16),"Please adjust the monochromator wavelength for the zero-
point calibration (light)"
2898 PRINT TABXY(1,17),"centered on the launch spot, approaching it using a clockwise
knob rotation)."
2900 BEEP
2902 ON KEY 5 LABEL "PROCEED" GOTO Wave_cal
2904 Wait3:GOTO Wait3
2906 Wave_cal: CALL F2000send("WAVE0")
2908 ! CALL F2000send("WAVE0")
2910 !
2912 Skipped: OFF KEY
2914 ! IF Alignment(0)=0 THEN CALL Fibertype !Query for fibertype
2916 Done:OUTPUT KBD USING "#,K";"K"
2918 CALL F2000send("ALIGN",1) !Leave the system in alignment set up
2920 LOCAL @Foa2000 !Also leave the control panel in local mode
2922 CALL Cleardisplay
2924 SUBEND
2926 !
2928 !
2930 SUB E5205comm(Message$,OPTIONAL Value)
2932 !+-----+
2934 ! EGG5205 COMMUNICATION MODULE VERSION 2.1P
2936 !------+
2938 COM /Iopaths/ @Foa2000,@Egg5205,@Tek7854,@Bncdelay,Printer_add
2940 INTEGER Eggstatus
2942 DISP "EGG5205: "&Message$
2944 Start=TIMEDATE
2946 !
2948 ! Send the command or query to the 5205
2950 !
2952 Busy:GOSUB Poll_egg !Serial poll the EGG5205
2954 IF TIMEDATE-Start>5 THEN GOTO Timeout !Report timeout
2956 IF NOT BIT(Eggstatus,0) THEN GOTO Busy
2958 OUTPUT @Egg5205 USING "K";Message$ !It's ready, send message
2960 !
2962 ! Take in a response from the 5205 if one is indicated; Wait for
2964 ! "command complete" and "settled" before returning.
2966 !
2968 Wait_done:GOSUB Poll_egg
2970 IF BIT(Eggstatus,7) THEN ENTER @Egg5205;Value1
2972 IF NPAR>1 THEN
2974 Value=Value1
2976 END IF
2978 IF BINAND(Eggstatus,33)<>33 THEN GOTO Wait_done
2980 DISP " "
2982 GOTO Done
2984 Poll_egg:WAIT .01
2986 Eggstatus=SPOLL(@Egg5205) !Serial poll
2988 RETURN

```

```

2998 Wait_1:GOTO Wait_1
3000 Proceed:OFF KEY
3002 Start=TIMEDATE
3004 GOTO Busy
3006 Quit:OFF KEY
3008 STOP
3010 Done:SUBEND
3012 |
3014 |
3016 DEF FNVoltmeter(Accuracy)
3018 |*****+*****+*****+*****+*****+*****+*****+*****+*****+*****+
3020 | EGG5205 VOLTAJE READING MODULE VERSION 2.1
3022 |-----
3024 COM /Egg5205/ Scales(*),Settle,INTEGER Num_aver,Range
3026 COM /Syscal/ Pin_x,Pin_y,Pin_z,Inx_step,Iny_step,Outx_step,Outy_step,Far
field_step,Noiselevel
3028 COM /Iopaths/ @Foa2000,@Egg5205,@Tek496p,@Tek7854,Printer_add
3030 DIM Oldreading(31)
3032 INTEGER Index,I,Down_count,Num_readings,Referlow,Overload
3034 |
3036 Lowest_range=12 !Lowest allowed EGG5205 scale =500uv
3038 |
3040 IF Accuracy<>0 THEN !Make sure we know the 5205 range
3042 CALL E5205comm("S",Rangeread)
3044 Range=INT(Rangeread)
3046 END IF
3048 |
3050 ! If Accuracy=0, the number of averages and range should not be adjusted.
3052 ! If Accuracy<>0, compute the number of averages required to achieve the
3054 ! requested accuracy. Accuracy is expressed in dB. Use TEMP to avoid
3056 ! INTEGER overflow.
3058 |
3060 Restart:IF Accuracy<>0 THEN
3062 Perror=.23*Accuracy !Convert dB to % error
3064 Temp=(Noiselevel/(Perror*400*Scales(Range)))^2
3066 IF Temp<6 THEN Temp=6 !Minimum # of averages = 6
3068 IF Temp>30 THEN Temp=30 !Maximum # of averages = 30
3070 Num_aver=Temp
3072 Settle=Perror*400*Scales(Range) !Settling requirement
3074 END IF
3076 Sum=0 !Initialize the running sum
3078 Sum_squares=0 !And the sum of the squares
3080 Num_readings=0 !Initialize the readings counter
3082 FOR Index=0 TO Num_aver !Set the oldreadings array = 0
3084 Oldreading(Index)=0
3086 NEXT Index
3088 Index=0 !And initialize oldreadings index
3090 Res_limit=Scales(Range) !Resolution limit is 1 LSB
3092 |
3094 ! Get a voltage reading
3096 |
3098 T1=TIMEDATE
3100 Acquire:GOSUB Pollegg
3102 IF Referlow THEN
3104 BEEP
3106 DISP "VOLTMETER -- EGG 5205 Reference level is too low."
3108 ON KEY 5 LABEL "PROCEED" GOTO Rerefstart
3110 Wait7:GOTO Wait7
3112 Rerefstart:OFF KEY
3114 GOTO Restart
3116 END IF

```

```

3128 IF Accuracy<>0 THEN !DON'T down range,if accuracy=0
3130 IF ABS(Reading)<400 AND Range<Lowest_range THEN
3132 GOSUB Down_range
3134 GOTO Restart !Start over on averages
3136 END IF
3138 END IF
3140 IF ABS(Reading)>2000 THEN !We can always try to up-range
3142 GOSUB Up_range
3144 GOTO Restart !Start over on averages
3146 END IF
3148 !
3150 ! This reading is within the range limits, so scale it into volts
3152 ! before adding it to the running sum and computing standard
3154 ! deviation.
3156 !
3158 Reading=Reading*Scales(Range)
3160 !
3162 ! A running sum and sum of squares is kept of the number of most
3164 ! current readings specified by num_aver. Each time a new reading
3166 ! is added to the running sum the oldest reading is removed from
3168 ! the sum so that the sum always reflects the most current readings.
3170 !
3172 Sum=Sum+Reading-Oldreading(Index) !Update the sums
3174 Sum_squares=Sum_squares+(Reading^2)-Oldreading(Index)^2
3176 Oldreading(Index)=Reading !Replace old reading with new one
3178 Index=(Index+1) MOD Num_aver !And update oldreadings index
3180 Num_readings=Num_readings+1 !Count the new reading
3182 !
3184 ! If we have acquired at least num_aver readings, compute the standard
3186 ! deviation of the last num_aver readings and compare it to the noise
3188 ! limit and resolution limit. If the result is inside these limits,
3190 ! the EG65205 has settled, so return the average of the readings.
3192 !
3194 IF Num_readings>=Num_aver THEN !If acquired enough, check noise
3196 Noise=SQR(ABS(Sum_squares-(Sum)^2/Num_aver)/Num_aver)
3198 IF Noise<Noiselevel OR Noise<Res_limit OR Noise<Settle OR TIMEDATE-T1>
5 THEN
3200 Result=Sum/Num_aver !If noise is within limits, return
3202 GOTO Done !the average of the readings.
3204 END IF
3206 END IF
3208 GOTO Acquire !If not enough averages or too much
3210 !noise, go get another reading
3212 !
3214 ! Poll the EG65205 and break its status down into 2 conditions:
3216 ! Reference low and Overload These conditions are Returned to
3218 ! as separate variables with a value of 1 if the condition is
3220 ! true or 0 if it is false.
3222 !
3224 Pollegg:Eggstatus=SPOLL(@Egg5205)
3226 Referlow=BIT(Eggstatus,3)
3228 Overload=BIT(Eggstatus,4)
3230 RETURN
3232 !
3234 ! This subroutine increments the EG65205 range when the reading is
3236 ! greater than 2000 or when overload status occurs.
3238 !
3240 Up_range:IF Range=0 THEN !We're already at highest range
3242 BEEP
3244 DISP "VOLTMETER -- EG65205 is overrange on highest range."
3246 ON KEY 5 LABEL "PROCEED" GOTO Reoverstart
3248 Wait8:GOTO Wait8

```

```

3258 IF Accuracy < 0 THEN
3259     Range=Range-1
3260 ELSE
3261     Range=Range+1
3262 END IF
3263 IF Range<0 THEN Range=0
3264 CALL E5205comm("S "&VAL$(Range)) !Set the EGG to the new range
3265 WAIT 1 ! Time for EGG5205 transient
3266 RETURN
3267 !
3268 ! This subroutine decrements the EGG5205 sensitivity to achieve readings
3269 ! greater than 400.
3270 !
3271 Down_range:Vmagnitude=ABS(Reading*Scales(Range))
3272 FOR I=1 TO 5 !Max allowed range change=5 steps
3273     Range=Range+1
3274     IF Vmagnitude>400*Scales(Range) THEN Set_down
3275 NEXT I
3276 Set_down:IF Range>Lowest_range THEN Range=Lowest_range
3277 CALL E5205comm("S "&VAL$(Range))
3278 WAIT 1 !Allow recovery time
3279 RETURN
3280 !
3281 ! Return the average of the readings to the caller
3282 !
3283 Done:RETURN Result
3284 FNEND
3285 !
3286 !
3287 SUB Setscale(Accuracy,Maxvolts)
3288 !+*****+
3289 ! SET EGG5205 RANGE MODULE VERSION 2.1
3290 !-*****+
3291 COM /Egg5205/ Scales(*),Settle,INTEGER Num_aver,Range
3292 COM /Syscal/ Pin_x,Pin_y,Pin_z,Inx_step,Iny_step,Outx_step,Outy_step,Far
3293 field_step,Noiselevel
3294 FOR Index=14 TO 0 STEP -1 ! Figure out the appropriate range
3295     IF Scales(Index)*2000>=Maxvolts THEN GOTO Set_range
3296 NEXT Index
3297 Index=0
3298 BEEP !Maxvolts is too big!
3299 PRINT TABXY(1,17);"SETSCALE -- The maximum voltage specified for"
3300 PRINT TABXY(1,18);"the EGG 5205 is too large."
3301 Dead1:GOTO Dead1
3302 Set_range:Range=Index !Set the range
3303 CALL E5205comm("S "&VAL$(Range))
3304 Perror=.23*Accuracy !Convert dB to % error
3305 Num_aver=(Noiselevel/(Perror*400*Scales(Range)))^2
3306 IF Num_aver<6 THEN Num_aver=6 !Minimum # of averages = 6
3307 IF Num_aver>30 THEN Num_aver=30 !Maximum # of averages = 30
3308 Settle=Perror*400*Scales(Range) !Settling requirement
3309 SUBEND
3310 !
3311 !
3312 SUB Arraybuild(Instring$,Outarray(*),Arraylen)
3313 !+*****+
3314 ! ARRAY BUILDER MODULE VERSION 2.1
3315 !-*****+
3316 For_flag=0 !Set for loop flag = 0
3317 Arraylen=0 !Set initial array length = 0
3318 Step_val=1 !Set default step index value
3319 Temp$="" !Initialize temporary string
3320 ON ERROR GOTO Errorline

```

```

3388 |
3390 | IF Index<LEN(Instring$)-1 THEN !Don't look if near the end
3392 | IF Instring$(Index;2)="to" OR Instring$(Index;2)="TO" THEN !Look for
"TO"
3394 | GOSUB For_loop !Found a "TO"--go process it
3396 | GOTO New_val
3398 | END IF
3400 | END IF
3402 |
3404 | Check for "STEP" keyword
3406 |
3408 | IF Index<LEN(Instring$)-3 THEN !Don't look if near the end
3410 | IF Instring$(Index;4)="step" OR Instring$(Index;4)="STEP" THEN !STEP
?
3412 | GOSUB Step_loop !Process the STEP
3414 | GOTO Next_char
3416 | END IF
3418 | END IF
3420 |
3422 | If the next character is not a number, decimal point (.) or minus sign,
3424 | it is a separator character, so figure out what to do about it. If the
3426 | next character is a number, . or -, just add it to the temp$.
3428 |
3430 | Value=NUM(Instring$(Index;1)) !Get the next char's value
3432 | IF (Value<48 OR Value>57) AND Value<>32 AND Value<>46 AND Value<>45 TH
EN
3434 |
3436 | First, check to see if we have a FOR loop in process.
3438 |
3440 | New_val:SELECT For_flag
3442 | CASE 1 !We've passed a "TO"
3444 | GOSUB Load_start !Go load the starting index
3446 | GOTO Next_char !And keep looking
3448 | CASE 2 !This is the ending value
3450 | GOSUB Load_end !Load ending index and run loop
3452 | GOTO Next_char
3454 | CASE 3 !A FOR loop with STEP value
3456 | GOSUB Run_loop !Run the loop
3458 | GOTO Next_char !And start checking again
3460 | END SELECT !No FOR loop is in progress
3462 | Outarray(Arraylen)=VAL(Temp$) !It's just a regular value
3464 | Arraylen=Arraylen+1 !Increment the array length
3466 | Temp$="" !And clear the temporary string
3468 | END IF
3470 | Next_char:NEXT Index !Check the next input character
3472 |
3474 | ! When we run out of characters in INSTRING$, check to see if
3476 | ! we have a FOR loop pending, or if it's just a regular value
3478 | !
3480 | SELECT For_flag
3482 | CASE 1 !A "TO" with no ending value
3484 | GOTO Syntax_err !That's a syntax error
3486 | CASE 2 !A FOR loop ending with no STEP
3488 | GOSUB Load_end !That's OK, go run the loop
3490 | GOTO Done
3492 | CASE 3 !A FOR loop with a STEP value
3494 | GOSUB Run_loop !Load the STEP and run the loop
3496 | GOTO Done
3498 | END SELECT
3500 | Outarray(Arraylen)=VAL(Temp$) !It's just a last regular value
3502 | Arraylen=Arraylen+1 !Increment array length
3504 | GOTO Done !And quit

```

```

3512 RETURN
3514 Step_loop:IF For_flag<>2 THEN Syntax_err !STEP isn't, allowed before 10
3516 End_index=VAL(Temp$) !Load the ending index
3518 Index=Index+3 !Point past the "STEP" keyword
3520 For_flag=3 !ready for the STEP value
3522 Temp$=""
3524 RETURN
3526 !
3528 ! Load the starting value for a nn TO nn loop.
3530 !
3532 Load_start:Start_index=VAL(Temp$) !Previous number is begin value
3534 Temp$=""
3536 For_flag=2 !Next value will be ending value
3538 RETURN
3540 !
3542 ! Load the ending value for a nn TO nn loop.
3544 !
3546 Load_end:End_index=VAL(Temp$) !So put it in end index
3548 FOR Value=Start_index TO End_index !And execute the loop
3550 Outarray(Arraylen)=Value !Store the value in output array
3552 Arraylen=Arraylen+1 !Increment output array pointer
3554 NEXT Value
3556 Temp$=""
3558 For_flag=0 !Reset the for flag
3560 RETURN
3562 !
3564 ! Execute a nn TO nn loop
3566 !
3568 Run_loop:Step_val=VAL(Temp$) !load step with this value
3570 FOR Value=Start_index TO End_index+Step_val/100 STEP Step_val
3572 Outarray(Arraylen)=Value !Load values in out array
3574 Arraylen=Arraylen+1 !Increment output pointer
3576 NEXT Value
3578 Temp$=""
3580 Step_val=1
3582 For_flag=0 !Reset the for flag
3584 RETURN
3586 !
3588 ! Here's where we end up if an error has been trapped.
3590 ! The only check is to see if the array has overflowed.
3592 ! If it has, the number of points is calculated and the routine
3594 ! is exited normally. If not, the error number is reported
3596 ! and the program hangs.
3598 !
3600 Errorline:IF ERRN=17 THEN
3602 SELECT For_flag
3604 CASE 2,3
3606 Arraylen=Arraylen+(End_index-Value)/Step_val
3608 CASE 0
3610 Arraylen=Arraylen+1
3612 CASE ELSE
3614 Arraylen=-1
3616 END SELECT
3618 GOTO Done
3620 ELSE
3622 BEEP
3624 PRINT TABXY(5,10);"ARRAYBUILD: Error #"&VAL$(ERRN)&" has occurred."
3626 PRINT TABXY(5,11);"Program idle."
3628 Dead5:GOTO Dead5
3630 END IF
3632 !
3634 ! Here's where we end up if we find a bad syntax.
3636 !

```

```

3644+
3646 SUB: Fiberident
3648 !+*****+
3650 ! FIBER IDENTIFICATION MODULE                                VERSION 2.1
3652 !-*****-
3654   COM /Fiber/ Fiber_id$,Fiber_len,Log_time$
3656   DIM Id$(80),Len$(80)
3658   Im1:IMAGE #,"Please enter the fiber identification: ",K
3660   OUTPUT KBD USING Im1
3662   BEEP
3664   ENTER KBD USING Im1;Id$
3666   IF LEN(Id$) THEN
3668     Fiber_id$=Id$
3670   END IF
3672   Im2:IMAGE #,"Please enter the fiber length in meters (or zero): ",K
3674   OUTPUT KBD USING Im2
3676   BEEP
3678   ENTER KBD USING Im2;Len$
3680   IF LEN(Len$) THEN
3682     Fiber_len=VAL(Len$)/1000
3684   END IF
3686   CALL Cleardisplay
3688 SUBEND
3690 !
3692 !
3694 SUB Fibertype(OPTIONAL Fiber_type)
3696 !+*****+
3698 ! FIBER TYPE SPECIFICATION MODULE                                VERSION 2.1
3700 !-*****-
3702   COM /Align_param/ A(*)
3704   !
3706   Get_type: !
3708   IF NPAR<1 THEN
3710     INPUT "Please enter the fiber type (20, 50, 85, 100, or 150): ",Ftype
3712   ELSE
3714     Ftype=Fiber_type      !If fiber_type argument is included, use it
3716   END IF
3718   !
3720   SELECT Ftype .
3722   CASE 20
3724     A(0)=1                !Queried to see if fibertype has been set (no=0)
3726     A(1)=10 !Rough_dx     !Step size for rough alignment
3728     A(2)=10 !Rough_dy
3730     A(3)=100 !Rough_dz
3732     A(4)=4  !Fine_dx     !Step size for fine alignment
3734     A(5)=4  !Fine_dy
3736     A(6)=15 !Fine_dz
3738   !
3740   CASE 50                !50 micron fiber diameter
3742     A(0)=1                !Queried to see if fibertype has been set (no=0)
3744     A(1)=20 !Rough_dx     !Step size for rough alignment
3746     A(2)=20 !Rough_dy
3748     A(3)=160 !Rough_dz
3750     A(4)=8  !Fine_dx     !Step size for fine alignment
3752     A(5)=8  !Fine_dy
3754     A(6)=20 !Fine_dz
3756   !
3758   CASE 85                !85 micron fiber diameter
3760     A(0)=1                !Queried to see if fibertype has been set (no=0)
3762     A(1)=36 !Rough_dx     !Step size for rough alignment
3764     A(2)=36 !Rough_dy
3766     A(3)=272 !Rough_dz
3768     A(4)=12 !Fine_dx     !Step size for fine alignment

```

```

3778      A(0)=1      !Queried to see if fibertype has been set (no=0)
3780      A(1)=40      !Rough_dx      !Step size for rough alignment
3782      A(2)=40      !Rough_dy
3784      A(3)=300     !Rough_dz
3786      A(4)=12      !Fine_dx      !Step size for fine alignment
3788      A(5)=12      !Fine_dy
3790      A(6)=50      !Fine_dz
3792      !
3794      CASE 150      !150 micron fiber diameter.
3796      A(0)=1      !Queried to see if fibertype has been set (no=0)
3798      A(1)=60      !Rough_dx      !Step size for rough alignment
3800      A(2)=60      !Rough_dy
3802      A(3)=300     !Rough_dz
3804      A(4)=16      !Fine_dx      !Step size for fine alignment
3806      A(5)=16      !Fine_dy
3808      A(6)=50      !Fine_dz
3810      !
3812      ! If the user didn't supply a valid fiber type (no CASE match), come here
3814      !
3816      CASE ELSE
3818      BEEP
3820      GOTO Get_type
3822      END SELECT
3824      SUBEND
3826      !
3828      !
3830      SUB Fiberload(String$)
3832      !+*****+
3834      ! FIBER LOAD MODULE      VERSION 2.1P
3836      !-*****-
3838      COM /Iopaths/ @Foa2000,@Egg5205,@Tek7854,@Bncdelay,Printer_add
3840      CALL F2000send("ALIGN",1)
3842      LOCAL @Foa2000
3844      OUTPUT KBD USING "#,K";"K"
3846      PRINT TABXY(1,10);String$
3848      BEEP
3850      ON KEY 5 LABEL "PROCEED" GOTO Proceed
3852      Here:GOTO Here
3854      Proceed:OFF KEY
3856      CALL F2000send("STAGE0",1)
3858      OUTPUT KBD USING "#,K";"K"
3860      SUBEND
3862      !
3864      !
3866      SUB Specwaves(String$)
3868      !+*****+
3870      ! SPECTRAL ATTENUATION WAVELENGTHS MODULE      VERSION 2.1
3872      !-*****-
3874      COM /Wavelength/ Wavelength(*),Numsteps
3876      COM /Sysdata/ Serial_nums,Lasers(*),Filter_flag,Filter(*),Num_focus.Focus(*),Cutoff,Low_wave,High_wave,Det_switch
3878      !
3880      ! The array builder parses the user's input string and builds a
3882      ! wavelength array.
3884      !
3886      CALL Arraybuild(String$,Wavelength(*),Numsteps)
3888      IF Numsteps<=0 THEN      !ARRAYBUILD got an error?
3890      BEEP
3892      DISP "SPECWAVES -- Bad command format. Program idle."
3894      Dead1:GOTO Dead1
3896      END IF
3898      IF Numsteps>350 THEN      !Check for more than 100 values

```

```

3906 Numsteps=350 !Set number of steps to 350
3908 END IF
3910 !
3912 ! Now we just check to see if the values are all within the
3914 ! valid range.
3916 !
3918 FOR Index=0 TO Numsteps-1
3920 IF Wavelength(Index)<Low_wave THEN
3922 BEEP
3924 DISP "SPECWAVES -- A wavelength below "&VAL$(Low_wave)&" nm is speci
fied. It will be set to "&VAL$(Low_wave)&" nm."
3926 WAIT 3
3928 Wavelength(Index)=Low_wave
3930 END IF
3932 IF Wavelength(Index)>High_wave THEN
3934 BEEP
3936 DISP "SPECWAVES -- A wavelength above "&VAL$(High_wave)&" nm is spec
ified. It will be set to "&VAL$(High_wave)&" nm."
3938 WAIT 3
3940 Wavelength(Index)=High_wave
3942 END IF
3944 NEXT Index
3946 DISP ""
3948 SUBEND
3950 !
3952 !
3954 SUB Setfocus(Wavelength)
3956 !+*****+
3958 ! SET FOA-2000 FOCUS CORRECTION MODULE VERSION 2.1
3960 !-*****-
3962 COM /Sysdata/ Serial_num$,Lasers(*),Filter_flag,Filter(*),Num_focus,Focu
s(*),Cutoff,Low_wave,High_wave,Det_switch
3964 INTEGER Index,Wave1,Wave2,Aindex,Cor_val
3966 DIM Cmd$(40)
3968 Cmd$=""
3970 Axis$(0)="IN-X"
3972 Axis$(1)="IN-Y"
3974 Axis$(2)="IN-Z"
3976 !
3978 ! Find the two entries in the focus correction table that are closest to
3980 ! the desired wavelength
3982 !
3984 IF Num_focus<2 THEN SUBEXIT
3986 FOR Index=1 TO Num_focus-1
3988 IF Focus(Index,0)>=Wavelength THEN GOTO Exit_loop
3990 NEXT Index
3992 !
3994 ! Next, get the correction value for the specified wavelength for
3996 ! each axis. If the specified wavelength was not found in the array,
3998 ! interpolate between the adjacent values to compute the correction
4000 ! value. This process is done for each axis (X, Y, and Z).
4002 !
4004 Exit_loop:FOR Aindex=1 TO 3
4006 GOSUB Get_cor !Get the correction
4008 Cmd$=Cmd$&VAL$(Cor_val)&" "&Axis$(Aindex-1)&" " !And send it
4010 NEXT Aindex !Do the next axis
4012 CALL F2000send(Cmd$,1)
4014 GOTO Done !All done
4016 Get_cor:Wave1=Focus(Index-1,0)
4018 Wave2=Focus(Index,0)
4020 Val1=Focus(Index-1,Aindex)
4022 Val2=Focus(Index,Aindex)
4024 Cor_val=Val1+(Val2-Val1)*(Wavelength-Wave1)/(Wave2-Wave1)

```

```

4032 |
4034 SUB Specrun(OPTIONAL Spot$,Runmsg$)
4036 |*****+
4038 | RUN SPECTRAL MEASUREMENTS MODULE                                VERSION 2.1
4040 |-----+
4042     DIM Run$(80)
4044     IF NPAR<2 THEN                !If DMA is not specified, assume spec atten meas.
4046         Run$="Spectral attenuation measurements in process"
4048     ELSE
4050         Run$=Runmsg$
4052     END IF
4054     Spot_flag=1
4056 !Check for over-filled launch specification
4058     IF NPAR>0 THEN
4060         IF (POS(Spot$,"F")<>0 OR POS(Spot$,"f")<>0) THEN
4062             Spot_flag=0
4064             Run$=Run$&"
"&"Launch overfilled."
4066         END IF
4068     END IF
4070     CALL Rundisplay(Run$)
4072     CALL Specmeas(0,Spot_flag)
4074     CALL Cleardisplay
4076 SUBEND
4078 |
4080 |
4082 SUB Specref(OPTIONAL Direct$,Runmsg$)
4084 |*****+
4086 | SPECTRAL ATTENUATION REFERENCE MEASUREMENTS MODULE                VERSION 2.1
4088 |-----+
4090     DIM Run$(200)
4092     Crlf$=CHR$(13)&CHR$(10)
4094     Spot_flag=1
4096     IF NPAR>0 THEN
4098         IF (POS(Direct$,"F")<>0 OR POS(Direct$,"f")<>0) THEN Spot_flag=0
4100     !
4102     ! Direct$ was included, so check for a "D" or "d"
4104     !
4106         IF POS(Direct$,"D") OR POS(Direct$,"d") THEN
4108             !
4110             ! Now check to see if and uncorrected run was specified.
4112             !
4114             IF POS(Direct$,"U") OR POS(Direct$,"u") THEN
4116                 !
4118                 ! A Direct Uncorrected run is requested.
4120                 !
4122                 IF NPAR<2 THEN
4124                     Run$="Collecting uncorrected direct reference data"&Crlf$&"for s
pectral attenuation."
4126                 ELSE
4128                     Run$="Collecting uncorrected direct reference data"&Crlf$&Runmsg
$
4130                 END IF
4132                 IF Spot_flag=0 THEN Run$=Run$&Crlf$&"Launch overfilled."
4134                 CALL Rundisplay(Run$)
4136                 CALL Specmeas(2,Spot_flag)
4138                 CALL Cleardisplay
4140             ELSE
4142                 !
4144                 ! Uncorrected NOT specified, do a corrected direct reference run.
4146                 !
4148                 IF NPAR<2 THEN
4150                     Run$="Collecting direct reference data for "&Crlf$&"for s
pectral attenuation."

```

```

4156     END IF
4158     IF Spot_flag=0 THEN Run$=Run$&CrLf$&"Launch overfilled."
4160     CALL Rundisplay(Run$)
4162     CALL Specmeas(3,Spot_flag)
4164     CALL Cleardisplay
4166     END IF
4168     ELSE
4170     GOTO Ref
4172     END IF
4174     ELSE
4176     !
4178     ! The Direct$ string did not contain a "D" or "d" or the direct$
4180     ! parameter was not specified, so do a short-fiber reference run.
4182     !
4184     Ref: !
4186     IF NPAR<2 THEN
4188     Run$="Collecting spectral attenuation"&CrLf$&"reference data."
4190     ELSE
4192     Run$="Collecting "&Runmsg$&" reference data."
4194     END IF
4196     IF Spot_flag=0 THEN Run$=Run$&CrLf$&"Launch overfilled."
4198     CALL Rundisplay(Run$)
4200     CALL Specmeas(1,Spot_flag)
4202     CALL Cleardisplay
4204     END IF
4206     SUBEND
4208     !
4210     !
4212     SUB Specmeas(Run_flag,OPTIONAL Spot)
4214     !+*****+
4216     ! SPECTRAL ATTENUATION MEASUREMENTS MODULE                                VERSION 2.1P
4218     !-*****-
4220     COM /Diskdrive/ Sysdrive$,Arcdrive$
4222     COM /Sysdata/ Serial_num$,Lasers(*),Filter_flag,Filter(*),Num_focus Focus(*),Cutoff,Low_wave,High_wave,Det_switch
4224     COM /Fiber/ Fiber_id$,Fiber_len,Log_time$
4226     COM /Wavelength/ Wavelength(*),Numsteps
4228     COM /Specrundata/ Specrundata(*),Specrun_id$
4230     COM /Specrerefdata/ Specrerefdata(*),Specreref_id$
4232     COM /Directref/ Specrerefcon(*),Pulserefcon(*),Pulseconwave(*),Correct_flag(*)
4234     COM /Cutoff/ Cutref(*),Cutresult(*),Cutoff_id$,Cutoff_wave,First,Last,Slope,Intercept
4236     DIM Filename$(25)
4238     INTEGER Index
4240     :
4242     ! Set-up instruments for Spectral Measurements
4244     !
4246     IF NPAR=2 THEN
4248     Spot_flag=Spot
4250     ELSE
4252     Spot_flag=1
4254     END IF
4256     IF Filter_flag<>1 THEN
4258     CALL F2000send("WAV COUPL")
4260     ELSE IF Filter_flag=1 means bandpass filters used and not monochrometer.
4262     CALL F2000send("FIL COUPL")
4264     END IF
4266     IF Spot_flag THEN
4268     CALL F2000send("SPOT-IN")
4270     ELSE
4272     CALL F2000send("SPOT-OUT")
4274     END IF

```

```

4280      CALL F2000send( "XMIT" )
4282  ELSE
4284      CALL F2000send( "XMIT" )
4286  END IF
4288  CALL F2000send( "VOUT TARGET-OUT FF-OUT", 1 )
4290  SELECT Run_flag
4292  |
4294  | For fiber measurements, store data in Specrundata array.
4296  |
4298  CASE =0
4300      Specrun_id$=Fiber_id$&" "&Log_times$
4302      Specrundata(0,0)=Numsteps
4304      Specrundata(0,1)=Fiber_len
4306  |
4308  | For reference or direct measurements, store data in specrefdata array.
4310  |
4312  CASE =1,2,3
4314      Specref_id$=Fiber_id$&" "&Log_times$
4316      Specrefdata(0,0)=Numsteps
4318      Specrefdata(0,1)=Fiber_len
4320  CASE =4
4322      Cutoff_id$=Fiber_id$&Log_times$
4324      Cutref(0,0)=Numsteps
4326  END SELECT
4328  |
4330  | Run measurements at each wavelength in the wavelength array
4332  |
4334  FOR Index=0 TO Numsteps-1      !Make measurement at each wavelength
4336  |
4338  | Set the FOA-2000 to the next wavelength
4340  |
4342  CALL Nextwave(Wavelength(Index))
4344  IF Run_flag=0 OR Run_flag=1 OR Run_flag=4 THEN ! Skip focus for direct
4346      CALL Setfocus(Wavelength(Index))      !Set focus
4348  END IF
4350  |
4352  | Make the measurement at this wavelength
4354  |
4356  Measurement=FNVoltmeter(.01)
4358  |
4360  | Now store the measurement in the appropriate common array
4362  |
4364  SELECT Run_flag
4366  CASE 0
4368      Specrundata(Index+1,0)=Wavelength(Index)
4370      Specrundata(Index+1,1)=Measurement
4372  CASE =1,2,3
4374      Specrefdata(Index+1,0)=Wavelength(Index)
4376      Specrefdata(Index+1,1)=Measurement
4378  CASE =4
4380      Cutref(Index+1,0)=Wavelength(Index)
4382      Cutref(Index+1,1)=Measurement
4384  END SELECT
4386  NEXT Index
4388  |
4390  | End of measurement loop
4392  |
4394  CALL F2000send( "0 IN-X 0 IN-Y 0 IN-Z " )
4396  |
4398  | For corrected direct measurements, the direct data must be multiplied
4400  | by the launch correction factors stored in the common array Specrefcor.
4402  |
4404  IF Run_flag=3 THEN

```

```

4412 Dead2: GOTO Dead2
4414     ELSE
4416         Ioffset=0           !Offset allow for extra points in speccor
4418         FOR Index=1 TO Numsteps
4420             WHILE Specrefdata(Index,0)<>Specrefcor(Index+Ioffset,0)
4422                 Ioffset=Ioffset+1   !Search ahead for a wavelength match
4424                 IF Index+Ioffset>Specrefcor(0,0) THEN
4426                     BEEP
4428                     PRINT TABXY(1,17);"SPECMEAS -- A correction factor was not fou
nd for a wavelength used in"
4430                     PRINT TABXY(1,18);"the direct-spot measurements."
4432 Dead1: GOTO Dead1
4434     END IF
4436     END WHILE
4438     Specrefdata(Index,1)=Specrefdata(Index,1)*Specrefcor(Index+Ioffset
,1) !Apply the correction
4440     NEXT Index
4442     END IF
4444     END IF
4446 SUBEND
4448 !
4450 !
4452 SUB Speccor
4454 !+-----+
4456 ! CALCULATE SPEC ATTEN DIRECT CORRECTION FACTORS MODULE          VERSION 2.1P
4458 !------+
4460     COM /Diskdrive/ Sysdrive$  ndrive$
4462     COM /Specrundata/ Specrundata(*),Specrun_id$
4464     COM /Specrefdata/ Specrefdata(*),Specref_id$
4466     COM /Directref/ Specrefcor(*),Pulserefcor(*),Pulsecorwave(*),Correct_fla
g(*)
4468     Filename$="speccor"
4470     INTEGER Index
4472     Specrefcor(0,0)=Specrefdata(0,0)
4474     Specrefcor(0,1)=Specrefdata(0,1)
4476     FOR Index=1 TO Specrefdata(0,0)
4478         IF Specrefdata(Index,0)<>Specrundata(Index,0) THEN
4480             BEEP
4482             DISP "SPECCOR --- Short fiber and direct data wavelengths do not matc
h."
4484 Dead1: GOTO Dead1
4486         ELSE
4488             Specrefcor(Index,0)=Specrefdata(Index,0)
4490             Specrefcor(Index,1)=Specrundata(Index,1)/Specrefdata(Index,1)
4492         END IF
4494     NEXT Index
4496 !
4498 ! Write the new data in the file called "speccor"
4500 !
4502     ON ERROR GOSUB File_err
4504     CREATE BDAT Filename$&Sysdrive$,210,8
4506     ASSIGN @Outfile TO Filename$&Sysdrive$
4508     OFF ERROR
4510     OUTPUT @Outfile;Specrefcor(*)
4512     ASSIGN @Outfile TO *
4514     GOTO Done
4516 File_err:IF ERRN=54 THEN
4518     PURGE Filename$&Sysdrive$
4520 ELSE
4522     PRINT "SPECCOR -- Error number "&VAL$(ERRN)
4524 Dead2:GOTO Dead2
4526 END IF

```

```

4534 !
4536 SUB Specatcomp
4538 !+*****+
4540 ! SPECTRAL ATTENUATION COMPUTE MODULE                                VERSION 2.1
4542 !-*****-
4544     COM /Specrundata/ Specrundata(*),Specrun_id$
4546     COM /Specrdata/ Specrdata(*),Specr_id$
4548     COM /Specattdata/ Specattdata(*),Specatt_id$
4550     INTEGER Index
4552     CALL Rundiplay("Computing Spectral Attenuation Results.")
4554     Length=Specrundata(0,1)                                !If fiber length is not given,
4556     IF Length=0 THEN Length=4.6                             !then use 1 for length.
4558     Specattdata(0,0)=Specrundata(0,0)                       !Store the number of points
4560     Specattdata(0,1)=Specrundata(0,1)                       !Store the fiber length
4562     Specatt_id$=Specrun_id$                                  !Store the fiber id string
4564 !
4566 ! Now compute the results at each wavelength
4568 !
4570     FOR Index=1 TO Specrundata(0,0)
4572 !
4574 ! Find the wavelength in the REF sample that corresponds to the RUN.
4576 !
4578         Index1=1
4580         WHILE Specrundata(Index,0)<>Specrdata(Index1,0) AND Index1<=Specrdata(0,0)
4582             Index1=Index1+1
4584         END WHILE
4586         IF Index1>Specrdata(0,0) THEN
4588             BEEP
4590             PRINT TABXY(17,1);"SPECATCOMP -- The reference does not contain a wavelength found in the measurement. Program idle."
4592             GOTO Dead2
4594         END IF
4596         Specattdata(Index,0)=Specrundata(Index,0)!Record the wavelength
4598         IF Specrdata(Index1,1)/Specrundata(Index,1)<=0 THEN
4600             Specattdata(Index,1)=-100
4602         ELSE
4604             Specattdata(Index,1)=10*LGT(Specrdata(Index1,1)/Specrundata(Index,1))
4606         END IF
4608 !
4610 ! Divide by fiber length
4612 !
4614         Specattdata(Index,1)=Specattdata(Index,1)/Length
4616     NEXT Index
4618     CALL Cleardisplay
4620 SUBEND
4622 !
4624 !
4626 SUB Specatlist(OPTIONAL Print_flag$,Newtitle$)
4628 !+*****+
4630 ! SPECTRAL ATTENUATION OUTPUT LISTING MODULE                                VERSION 2.1
4632 !-*****-
4634     DIM Title$(25)
4636     INTEGER I
4638     REAL Divby
4640     COM /Iopaths/ @Foa2000,@Egg5205,@Tek496p,@Tek7854,Printer_add
4642     COM /Specattdata/ Specattdata(*),Specatt_id$
4644 !
4646 ! Now set-up the table output
4648 !
4650     OUTPUT KBD USING "#,K";"K"                                ! Set up screen for the table
4652 !
4654 ! If the caller included the print_flag$ parameter and the first

```

```

4662 Divby=1
4664 IF NPAR>0 THEN
4666     IF POS(Print_flag$,"MET") THEN Divby=1000
4668     IF POS(Print_flag$,"TEN") THEN Divby=100
4670     IF POS(Print_flag$,"HUN") THEN Divby=10
4672     IF POS(Print_flag$,"KILO") THEN Divby=1
4674     IF POS(Print_flag$,"P") OR POS(Print_flag$,"p") THEN Print_it
4676 END IF
4678 !
1680 GOSUB Print_tbl
4682 ON KEY 8 LABEL "PRINT" GOTO Print_it ! Hardcopy?
4684 ON KEY 5 LABEL "CONTINUE" GOTO Done
4686 BEEP
4688 Wait_here:GOTO Wait_here
4690 Print_it:OFF KEY
4692 PRINTER IS Printer_add
4694 GOSUB Print_tbl
4696 PRINT !Put some white space at the bottom
4698 PRINT
4700 PRINT
4702 PRINTER IS !
4704 GOTO Done
4706 Print_tbl: !
4708 IF NPAR<2 THEN
4710     PRINT "SPECTRAL ATTENUATION"
4712     PRINT "-----"
4714 ELSE
4716     PRINT Newtitle$
4718 END IF
4720 PRINT "FIBER ID: "&Specatt_id$
4722 PRINT "LENGTH: ";Specattdata(0,1);" km"
4724 PRINT
4726 IF Specattdata(0,1)=0 THEN
4728     Title$="ATTENUATION (dB)"
4730 ELSE
4732     IF Divby=1 THEN Title$="ATTENUATION (dB/Km)"
4734     IF Divby=10 THEN Title$="ATTENUATION (dB/100m)"
4736     IF Divby=100 THEN Title$="ATTENUATION (dB/10m)"
4738     IF Divby=1000 THEN Title$="ATTENUATION (dB/m)"
4740 END IF
4742 PRINT "WAVELENGTH      ";Title$
4744 PRINT
4746 FOR I=1 TO Specattdata(0,0) ! Print the table
4748     PRINT USING "4>,4D,10X,6D.4D";Specattdata(I,0),Specattdata(I,1)/Divby
4750 NEXT I
4752 RETURN
4754 Done:OUTPUT KBD USING "#,K";"K" ! Clear the screen
4756 SUBEND
4758 !
4760 !
4762 SUB Specatplot(OPTIONAL Print_flag$,Low_wave,High_wave,Newtitle$)
4764 !+*****+
4766 ! PLOTTER FOR SPECTRAL ATTENUATION VERSION 2.1
4768 !-*****+
4770 COM /Iopaths/ @Foa2000,@Egg5205,@Tek496p,@Tek7854,Printer_add
4772 COM /Specattdata/ Specattdata(*),Specatt_id$
4774 INTEGER Index
4776 INTEGER Lowave
4778 REAL Divby
4780 DIM Xlabel$(40),Ylabel$(40)
4782 Divby=1 ! In case this parameter isn't passed
4784 Top: !

```

```

4794 IF POS(Print_flag$,"KILO") THEN Divby=1
4796 END IF
4798 !
4800 ! Initialize plotting labels and limits
4802 !
4804 Xlabel$="Wavelength (um)"
4806 IF Specattdata(0,1)=0 THEN
4808 Ylabel$="dB"
4810 ELSE
4812 IF Divby=1 THEN Ylabel$="dB/km"
4814 IF Divby=10 THEN Ylabel$="dB/100m"
4816 IF Divby=100 THEN Ylabel$="dB/10m"
4818 IF Divby=1000 THEN Ylabel$="dB/m"
4820 END IF
4822 !
4824 IF (NPAR>1) THEN
4826 IF Low_wave>0 THEN
4828 Minx=Low_wave
4830 ELSE
4832 Minx=Specattdata(1,0)
4834 END IF
4836 ELSE
4838 IF Print_flag$="2" THEN
4840 INPUT "Enter the minimum wavelength value in nm:",Minx
4842 ELSE
4844 Minx=Specattdata(1,0)
4846 END IF
4848 END IF
4850 IF (NPAR>2) THEN
4852 IF High_wave>0 THEN
4854 Maxx=High_wave
4856 ELSE
4858 Maxx=Specattdata(Specattdata(0,0),0)
4860 END IF
4862 ELSE
4864 IF Print_flag$="2" THEN
4866 INPUT "Enter the MAXIMUM wavelength value in nm: ",Maxx
4868 ELSE
4870 Maxx=Specattdata(Specattdata(0,0),0)
4872 END IF
4874 END IF
4876 Minx=INT(Minx/100)*100
4878 Maxx=INT((Maxx+99)/100)*100
4880 Miny=0
4882 Maxy=0
4884 FOR Index=1 TO Specattdata(0,0)
4886 IF (Specattdata(Index,1)/Divby)>Maxy THEN Maxy=Specattdata(Index,1)/Di
vby
4888 NEXT Index
4890 Maxy=INT((Maxy+4)/5)*5
4892 IF Maxy<5 THEN Maxy=5
4894 IF Maxy>20 THEN Maxy=20
4896 Tix=(Specattdata(Specattdata(0,0),0)-Specattdata(1,0))/10
4898 Tix=INT(Tix/10)*10
4900 Ticy=1
4902 !
4904 ! Initialize screen, set line type to dotted, and draw the grid
4906 !
4908 GINIT
4910 GCLEAR
4912 GRAPHICS ON
4914 CSIZE 5,.55

```

```

4924 IF Specattdata(0,1)=0 THEN
4926 LABEL "SPECTRAL ATTENUATION"
4928 ELSE
4930 LABEL USING "" "SPECTRAL ATTENUATION" LENGTH: "",DD.DDDD,"" "m"";
Specattdata(0,1)
4932 END IF
4934 ELSE
4936 LABEL " "&Newtitles$
4938 END IF
4940 PRINT TABXY(1,2);
4942 PRINT "ID: "&Specatt_id$;
4944 PRINT USING "2X,8A,DD.DDD,3A";"Length: ",Specattdata(0,1)," m"
4946 VIEWPORT 20,92*RATIO,30,86
4948 WINDOW Minx,Maxx,Miny,Maxy
4950 LINE TYPE 4
4952 GRID Tiox,Ticy,Minx,Miny
4954 !
4956 !Reset the line type to solid, and plot the data
4958 !
4960 LINE TYPE 1
4962 FOR Index=1 TO Specattdata(0,0)
4964 PLOT Specattdata(Index,0),Specattdata(Index,1)/Divby
4966 NEXT Index
4968 !
4970 !Set the label mode to center, units to degrees, rotation to zero
4972 !degrees, and expand the hard clip to make room for the labels.
4974 !Then set the label size for the x-axis.
4976 !
4978 LONG 5
4980 DEG
4982 LDIR 0
4984 VIEWPORT 0,100*RATIO,0,100
4986 WINDOW 0,100*RATIO,0,100
4988 CSIZE 6,.6
4990 !
4992 !Label the x-axis
4994 !
4996 MOVE 70,18
4998 LABEL Xlabel$
5000 CSIZE 4,.65
5002 LONG 6
5004 FOR Xpos=20 TO 123 STEP 100*Tiox/(Maxx-Minx)*2
5006 MOVE Xpos,29
5008 LABEL USING "0.00";(Xpos-20)/100*(Maxx-Minx)/1000+Minx/1000
5010 NEXT Xpos
5012 !
5014 !Change to the Y-axis, put the title on the y-axis, then
5016 !label the grid marks on the y-axis.
5018 !
5020 CSIZE 6,.6
5022 LONG 5
5024 MOVE 8,53+LEN(Ylabel$)*3
5026 FOR I=1 TO LEN(Ylabel$)
5028 LABEL Ylabel$[I,1]
5030 NEXT I
5032 CSIZE 4,.6
5034 LONG 8
5036 FOR Ypos=30 TO 88 STEP 56*Ticy/(Maxy-Miny)
5038 MOVE 19,Ypos
5040 LABEL USING "0.00";(Ypos-30)/56*(Maxy-Miny)+Miny
5042 NEXT Ypos
5044 !

```

```

5052 IF Print_flag=1 THEN GOTO Print_plot
5054 END IF
5056 |
5058 |Otherwise set up keys for operator interaction
5060 |
5062 ON KEY 1 LABEL "RESCALE PLOT" GOTO Rescale
5064 ON KEY 2 LABEL " PRINT LISTING" GOTO Listing
5066 ON KEY 3 LABEL " STORE DATA" GOTO Storeit
5068 ON KEY 5 LABEL " QUIT" GOTO Quitit
5070 ON KEY 8 LABEL " PRINT PLOT" GOTO Print_plot
5072 Wait:GOTO Wait
5074 Rescale: Print_flag="RESCALE"
5076 CALL Cleardisplay
5078 SUBEXIT
5080 Listing: Print_flag="LISTING"
5082 SUBEXIT
5084 Storeit: Print_flag="STORE"
5086 CALL Cleardisplay
5088 SUBEXIT
5090 Quitit: Print_flag="QUIT"
5092 SUBEXIT
5094 Print_plot: OFF KEY
5096 OUTPUT KBD USING "*,K";"!"
5098 DUMP GRAPHICS
5100 OUTPUT KBD USING "*,K";"!"
5102 GOTO Top
5104 Return:GINIT
5106 GCLEAR
5108 SUBEND
5110 |
5112 |
5114 SUB Nfieldvals(String$)
5116 |+*****+
5118 | NEAR FIELD VALUES SPECIFICATION MODULE VERSION 2.1
5120 |-----+
5122 COM /Nearfield/ Nfieldval(*),Num_points,Nearfield(*),Nfield_id$
5124 |
5126 | The array builder parses the user's input string and builds a
5128 | wavelength array.
5130 |
5132 CALL Arraybuild(String$,Nfieldval(*),Num_points)
5134 IF Num_points<0 THEN !Array builder got an error?
5136 BEEP
5138 DISP "NFIELDVALS -- Bad command format. Program now hung in a loop(hi
t PAUSE or STOP)"
5140 Dead1:GOTO Dead1
5142 END IF
5144 IF Num_points>200 THEN !Check for more than 100 points
5146 BEEP
5148 DISP "NFIELDVALS -- More than 200 points are specified. Extras will be
ignored."
5150 WAIT 3
5152 Num_points=200 !And set number of points to 100
5154 END IF
5156 |
5158 | Now check to see if the values are all within the valid range.
5160 |
5162 FOR Index=0 TO Num_points-1
5164 IF Nfieldval(Index)<-250 THEN
5166 BEEP
5168 DISP "NFIELDVALS -- A value less than -250 is specified. It will be
set to -250."
5170 WAIT 3
5172 Nfieldval(Index)=-250

```

```

90      DISP "NFIELDVALS -- A value greater than 250 is specified. It will b
91  set to 250."
92      WAIT 3
94      END IF
96      NEXT Index
98      DISP ""
99  SUBEND
100
101  SUB Nfieldrun
102  !+-----+
103  ! NEAR-FIELD MEASUREMENTS RUN MODULE                                VERSION 2.1
104  !------+
105  COM /Nearfield/ Nfieldval(*),Num_points,Nearfield(*),Nfield_id$
106  COM /Fiber/ Fiber_id$,Fiber_len,Log_time$
107  COM /Syscal/ Pin_x,Pin_y,Pin_z,Inx_step,Iny_step,Outx_step,Outy_step,Far
108  eld_step,Lfnnoise
109  INTEGER Index,Setting,Meas_range,Maxloc
110  OUTPUT KBD USING "#,K","K"
111  CALL Rundisplay("Near-field measurements in progress.")
112  !
113  ! Set up instruments for near field measurements
114  !
115  CALL F2000send("GERMAIN LED LED-ON CHOP-ON SPOT-OUT XMIT PIN-IN")
116  CALL F2000send("VOUT 0 ATTENUAT FF-OUT")
117  CALL F2000send("OUTX COUPL")
118  !
119  ! Now move the stage to correct for the actual pinhole position
120  !
121  CALL F2000send(VAL$(Pin_y)&" OUT-Y "&VAL$(Pin_z)&" OUT-Z")
122  !
123  ! Measure the signal at the fiber center, and fix the lock-in scale
124  !
125  Reading=FNVoltmeter(.1)
126  Peakval=2*Reading
127  CALL Setscale(.1,Peakval)
128  !
129  !
130  ! Take the measurements at each specified near-field position
131  !
132  Maxval=0
133  Setting=2*Nfieldval(0)-20          ! Backup to eliminate backlash
134  CALL F2000send(VAL$(Setting+Pin_x)&" OUT-X",1)
135  FOR Index=1 TO Num_points
136      Setting=2*Nfieldval(Index-1)
137      CALL F2000send(VAL$(Setting+Pin_x)&" OUT-X",1)
138      Nearfield(Index,1)=FNVoltmeter(0)    !Get a reading from 5205
139      Nearfield(Index,0)=Setting*Outx_step  !Store X-axis location
140  !
141  ! Remember the largest value and its location
142  !
143  IF Nearfield(Index,1)>Maxval THEN
144      Maxval=Nearfield(Index,1)
145      Maxloc=Index
146  END IF
147  NEXT Index
148  !
149  ! Now put the stage back to the original zero value before correcting
150  ! for the pinhole position.
151  !
152  CALL F2000send("0 OUT-X 0 OUT-Y 0 OUT-Z",1)
153  !

```

```

10 FOR Index=1 TO Num_points
12   Nearfield(Index,1)=Nearfield(Index,1)/Maxval
14 NEXT Index
16 Nearfield(0,0)=Num_points      !Store number of points in array
18 Nfield_id$=Fiber_id$$ " &Log_time$ !And store the fiber ID & time
20 CALL Cleardisplay
22 SUBEND
24 SUB Nfieldplot(OPTIONAL Print_flag$)
26 !+*****+
28 ! NEAR FIELD GRAPHICS OUTPUT MODULE                                VERSION 2.1
30 !-*****-
32   INTEGER Index
34   COM /Nearfield/ Nfieldval(*),Num_points,Nearfield(*),Nfield_id$
36   DIM Titles$(40),Xlabels$(40)
38   !
40   ! Compute core diameter and print it with the near field pattern graph
42   !
44   CALL Corediam(Nearfield(*),Core_diam)
46   Core_diam=.1*INT(10*Core_diam+.5)   !Round the results
48   Titles$="NEAR FIELD PATTERN"
50   Xlabels$="Distance (um)"
52   GINIT
54   GCLEAR
56   GRAPHICS ON
58   VIEWPORT 0,100*RATIO,10,100
60   MOVE 0,95.5
62   CSIZE 5
64   LABEL Titles$
66   LABEL "ID: "&Nfield_id$
68   Minx=-100
70   Maxx=100
72   Miny=0
74   Maxy=1
76   Xsize=ABS(Maxx-Minx)
78   Ysize=ABS(Maxy-Miny)
80   Botborder=Miny-.2*Ysize           ! Create a graph layout with space for
82   Topborder=Maxy+.1*Ysize           ! labels
84   Leftborder=Minx-.2*Xsize
86   Rgtborder=Maxx+.05*Xsize
88   VIEWPORT 0,100*RATIO,18,95
90   WINDOW Leftborder,Rgtborder,Botborder,Topborder
92   !
94   ! ** Generate the frame **
96   !
98   MOVE Minx,Miny
100  IDRAW Xsize,0
102  IDRAW 0,Ysize
104  IMOVE -Xsize,0
106  IDRAW 0,-Ysize
108  !
110  ! ** Generate the graticule lines **
112  !
114  LINE TYPE 4                        !Graticule in dotted lines
116  FOR Index=0 TO 5                   !5 Vertical divisions
118    MOVE Minx,Miny+(Ysize*Index/5)
120    IDRAW Xsize,0                    !Draw a horizontal line
122  NEXT Index
124  FOR Index=0 TO 8                   !8 Horizontal divisions
126    MOVE Minx+(Xsize*Index/8),Miny
128    IDRAW 0,Ysize                    !Draw a vertical line
130  NEXT Index
132  LINE TYPE 1                        !Back to solid lines

```

```

0  MOVE Nearfield(1,0),Nearfield(1,1)
12  FOR Index=2 TO Nearfield(0,0)
14      DRAW Nearfield(Index,0),Nearfield(Index,1)
16  NEXT Index
18  !
10  ! ** Put in the X-axis graticule labels **
12  !
14  CSIZE 4
16  FOR Index=0 TO 8
18      Value=Minx+Index*Xsize/8      !Compute the value of the label
20      MOVE Value-.06*Xsize,Miny-.4*(Miny-Botborder)
22      LABEL USING "S3D.":Value
24  NEXT Index
26  !
28  Xpos=Minx+Xsize/2-LEN(Xlabel$)*(Xsize/40)/2 !Compute place for XLABEL$
30  !
32  ! ** Print the X label string **
34  !
36  MOVE Xpos,Botborder
38  CSIZE 5
40  LABEL Xlabel$
42  !
44  ! ** Print the core diameter **
46  !
48  WINDOW 0,100*RATIO,10,100
50  VIEWPORT 0,100*RATIO,10,100
52  MOVE 0,9
54  IF Core_diam=0 THEN
56      LABEL "Core diameter not found"
58  ELSE
60      LABEL USING ""Core diameter = ",DDD.DD":Core_diam
62  END IF
64  IF NPAR=1 THEN
66      IF UPC$(Print_flag$(1,1))="P" THEN Print_it
68  END IF
70  ON KEY 8 LABEL "PRINT" GOTO Print_it
72  ON KEY 5 LABEL "CONTINUE" GOTO Done
74  Wait_here:GOTO Wait_here
76  Print_it:OFF KEY
78  OUTPUT KBD USING "#,K";"! "
80  DUMP GRAPHICS
82  OUTPUT KBD USING "#,K";"! "
84  Done:GCLEAR
86  GRAPHICS OFF
88  SUBEND
90  !
92  !
94  SUB Corediam(Nearfield(*),Diameter)
96  !*****+
98  ! COMPUTE CORE DIAMETER MODULE                                VERSION 2.1
100  !-*****+
102  ! This module computes core diameter on the near-field pattern.
104  Threshold=.025      ! Use 2.5% points
106  !
108  ! First, locate the 15% points to be sure we are off the noise
110  ! floor.
112  !
114  Diameter=0
116  Index=1
118  WHILE Nearfield(Index,1)<.15
120      Index=Index+1
122  IF Index>Nearfield(0,0) THEN Done
124  END WHILE

```

```

5572 WHILE Nearfield(Index,1)>Threshold
5574     Index=Index-1
5576     IF Index<1 THEN Done
5578 END WHILE
5580 !
5582 ! Compute an interpolated crossing
5584 !
5586 R1=Nearfield(Index,0)+(Nearfield(Index+1,0)-Nearfield(Index,0))*(Threshold-Nearfield(Index,1))/(Nearfield(Index+1,1)-Nearfield(Index,1))
5588 !
5590 ! Finally search forward to the second threshold crossing.
5592 !
5594 Index=Index+1
5596 WHILE Nearfield(Index,1)>Threshold
5598     Index=Index+1
5600     IF Index>Nearfield(0,0) THEN Done
5602 END WHILE
5604 R2=Nearfield(Index,0)+(Nearfield(Index-1,0)-Nearfield(Index,0))*(Threshold-Nearfield(Index,1))/(Nearfield(Index-1,1)-Nearfield(Index,1))
5606 Diameter=R2-R1
5608 Done:SUBEND
5610 !
5612 !
5614 SUB Ffieldvals(String$)
5616 !+*****+
5618 ! FAR FIELD VALUES SPECIFICATION MODULE                                VERSION 2.1
5620 !-*****-
5622 COM /Farfield/ Ffieldval(*),Num_points,Farfield(*),Ffield_id$
5624 COM /Syscal/ Pin_x,Pin_y,Pin_z,Inx_step,Iny_step,Outx_step,Outy_step,Far
field_step,Lfnnoise
5626 Upper_lim=140*Farfield_step      !Upper limit of valid farfield values
5628 Lower_lim=-550*Farfield_step     !Lower limit of valid farfield values
5630 !
5632 ! The array builder parses the user's input string and builds a
5634 ! wavelength array.
5636 !
5638 CALL Arraybuild(String$,Ffieldval(*),Num_points)
5640 IF Num_points<0 THEN              !ARRAYBUILD got an error?
5642     BEEP
5644     DISP "FFIELDVALS -- Syntax error on far-field input values string."
5646 Dead1:GOTO Dead1
5648 END IF
5650 IF Num_points>200 THEN             !Check for too many points
5652     BEEP
5654     DISP "FFIELDVALS -- More than 200 values are specified. Extras will be
ignored."
5656     WAIT 3
5658     Num_points=200                 !Set number of points to 200
5660 END IF
5662 !
5664 ! Now check to see if the values are all within the valid range
5666 !
5668 FOR Index=0 TO Num_points-1
5670     IF Ffieldval(Index)<=-550*Farfield_step THEN
5672         BEEP
5674         PRINT TABXY(1,17);"FFIELDVALS -- A value less than ";Lower_lim;" was
specified."
5676         PRINT TABXY(1,18);"The out-of-range value will be set to ";Lower_lim
5678         WAIT 3
5680         Ffieldval(Index)=-550*Farfield_step
5682     END IF
5684     IF Ffieldval(Index)>140*Farfield_step THEN

```

```

5692     WAIT 3
5694     Ffieldval(Index)=140*Farfield_step
5696     END IF
5698     NEXT Index
5700     DISP ""
5702 SUBEND
5704 |
5706 |
5708 SUB Ffieldrun(Ffwave,OPTIONAL Runflag$)
5710 |*****+
5712 | FAR-FIELD MEASUREMENTS RUN MODULE                                VERSION 2.1
5714 |-----+
5716     COM /Farfield/ Ffieldval(*),Num_points,Farfield(*),Ffield_id$
5718     COM /Fiber/ Fiber_id$,Fiber_len,Log_time$
5720     COM /Syscal/ Pin_x,Pin_y,Pin_z,Inx_step,Iny_step,Outx_step,Outy_step,Far
field_step,Lfnoise
5722     COM /Farfield_wave/ Ffwavelen
5724     INTEGER Index,Setting,Meas_range,Runflag
5726     REAL Sintheta,Delta
5728     Ffwavelen=Ffwave
5730     IF NPAR<2 THEN
5732         Runflag=1 ! defaults to using scanner edge if not specified
5734     ELSE
5736         IF POS(Runflag$,"PIN") THEN
5738             Runflag=0
5740         ELSE
5742             Runflag=1
5744         END IF
5746     END IF
5748     OUTPUT KBD USING "#,K";"K"
5750     IF Runflag THEN
5752         CALL Rundisplay("Far-field measurements in progress.
(Using scan
ner edge.)")
5754     ELSE
5756         CALL Rundisplay("Far-field measurements in progress.
(Using pinh
ole.)")
5758     END IF
5760 |
5762 | Set up instruments for far field measurements
5764 |
5766     CALL Nextwave(Ffwave)
5768     CALL F2000send("INSB LAMP LAMP-ON CHOP-ON SPOT-OUT XMIT FF-IN")
5770     CALL F2000send("VOUT TARGET-OUT 0 ATTENUAT",1)
5772     CALL F2000send("FF COUPL")
5774     CALL F2000send("-550 FAR-FIELD",1) ! eliminate backlash
5776 |
5778 | Measure the approx peak amplitude and fix the lock-in voltmeter scale.
5780 |
5782     Reading=FNVoltmeter(.1)
5784     Peakval=2*Reading
5786     CALL Setscale(.1,Peakval)
5788 |
5790 | Take the measurements at each specified far-field position
5792 |
5794     Delta=1.59 ! Positional correction of edge of Far Field Scanner
5796         ! (Actually this # is delta/focal_length. delta=0.4261")
5798         ! The value of Delta will affect how well the center of
5800         ! the far field plot lines up with the peak intensity of
5802         ! the output intensity pattern.
5804     CALL Rundisplay("

```

```

5810 IF Running THEN
5812 |
5814 | Scanner edge technique |
5816 |
5818 Setting=(Sintheta-Delta)/Farfield_step
5820 Actual=(Setting*Farfield_step+Delta)
5822 CALL F2000send(VAL$(Setting)&" FAR-FIELD",1)
5824 Reading=FNvoltage(.05)
5826 Farfield(Index,1)=Reading
5828 ELSE
5830 |
5832 | Pinhole technique
5834 | Corrects measurement for COS(PHI)
5836 |
5838 Setting=Sinttheta/Farfield_step
5840 Actual=Setting*Farfield_step | note integer truncation
5842 CALL F2000send(VAL$(Setting)&" FAR-FIELD",1)
5844 Reading=FNvoltage(.05)
5846 Farfield(Index,1)=Reading
5848 END IF
5850 PRINT Actual,Reading
5852 | The following factor of .873 is a calibration factor. It was derived
5854 | by comparing a numerical aperture measurement made on this machine
5856 | with one made on George McCabe's NA measurement station. The fiber
5858 | used for comparison was 900228 on 28 Mar 90.
5860 Farfield(Index,0)=Actual*.873
5862 NEXT Index
5864 Ffield_id$=Fiber_id$&" "&Log_time$ |Store the fiber ID & time
5866 Farfield(0,0)=Num_points |Also store # points here (for ffieldplot)
5868 CALL F2000send("-550 FAR-FIELD") |Move scanner back down
5870 CALL Cleardisplay
5872 SUBEND
5874 |
5876 |
5878 SUB Ffieldplot(OPTIONAL Print_flag$,New_title$)
5880 |*****+
5882 | OUTPUT GRAPHICS MODULE FOR FAR-FIELD PATTERN VERSION 2.1
5884 |-----+
5886 | This module is responsible for both plotting and printing all Far Field
5888 | data, including raw data, differentiated data, and smoothed data.
5890 |
5892 COM /Farfield/ Ffieldval(*),Num_points,Farfield(*),Ffield_id$
5894 COM /Fftempdata/ Ffrawdata(*),Ffdiffdata(*),Ffsmoothdata(*)
5896 COM /Farfield_wave/ Ffwavelen
5898 |
5900 INTEGER I,J,Index
5902 DIM Title$(80),Xlabel$(40)
5904 |
5906 | Create a file in which to store the raw data. This is the file which
5908 | is loaded back into the Farfield(*) array if the store option is chosen.
5910 | Also create a file for the differentiate, rough (not smoothed) data.
5912 | Either the raw or rough data can be smoothed.
5914 |
5916 IF Print_flag$="RAW DATA" THEN
5918 FOR I=0 TO Farfield(0,0)
5920 FOR J=0 TO 1
5922 Ffrawdata(I,J)=Farfield(I,J)
5924 NEXT J
5926 NEXT I
5928 END IF
5930 |
5932 | Compute the NA for differentiated or smoothed, differentiated data only.
5934 IF Print_flag$="DIFF" THEN
5936 CALL Ffieldplot("DIFF",New_title$)

```

```

5944     CALL Numaper("SMOOTH",Num_aper)
5946     Num_aper=.001*INT(1000*Num_aper+.5) !Round to 3 places
5948     END IF
5950
5952     ! Now plot the data.
5954
5956     Plotit:|
5958     Xlabel$="SIN(angle)"
5960     Title$="          Far Field Pattern"
5962     IF NPAR>1 THEN Title$=New_titles
5964     GINIT
5966     GCLEAR
5968     GRAPHICS ON
5970     VIEWPORT 0,100*RATIO,10,100
5972     MOVE 0,95.5
5974     CSIZE 5
5976     LABEL Title$
5978     LABEL "          ID: "&Ffield_id$
5980     Minx=-.3
5982     Maxx=.3
5984     Miny=0
5986     Maxy=1
5988     Xsize=ABS(Maxx-Minx)
5990     Ysize=ABS(Maxy-Miny)
5992     Botborder=Miny-.2*Ysize      ! Create a graph layout with space for
5994     Topborder=Maxy+.1*Ysize      ! labels
5996     Leftborder=Minx-.2*Xsize
5998     Rgtborder=Maxx+.05*Xsize
6000     VIEWPORT 0,100*RATIO,20,95
6002     WINDOW Leftborder,Rgtborder,Botborder,Topborder
6004
6006     ** Generate the frame **
6008
6010     MOVE Minx,Miny
6012     IDRAW Xsize,0
6014     IDRAW 0,Ysize
6016     IMOVE -Xsize,0
6018     IDRAW 0,-Ysize
6020
6022     ** Generate the graticule lines **
6024
6026     LINE TYPE 4                  !Graticule in dotted lines
6028     FOR Index=0 TO 5             !5 Vertical divisions
6030         MOVE Minx,Miny+(Ysize*Index/5)
6032         IDRAW Xsize,0           !Draw a horizontal line
6034     NEXT Index
6036     FOR Index=0 TO 6             !6 Horizontal divisions
6038         MOVE Minx+(Xsize*Index/6),Miny
6040         IDRAW 0,Ysize          !Draw a vertical line
6042     NEXT Index
6044     LINE TYPE 1                  !Back to solid lines
6046
6048     ** Draw the graph itself
6050
6052     IF Print_flag$="RAW DATA" THEN
6054         MOVE Ffrawdata(1,0),Ffrawdata(1,1)
6056         FOR Index=2 TO Ffrawdata(0,0)
6058             DRAW Ffrawdata(Index,0),Ffrawdata(Index,1)
6060         NEXT Index
6062     END IF
6064
6066     IF Print_flag$="DIFF" THEN
6068         MOVE Ffdiffdata(1,0),Ffdiffdata(1,1)

```

```

6074      NEXT Index
6076      END IF
6078      !
6080      IF Print_flag$="SMOOTH" THEN
6082          MOVE Ffsmoothdata(1,0),Ffsmoothdata(1,1)
6084          FOR Index=2 TO Ffsmoothdata(0,0)
6086              DRAW Ffsmoothdata(Index,0),Ffsmoothdata(Index,1)
6088          NEXT Index
6090      END IF
6092      !
6094      ** Put in the X-axis graticule labels **
6096      !
6098      CSIZE 4
6100      FOR Index=0 TO 6
6102          Value=Minx+Index*Xsize/6          !Compute the value of the label
6104          MOVE Value-.09*Xsize,Miny-.4*(Miny-Botborder)
6106          LABEL USING "2D.2D";Value
6108      NEXT Index
6110      !
6112      Xpos=Minx+Xsize/2-LEN(Xlabel$)*(Xsize/40)/2 !Compute place for XLABEL$
6114      !
6116      ** Print the X label string **
6118      !
6120      CSIZE 5
6122      MOVE Xpos,Botborder
6124      LABEL Xlabel$
6126      !
6128      ** Print numerical aperture value **
6130      !
6132      WINDOW 0,100*RATIO,10,100
6134      VIEWPORT 0,100*RATIO,10,100
6136      MOVE 0,12
6138      IF Print_flag$="DIFF" OR (Print_flag$="SMOOTH" AND Ffdiffdata(0,0) < 0) THEN

6140          IF Num_aper=0 THEN
6142              LABEL "      Numerical Aperture Not Found."
6144          ELSE
6146              IF Ffwavelen=0 THEN
6148                  LABEL USING " 7X,4A,D.DDD,3X,13A,DDDDD,3A";"NA =",Num_aper
6150              ELSE
6152                  LABEL USING "7X,4A,D.DDD,3X,13A,DDDDD,3A";"NA =",Num_aper,"Wave
length =",Ffwavelen," nm"
6154              END IF
6156          END IF
6158      END IF
6160      !
6162      ! The rest of this is concerned with where to go after the screen plot.
6164      Key_guys: !
6166      ! Keys which appear on every plot:
6168      ON KEY 1 LABEL " SMOOTH  DATA" GOTO Smooth
6170      ON KEY 2 LABEL "DIFFER- ENTIAE" GOTO Done
6172      ON KEY 4 LABEL " STORE  RAW DATA" GOTO Storeit
6174      ON KEY 5 LABEL "  EXIT" GOTO Exit_all
6176      ON KEY 7 LABEL " PRINT  LISTING" GOTO Print_list
6178      ON KEY 8 LABEL " PRINT  PLOT" GOTO Print_plot
6180      !
6182      Wait_key_guys:GOTO Wait_key_guys
6184      !
6186      !-----
6188      !
6190      Smooth: OFF KEY
6192      PRINT TABXY(15,10);"Smooth the RAW, DIFFerentiated or SMOOTHED data?"
6194      ON KEY 1 LABEL "  RAW" GOTO Raw_smooth

```

```

6204 Raw_smooth: OFF KEY
6206 CALL Ffsmooth("RAW DATA")
6208 Print_flag$="SMOOTH"
6210 GOTO Plotit
6212 Diff_smooth: OFF KEY !If we haven't computed diff data, then do that first
6214 IF Ffdiffdata(0,0)=0 THEN
6216 PRINT
6218 PRINT USING "6X,70A"; "Differentiated data has not been calculated. C
an't be smoothed yet."
6220 GOTO Smooth
6222 END IF
6224 CALL Ffsmooth("DIFF")
6226 Print_flag$="SMOOTH"
6228 SUBEXIT
6230 Smooth_smooth: OFF KEY
6232 IF Ffsmoothdata(0,0)=0 THEN
6234 PRINT
6236 PRINT USING "6X,70A"; "Smoothed data has not been calculated. Can't b
e smoothed yet."
6238 GOTO Smooth
6240 END IF
6242 CALL Ffsmooth("SMOOTH")
6244 Print_flag$="SMOOTH"
6246 SUBEXIT
6248 !
6250 !-----
6252 !
6254 Storeit: OFF KEY
6256 CALL Cleardisplay
6258 CALL Archive
6260 GOTO Plotit
6262 !
6264 !-----
6266 !
6268 Print_list: OFF KEY
6270 PRINT TABXY(15,10); "Smooth the RAW, DIFFerentiated or SMOOTHED data?"
6272 ON KEY 1 LABEL " RAW" GOTO Print_raw
6274 ON KEY 4 LABEL " DIFF" GOTO Print_diff
6276 ON KEY 8 LABEL "SMOOTHED" GOTO Print_smooth
6278 Nogo: GOTO Nogo
6280 !
6282 Print_raw: OFF KEY
6284 PRINTER IS PRT
6286 PRINT " Far Field Raw Data for Fiber:", Ffield_id$
6288 PRINT ""
6290 PRINT USING "15X,48A"; "Number Scanner Position Normalized Signal"
6292 PRINT " "
6294 FOR I=1 TO Ffrawdata(0,0)
6296 PRINT USING "16X,DDD,10X,M.DDD,15X,MD.3D"; I, Ffrawdata(I,0), Ffrawdata(I,1)
6298 NEXT I
6300 PRINT " "
6302 PRINTER IS CRT
6304 CALL Cleardisplay
6306 GOTO Plotit
6308 !
6310 Print_diff: OFF KEY
6312 IF Ffdiffdata(0,0)=0 THEN
6314 PRINT
6316 PRINT USING "6X,70A"; "Differentiated data has not been calculated. C
an't be printed yet."
6318 GOTO Print_list
6320 END IF
6322 PRINTER IS CRT

```

```

6328 PRINT USING "16X,30,10X,M.3D,15X,MD.3D";I,Ffdiffdata(I,0),Ffdiffdata(I,1)
6330 PRINT " "
6332 FOR I=1 TO Ffdiffdata(0,0)
6334 PRINT USING "16X,30,10X,M.3D,15X,MD.3D";I,Ffdiffdata(I,0),Ffdiffdata(I,1)
6336 NEXT I
6338 PRINT " "
6340 PRINTER IS CRT
6342 CALL Cleardisplay
6344 GOTO Plotit
6346 !
6348 Print_smooth: OFF KEY
6350 IF Fsmoothdata(0,0)=0 THEN
6352 PRINT
6354 PRINT USING "6X,70A";"Smoothed data has not been calculated. Can't b
e printed yet.
6356 GOTO Print_list
6358 END IF
6360 PRINTER IS PRT
6362 PRINT " Far Field Smoothed Data for Fiber:",Ffield_id$
6364 PRINT ""
6366 PRINT USING "15X,48A";"Number Scanner Position Normalized Signal"
6368 PRINT " "
6370 FOR I=1 TO Fsmoothdata(0,0)
6372 PRINT USING "16X,30,10X,M.3D,15X,MD.3D";I,Fsmoothdata(I,0),Fsmoothd
ata(I,1)
6374 NEXT I
6376 PRINT " "
6378 PRINTER IS CRT
6380 CALL Cleardisplay
6382 GOTO Plotit
6384 !
6386 !-----
6388 !
6390 Print_plot: OFF KEY
6392 OUTPUT KBD USING "#,K";"! "
6394 DUMP GRAPHICS
6396 OUTPUT KBD USING "#,K";"! "
6398 GOTO Plotit
6400 !
6402 !-----
6404 !
6406 Exit_all: OFF KEY
6408 CALL Menu
6410 !
6412 Done: OFF KEY
6414 IF Print_flag$="DIFF" THEN
6416 PRINT ""
6418 PRINT "Sorry to deceive you, you can't differentiate this data."
6420 GOTO Plotit
6422 END IF
6424 GCLEAR
6426 GRAPHICS OFF
6428 SUBEND
6430 !
6432 !
6434 SUB Numaper(Print_flag$,Num_aper)
6436 !+*****+
6438 ! COMPUTE RIGOROUS APERTURE MODULE VERSION 2.1
6440 !-*****-
6442 ! This module calculates the fiber NA using a variable threshold method
6444 ! (presently set at 5%). The input data set may either be the rough
6446 ! differentiated data, or a smoothed version of the same.
6448 !
6450 COM Farfield/ Ffield (*),Num points Farfield(*),Ffield id$

```

```

6450 DIM Nadata(200,1)
6458 Threshold=.05 !Use 5% threshold
6460 !
6462 ! First, determine which data to use to calculate the NA.
6464 !
6466 IF Print_flag$="DIFF" THEN
6468 FOR I=0 TO Ffdiffdata(0,0)
6470 FOR J=0 TO 1
6472 Nadata(I,J)=Ffdiffdata(I,J)
6474 NEXT J
6476 NEXT I
6478 END IF
6480 !
6482 IF Print_flag$="SMOOTH" THEN
6484 FOR I=0 TO fsmoothdata(0,0)
6486 FOR J=0 TO 1
6488 Nadata(I,J)=Fsmoothdata(I,J)
6490 NEXT J
6492 NEXT I
6494 END IF
6496 !
6498 ! Next, locate the 15% points to be sure we are off the noise floor.
6500 !
6502 Num_aper=0
6504 Index=1
6506 WHILE Nadata(Index,1)<.15
6508 Index=Index+1
6510 IF Index>Nadata(0,0) THEN Done
6512 END WHILE
6514 !
6516 ! Next, search backward to the threshold crossing.
6518 !
6520 WHILE Nadata(Index,1)>Threshold
6522 Index=Index-1
6524 IF Index<1 THEN Done
6526 END WHILE
6528 !
6530 ! Compute a crossing using linear interpolation.
6532 !
6534 Sin1=Nadata(Index,0)+(Nadata(Index+1,0)-Nadata(Index,0))*(Threshold-Nadata(Index,1))/(Nadata(Index+1,1)-Nadata(Index,1))
6536 !
6538 ! Finally, start at the 15% level, and search forward to the
6540 ! next interpolated threshold crossing.
6542 !
6544 Index=Index+1
6546 WHILE Nadata(Index,1)>Threshold
6548 Index=Index+1
6550 IF Index>Nadata(0,0) THEN Done
6552 END WHILE
6554 Sin2=Nadata(Index,0)+(Nadata(Index-1,0)-Nadata(Index,0))*(1-Threshold-Nadata(Index,1))/(Nadata(Index-1,1)-Nadata(Index,1))
6556 Num_aper=SIN((ASN(Sin2)-ASN(Sin1))/2)
6558 Done:SUBEND
6560 !
6562 !
6564 SUB Menu
6566 !+*****+
6568 !+ MENU MODULE VERSION 2.1P
6570 !-*****-
6572 COM /Addition/ Curr_wave,Gratings(*),Cur_grating,Wave_step
6574 DIM M$(1:5,1:8)[40],K$(1:5,1:8)[16],Title$(40)
6576 INTEGER First,Last,Temp! variables used for selecting wave length! : 2000

```

```

6584 The following images are for the menu prompts.
6586 |
6588 Headimage:IMAGE 14X,"KEY",9X,"FUNCTION" |Headings (underlined)
6590 Keyimage:IMAGE 14X,"f",D,10X,40A |Unshifted keys
6592 |
6594 |-----
6596 |-----
6598 |
6600 |The following data statements are for the menu prompts.
6602 |
6604 |-----
6606 |
6608 | FIRST MENU
6610 |
6612 DATA RUN FIBER TESTS,PRINT PROGRAM LISTING,EXAMINE SYSTEM DATA,EQUIPMENT
PRE-SET
6614 DATA Set Time and Date,Save Results (ARCHIVE),Retrieve Archived Data,Res
tart Program
6616 |
6618 |-----
6620 |
6622 | SECOND MENU
6624 |
6626 DATA RETURN TO MAIN MENU,LOAD FIBER AND IDENTIFY,FIBER INPUT ALIGN,FIBER
OUTPUT ALIGN
6628 DATA Fiber Test 1: SPECTRAL ATTENUATION,Fiber Test 2: DIFFERENTIAL M
ODAL ATTEN,Fiber Test 3/4: FAR FIELD (edge/pinhole)
6630 DATA Fiber Test 5: NEAR FIELD (Inactive)
6632 |
6634 |-----
6636 |
6638 | THIRD MENU
6640 |
6642 DATA RETURN TO MAIN MENU,RETURN TO FIBER TEST MENU,LOAD FIBER AND IDENTI
FY,Run FAR FIELD-pinhole (low loss fiber)
6644 DATA Run FAR FIELD-edge (higher loss fiber),Recall data from previous te
st,not used,not used
6646 |
6648 |-----
6650 |
6652 | FOURTH MENU
6654 |
6656 DATA " RETURN TO MAIN MENU"," 800 nm to 1800 nm (Grating 1)"
6658 DATA "1800 nm to 2700 nm (Grating 2)","2700 nm to 4000 nm (Grating 3)"
6660 DATA "800 nm to 4000 nm (Full Spectral Range)","Recall data from previous
s test"
6662 DATA "Change wavelength stepping increment","Enter your own wavelength r
ange"
6664 |
6666 |-----
6668 |
6670 | FIFTH MENU
6672 |
6674 DATA " RETURN TO MAIN MENU"," 800 nm to 1800 nm (Grating 1)"
6676 DATA "1800 nm to 2700 nm (Grating 2)","2700 nm to 4000 nm (Grating 3)"
6678 DATA "800 nm to 4000 nm (Full Spectral Range)","Recall data from previous
s test"
6680 DATA "Change wavelength stepping increment","Enter your own wavelength r
ange"
6682 READ M$(*)
6684 |
6686 |-----
6688 |-----
6689 |

```

```

6696 | are organized into one per menu.
6698 |
6700 | -----
6702 | -----
6704 |
6706 | FIRST MENU KEY LABELS, 9817 MAIN MENU
6708 |
6710 Data17: DATA " FIBER TESTS",PROGRAM LISTING,SYSTEM DATA,PRESET EQUIPMN
T,SET TIME& DATE,ARCHIVE,RETRIEVE,"RESTART PROGRAM"
6712 |
6714 | -----
6716 |
6718 | SECOND MENU KEY LABELS, 9817 FIBER TESTS MENU
6720 |
6722 DATA " MAIN MENU"," LOAD FIBER"," INPUT ALIGN"," OUTPUT ALIGN"
,SPECTRAL ATTEN,DIF MODE ATTEN," FAR FIELD","NEAR FLDINACTIVE"
6724 |
6726 | -----
6728 |
6730 | THIRD MENU KEY LABELS, 9817 FAR FIELD MENU
6732 |
6734 DATA " MAIN MENU"," TEST MENU"," LOAD FIBER","PIN HOLE(silica
)," EDGE (usual)"," RECALL DATA"," ",""
6736 |
6738 | -----
6740 |
6742 | FOURTH MENU KEY LABELS, 9817 DMA MENU
6744 |
6746 DATA " MAIN MENU",GRATING 1,GRATING 2,GRATING 3,GRATINGS 1/
2/3," RECALL DATA",WAVELEN STEP," USER DEFINED"
6748 |
6750 | -----
6752 |
6754 | FIFTH MENU KEY LABELS, 9817 SPECTRAL ATTENUATION MENU
6756 |
6758 DATA " MAIN MENU",GRATING 1,GRATING 2,GRATING 3,GRATINGS 1/
2/3," RECALL DATA",WAVELEN STEP," USER DEFINED"
6760 |
6762 | -----
6764 |
6766 STATUS KBD,9:Key_id !Determine that the computer is in fact the 9817
6768 IF BIT(Key_id,5) THEN RESTORE Data17
6770 READ K$(*)
6772 GOSUB Cln_screen
6774 |
6776 | The following section creates the various menus.
6778 |
6780 Menu_1:Menu_num=1
6782 Title$="NRL IR FIBER CHARACTERIZATION SYSTEM"
6784 Curr_wave_step=Wave_step
6786 GOSUB Draw_box1 !Draw the menu picture
6788 BEEP
6790 ALPHA ON
6792 GRAPHICS ON
6794 ON KEY 0 LABEL "" GOTO Update_time
6796 ON KEY 1 LABEL K$(1,1) GOTO Key1_1
6798 ON KEY 2 LABEL K$(1,2) GOTO Key1_2
6800 ON KEY 3 LABEL K$(1,3) GOTO Key1_3
6802 ON KEY 4 LABEL K$(1,4) GOTO Key1_4
6804 ON KEY 5 LABEL K$(1,5) GOTO Key1_5
6806 ON KEY 6 LABEL K$(1,6) GOTO Key1_6
6808 ON KEY 7 LABEL K$(1,7) GOTO Key1_7
6810 ON KEY 8 LABEL K$(1,8) GOTO Key1_8
6812 ON KEY 9 LABEL "" GOTO Update_time

```

```

6810     GOTO Update_time
6820  !
6822 Menu_2: Title$=" FIBER TEST MENU"
6824     Menu_num=2
6826     GOSUB Draw_box2           !Draw the menu picture
6828     BEEP
6830     ALPHA ON
6832     GRAPHICS ON
6834     ON KEY 0 LABEL "" GOTO Update_time
6836     ON KEY 1 LABEL K$(2,1) GOTO Key2_1
6838     ON KEY 2 LABEL K$(2,2) GOTO Key2_2
6840     ON KEY 3 LABEL K$(2,3) GOTO Key2_3
6842     ON KEY 4 LABEL K$(2,4) GOTO Key2_4
6844     ON KEY 5 LABEL K$(2,5) GOTO Key2_5
6846     ON KEY 6 LABEL K$(2,6) GOTO Key2_6
6848     ON KEY 7 LABEL K$(2,7) GOTO Key2_7
6850     ON KEY 8 LABEL K$(2,8) GOTO Key2_8
6852     ON KEY 9 LABEL "" GOTO Update_time
6854     GOTO Update_time
6856  !
6858 Menu_3: Title$="FAR FIELD MENU"
6860     Menu_num=3
6862     GOSUB Draw_box3
6864     BEEP
6866     ALPHA ON
6868     GRAPHICS ON
6870     ON KEY 0 LABEL "" GOTO Update_time
6872     ON KEY 1 LABEL K$(3,1) GOTO Key3_1
6874     ON KEY 2 LABEL K$(3,2) GOTO Key3_2
6876     ON KEY 3 LABEL K$(3,3) GOTO Key3_3
6878     ON KEY 4 LABEL K$(3,4) GOTO Key3_4
6880     ON KEY 5 LABEL K$(3,5) GOTO Key3_5
6882     ON KEY 6 LABEL K$(3,6) GOTO Key3_6
6884     ON KEY 7 LABEL K$(3,7) GOTO Key3_7
6886     ON KEY 8 LABEL K$(3,8) GOTO Key3_8
6888     ON KEY 9 LABEL "" GOTO Update_time
6890     GOTO Update_time
6892  !
6894 Menu_4: Title$="DIFFERENTIAL MODAL ATTENUATION"
6896     Menu_num=4
6898     GOSUB Draw_box4
6900     PRINT
6902     PRINT
6904     PRINT USING "26X,28A,3D,3A"; "Current Wavelength step is:", Curr_wave_step
        , " nm"
6906     BEEP
6908     ALPHA ON
6910     GRAPHICS ON
6912     ON KEY 0 LABEL "" GOTO Update_time
6914     ON KEY 1 LABEL K$(4,1) GOTO Key4_1
6916     ON KEY 2 LABEL K$(4,2) GOTO Key4_2
6918     ON KEY 3 LABEL K$(4,3) GOTO Key4_3
6920     ON KEY 4 LABEL K$(4,4) GOTO Key4_4
6922     ON KEY 5 LABEL K$(4,5) GOTO Key4_5
6924     ON KEY 6 LABEL K$(4,6) GOTO Key4_6
6926     ON KEY 7 LABEL K$(4,7) GOTO Key4_7
6928     ON KEY 8 LABEL K$(4,8) GOTO Key4_8
6930     ON KEY 9 LABEL "" GOTO Update_time
6932     GOTO Update_time
6934  !
6936 Menu_5: Title$="SPECTRAL ATTENUATION MENU"
6938     Menu_num=5
6940     GOSUB Draw_box5

```

```

6948 BEEP
6950 ALPHA ON
6952 GRAPHICS ON
6954 ON KEY 0 LABEL "" GOTO Update_time
6956 ON KEY 1 LABEL K$(5,1) GOTO Key5_1
6958 ON KEY 2 LABEL K$(5,2) GOTO Key5_2
6960 ON KEY 3 LABEL K$(5,3) GOTO Key5_3
6962 ON KEY 4 LABEL K$(5,4) GOTO Key5_4
6964 ON KEY 5 LABEL K$(5,5) GOTO Key5_5
6966 ON KEY 6 LABEL K$(5,6) GOTO Key5_6
6968 ON KEY 7 LABEL K$(5,7) GOTO Key5_7
6970 ON KEY 8 LABEL K$(5,8) GOTO Key5_8
6972 ON KEY 9 LABEL "" GOTO Update_time
6974 GOTO Update_time
6976 !
6978 ! A key press from any menu causes the program to branch to a point below:
6980 !
6982 !First menu branches.
6984 Key1_1:GOSUB Clr_screen
6986 GOTO Menu_2 ! Go to the next menu
6988 Key1_2:GOSUB Clr_screen
6990 CALL Proglst ! Examine serial number
6992 GOTO Menu_1 ! Go nowhere, and fast
6994 Key1_3:GOSUB Clr_screen
6996 CALL Systemdata ! Examine/modify system data
6998 CALL Serialno
7000 GOTO Menu_1
7002 Key1_4:GOSUB Clr_screen
7004 CALL Preset ! Pre-set the system equipment
7006 GOTO Menu_1
7008 Key1_5:GOSUB Clr_screen
7010 CALL Timeset ! Set the time and date
7012 GOTO Menu_1
7014 Key1_6:GOSUB Clr_screen
7016 CALL Archive ! Archive test results
7018 GOTO Menu_1
7020 Key1_7:GOSUB Clr_screen
7022 CALL Retrieve ! Retrieve archived test results
7024 GOTO Menu_1
7026 Key1_8:GOSUB Clr_screen
7028 GOTO Done ! Exit MAINPROG
7030 GOTO Menu_1
7032 !
7034 !Second menu branches.
7036 Key2_1:GOSUB Clr_screen
7038 GOTO Menu_1 ! Return to main menu
7040 Key2_2:GOSUB Clr_screen
7042 CALL Fibertest6 ! Run Fiberload routine
7044 GOTO Menu_2 ! Return to Fiber Test menu
7046 Key2_3:GOSUB Clr_screen
7048 CALL Inalign ! Align input fiber end
7050 GOTO Menu_2 ! Return to Fiber Test menu
7052 Key2_4:GOSUB Clr_screen
7054 CALL Outalign ! Align output fiber end
7056 GOTO Menu_2 ! Return to Fiber Test menu
7058 Key2_5:GOSUB Clr_screen
7060 GOSUB Menu_5 ! Go to Spectral Attenuation menu
7062 Key2_6:GOSUB Clr_screen
7064 GOSUB Menu_4 ! Go to DMA menu
7066 Key2_7: GOSUB Clr_screen
7068 GOTO Menu_3 ! Go to Far Field menu
7070 Key2_8:GOSUB Clr_screen

```

```

7080 Key3_1:GOSUB Clr_screen
7082     GOTO Menu_1
7084 Key3_2:GOSUB Clr_screen
7086     GOTO Menu_2
7088 Key3_3:GOSUB Clr_screen
7090     CALL Fibertest6
7092     GOTO Menu_3
7094 Key3_4:GOSUB Clr_screen
7096     CALL Fibertest4
7098     GOTO Menu_3
7100 Key3_5:GOSUB Clr_screen
7102     CALL Fibertest3(0)
7104     GOTO Menu_3
7106 Key3_6:GOSUB Clr_screen
7108     Source_flag=FNDatasource
7110     CALL Cleardisplay
7112     CALL Fibertest3(Source_flag)
7114     GOTO Menu_3
7116 Key3_7:GOSUB Clr_screen
7118     GOTO Menu_3
7120 Key3_8:GOSUB Clr_screen
7122     GOTO Menu_3
7124 !
7126 !Fourth menu branches.
7128 Key4_1: GOSUB Clr_screen
7130     GOTO Menu_1
7132 Key4_2: GOSUB Clr_screen
7134     Specwaves("800 TO 1798 STEP "&VAL$(Curr_wave_step))
7136     CALL Fibertest2(0)
7138     GOTO Menu_4
7140 Key4_3: GOSUB Clr_screen
7142     Specwaves("1800 TO 2698 STEP "&VAL$(Curr_wave_step))
7144     CALL Fibertest2(0)
7146     GOTO Menu_4
7148 Key4_4: GOSUB Clr_screen
7150     Specwaves("2700 TO 4000 STEP "&VAL$(Curr_wave_step))
7152     CALL Fibertest2(0)
7154     GOTO Menu_4
7156 Key4_5: GOSUB Clr_screen
7158     Specwaves("800 TO 4000 STEP "&VAL$(Curr_wave_step))
7160     CALL Fibertest2(0)
7162     GOTO Menu_4
7164 Key4_6: GOSUB Clr_screen
7166     Source_flag=FNDatasource
7168     CALL Cleardisplay
7170     CALL Fibertest2(Source_flag)
7172     RETURN
7174 Key4_7: GOSUB Clr_screen
7176     Curr_wave_step=FNGetint("Enter new wavelength stepping increment (20-200): ",10,200)
7178     GOSUB Clr_screen
7180     GOTO Menu_4
7182 Key4_8: GOSUB Clr_screen
7184     First=FNGetint("Enter First Wavelength (600-4000 nm): ",600,4000)
7186     Last=FNGetint("Enter Last Wavelength (600-4000 nm): ",600,4000)
7188     IF Last<First THEN
7190         Temp=First
7192         First=Last
7194         Last=Temp
7196     END IF
7198     Specwaves(VAL$(First)&" TO "&VAL$(Last)&" STEP "&VAL$(Curr_wave_step))
7200     GOSUB Clr_screen

```

```

7210 Key5_1: CALL Cleardisplay           !Return to main menu
7212     GOTO Menu_1
7214     RETURN
7216 Key5_2: CALL Cleardisplay           !Wavelength range for next test
7218     Specwaves("800 TO 1798 STEP "&VAL$(Curr_wave_step))
7220     CALL Fibertest1(0)              !Source_flag=0; run new test
7222     GOTO Menu_5
7224 Key5_3: CALL Cleardisplay
7226     Specwaves("1800 TO 2698 STEP "&VAL$(Curr_wave_step))
7228     CALL Fibertest1(0)              !Source_flag=0; new test
7230     GOTO Menu_5
7232 Key5_4: CALL Cleardisplay
7234     Specwaves("2700 TO 4000 STEP "&VAL$(Curr_wave_step))
7236     CALL Fibertest1(0)              !Source_flag=0; new test
7238     GOTO Menu_5
7240 Key5_5: CALL Cleardisplay
7242     Specwaves("800 TO 4000 STEP "&VAL$(Curr_wave_step))
7244     CALL Fibertest1(0)              !Source_flag=0; new test
7246     GOTO Menu_5
7248 Key5_6: CALL Cleardisplay           !Retrieve data
7250     Source_flag=FNDatasource         !First determine the source
7252     CALL Cleardisplay               !Clear data query from screen
7254     CALL Fibertest1(Source_flag)    !Review data from within test
7256     RETURN
7258 Key5_7: CALL Cleardisplay
7260     Curr_wave_step=FNGetint("Enter new wavelength stepping increment (20-200
): ",10,200)
7262     CALL Cleardisplay
7264     GOTO Menu_5
7266 Key5_8: CALL Cleardisplay
7268     First=FNGetint("Enter First Wavelength (600-4000 nm): ",600,4000)
7270     Last=FNGetint("Enter Last Wavelength (600-4000 nm): ",600,4000)
7272     IF Last<First THEN
7274         Temp=First
7276         First=Last
7278         Last=Temp
7280     END IF
7282     Specwaves(VAL$(First)&" TO "&VAL$(Last)&" STEP "&VAL$(Curr_wave_step))
7284     CALL Cleardisplay
7286     CALL Fibertest1                  !Source_flag=0; new test
7288     GOTO Menu_5
7290     !
7292     ! This part of the subroutine clears the screen:
7294     !
7296     Clr_screen: !
7298         OFF KEY
7300         DISP " "
7302         OUTPUT KBD USING "#,K";"K"
7304         GCLEAR
7306         RETURN
7308     !
7310     ! This part of subroutine prints the current time and date on the menu:
7312     !
7314     Update_time:Date$=FNTimedate$
7316     CONTROL CRT,1;5
7318     CONTROL CRT,0;65
7320     OUTPUT CRT;Date$[1,POS(Date$," ")]
7322     CONTROL CRT,1;6
7324     CONTROL CRT,0;65
7326     OUTPUT CRT;Date$[POS(Date$," ")^1,LEN(Date$)]
7328     GOTO Update_time

```

```

7340 WINDOW 0,100*RATIO,0,100
7342 FOR Delta=0 TO .8 STEP .8
7344     MOVE Delta*RATIO/1.3,12+Delta
7346     DRAW Delta*RATIO/1.3,92-Delta
7348     DRAW 10*RATIO/1.3,92-Delta
7350     IMOVE 0,-3
7352     IDRAW 0,8
7354     IDRAW 111*RATIO/1.3,0
7356     IDRAW 0,-8
7358     IDRAW -111*RATIO/1.3,0
7360     MOVE 121*RATIO/1.3,92-Delta
7362     DRAW (130-Delta)*RATIO/1.3,92-Delta
7364     DRAW (130-Delta)*RATIO/1.3,12+Delta
7366     DRAW Delta*RATIO/1.3,12+Delta
7368 NEXT Delta
7370 CSIZE 5,.60
7372 FOR Delta=0 TO .3 STEP .2
7374     MOVE 10.5*RATIO/1.3,90
7376     IMOVE Delta*RATIO/1.3,0
7378     LABEL Titles$
7380 NEXT Delta
7382 ! Time, date, and title:
7384 CONTROL CRT,1;5
7386 CONTROL CRT,0;59
7388 OUTPUT CRT;"DATE:"
7390 CONTROL CRT,1;6
7392 CONTROL CRT,0;59
7394 OUTPUT CRT;"TIME:"
7396 CONTROL CRT,1;7
7398 OUTPUT CRT USING Headimage
7400 CONTROL CRT,1;9
7402 GOTO Box_end
7404 !
7406 Draw_box2:                                !Draw background for Fiber Tests Menu
7408     GINIT
7410     WINDOW 0,100*RATIO,0,100
7412     FOR Delta=0 TO .8 STEP .8
7414         MOVE Delta*RATIO/1.3,12+Delta
7416         DRAW Delta*RATIO/1.3,92-Delta
7418         DRAW 40*RATIO/1.3,92-Delta
7420         IMOVE 0,-3
7422         IDRAW 0,8
7424         IDRAW 50*RATIO/1.3,0
7426         IDRAW 0,-8
7428         IDRAW -50*RATIO/1.3,0
7430         MOVE 90*RATIO/1.3,92-Delta
7432         DRAW (130-Delta)*RATIO/1.3,92-Delta
7434         DRAW (130-Delta)*RATIO/1.3,12+Delta
7436         DRAW Delta*RATIO/1.3,12+Delta
7438     NEXT Delta
7440     FOR Delta=0 TO .3 STEP .05
7442         CSIZE 7
7444         MOVE 0,93
7446         IMOVE Delta*RATIO/1.3,Delta
7448         LABEL "FOA-2000"
7450         CSIZE 4
7452         MOVE 95,93
7454         IMOVE Delta*RATIO/1.3,Delta/10
7456         LABEL "PK - UPI"
7458     NEXT Delta
7460     CSIZE 5,.58
7462     FOR Delta=0 TO .3 STEP .2

```

```

7470 NEXT Delta
7472 ! Time, date, and title:
7474 CONTROL CRT,1:5
7476 CONTROL CRT,0:59
7478 OUTPUT CRT;"DATE:"
7480 CONTROL CRT,1:6
7482 CONTROL CRT,0:59
7484 OUTPUT CRT;"TIME:"
7486 CONTROL CRT,1:7
7488 OUTPUT CRT USING Headimage
7490 CONTROL CRT,1:9
7492 GOTO Box_end
7494 !
7496 Draw_box3:                                !Draw background for Far Field menu
7498 GINIT
7500 WINDOW 0,100*RATIO,0,100
7502 FOR Delta=0 TO .8 STEP .8
7504     MOVE Delta*RATIO/1.3,12+Delta
7506     DRAW Delta*RATIO/1.3,92-Delta
7508     DRAW 42*RATIO/1.3,92-Delta
7510     IMOVE 0,-3
7512     IDRAW 0,8
7514     IDRAW 48*RATIO/1.3,0
7516     IDRAW 0,-8
7518     IDRAW -48*RATIO/1.3,0
7520     MOVE 90*RATIO/1.3,92-Delta
7522     DRAW (130-Delta)*RATIO/1.3,92-Delta
7524     DRAW (130-Delta)*RATIO/1.3,12+Delta
7526     DRAW Delta*RATIO/1.3,12+Delta
7528 NEXT Delta
7530 CSIZE 5,.58
7532 FOR Delta=0 TO .3 STEP .2
7534     MOVE 45.0*RATIO/1.3,90
7536     IMOVE Delta*RATIO/1.3,0
7538 LABEL Title$
7540 NEXT Delta
7542 ! Time, date, and title:
7544 CONTROL CRT,1:5
7546 CONTROL CRT,0:59
7548 OUTPUT CRT;"DATE:"
7550 CONTROL CRT,1:6
7552 CONTROL CRT,0:59
7554 OUTPUT CRT;"TIME:"
7556 CONTROL CRT,1:6
7558 OUTPUT CRT USING Headimage
7560 CONTROL CRT,1:8
7562 GOTO Box_end
7564 !
7566 Draw_box4:                                !Draw background for DMA menu
7568 GINIT
7570 WINDOW 0,100*RATIO,0,100
7572 FOR Delta=0 TO .8 STEP .8
7574     MOVE Delta*RATIO/1.3,12+Delta           !Go to lower left corner of screen
7576     DRAW Delta*RATIO/1.3,92-Delta          !Draw line up left side of screen
7578     DRAW 20*RATIO/1.3,92-Delta             !Draw right, towards middle,top
7580     IMOVE 0,-3                             !Move down a bit
7582     IDRAW 0,8                             !Draw up, l. side of label box
7584     IDRAW 95*RATIO/1.3,0                   !Draw right, over menu label
7586     IDRAW 0,-8                             !Draw down, r. side of label box
7588     IDRAW -95*RATIO/1.3,0                 !Draw left, under menu label
7590     MOVE 115*RATIO/1.3,92-Delta           !Move to center/right of label box
7592     DRAW (130-Delta)*RATIO/1.3,92-Delta   !Draw to right edge of screen
7594     DRAW (130-Delta)*RATIO/1.3,12+Delta   !Draw down right side of screen
7596     DRAW Delta*RATIO/1.3,12+Delta         !Draw up left side of label box

```

```

7602     FOR Delta=0 TO .3 STEP .1
7604         MOVE 24.0*RATIO/1.3,90
7606         IMOVE Delta*RATIO/1.3,0
7608         LABEL Titles$
7610     NEXT Delta
7612     ! Time, date, and title:
7614     CONTROL CRT,1;5
7616     CONTROL CRT,0;59
7618     OUTPUT CRT;"DATE:"
7620     CONTROL CRT,1;6
7622     CONTROL CRT,0;59
7624     OUTPUT CRT;"TIME:"
7626     CONTROL CRT,1;6
7628     OUTPUT CRT USING Headimage
7630     CONTROL CRT,1;8
7632     GOTO Box_end
7634     !
7636 Draw_box5:                                !Draw background for Spectral Attenuation menu
7638     GINIT
7640     WINDOW 0,100*RATIO,0,100
7642     FOR Delta=0 TO .8 STEP .8
7644         MOVE Delta*RATIO/1.3,12+Delta
7646         DRAW Delta*RATIO/1.3,92-Delta
7648         DRAW 25*RATIO/1.3,92-Delta
7650         IMOVE 0,-3
7652         IDRAW 0,8
7654         IDRAW 77*RATIO/1.3,0
7656         IDRAW 0,-8
7658         IDRAW -77*RATIO/1.3,0
7660         MOVE 102*RATIO/1.3,92-Delta
7662         DRAW (130-Delta)*RATIO/1.3,92-Delta
7664         DRAW (130-Delta)*RATIO/1.3,12+Delta
7666         DRAW Delta*RATIO/1.3,12+Delta
7668     NEXT Delta
7670     CSIZE 5,.58
7672     FOR Delta=0 TO .3 STEP .2
7674         MOVE 26.5*RATIO/1.3,90
7676         IMOVE Delta*RATIO/1.3,0
7678         LABEL Titles$
7680     NEXT Delta
7682     ! Time, date, and title:
7684     CONTROL CRT,1;5
7686     CONTROL CRT,0;59
7688     OUTPUT CRT;"DATE:"
7690     CONTROL CRT,1;6
7692     CONTROL CRT,0;59
7694     OUTPUT CRT;"TIME:"
7696     CONTROL CRT,1;6
7698     OUTPUT CRT USING Headimage
7700     CONTROL CRT,1;8
7702     !
7704 Box_end: !
7706     FOR I=1 TO 4
7708         IF BIT(Key_id,5) THEN
7710             OUTPUT CRT USING Keyimage,I,M$(Menu_num,I)
7712         ELSE
7714             OUTPUT CRT USING Skeyimage,I,M$(Menu_num,I)
7716         END IF
7718     NEXT I
7720     OUTPUT CRT
7722     FOR I=5 TO 8
7724         OUTPUT CRT USING Keyimage,I,M$(Menu_num,I)
7726     NEXT I

```

!Move to where title is to begin'

```

7736 |
7738 SUB Serialno
7740 |*****
7742 | See Machine Serial Numbers
7744 |*****
7746 COM /Sysdata/ Serial_num$,Lasers(*),Filter_flag,Filter(*),Num_focus,Focu
s(*),Cutoff,Low_wave,High_wave,Det_switch
7748 |
7750 OUTPUT KBD USING "#,K";"K"
7752 PRINT TABXY(5,10);" Machine Serial Number: "&Serial_num$
7754 |
7756 ON KEY 5 LABEL "PROCEED" GOTO Done
7758 Waiter:GOTO Waiter
7760 Done:SUBEND
7762 |
7764 |
7766 DEF FNGetint(Prompt$,Lo,Hi)
7768 |*****+
7770 | FNGetint: for inputting integer values
7772 |*****-
7774 INTEGER Value,I
7776 DIM Inp$(80)
7778 |
7780 | Prompts the user for an integer with the prompt Prompt$.
7782 | Data entry is forced to a positive integer within the range of
7784 | Lo & Hi, inclusively.
7786 |
7788 Get_it:PRINT Prompt$;
7790 LINPUT Inp$
7792 Inp$=TRIM$(Inp$)
7794 PRINT Inp$
7796 IF LEN(Inp$)>5 OR LEN(Inp$)=0 THEN GOTO Bad_inp
7798 IF LEN(Inp$)=5 AND Inp$>"32767" THEN GOTO Bad_inp
7800 I=1
7802 WHILE (I<=LEN(Inp$))
7804 IF Inp$[I;1]<"0" OR Inp$[I;1]>"9" THEN GOTO Bad_inp
7806 I=I+1
7808 END WHILE
7810 Value=VAL(Inp$)
7812 IF Value<Lo OR Value>Hi THEN GOTO Bad_inp
7814 RETURN Value
7816 Bad_inp: PRINT
7818 PRINT "You must enter an integer value between ";Lo;
7820 PRINT "and ";Hi; ", inclusive."
7822 PRINT
7824 GOTO Get_it
7826 FNEND
7828 |
7830 |
7832 DEF FNGrating(Wavelen)
7834 |*****+
7836 | FNGrating(Wavelen): This determines which grating is required for
7838 | a wavelength specified in the calling routine.
7840 |*****-
7842 COM /Addition/ Curr_wave,Gratings(*),Cur_grating,Wave_step
7844 INTEGER I
7846 |
7848 FOR I=Gratings(0) TO 1 STEP -1
7850 IF Gratings(I)<=Wavelen THEN RETURN (I)
7852 NEXT I
7854 RETURN (-1)! Unknown grating setting
7856 FNEND

```

```

7866 | REQUEST ALIGNMENT ROUTINE
7868 |-----
7870 | This routine gives the user the option of bypassing the alignment.
7872 | DISP "Do the fiber ends need to be aligned?"
7874 | BEEP
7876 | ON KEY 1 LABEL "YES" GOTO Align
7878 | ON KEY 5 LABEL "NO" GOTO Done
7880 | Infinite:GOTO Infinite
7882 | Align: |
7884 | OFF KEY
7886 | OUTPUT KBD USING "#,K"."K"
7888 | DISP
7890 | CALL Fibertype
7892 | CALL Inalign
7894 | CALL Outalign
7896 | Done: |
7898 | OFF KEY
7900 | DISP
7902 | OUTPUT KBD USING "#,K";"K"
7904 | SUBEND
7906 |
7908 |
7910 | SUB Init_foa_ctrl
7912 | +-----+
7914 | | FOA-2000 new commands for IR detectors and multi-grating monochromator
7916 | |-----|
7918 | COM /Ipaths/ @Foa2000,@Egg5205,@Tek7854,@Bncdelay,Printer_add
7920 | COM /Addition/ Curr_wave,Gratings(*),Cur_grating,Wave_step
7922 |
7924 | CALL F2000send("INZ SEL -4000 -RANGE | 4000 +RANGE | >MTAB",1)
7926 |
7928 | | NOTE: the routines below are written in FORTH, the native operating
7930 | | system for the Z-80 processor card inside the FOA-2000 control box.
7932 | | For more information, see a text on the FORTH language.
7934 | |
7936 | | Change the monochromator's motor table to reflect the different mono.
7938 | | ' M+ | changes the motor step routine's address to run the mono in
7940 | | the other direction.
7942 | | 1 MPY | is the multiplicative display scaling factor.
7944 | | 12 DIV | is the display scaling divisor. DIV will change with the
7946 | | selected gratings (see the GRAT? commands below). This one is
7948 | | the value for grating #1.
7950 | | -32000 FTARG | is the distance to look backwards (in motor steps)
7952 | | for the optical sensor edge when trying to locate the monochrom's
7954 | | zero order window.
7956 | | >MTAB copies the data into the permanent motor table
7958 | | -32700 -RANGE | allows the moves in complete range forward and back.
7960 | |
7962 | CALL F2000send("WAV SEL ' M+ DIR ' 1 MPY | 12 DIV | -12000 FTARG | MTAB
7964 | ",1)
7966 | CALL F2000send("WAV SEL -32700 -RANGE | 32700 +RANGE | 1 SENS | MTAB",1)
7968 |
7970 | | 0 SCX | allows us to define the new commands below
7972 | CALL F2000send("0 SCX |",1)
7974 |
7976 | | Since the computer does not yet know what grating the monochromator
7978 | | is turned to, set current wavelength to -1 (unknown)
7980 | Cur_grating=0
7982 | Curr_wave=-1
7984 |
7986 | | Define the gratings installed in the system

```

```

7994 Gratings(2)=1800 ! grating 2 for >=1800 nm but <2700 nm
7996 Gratings(3)=2700 ! grating 3 for >=2700 nm
7998 !
8000 ! Set default wavelength step for spectral atten. & diff. modal atten.
8002 !
8004 Wave_step=10
8006 !
8008 ! The new command MARKSTART is a dummy to mark where the new commands
8010 ! start in RAM. If this routine has already been called, then we
8012 ! will recover the RAM already used by FORGETting the defined commands
8014 ! and re-defining them. If this routine hasn't been called yet, then
8016 ! FORGET MARKSTART will produce, an error. This is OK, but we can't
8018 ! use the F2000send routine, since it will trap the error.
8020 !
8022 OUTPUT @Foa2000;"FORGET MARKSTART"
8024 Wait: Statbyt=SPOLL(@Foa2000) !THIS WILL THROW AWAY TH' ERROR ON POWER-U
P
8026 IF BIT(Statbyt,4) THEN Wait
8028 CALL F2000send(":" MARKSTART ";" ,1)
8030 !
8032 ! This is the zero order find routine for the monochromator
8034 !
8036 CALL F2000send(":" FIND89 LOC @ 60 OVER +- - GOTO @ LOC ! FTARG @ DARK IF
MER7 THEN LOC @ " ,1)
8038 CALL F2000send("120 OVER +- - LIGHT IF MER7 THEN >FOUND RESEL ;" ,1)
8040 CALL F2000send(":" FIND88 @ LOC ! 40 LIGHT IF -40 LIGHT IF MER7 THEN THEN
@ LOC ! FTARG @ " ,1)
8042 CALL F2000send("DARK IF @ LOC ! FTARG @ DARK IF MER7 THEN THEN FDLY @ MI
NDLY ! FIND89 ;" ,1)
8044 CALL F2000send(":" @SEEK WAV SEL FIND88 @ FOUND ! ;" ,1)
8046 !
8048 ! These are the commands to set the controller to understand the grating
8050 ! it's trying to run. GRAT1 is the command for grating #1, etc.
8052 !
8054 CALL F2000send(":" GRAT1 WAV SEL 12 DIV ! >MTAB ;" ,1)
8056 CALL F2000send(":" GRAT2 WAV SEL 6 DIV ! >MTAB ;" ,1)
8058 CALL F2000send(":" GRAT3 WAV SEL 3 DIV ! >MTAB ;" ,1)
8060 !
8062 ! The command CUTLOC converts motor steps into wavelength. THIS SHOULD
8064 ! NOT BE USED OVER GPIB!!!!!!
8066 !
8068 CALL F2000send(":" CUTLOC DIV @ DUP @= IF DROP ELSE / THEN MPY @ DUP @= I
F DROP ELSE * THEN ;" ,1)
8070 !
8072 ! The command CUTWAVE converts wavelength to motor steps. THIS SHOULD
8074 ! NOT BE USED OVER GPIB!!!!!!
8076 !
8078 CALL F2000send(":" CUTWAVE MPY @ DUP @= IF DROP ELSE / THEN DIV @ DUP @=
IF DROP ELSE * THEN ;" ,1)
8080 !
8082 ! The command GETNEARWAV moves the mono near the wavelength desired.
8084 ! If the wavelength is too far away, it will need to be called
8086 ! more than once. If an error occurs, GETNEARWAV returns either 1
8088 ! or -1. If it needs to be called again, it returns 0. If it doesn't
8090 ! need to be called again, it will return -88.
8092 ! THIS COMMAND SHOULDN'T BE USED OVER GPIB!!!!!!
8094 !
8096 CALL F2000send(":" GETNEARWAV LOC @ CUTLOC - DUP ABS 650 > IF LOC @ CUTLO
C SWAP 0< IF 650 - ELSE " ,1)
8098 CALL F2000send("650 + THEN CUTWAVE DUP DUP 32000 > IF DROP DROP 1 ELSE -
2000 < IF DROP 1 ELSE " ,1)
8100 CALL F2000send("MOV IF MER7 1 ELSE 0 THEN THEN THEN 1 IF DROP -88 THEN ;

```

```

8100 ! wavelength according to the current GRAB command.
8108 !
8110 CALL F2000send(": WAVE WAV SEL 20 0 DO DUP GETNEARWAV DUP -88 = ",1)
8112 CALL F2000send("IF DROP 0 LEAVE ELSE IF 1 LEAVE THEN THEN LOOP ",1)
8114 CALL F2000send("IF DROP ELSE CUTWAVE MOV IF MER7 THEN THEN ;",1)
8116 !
8118 ! These two GPIB commands, GERMAIN and INSB, select one of the two
8120 ! detectors on the bench
8122 !
8124 CALL F2000send(": GERMAIN HIGH ;",1)
8126 CALL F2000send(": INSB SILICON APDET ;",1)
8128 !
8130 CALL F2000send(": DELAY 0 DO 255 0 DO LOOP LOOP ;",1)
8132 !CALL F2000send(": GRELS BS1 SEL 1000 MINDLY ! LOC @ 3 AND ",1)
8134 !CALL F2000send("    DUP LOC ! SWAP - GOTO >LEDS ;",1)
8136 CALL F2000send(": GREL BS1 SEL MINDLY ! LOC @ 3 AND ",1)
8138 CALL F2000send("    DUP LOC ! SWAP - GOTO >LEDS ;",1)
8140 CALL F2000send(": TURN 70 1000 GREL 432 50 GREL 32 DELAY -40 1000 GREL ;",1)
8142 CALL F2000send(": 1TO1 WAV SEL 24 DIV ! >MTAB ;",1)
8144 !
8146 ! Disable definition of new forth words
8148 !
8150 CALL F2000send("! SCX !",1)
8152 DISP
8154 SUBEND
8156 !
8158 !
8160 SUB Ffnormalize(Data_flag$)
8162 !+-----+
8164 ! NORMALIZE FAR FIELD DATA: Normalize the farfield pattern with respect
8166 ! to the maximum detected signal.
8168 !-----+
8170 COM /Farfield/ Ffieldval(*),Num_points,Farfield(*),Ffield_id$
8172 COM /Fftempdata/ Ffrawdata(*),Ffdiffdata(*),Ffsmoothdata(*)
8174 !
8176 INTEGER I,J
8178 REAL Maxval
8180 !
8182 Maxval=-32767
8184 CALL Rundisplay("Normalizing far-field pattern.")
8186 !
8188 ! Determine which data set to normalize, then do it.
8190 !
8192 IF Data_flag$="RAW DATA" THEN
8194   FOR I=1 TO Num_points
8196     IF Farfield(I,1)>Maxval THEN Maxval=Farfield(I,1)
8198   NEXT I
8200   FOR I=1 TO Num_points
8202     Farfield(I,1)=Farfield(I,1)/Maxval
8204   NEXT I
8206 END IF
8208 !
8210 IF Data_flag$="DIFF" THEN
8212   FOR I=1 TO Ffdiffdata(0,0)
8214     IF Ffdiffdata(I,1)>Maxval THEN Maxval=Ffdiffdata(I,1)
8216   NEXT I
8218   FOR I=1 TO Ffdiffdata(0,0)
8220     Ffdiffdata(I,1)=Ffdiffdata(I,1)/Maxval
8222   NEXT I
8224 END IF
8226 !
8228 IF Data_flag$="SMOOTH" THEN

```

```

8230      FOR I=1 TO Ffrawdata(0,0)
8238          Ffsmoothdata(I,1)=Ffsmoothdata(I,1)/Maxval
8240      NEXT I
8242  END IF
8244  SUBEND
8246  !
8248  !
8250  SUB Ffdiff
8252  !+*****+
8254  ! Ffdiff: Differentiates integrated farfield pattern that is
8256  !         derived by the knife-edge technique (see note below).
8258  !-*****-
8260  ! This routine is used to differentiate the farfield pattern with respect
8262  ! to sin(theta). Note that differentiation should actually be with
8264  ! respect to the vertical scanner position, but the above method is
8266  ! equivalent (and simpler) because there is a linear relationship between
8268  ! the scanner position and sin(theta), and we are not interested in the
8270  ! magnitude after differentiation since we will normalize anyway.
8272  ! Also note that this routine takes the negative derivative due to the
8274  ! physical motion of the farfield scanner (see the RAW data plot).
8276  !
8278  COM /Fftempdata/ Ffrawdata(*),Ffdiffdata(*),Ffsmoothdata(*)
8280  !
8282  INTEGER I
8284  !
8286  CALL Rundisplay("Differentiating far-field pattern.")
8288  FOR I=2 TO Ffrawdata(0,0)
8290      Ffdiffdata(I-1,0)=Ffrawdata(I,0)
8292      Ffdiffdata(I-1,1)=-(Ffrawdata(I,1)-Ffrawdata(I-1,1))/(Ffrawdata(I,0)-
Ffrawdata(I-1,0))
8294  NEXT I
8296  Ffdiffdata(0,0)=Ffrawdata(0,0) ! Reduce the number of points by 1
8298  !
8300  SUBEND
8302  !
8304  !
8306  SUB Ffcorrect
8308  !+*****+
8310  ! FFCORRECT: This corrects far-field measurements for COS(PHI)
8312  !-*****-
8314  !
8316  COM /Fftempdata/ Ffrawdata(*),Ffdiffdata(*),Ffsmoothdata(*)
8318  !
8320  INTEGER I
8322  REAL Sintheta
8324  !
8326  CALL Rundisplay("Correcting far-field pattern.")
8328  !
8330  FOR I=1 TO Ffdiffdata(0,0)
8332      Sintheta=Ffdiffdata(I,0)
8334      Ffdiffdata(I,1)=Ffdiffdata(I,1)*SQR(1-Sintheta*Sintheta)
8336  NEXT I
8338  !
8340  SUBEND
8342  !
8344  !
8346  DEF FNGetffwave
8348  !+*****+
8350  ! FNGetwave: this function asks the operator for the wavelength for
8352  !         the farfield scan.
8354  !-*****-
8356  COM /Sysdata/ Serial_num$(40),Lasers(*),Filter_flag,Filters(*),Num_focus
,Focus(*),Cutoff,Low_wave,High_wave,Det_switch
8358  PRINT TAB(11); " "

```

```

8364 |
8366 |
8368 SUB Align(Axis$,Step_len,Fail_flag,Min_factor,Accuracy)
8370 |*****+
8372 | FIBER ALIGNMENT MODULE                                     3/8/90
8374 |-----
8376 | This module is called by both Inalign and Outalign. It is responsible
8378 | for the alignment of a single axis only (specified in the call).
8380 |
8382 COM /Align_read/ Reading
8384 REAL Signall
8386 INTEGER Position,Step
8388 |
8390 Step=ABS(Step_len)           !Store the absolute value of step
8392 Maxallowed=.3                !300 mV maximum allowable signal
8394 Att=0                        !Starting attenuator setting
8396 PRINTER IS CRT              !Print out table headings
8398 PRINT " "
8400 PRINT " "
8402 PRINT " "
8404 PRINT USING "7X,7A,6A,3X,14A,4D";"AXIS =",Axis$,"Step length =",Step_len
8406 PRINT " "
8408 PRINT USING "4X,10A,9X,6A,8X,8A";"status","signal","position"
8410 PRINT " -----"
8412 | Define axis and initialize:
8414 CALL F2000send(Axis$[1,POS(Axis$,"-")-1]&Axis$[POS(Axis$,"-")+1;1]&" COU
PL")
8416 |
8418 Start: Position=0           !Come back here only if signal greater than Maxallowed.
8420 Reading=FNVoltmeter(Accuracy) !Get a reading from the 5205/7
8422 PRINT USING "4X,10A,8X,M.DDDDDD,8X,DDDD.D";"INITIAL",Reading,Position
8424 IF Reading>Maxallowed THEN   !Make sure 5205/7 isn't saturated
8426 GOSUB Set_attn
8428 GOTO Start
8430 END IF
8432 |
8434 Signall=Reading              !Store initial signal before moving
8436 Position=Position           !and initial position in case it's max
8438 Position=Position+Step_len   !Increment position by step length
8440 IF Position<-800 OR Position>800 THEN GOTO Failure !Keep in range
8442 CALL F2000send(VAL$(Position)&" "&Axis$,1) !Move to the new position
8444 PRINT " Checking direction"
8446 Reading=FNVoltmeter(Accuracy) !Get another reading from the 5205/7
8448 PRINT USING "4X,11A,7X,M.DDDDDD,8X,DDDD.D";"FIRST STEP",Reading,Position
8450 IF Reading>Maxallowed THEN   !Again check for saturation
8452 GOSUB Set_attn
8454 GOTO Start
8456 END IF
8458 |
8460 | If the signal is getting stronger, keep going in this direction.
8462 | If not, reverse directions and start on the other side of the 1st
8464 | point.
8466 |
8468 IF Reading<Signall THEN
8470 PRINT " Reversing direction"
8472 Step_len=-Step_len           !Step in the other direction
8474 Position=Position+Step_len   !Move back to original position
8476 CALL F2000send(VAL$(Position)&" "&Axis$,1)
8478 ELSE
8480 PRINT " Direction okay"
8482 Signall=Reading              !Store a new max value
8484 Position=Position           !and corresponding position
8486 END IF

```

```

8494 CALL F2000send(VAL$(Position)&" "&Axis$,1)
8496 !
8498 ! Now start looking for the signal to begin decreasing again,
8500 ! indicating that we have passed the maximum level.
8502 !
8504 Reading=FNVoltmeter(Accuracy) !Get a reading from the 5205
8506 IF Reading>Maxallowed THEN !Check again for saturation
8508     GOSUB Set_attn
8510     GOTO Start
8512 END IF
8514 PRINT USING "4X,10A,8X,M.DDDDDD,8X,DDDD.D";"MAX SEARCH",Reading,Position
8516 !
8518 IF Reading>Signal1 THEN !Signal still increasing
8520     PRINT " Signal still increasing"
8522     Signal1=Reading !And put the new level in register
8524     Position1=Position !As well as its position
8526     GOTO Loop1
8528 END IF
8530 !
8532 ! If signal is decreasing, keep moving past the peak until signal is
8534 ! some percentage of the max value to avoid peaking on a noise spike:
8536 !
8538 IF Reading>Min_factor*Signal1 THEN GOTO Loop1
8540 CALL F2000send(VAL$(Position1)&" "&Axis$,1) !Move to max position
8542 Reading=FNVoltmeter(Accuracy) !Re-confirm max signal
8544 PRINT USING "4X,10A,8X,M.DDDDDD,8X,DDDD.D";"FINAL",Reading,Position1
8546 !
8548 CALL Setscale(Accuracy,Reading)
8550 BEEP
8552 CALL Cleardisplay
8554 SUBEXIT
8556 !
8558 Set_attn:Att=Att+1 !Change attenuator to reduce signal
8560 IF Att>4 THEN !Have we run out of range?
8562     BEEP !If so then error
8564     OUTPUT KBD USING "#,K";"K"
8566     GCLEAR
8568     CONTROL CRT,1;10
8570     OUTPUT CRT;"ALIGNMENT DIFFICULTIES"
8572     OUTPUT CRT;"Signal greater than "&VAL$(Maxallowed)&" volts; too great
        for proper alignment."
8574 Hang_over: GOTO Hang_over
8576 ELSE
8578     CALL F2000send(VAL$(INT(Att))&" ATTENUAT",1)
8580 END IF
8582 GOTO Start
8584 !
8586 Failure: Fail_flag=1
8588 SUBEXIT
8590 SUBEND
8592 !
8594 !
8596 SUB Cleardisplay
8598     OUTPUT KBD USING "#,K";"K"
8600     GCLEAR
8602 SUBEND
8604 !
8606 !
8608 SUB Steptest(Axis$)
8610 !+*****
8612 ! STEPTEST
8614 !

```

```

8622 ! parameters are the lower position limit, upper limit, and step size
8624 ! All parameters should be specified in motor steps, which are twice as
8626 ! large as displayed on the front panel for the x and y axes, and are in
8628 ! the ratio of 10:8 larger for the z axis. Front panel reads in microns.
8630 !-----
8632 !
8634 CALL F2000send(VAL$(0)&" ATTENUAT",1)
8636 CALL F2000send("XMIT CHOP-ON SPOT-IN")
8638 CALL F2000send("GERMAIN VOUT FF-OUT TARGET-OUT")
8640 Step=50
8642 PRINTER IS PRT
8644 PRINT " "
8646 PRINT " AXIS =",Axis$
8648 CALL F2000send(Axis$[1,POS(Axis$,"-")-1]&Axis$[POS(Axis$,"-")+1;1]&" C
OUPL")
8650 PRINT " "
8652 PRINT USING "10A,2X,10A";"POSITION","SIGNAL"
8654 Position=-700
8656 CALL F2000send(VAL$(Position)&" "&Axis$,1)
8658 ! Hang_it: GOTO Hang_it
8660 !
8662 Loopsy: IF Position<=600 THEN
8664 Reading=FNVoltmeter(.1)
8666 PRINT USING "DDDD.D,5X,M.DDDDDDD";Position,Reading
8668 Position=Position+Step
8670 CALL F2000send(VAL$(Position)&" "&Axis$,1)
8672 GOTO Loopsy
8674 END IF
8676 Position=0
8678 CALL F2000send(VAL$(Position)&" "&Axis$,1)
8680 PRINTER IS CRT
8682 SUBEND
8684 !
8686 !
8688 SUB Inalign
8690 !+-----+
8692 ! INPUT AUTO-ALIGNMENT MODULE 3/8/90
8694 !-----
8696 !
8698 COM /Align_param/ Ap(*) !Auto-alignment parameters set by FIBERTYPE
8700 COM /Align_read/ Reading
8702 !
8704 REAL Sig_change
8706 INTEGER Trial_no
8708 DIM Sig(10)
8710 !
8712 CALL Rundisplay("Input Auto-Alignment in progress.")
8714 !
8716 ! Test to see if the fiber type has been set.
8718 !
8720 IF Ap(0)=0 THEN CALL Fibertype
8722 !
8724 ! Initialize parameters:
8726 Rough_dx=Ap(1) !Step size for rough alignment
8728 Rough_dy=Ap(2)
8730 Rough_dz=Ap(3)
8732 Fine_dx=Ap(4) !Step size for fine alignment
8734 Fine_dy=Ap(5)
8736 Fine_dz=Ap(6)
8738 Rough_min=.95 !Search past the peak for this percent of max power
8740 Fine_min=.98 !Same for fine (change in conjunction w. accuracy)
8742 Rough_acc=.2 !Accuracy used in calling EG&G in rough align
8744 Fine_acc=.1 !Accuracy for fine (change w/Fine_min)
8746 !

```

```

8754 IF Rough_dx=20 THEN PRINT TABXY(5,6);"Fiber diameter of 50 microns is as
sumed."
8756 IF Rough_dx=36 THEN PRINT TABXY(5,6);"Fiber diameter of 85 microns is as
sumed."
8758 IF Rough_dx=40 THEN PRINT TABXY(5,6);"Fiber diameter of 100 microns is a
ssumed."
8760 IF Rough_dx=60 THEN PRINT TABXY(5,6);"Fiber diameter of 150 microns is a
ssumed."
8762 WAIT 2
8764 CALL Rundisplay(" ")
8766 !
8768 ! Begin the alignment loop. Come back in the event of failure in z.
8770 Retry: !First initialize loop parameters and set up system
8772 OFF KEY
8774 Trial_no=Trials_no+1
8776 Fail_flag=0
8778 PRINT TABXY(60,10);
8780 PRINT USING "10A,DD";"Inalign # ",Trial_no
8782 CALL F2000send("XMIT LED LED-ON CHOP-ON SPOT-IN")
8784 CALL F2000send("GERMAIN VOUT FF-OUT TARGET-OUT")
8786 CALL F2000send("STAGE0",1)
8788 !
8790 ! Rough align each axis. After each alignment call, check the
8792 ! alignment parameter. If it fails, do the alignment manually.
8794 !
8796 CALL Align("IN-X",Rough_dx,Fail_flag,Rough_min,Rough_acc)
8798 IF Fail_flag=1 THEN Failure
8800 CALL Align("IN-Y",Rough_dy,Fail_flag,Rough_min,Rough_acc)
8802 IF Fail_flag=1 THEN Failure
8804 CALL Align("IN-Z",Rough_dz,Fail_flag,Rough_min,Rough_acc)
8806 IF Fail_flag=1 THEN Failure_z
8808 CALL F2000send("STAGE0",1)
8810 !
8812 ! Now, fine align each axis. Again, test alignment parameters and
8814 ! do the alignment manually if any parameters are not met.
8816 !
8818 CALL Align("IN-X",Fine_dx,Fail_flag,Fine_min,Fine_acc)
8820 IF Fail_flag=1 THEN Failure
8822 CALL Align("IN-Y",Fine_dy,Fail_flag,Fine_min,Fine_acc)
8824 IF Fail_flag=1 THEN Failure
8826 CALL Align("IN-Z",Fine_dz,Fail_flag,Fine_min,Fine_acc)
8828 IF Fail_flag=1 THEN Failure_z
8830 CALL F2000send("STAGE0",1)
8832 !
8834 ! Test to see how repeatable the alignment is. If there is more than 1%
8836 ! difference in signal between alignments, give user the choice to retry.
8838 !
8840 Sig(Trial_no)=Reading
8842 IF Trial_no<2 THEN !Do alignment at least twice, test for stability
8844 GOTO Retry
8846 ELSE
8848 Sig_change=100*(Sig(Trial_no)-Sig(Trial_no-1))/Sig(Trial_no-1)
8850 IF Sig_change>1 THEN
8852 PRINT USING "22A,MOD.D,22A,DD,4A,DD";"A change in signal of ",Sig_
change," occurred between INALIGN trial",Trial_no," and",Trial_no-1
8854 PRINT "Press f1 to RERUN the alignment routine, f5 to EXIT."
8856 ON KEY 1 LABEL " RERUN" GOTO Retry
8858 ON KEY 5 LABEL " EXIT" GOTO Cleanup
8860 Snooze_dude: GOTO Snooze_dude
8862 END IF
8864 END IF
8866 !

```

```

8874 Clearout:  OFF KEY
8876     BEEP
8878     BEEP
8880     WAIT 2
8882     CALL Cleardisplay
8884     SUBEXIT
8886     !
8888     ! If any of the success parameters are not met, this manual alignment
8890     ! routine is entered to give the user manual control of the FOA-2000
8892     ! and prompt him to manually align the fiber. Failure_z anticipates
8894     ! particular errors which result from non-optimal placement of the fiber
8896     ! in the vacuum chuck. The user is prompted to focus the fiber end at a
8898     ! position particular to this system figured to encounter the least error.
8900     !
8902 Failure_z:BEEP
8904     IF Trial_no>1 THEN GOTO Failure
8906     CALL F2000send("ALIGN INZ COUPL 3000 DARK",1)  !Find edge of INZ sensor
8908     CALL F2000send("INZ ZER -900 GOTO INZ ZER",1)  !Back up and stop
8910     CALL F2000send("250 IN-Z",1)
8912     CALL Cleardisplay
8914     PRINT TABXY(1,17),"INALIGN -- Unsuccessful auto-alignment."
8916     PRINT TABXY(1,18),"Adjust the input end of the fiber in the vacuum chuck
      until"
8918     PRINT TABXY(1,19),"it comes into rough focus on the monitor. Then press
      RE-TRY."
8920     ON KEY 5 LABEL "PROCEED" GOTO Quit
8922     ON KEY 6 LABEL " RE-TRY  AUTO" GOTO Retry_prep
8924 Wait_here:  GOTO Wait_here
8926     !
8928 Failure:  OFF KEY
8930     CALL Cleardisplay
8932     PRINT TABXY(1,17),"INALIGN -- Auto-alignment unsuccessful in the IN-Z mo
      tor."
8934     PRINT TABXY(1,18),"Align input end of fiber using the FOA-2000 panel con
      trols."
8936     ON KEY 5 LABEL "PROCEED" GOTO Quit
8938     ON KEY 6 LABEL " RE-TRY  AUTO" GOTO Retry_prep
8940 Wait_there:  GOTO Wait_there
8942     !
8944 Retry_prep:  !
8946     OFF KEY
8948     CALL Cleardisplay
8950     CALL Rundisplay("Input Auto-Alignment in progress.")
8952     GOTO Retry
8954     !
8956 Quit:  !
8958     OFF KEY
8960     OUTPUT KBD USING "#,K":"K"
8962     GCLEAR
8964     SUBEND
8966     !
8968     !
8970 SUB Outalign
8972 !+*****
8974 ! OUTPUT AUTO-ALIGNMENT MODULE                                     3/8/90
8976 !-*****
8978     !
8980     COM /Align_param/ Ap(*)  !Auto-alignment parameters set by FIBERTYPE
8982     COM /Align_read/ Reading
8984     !
8986     REAL Sig_change
8988     INTEGER Trial_no
8990     DIM Sig(10)

```

```

9000 |
9002 | IF Ap(0)=0 THEN CALL Fibertype
9004 |
9006 | Initialize parameters:
9008 | Rough_dx=Ap(1)      !Step size for rough alignment
9010 | Rough_dy=Ap(2)
9012 | Rough_dz=Ap(3)
9014 | Fine_dx=Ap(4)       !Step size for fine alignment
9016 | Fine_dy=Ap(5)
9018 | Fine_dz=Ap(6)
9020 | Rough_min=.95       !Search past the peak for this percent of max power
9022 | Fine_min=.98        !Same for fine (change in conjunction w/accuracy)
9024 | Rough_acc=.2        !Accuracy used in calling EG&G in rough align
9026 | Fine_acc=.1         !Accuracy for fine (change w/Fine_min)
9028 | Trial_no=0
9030 |
9032 | Remind the user what your fiber type is.
9034 |
9036 | IF Rough_dx=20 THEN PRINT TABXY(5,6);"Fiber diameter of 50 microns is as
sumed."
9038 | IF Rough_dx=36 THEN PRINT TABXY(5,6);"Fiber diameter of 85 microns is as
sumed."
9040 | IF Rough_dx=40 THEN PRINT TABXY(5,6);"Fiber diameter of 100 microns is a
ssumed."
9042 | IF Rough_dx=60 THEN PRINT TABXY(5,6);"Fiber diameter of 150 microns is a
ssumed."
9044 | WAIT 2
9046 | CALL Rundisplay(" ")
9048 |
9050 | Begin the alignment loop. Come back in the event of failure in z.
9052 | Retry:             !First initialize loop parameters and set up system
9054 | OFF KEY
9056 | Trial_no=Trial_no+1
9058 | Fail_flag=0
9060 | PRINT TABXY(60,10);
9062 | PRINT USING "11A,DD";"Outalign # ",Trial_no
9064 | CALL F2000send("XMIT LED LED-ON CHOP-ON SPOT-OUT")
9066 | CALL F2000send("GERMAIN VOUT FF-OUT TARGET-IN")
9068 | CALL F2000send("STAGE0",1)
9070 |
9072 | Rough align each axis. After each alignment call, check the
9074 | alignment parameter. If it fails, do the alignment manually.
9076 |
9078 | CALL Align("OUT-X",Rough_dx,Fail_flag,Rough_min,Rough_acc)
9080 | IF Fail_flag=1 THEN Failure
9082 | CALL Align("OUT-Y",Rough_dy,Fail_flag,Rough_min,Rough_acc)
9084 | IF Fail_flag=1 THEN Failure
9086 | CALL Align("OUT-Z",Rough_dz,Fail_flag,Rough_min,Rough_acc)
9088 | IF Fail_flag=1 THEN Failure_z
9090 | CALL F2000send("STAGE0",1)
9092 |
9094 | Now, fine align each axis. Again, test alignment parameters and
9096 | do the alignment manually if any parameters are not met.
9098 |
9100 | CALL Align("OUT-X",Fine_dx,Fail_flag,Fine_min,Fine_acc)
9102 | IF Fail_flag=1 THEN Failure
9104 | CALL Align("OUT-Y",Fine_dy,Fail_flag,Fine_min,Fine_acc)
9106 | IF Fail_flag=1 THEN Failure
9108 | CALL Align("OUT-Z",Fine_dz,Fail_flag,Fine_min,Fine_acc)
9110 | IF Fail_flag=1 THEN Failure_z
9112 | CALL F2000send("STAGE0",1)
9114 |
9116 |

```

```

9122      Sig(Trial_no)-Reading
9124      IF Trial_no<2 THEN      !Do alignment at least twice, test for stability
9126          GOTO Retry
9128      ELSE
9130          Sig_change=100*(Sig(Trial_no)-Sig(Trial_no-1))/Sig(Trial_no-1)
9132          IF Sig_change>1 THEN
9134              PRINT USING "22A,MOD.D,22A,DD,4A,DD";"A change in signal of ",Sig_
change," occurred between OUTALIGN trial",Trial_no," and",Trial_no-1
9136              PRINT "Press f1 to RERUN the alignment routine, f5 to EXIT."
9138              ON KEY 1 LABEL " RERUN" GOTO Retry
9140              ON KEY 5 LABEL " EXIT" GOTO Cleanout
9142 Snooze_man: GOTO Snooze_man
9144          END IF
9146      END IF
9148      !
9150      ! Now clean up and quit.
9152      !
9154      PRINT TABXY(16,12),"Output fiber end successfully aligned."
9156 Cleanout: OFF KEY
9158      BEEP
9160      BEEP
9162      WAIT 2
9164      CALL Cleardisplay
9166      SUBEXIT
9168      !
9170      ! If any of the success parameters are not met, this manual alignment
9172      ! routine is entered to give the user manual control of the FOA-2000
9174      ! and prompt him to manually align the fiber. Failure_z anticipates
9176      ! particular errors which result from non-optimal placement of the fiber
9178      ! in the vacuum chuck. The user is prompted to focus the fiber end at a
9180      ! position particular to this system figured to encounter the least error.
9182      !
9184 Failure_z: BEEP
9186      IF Trial_no>1 THEN GOTO Failure
9188      CALL F2000send("ALIGN OUTZ COUPL 3000 DARK",1) !Find edge of OUTZ sensor
9190      CALL F2000send("OUTZ ZER -900 GOTO OUTZ ZER",1) !Back up and stop
9192      CALL F2000send("250 OUT-Z",1)
9194      CALL Cleardisplay
9196      PRINT TABXY(1,17),"OUTALIGN -- Auto-alignment unsuccessful in the OUT-Z
motor."
9198      PRINT TABXY(1,18),"Adjust the output end of the fiber in the vacuum chuc
k until"
9200      PRINT TABXY(1,19),"it comes into rough focus on the monitor. Then press
RE-TRY."
9202      ON KEY 5 LABEL "PROCEED" GOTO Quit
9204      ON KEY 6 LABEL " RE-TRY AUTO" GOTO Retry_prep
9206 Wait_here: GOTO Wait_here
9208      !
9210 Failure: OFF KEY
9212      CALL Cleardisplay
9214      PRINT TABXY(1,17),"OUTALIGN -- Unsuccessful auto-alignment."
9216      PRINT TABXY(1,18),"Align output end of fiber using the FOA-2000 panel co
ntrols."
9218      ON KEY 5 LABEL "PROCEED" GOTO Quit
9220      ON KEY 6 LABEL "RE-TRY AUTO" GOTO Retry_prep
9222 Wait_there: GOTO Wait_there
9224      !
9226 Retry_prep: !
9228      OFF KEY
9230      CALL Cleardisplay
9232      CALL Rundisplay("Output Auto-Alignment in progress.")
9234      GOTO Retry
9236      !
9238      !

```

```

9244      SUBEND
9246 SUBEND
9248 |
9250 |
9252 SUB Nextwave(Wavelen)
9254 | +*****+
9256 | GET NEXT WAVELENGTH MODULE                                VERSION 2.1IR
9258 | -*****+
9260   COM /Sysdata/ Serial_num$,Lasers(*),Filter_flag,Filters(*),Num_focus,Foc
us(*),Cutoff,Low_wave,High_wave,Det_switch
9262   COM /Addition/ Curr_wave,Gratings(*),Cur_grating,Wave_step
9264   INTEGER Index
9266   DIM Cmd$(80),Dum$(40)
9268   Cmd$=""
9270   |
9272   ! First, make sure the wavelength called is not out of range.
9274   IF Wavelen<Low_wave OR Wavelen>High_wave THEN GOTO Filter_err
9276   |
9278   ! Next, figure out which grating to use.
9280   New_grating=FNGrating(Wavelen)
9282   |
9284   ! If we don't know what wavelength we were at, which grating we were
9286   ! using, or the grating we want isn't the grating currently in use,
9288   ! we will ask the user to switch the grating by hand.
9290   |
9292   IF Curr_wave=-1 THEN
9294     DISP "PLEASE TURN TO GRATING NUMBER";New_grating
9296     Cur_grating=New_grating
9298     BEEP
9300     ON KEY 5 LABEL "PROCEED" GOTO Proceed
9302 Infinite: GOTO Infinite
9304 Proceed: |
9306     OFF KEY
9308     CALL F2000send("ITO1 300 WAVE",1) !Eliminate possible backlash
9310     OUTPUT KBD USING "#,K";"K"
9312     DISP                                     !Clear grating request off screen
9314   END IF
9316   |
9318   IF Curr_wave=-1 OR Cur_grating<>New_grating THEN
9320     OUTPUT Dum$ USING "" GRAT"" ,D,"" "" ,#";New_grating
9322     Cmd$=Cmd$&Dum$
9324     WHILE Cur_grating<>New_grating
9326       CALL F2000send("ITO1 300 WAVE TURN",1)
9328       WAIT 1.5
9330       Cur_grating=(Cur_grating MOD 3)+1
9332     END WHILE
9334   END IF
9336   |
9338   IF Curr_wave>Wavelen THEN ! eliminate backlash
9340     Cmd$=Cmd$&VAL$(Wavelen-40)&" WAVE "
9342   END IF
9344   |
9346   Cmd$=Cmd$&VAL$(Wavelen)&" WAVE "
9348   Curr_wave=Wavelen
9350   |
9352   ! In the original FOA-2000, the monochromator only covers the range from
9354   ! 800 to 1600 nm. For this range, only two cutoff filters were needed,
9356   ! one to cover 800 to 1000 nm, and another to cover 1000 to 1600 nm. The
9358   ! value at which the filter was switched was denoted in the software as a
9360   ! parameter named Cutoff. The NRL system requires five cutoff filters, so
9362   ! we need an array to pass the values of the wavelengths at which the
9364   ! cutoff filters should be switched. For this we use an array called
9366   ! Filter(*), which is passed to this subroutine by the Sysdata COM block.

```

```

9374 | the filter values modification that. Then we have
9376 | the file that we are using a monochromator with cutoff filters, which
9378 | is necessary in order to set the Filter_flag to 2 (which in turn flags
9380 | the program to determine which value of Filter(*) to use).
9382 |
9384 | The cut-on wavelengths for the cutoff filters are as follows:
9386 |     Filter(1) = 500 nm
9388 |     Filter(2) = 900 nm
9390 |     Filter(3) = 1525 nm
9392 |     Filter(4) = 2175 nm
9394 |     Filter(5) = 3150 nm
9396 |
9398 | If Filter_flag=2, we are using the monochromator with cutoff filters
9400 | installed in SEVERAL positions of the filter wheel, so decide which
9402 | one to use. If Filter_flag=0, we are not using the cutoff filters.
9404 |
9406 | IF Filter_flag=2 THEN
9408 |     FOR Index=11 TO 0 STEP -1
9410 |         IF Filters(Index)<=Wavelen THEN GOTO Change
9412 |     NEXT Index
9414 |     GOTO Filter_err
9416 | END IF
9418 | Change: Cmd$=Cmd$&VAL$(Index)&" FILTER "
9420 |
9422 |
9424 | Figure out which detector to use.
9426 |
9428 | IF Wavelen<Det_switch THEN
9430 |     Cmd$=Cmd$&"GERMAIN"           !Less than switch so use Germanium
9432 | ELSE
9434 |     Cmd$=Cmd$&"INSB"             !Otherwise use Indium-Antimonide
9436 | END IF
9438 | CALL F2000send(Cmd$,1)
9440 | Done: SUBEXIT
9442 |
9444 | Filter_err: BEEP
9446 |     DISP "NEXTWAVE -- Wavelength "&VAL$(Wavelen)&" is not available on the
9448 |     filter wheel."
9450 | Dead1: GOTO Dead1
9452 |
9454 |
9456 | SUB Cleanup
9458 | !*****
9460 | ! CLEARUP: This routine can be called to clear the I/O path to the lock-
9462 | ! in amp, and reset the phase setting to maximize sensitivity.
9464 | !*****
9466 | COM /Iopaths/ @Foa2000,@Egg5205,@Tek7854,@Bncdelay,Printer_add
9468 | CLEAR 7
9470 | CALL Cleardisplay
9472 | PRINT TABXY(15,8);"Please be patient, this might take a moment."
9474 | CALL F2000send("LED SPOT-OUT TARGET-OUT ILLUMIN VOUT GERMAIN")
9476 | CLEAR @Egg5205
9478 | CALL E5205comm("A2 1")
9480 | CALL Setscale(.1,1)
9482 | BEEP
9484 | PRINT TABXY(22,14);"EG&G Lock-in cleared and reset!"
9486 | CALL F2000send("ALIGN")
9488 | WAIT 3
9490 | CALL Cleardisplay
9492 | SUBEND
9494 |
9496 |
9498 |

```

```

9506 | This module contains the primary code to run a DMA measurement. It
9508 | differs from a spectral attenuation measurement in that it allows a
9510 | number of wavelength scans to be performed on a long length of fiber
9512 | before cutback. NA Restrictors are requested for each run. After
9514 | cutback, Restrictors are requested in the same order as used originally.
9516 | Data is stored in two arrays, Dmarundata, for measurements before, and
9518 | Dmarefdata, for measurements after cutback.
9520 |
9522 COM /Iopaths/ @Foa2000,@Egg5205,@Tek7854,@Bncdelay,Printer_add
9524 COM /Sysdata/ Serial_num$,Lasers(*),Filter_flag,Filter(*),Num_focus,Focu
s(*),Cutoff,Low_wave,High_wave,Det_switch
9526 COM /Wavelength/ Wavelength(*),Numsteps
9528 COM /Fiber/ Fiber_id$,Fiber_len,Log_time$
9530 COM /Dmadata/ Dmarundata(*),Dmarefdata(*),Dmaattendata(*),Dma_id$
9532 |
9534 REAL Measurement,Align1,Align2,Align_change
9536 INTEGER Restr_no,Run_no,Wavecount,Totalruns
9538 DIM Restr$(11)[17]
9540 |
9542 | Set up parameters.
9544 Dmarundata(0,0)=Numsteps
9546 Dmarefdata(0,0)=Numsteps
9548 Dmarundata(1,0)=Fiber_len
9550 Dmarefdata(1,0)=Fiber_len
9552 Dma_id$=Fiber_id$&" "&Log_time$
9554 Run_no=0
9556 |
9558 | Start the "run" (i.e. long) fiber measurements.
9560 Next_restr: |
9562 Run_no=Run_no+1
9564 Restrstring$=FNGetrestrictor$("LONG") !Ask for NA Restrictor #
9566 Restr_no=VAL(Restrstring$(1:1)) !Extract the number from the string
9568 Dmarundata(0,Run_no)=Restr_no !Store it at the top of each column
9570 Dmarefdata(0,Run_no)=Restr_no !And in this array as well
9572 Once_again: OFF KEY !Set up the optics
9574 CALL F2000send("0 IN-X 0 IN-Y 0 IN-Z") !Make sure it's at 0 location
9576 CALL F2000send("0 OUT-X 0 OUT-Y 0 OUT-Z")
9578 CALL F2000send("LED LED-ON CHOP-ON SPOT-OUT XMIT")
9580 CALL F2000send("TARGET-OUT VOUT GERMAIN")
9582 Align1=FNVoltmeter(.05)
9584 CALL F2000send("LAMP LAMP-ON")
9586 |
9588 | Now the actual measurement loop.
9590 PRINT TABXY(1,6);"Long fiber wavelength scan in progress using Restr
ictor #";Restr_no
9592 FOR Wavecount=1 TO Numsteps X wavecount - 1
9594 CALL Nextwave(Wavelength(Wavecount))
9596 CALL Setfocus(Wavelength(Wavecount))
9598 Measurement=FNVoltmeter(.01)
9600 Dmarundata(Wavecount,Run_no)=Measurement
9602 NEXT Wavecount
9604 |
9606 CALL F2000send("0 IN-X 0 IN-Y 0 IN-Z") !Go back to alignment position
9608 CALL F2000send("0 OUT-X 0 OUT-Y 0 OUT-Z") !In case of manual adjustmnt
9610 CALL F2000send("GERMAIN LED LED-ON") !Prep for LED voltage reading
9612 Align2=FNVoltmeter(.05)
9614 | Check signal integrity.
9616 Align_change=100*(Align1-Align2)/Align1
9618 IF Align_change>1 THEN !More than 1% signal change
9620 BEEP
9622 CALL Cleardisplay
9624 PRINT TABXY(1,10);
9626 PRINT USING "###.###" MDDD.D

```

in this restrictor, press f1.

```
9630      PRINT TABXY(1,14);"To PROCEED with the test, press f5. To EXIT th
a test, press f8."
9632      ON KEY 1 LABEL " RE-RUN" GOTO Once_again
9634      ON KEY 5 LABEL "PROCEED" GOTO Choose_another
9636      ON KEY 8 LABEL " EXIT" GOTO Done
9638 Snoozer: GOTO Snoozer
9640      ELSE
9642      PRINT TABXY(1,8);"Alignment okay; test proceeding."
9644      END IF
9646      !
9648 Choose_another: OFF KEY
9650      PRINT TABXY(1,10);"To run another wavelength scan with another NA res
trictor, press f1."
9652      PRINT TABXY(1,12);"To proceed to the cutback, press f5."
9654      ON KEY 1 LABEL "CHANGE RESTRICTR" GOTO Next_restr
9656      ON KEY 5 LABEL " GO TO CUTBACK" GOTO Cutback
9658      ON KEY 8 LABEL " EXIT" GOTO Done
9660 Catch_here: GOTO Catch_here
9662      !
9664 Cutback: OFF KEY
9666      Totalruns=Run_no          !Total number of runs (one per restrictor)
9668      Dmarundata(2,0)=Totalruns !Store total number of runs here
9670      Dmarefdata(2,0)=Totalruns
9672      CALL Fiberload("          PLEASE CUT BACK THE FIBER")
9674      CALL Outalign
9676      !
9678      ! Now take measurements on the "ref" (i.e. short,cutback) fiber.
9680      FOR Run_no=1 TO Totalruns
9682      BEEP
9684      PRINT TABXY(1,10);"Please insert Restrictor #",Dmarefdata(0,Run_no),"
and press f5 when ready."
9686      ON KEY 5 LABEL "PROCEED" GOTO And_again
9688 Hang_on_here: GOTO Hang_on_here
9690      !
9692 And_again: OFF KEY      !Set up bench; do it all in case of manual adjstmnt
9694      CALL F2000send("0 IN-X 0 IN-Y 0 IN-Z") !Make sure it's at 0 location
9696      CALL F2000send("0 OUT-X 0 OUT-Y 0 OUT-Z")
9698      CALL F2000send("LED LED-ON CHOP-ON SPOT-OUT XMIT")
9700      CALL F2000send("TARGET-OUT VOUT GERMAIN")
9702      Align1=FNVoltmeter(.05)
9704      CALL F2000send("LAMP LAMP-ON")
9706      !
9708      ! Now the actual measurement loop.
9710      PRINT TABXY(1,20);"Cutback fiber wavelength scan in progress using Re
{ strictor #",Dmalongdata(0,Run_no)
9712      FOR Wavecount=1 TO NumstepsX
9714      CALL Nextwave(Wavelength(Wavecount))
9716      CALL Setfocus(Wavelength(Wavecount))
9718      Measurement=FNVoltmeter(.01)
9720      Dmarefdata(Wavecount,Run_no)=Measurement
9722      NEXT Wavecount
9724      !
9726      CALL F2000send("0 IN-X 0 IN-Y 0 IN-Z") !Go back to alignment position
9728      CALL F2000send("0 OUT-X 0 OUT-Y 0 OUT-Z")
9730      CALL F2000send("GERMAIN LED LED-ON") !Prep for LED voltage reading
9732      Align2=FNVoltmeter(.05)
9734      ! Check signal integrity.
9736      Align_change=100*(Align1-Align2)/Align1
9738      IF Align_change>1 THEN          !More than 1% signal change
9740      CALL Cleardisplay
9742      PRINT TABXY(1,10);
9744      PRINT USING "36A,MDD.D,9A";"The LED alignment signal changed by",A
```

```

3740
a test, press f8."
9750      ON KEY 1 LABEL " RE-RUN" GOTO And_again
9752      ON KEY 5 LABEL "PROCEED" GOTO On_dasher
9754      ON KEY 8 LABEL " EXIT" GOTO Done
9756 Sleeper:  GOTO Sleeper
9758      ELSE
9760      PRINT TABXY(1,10);"Alignment okay; test proceeding."
9762      END IF
9764 On_dasher: OFF KEY
9766      NEXT Run_no
9768      !
9770 Done:      OFF KEY
9772      CALL Cleardisplay
9774      LOCAL @Foa2000
9776      SUBEND
9778      !
9780      !
9782      SUB Dmacomp
9784      !+*****+
9786      ! DIFFERENTIAL MODAL ATTENUATION COMPUTE MODULE
9788      !-*****+
9790      ! This module computes the fiber spectral attenuation for the different
9792      ! NA ranges used for the test.
9794      !
9796      COM /Wavelength/ Wavelength(*),Numsteps
9798      COM /Dmadata/ Dmarundata(*),Dmarefdata(*),Dmaattendata(*),Dma_id$
9800      !
9802      INTEGER I,J,Run_no,Totalruns
9804      REAL Steps_runs
9806      !
9808      Numsteps=Dmarundata(0,0)
9810      Fiber_len=Dmarundata(1,0)
9812      Totalruns=Dmarundata(2,0)
9814      !
9816      ! Since only the (0,0) slot is open in the Dmaattendata array, parse
9818      ! the number of wavelength steps (up to 350) and the number of DMA runs
9820      ! with different Restrictors (up to 11) into the integer and fractional
9822      ! parts of a single variable called "Steps_runs".
9824      Steps_runs=Numsteps+Totalruns/100
9826      Dmaattendata(0,0)=Steps_runs
9828      !
9830      FOR I=1 TO Numsteps(I-1)
9832          Dmaattendata(I,0)=Wavelength(I)
9834          FOR J=1 TO Totalruns
9836              Dmaattendata(0,J)=Dmarundata(0,J)
9838              Dmaattendata(1,J)=10*LGT(Dmarefdata(I,J)/Dmarundata(I,J))
9840              Dmaattendata(I,J)=Dmaattendata(I,J)/Fiber_len
9842          NEXT J
9844      NEXT I
9846      !
9848      SUBEND
9850      !
9852      !
9854      DEF FNGetrestrictor$(Plot$)
9856      !+*****+
9858      ! CHOOSE NA RESTRICTOR MODULE
9860      !-*****+
9862      ! This module is called before a DMA measurement to ask the user which
9864      ! NA Restrictor he desires to use for the test. It also pauses to allow
9866      ! the Restrictor to be put in the holder next to the cut-off filter wheel.
9868      ! After the test, or when reviewing recalled data, the module is called
9870      ! again to determine which column of data (one corresponding to each

```

```

3010 !
9880 INTEGER Indexi,Indexj,Restr_no,Totalruns
9882 DIM Restr$(11)(17)
9884 !
9886 CALL Cleardisplay
9888 !
9890 ! See if this is the first run, if so goto ask for a new Restrictor.
9892 Totalruns=FRACT(Dmaattendata(0,0))*100
9894 IF Totalruns=0 THEN GOTO New_restr
9896 Reprint: !
9898 PRINT TABXY(1,4); "NA Restrictor values in the present data set are:"
9900 FOR Indexi=1 TO Totalruns
9902 PRINT TABXY(47+Indexi*3,4);Dmaattendata(0,Indexi)
9904 NEXT Indexi
9906 !
9908 ! Ask operator which restrictor to use.
9910 New_restr: !
9912 OFF KEY
9914 Restr$(0)="0 Full NA = .24"
9916 Restr$(1)="1 NA = .04"
9918 Restr$(2)="2 NA = .08"
9920 Restr$(3)="3 NA = .10"
9922 Restr$(4)="4 NA = .13"
9924 Restr$(5)="5 NA = .15"
9926 Restr$(6)="6 NA = .18"
9928 Restr$(7)="7 NA = .20"
9930 Restr$(8)="8 .04<NA<.08"
9932 Restr$(9)="9 .08<NA<.13"
9934 Restr$(10)="10 .11<NA<.17"
9936 Restr$(11)="11 .14<NA<.21"
9938 PRINT TABXY(19,6); " Restr.# NA Range "
9940 FOR Indexj=0 TO 11
9942 PRINT TABXY(25,Indexj+7);Restr$(Indexj)
9944 NEXT Indexj
9946 PRINT " "
9948 BEEP
9950 Restr_no=FNGetint("Enter the restrictor # to use: ",0,11)
9952 CALL Cleardisplay
9954 !
9956 ! The next condition being met means we're preparing to plot data;
9958 ! in that case, go down and return to Dmaplotprep. Else load Restrictor.
9960 FOR Indexi=1 TO LEN(Plot$)
9962 IF Plot$="PLOT" THEN GOTO Headout
9964 NEXT Indexi
9966 !
9968 Got_no: !
9970 IF Restr_no=0 THEN
9972 PRINT TABXY(1,16); "No NA Restrictor was specified."
9974 PRINT TABXY(1,18); "A straight Spectral Attenuation measurement will b
e performed."
9976 ELSE
9978 PRINT TABXY(1,15);
9980 PRINT USING "30A,00,25A"; "Please insert NA Restrictor #",Restr_no," a
nd press f5 when ready."
9982 END IF
9984 ON KEY 1 LABEL "CHANGE RESTRCTR" GOTO Kleenscreen
9986 ON KEY 5 LABEL "PROCEED" GOTO Headout !Head back to Dmarun
9988 Prang: GOTO Prang
9990 !
9992 Kleenscreen: !
9994 OFF KEY
9996 OUTPUT KBD USING "#,K"; "K" !Clear alpha's only
9998 GOTO Reprint

```

```

10008 !
10010 FEND
10012 !
10014 !
10016 DEF FNdatasource
10018 !+*****+
10020 ! DETERMINE DATA SOURCE MODULE
10022 !-*****~
10024 ! This routine is called before each fiber test is performed, to determine
10026 ! where the data for the output plot is to come from. It allows a user to
10028 ! review data from a previous day (computer turned off in between), data
10030 ! presently in the memory (earlier the same day), or run a new test.
10032 !
10034 PRINT TABXY(4,15);"To access data from an archived file, press RETRIEVE.
"
10036 PRINT TABXY(4,16);"To review data presently in memory, press EXISTING DA
TA."
10038 PRINT TABXY(4,17);"To begin a new Far Field measurement, press NEW TEST.
"
10040 ON KEY 1 LABEL "RETRIEVE" GOTO Pullit
10042 ON KEY 3 LABEL "EXISTING DATA" GOTO Existing
10044 ON KEY 5 LABEL " NEW TEST" GOTO New_test
10046 Freeze: GOTO Freeze
10048 !
10050 Pullit: OFF KEY
10052 CALL Retrieve
10054 Source_flag=2 ! Flag number to retrieve data from disk
10056 GOTO Scram
10058 Existing: OFF KEY
10060 Source_flag=1 ! Flag number for data existing in memory
10062 GOTO Scram
10064 New_test: OFF KEY
10066 Source_flag=0 ! Flag number to run a new test
10068 Scram: RETURN Source_flag
10070 FEND
10072 !
10074 !
10076 SUB Dmaplotprep
10078 !+*****+
10080 ! PREPARE DMA DATA FOR PLOTTING
10082 !-*****~
10084 !
10085 !
10088 COM /Specattdata/ Specattdata(*),Specatt_id$
10090 COM /Dmaidata/ Dmarundata(*),Dmarefdata(*),Dmaattendata(*),Dma_id$
10092 !
10094 INTEGER Indexi,Indexj,Indexk,Numsteps,Totalruns,Restr_n,String_len
10096 DIM Restrictor$(30)
10098 !
10100 Numsteps=INT(Dmaattendata(0,0)) !Integer part is # wave steps
10102 Totalruns=FRAC(Dmaattendata(0,0))*100 !Fract part is # NA restr runs
10104 !
10106 Query: !
10108 ! Print Restrictor values in the data set; print NA ranges for each value;
10110 ! query the user as to which set to plot; extract Restrictor number from
10112 ! string (returned from FNGetrestrictor); search data for desired column.
10114 !
10116 Restrictor$=FNGetrestrictor$("PLOT") !Query
10118 String_len=LEN(Restrictor$)
10120 Restrictor$="; Restr # "&Restrictor$(1,2)&"; "&Restrictor$(8,String_len)
10122 !
10124 Restr_no=VAL(Restrictor$(12;2)) !Extract Restr_no from string

```

```

10132 IF Restr_no=Dmaattendata(0,Run_no) THEN GOTO Found_column
10134 NEXT Run_no
10136 PRINT TABXY(1,12);"No match for this Restrictor # was found in the data.
      Please try again. (WAIT)"
10138 WAIT 4
10140 OUTPUT KBD USING "#,K";"K"           !Clear alpha's only
10142 GOTO Query
10144 !
10146 Found_column: !Load the appropriate DMA data in the Specattdata array.
10148 Specatt_id$=Dma_id$&Restrictor$
10150 Specattdata(0,0)=Dmarundata(0,0)      !Transfer number of points
10152 Specattdata(0,1)=Dmarundata(1,0)      !Transfer fiber length
10154 FOR Index=1 TO Numsteps-1
10156     Specattdata(Index,0)=Dmaattendata(Index,0) !Load wavelengths first
10158     Specattdata(Index,1)=Dmaattendata(Index,Run_no) !Now the data
10160 NEXT Index
10162 ! Spectral attenuation routines now may be used to list and plot data.
10164 SUBEND
10166 !
10168 !
10170 SUB Ffsmooth(Data$)
10172 !+*****+
10174 ! SMOOTH FAR FIELD DATA
10176 !-*****-
10178 ! This routine is provided to offer the user the option of smoothing the
10180 ! far field data by a variable pointwise number. Smoothing is generally
10182 ! desirable owing to the spike-generating tendency of the differentiation
10184 ! process used to derive the far field scan values.
10186 !
10188 COM /Fftempdata/ Ffrawdata(*),Ffdiffdata(*),Ffsmoothdata(*)
10190 !
10192 INTEGER Smoothpts,I,J,Num_points
10194 !
10196 ! First ask for the number of points to use in the smoothing operation.
10198 ! Set an upper limit of a 25 point smooth (changable if necessary).
10200 !
10202 CALL Cleardisplay
10204 PRINT TABXY(1,11);" "
10206 Smoothpts=FNGetint("Enter the number of points to use in the smoothing p
rocedure:",0,25)
10208 IF Smoothpts=0 THEN Smoothpts=1      !Smooth by 0 pts really means 1
10210 CALL Cleardisplay
10212 !
10214 ! Next determine which data set to smooth (RAW or ROUGH), and smooth it.
10216 !
10218 IF Data$="RAW DATA" THEN
10220     Num_points=Ffrawdata(0,0)-Smoothpts+1
10222     Ffsmoothdata(0,0)=Num_points
10224     FOR I=1 TO Num_points
10226         Total=0
10228         FOR J=1 TO Smoothpts+1-I
10230             Total=Total+Ffrawdata(J,I)
10232         NEXT J
10234         Ffsmoothdata(I,0)=Ffrawdata(I,0)
10236         Ffsmoothdata(I,1)=Total/Smoothpts
10238     NEXT I
10240 END IF
10242 !
10244 IF Data$="DIFF" THEN
10246     Num_points=Ffdiffdata(0,0)-Smoothpts+1
10248     Ffsmoothdata(0,0)=Num_points
10250     FOR I=1 TO Num_points
10252         Total=0

```

```

10260      Ffsmoothdata(I,1)=Total/Smoothpts
10262      Ffsmoothdata(I,1)=Total/Smoothpts
10264      NEXT I
10266      END IF
10268 !
10270      IF Data$="SMOOTH" THEN
10272          Num_points=Ffsmoothdata(0,0)-Smoothpts+1
10274          Ffsmoothdata(0,0)=Num_points
10276          FOR I=1 TO Num_points
10278              Total=0
10280              FOR J=1 TO Smoothpts+1-1
10282                  Total=Total+Ffsmoothdata(J,1)
10284              NEXT J
10286              Ffsmoothdata(I,1)=Total/Smoothpts
10288          NEXT I
10290      END IF
10292 !
10294      IF Smoothpts>1 THEN
10296          IF Data$="SMOOTH" THEN
10298              PRINT TABXY(1,4);"Data further smoothed "
10300              PRINT USING "7A,00,15A";"using a ",Smoothpts," point average."
10302          ELSE
10304              PRINT TABXY(1,4);"Data smoothed using"
10306              PRINT USING "2A,00,15A";"a ",Smoothpts," point average."
10308          END IF
10310      END IF
10312 !
10314 SUBEND
10316 !
10318 !
10320 SUB Cleardata
10322 !+*****+
10324 ! CLEAR DATA MODULE
10326 !-*****-
10328 ! This routine can be called to effectively clear all data from memory.
10330 ! It simply sets all parameters equal to 0.
10332 !
10334     COM /Fiber/ Fiber_id$,Fiber_len,Log_time$
10336     COM /Specattdata/ Specattdata(*),Specatt_id$
10338     COM /Dmadata/ Dmarundata(*),Dmarefdata(*),Dmaattendata(*),Dma_id$
10340     COM /Farfield/ Ffieldval(*),Fnum_points,Farfield(*),Ffield_id$
10342     COM /Fftempdata/ Ffrawdata(*),Ffdiffdata(*),Ffsmoothdata(*)
10344     COM /Nearfield/ Nfieldval(*),Num_points,Nearfield(*),Nfield_id$
10346 !
10348     INTEGER I,J
10350 !
10352     IF Specattdata(0,0)<>0 THEN
10354         FOR I=0 TO Specattdata(0,0)
10356             FOR J=0 TO 1
10358                 Specattdata(I,J)=0
10360             NEXT J
10362         NEXT I
10364         Specatt_id$=" "
10366         Clear$="CLEAR"
10368     END IF
10370 !
10372     IF Dmarundata(0,0)<>0 THEN
10374         FOR I=0 TO Dmarundata(0,0)
10376             FOR J=0 TO Dmarundata(2,0)
10378                 Dmarundata(I,J)=0
10380                 Dmarefdata(I,J)=0
10382                 Dmaattendata(I,J)=0
10384             NEXT J
10386         NEXT I
10388     END IF

```

```

10392 END IF
10394 !
10396 IF Farfield(0,0)<>0 THEN
10398     FOR I=0 TO Farfield(0,0)
10400         FOR J=0 TO 1
10402             Farfield(I,J)=0
10404             Ffrawdata(I,J)=0
10406             Ffdiffdata(I,J)=0
10408             Ffsmoothdata(I,J)=0
10410         NEXT J
10412     NEXT I
10414     Ffield_id$=" "
10416     Clear$="CLEAR"
10418 END IF
10420 !
10422 CALL Cleardisplay
10424 IF Clear$="CLEAR" THEN
10426     PRINT TABXY(20,10);"DATA HAS BEEN CLEARED."
10428 ELSE
10430     PRINT TABXY(20,10);"NO DATA TO CLEAR."
10432 END IF
10434 WAIT 2
10436 CALL Cleardisplay
10438 !
10440 SUBEND
10442 !
10444 !
10446 SUB Proglis
10448 !+*****+
10450 ! PRINT PROGRAM LISTING OR PROGRAM CONTENTS
10452 !-*****-
10454 !
10456 CALL Cleardisplay
10458 PRINT TABXY(8,8);"To print a list of the subroutines contained in the ma
ster "
10460 PRINT TABXY(8,9);"program, as well as their locations within the program
, press f1."
10462 PRINT TABXY(8,11);"To print the entire program, press f5."
10464 PRINT TABXY(8,12);"Be forewarned that this take an hour or more."
10466 ON KEY 1 LABEL "CONTENTS" GOTO Contents
10468 ON KEY 8 LABEL "PROGRAM LISTING" GOTO Listit
10470 Crash_out: GOTO Crash_out
10472 !
10474 Listit: OFF KEY
10476 PRINT TABXY(20,16);"PRINTING PROGRAM LISTING"
10478 PRINTER IS PRT
10480 LIST
10482 PRINTER IS CRT
10484 OUTPUT KBD USING "#,K";"K"
10486 SUBEXIT
10488 !
10490 Contents: OFF KEY
10492 PRINT TABXY(20,16);"PRINTING PROGRAM CONTENTS"
10494 PRINTER IS PRT
10496 !
10498 ! Now the contents. Obviously, when the software is changed,
10500 ! the list of subroutines and their locations must be changed.
10502 !
10504 PRINT "ROUTINE NAME" LINE NUMBER
10506 PRINT "-----"
10508 PRINT "Mainprog" 10"
10510 PRINT "Sysinit" 334"
10512 PRINT "Systemdata" 719"

```

10520 PRINT "Retrieve	2308"
10524 PRINT "Zcenter	2548"
10526 PRINT "Rundisplay	2582"
10528 PRINT "Cleardisplay	2608"
10530 PRINT "F2000send	2630"
10532 PRINT "Preset	2736"
10534 PRINT "Egg5205comm	2930"
10536 PRINT "FNVoltmeter	3016"
10538 PRINT "Setscale	3314"
10540 PRINT "Arraybuild	3362"
10542 PRINT "Fiberident	3646"
10544 PRINT "Fibertype	3694"
10546 PRINT "Fiberload	3830"
10548 PRINT "Specwaves	3866"
10550 PRINT "Setfocus	3954"
10552 PRINT "Specrun	4034"
10554 PRINT "Specref	4082"
10556 PRINT "Specmeas	4212"
10558 PRINT "Speccor	4452"
10560 PRINT "Specatcomp	4536"
10562 PRINT "Specatlist	4626"
10564 PRINT "Specatplot	4752"
10566 PRINT "Nfieldvals	5114"
10568 PRINT "Nfieldrun	5196"
10570 PRINT "Nfieldplot	5324"
10572 PRINT "Core diam	5534"
10574 PRINT "Ffieldvals	5614"
10576 PRINT "Ffieldrun	5708"
10578 PRINT "Ffield plot	5878"
10580 PRINT "Numaper	6434"
10582 PRINT "Menu	6564"
10584 PRINT "Serialno	7738"
10586 PRINT "FNGetint	7766"
10588 PRINT "FNGrating	7832"
10590 PRINT "Askalign	7862"
10592 PRINT "Init_foa_cntrl	7910"
10594 PRINT "Ffnormalize	8160"
10596 PRINT "Ffdiff	8250"
10598 PRINT "Ffcorrect	8306"
10600 PRINT "FNGetwave	8346"
10602 PRINT "Align	8368"
10604 PRINT "Step test	8608"
10606 PRINT "Inalign	8688"
10608 PRINT "Outalign	8970"
10610 PRINT "Nextwave	9252"
10612 PRINT "Clearup	9456"
10614 PRINT "Dmarun	9498"
10616 PRINT "Dmacomp	9782"
10618 PRINT "FNGetrestrictor	9854"
10620 PRINT "FNDataSource	10016"
10622 PRINT "Dmaplotprep	10076"
10624 PRINT "Ffsmooth	10170"
10626 PRINT "Clear data	10320"
10628 PRINT "Proglis t	10446"
10630 PRINT "Fibertest1 (Specatten)	10656"
10632 PRINT "Fibertest2 (DMA)	10798"
10634 PRINT "Fibertest 3 (Far Field)	10946"
10636 PRINT "Fibertest 4 (pinhole)	11006"
10638 PRINT "Fibertest 5 (near field)	11050"
10640 PRINT "Fibertest 6 (fiberload)	11098"
10642 !	
10644 PRINTER IS CRT	

```

10652 |
10654 |
10656 SUB Fibertest1(OPTIONAL Source_flag)
10658 | +*****+
10660 | FIBERTEST SUBPROGRAM NO. 1 -- SPECTRAL ATTENUATION
10662 | -*****-
10668 DIM Flags$(10)
10670 IF NPAR>0 THEN 'If source_flag given and = 0
10671     IF Source_flag=0 THEN GOTO New_test1
10672     IF Source_flag=1 THEN GOTO Scale 'Data already loaded in memory
10673     IF Source_flag=2 THEN GOTO Plot_spec 'Data retrieved from disk
10674 END IF
10675 New_test1: !
10676 CALL Fiberload(" Please load the test fiber.")
10677 CALL Fiberident
10678 CALL Askalign
10679 CALL Logtime
10680 CALL Specrun("OVERFILL")
10681 CALL F2000send("GERMAIN")
10682 CALL Fiberload("PLEASE CUT BACK THE FIBER")
10683 CALL Outalign
10684 CALL Specref("OVERFILL")
10685 CALL Specatcomp
10686 Scale: !
10687 PRINT TABXY(20,16);"Select the desired range for the plot."
10688 BEEP
10689 Flags$=""
10690 ON KEY 1 LABEL " dB/km" GOTO Kilo_db
10691 ON KEY 2 LABEL "dB/100m" GOTO Hundred_db
10692 ON KEY 3 LABEL "dB/10m" GOTO Ten_db
10693 ON KEY 4 LABEL " dB/m" GOTO Db_per_m
10694 Out_to_lunch: GOTO Out_to_lunch
10695 Kilo_db: !
10696 Flags$="KILO"
10697 GOTO Got_factor
10698 Hundred_db: !
10699 Flags$="HUNDRED"
10700 GOTO Got_factor
10701 Ten_db: !
10702 Flags$="TEN"
10703 GOTO Got_factor
10704 Db_per_m: !
10705 Flags$="METER"
10706 GOTO Got_factor
10707 Plot_spec: !
10708 Flags$="2"
10709 CALL Specatcomp
10710 Got_factor: !
10711 OFF KEY
10712 DISP
10713 OUTPUT KBD USING "#,K";"K"
10714 !
10715 CALL Specatplot(Flags$)
10716 !
10717 ! Test flag values returned from Specatplot for where to go from here:
10718 IF Flags$="RESCALE" THEN GOTO Scale ' Rescale plot and do again
10719 IF Flags$="LISTING" THEN GOTO Print_list ' Print hard copy listing
10720 IF Flags$="STORE" THEN GOTO Storeit ' Archive data
10721 IF Flags$="QUIT" THEN GOTO Done ' None of the above
10722 GOTO Done
10723 Print_list: !
10724 OFF KEY
10725 DISP

```

```

10729 SUB Fibertest2(OPTIONAL Source_flag)
10730 OFF KEY
10731 CALL Archive
10732 Done: !
10733 OFF KEY
10734 DISP
10735 OUTPUT KBD USING "&,K";"K"
10736 SUBEND
10737 !
10738 !
10739 SUB Fibertest2(OPTIONAL Source_flag)
10740 !+*****
10741 ! Fibertest2: DIFFERENTIAL MODAL ATTENUATION
10742 !-*****
10743 ! This module controls the run of the DMA test.
10744 !
10745 DIM Flags$(10),Restrictor$(17)
10746 !
10747 IF NPAR>0 THEN !If source_flag given and = 0
10748 IF Source_flag=0 THEN GOTO New_test
10749 IF Source_flag=1 THEN GOTO Plot_prep !Data already loaded in memory
10750 IF Source_flag=2 THEN GOTO Plot_prep !Data retrieved from disk
10751 END IF
10752 !
10753 New_test: !
10754 CALL Fiberload(" Please load the test fiber.")
10755 CALL Fiberident
10756 CALL Askalign
10757 CALL Logtime
10758 CALL Dmarun
10759 CALL Dmacomp
10760 Plot_prep: !
10761 CALL Dmaplotprep
10762 !
10763 ! Prepare scale information for Specattplot:
10764 !
10765 Scale: !
10766 PRINT TABXY(20,16);"Select the desired range for the plot."
10767 BEEP
10768 Flags$=""
10769 ON KEY 1 LABEL " dB/km" GOTO Kilo_db
10770 ON KEY 2 LABEL "dB/100m" GOTO Hundred_db
10771 ON KEY 3 LABEL "dB/10m" GOTO Ten_db
10772 ON KEY 4 LABEL " dB/m" GOTO Db_per_m
10773 Out_to_lunch: GOTO Out_to_lunch
10774 Kilo_db: !
10775 Flags$="KILO"
10776 GOTO Got_factor
10777 Hundred_db: !
10778 Flags$="HUNDRED"
10779 GOTO Got_factor
10780 Ten_db: !
10781 Flags$="TEN"
10782 GOTO Got_factor
10783 Db_per_m: !
10784 Flags$="METER"
10785 GOTO Got_factor
10786 !
10787 Got_factor: !
10788 OFF KEY
10789 CALL Cleardisplay
10790 CALL Specatplot(Flags$,0,0,"DIFFERENTIAL MODAL ATTENUATION")
10791 !

```

```

10795 IF Flag$="STORE" THEN GOTO Storeit
10796 IF Flag$="QUIT" THEN GOTO Done
10797 GOTO Done
10798 Print_list:|
10799 OFF KEY
10800 DISP
10801 OUTPUT KBD USING "#,K";"K"
10802 CALL Specatlist("PRINT "&Flag$,"DIFFERENTIAL MODAL ATTENUATION
-----

```

Restrictor #:"&VAL\$(Restr_no))

```

10803 GOTO Done
10804 Storeit: |
10805 OFF KEY
10806 CALL Archive
10807 Done:|
10808 OFF KEY
10809 CALL Cleardisplay
10810 SUBEND
10811 |
10812 |
10813 SUB Fibertest3(OPTIONAL Source_flag)
10814 !+*****+
10815 ! FIBERTEST SUBPROGRAM NO. 3 -- FAR FIELD
10816 !-*****-
10817 |
10818 ! First test whether or not to run a new test, or go directly to plot.
10819 |
10820 IF NPAR>0 THEN !If source_flag given and = 0
10821 IF Source_flag<>0 THEN GOTO Plotit !i.e., data in memory, not new te
st
10822 END IF
10823 |
10824 CALL Fiberload(" Please load the test fiber.")
10825 CALL Fiberident
10826 BEEP
10827 Ffwave=FNGetffwave
10828 CALL Askalign
10829 CALL Ffieldvals("-.35 TO .35 STEP .0075")
10830 CALL Logtime
10831 CALL Ffieldrun(Ffwave)
10832 CALL Ffnormalize("RAW DATA")
10833 Plotit: |
10834 CALL Ffieldplot("RAW DATA","Far-Field Raw Data (before differentiation)"
)
10835 CALL Ffdiff
10836 CALL Ffcorrect
10837 Print_flag$="DIFF"
10838 Normalize_it:|
10839 CALL Ffnormalize(Print_flag$)
10840 CALL Ffieldplot(Print_flag$," FAR FIELD PATTERN")
10841 IF Print_flag$="SMOOTH" THEN GOTO Normalize_it
10842 SUBEND
10843 |
10844 |
10845 SUB Fibertest4(OPTIONAL Source_flag)
10846 !+*****+
10847 ! Fibertest4: FARFIELD WITH PINHOLE Fibertest4 has been set to the
10848 ! pinhole farfield test. This is
10849 ! used mainly for system diagnostics.
10850 !-*****-
10851 CALL Cleardisplay

```

```

10854 WINDUP_VIBRO: OFF KEY
10855 Ffpintest: OFF KEY
10856 CALL Fiberload(" Please load the test fiber.")
10857 CALL Fiberident
10858 CALL Askalign
10859 CALL Ffieldvals("-.35 TO .35 STEP .0075")
10860 CALL Ffieldrun(FNGetffwave,"PINHOLE")
10861 CALL Ffcorrect
10862 CALL Ffnormalize("RAW")
10863 CALL Ffieldplot("RAW"," Far Field Pattern (using pinhole)")
10864 SUBEND
10865 !
10866 !
10867 SUB Fibertest5(OPTIONAL Source_flag)
10868 !+*****+
10869 ! FIBERTEST SUBPROGRAM NO. 5 -- NEAR FIELD
10870 !-*****-
10871 ! This routine is presently inactive. To include the nearfield test as
10872 ! a test option, see NRL IR System! Operating Manual for basic needs.
10873 !
10874 CALL Cleardisplay
10875 PRINT TABXY(12,10);"It said this test is INACTIVE. Can't you read?"
10876 PRINT TABXY(25,12);"(Don't touch that dial!)"
10877 WAIT 4
10878 SUBEXIT
10879 !
10880 ! The real program begins here:
10881 CALL Fiberload(" Please load the test fiber.")
10882 CALL Fiberident
10883 CALL Askalign
10884 CALL Nfieldvals("-35 to -20.5 STEP .5,-20 TO 20 STEP 2,20.5 TO 35 STEP .
5")
10885 CALL Logtime
10886 CALL Nfieldrun
10887 CALL Nfieldplot
10888 SUBEND
10889 !
10890 !
10891 SUB Fibertest6
10892 !+*****+
10893 ! FIBERTEST SUBPROGRAM NO. 6 -- FIBER LOADING & IDENTIFICATION
10894 !-*****-
10895 CALL Fiberload(" Please load the test fiber.")
10896 CALL Fiberident
10897 SUBEND

```

ROUTINE NAME	LINE NUMBER
Mainprog	10
Sysinit	334
Systemdata	718
Timeset	1726
FNTimedates	1900
Logtime	1996
Archive	2022
Retrieve	2308
Zcenter	2548
Rundisplay	2582
Cleardisplay	2608
F2000sand	2630
Preset	2736
Egg5205comm	2930
FNVoltmeter	3016

Spécwavs	3866
Sétfocus	3954
Spécrun	4034
Spécref	4082
Spécméas	4212
Speccor	4452
Spécâtcomp	4536
Spécâtlist	4626
Spécâtplot	4762
Nfiëldvals	5114
Nfiëldrun	5196
Nfiëldplot	5324
Corëdiam	5534
Ffiëldvals	5614
Ffiëldrun	5708
Ffiëld plot	5878
Numäper	6434
Mënu	6564
Sëriälnö	7738
FNGëtint	7766
FNGrätìng	7832
Äskäalign	7862
Init_foä_cntrl	7910
Ffnormalizë	8160
Ffdiff	8250
Ffcorrëct	8306
FNGëtwave	8346
Align	8368
Stëptëst	8608
Inäalign	8688
Outäalign	8970
Nëxtwävë	9252
Clëärup	9456
Dmärün	9498
Dmäcomp	9782
FNGëtrestriCTOR	9854
FNDätäsourcë	10016
Dmäplotprëp	10076
Ffsmöoth	10170
Clëärdatä	10320
ProglisT	10446
Fibërtëst1 (SpëcätTën)	10656
Fibërtëst2 (DMA)	10798
Fibërtëst 3 (Fär Field)	10946
Fibërtëst 4 (pinhole)	11006
Fibërtëst 5 (nëär fiëld)	11050
Fibërtëst 6 (fiberload)	11098