


AD-A285 825



NISTIR 5101

**"ONR-Sponsored Research in
Ultrasonic Measurements at
NIST: 1982-92"**

N. N. Hsu
G. V. Blessing
F. R. Breckenridge

U.S. DEPARTMENT OF COMMERCE
Technology Administration
National Institute of Standards
and Technology
Manufacturing Engineering Laboratory
Automated Production Technology Division
Gaithersburg, MD 20899

Report to
Office of Naval Research
Physics Division Code 1112
800 North Quincy Street
Arlington, VA 22217-5000

NIST Principal Investigator: Franklin R. Breckenridge
ONR Scientific Officer: Logan E. Hargrove


DTIC
ELECTE
OCT 28 1994
S B D

DISTRIBUTION STATEMENT A
Approved for public release
Distribution Unlimited

DTIC QUALITY INSPECTED 2

9410 27 057

94-33586



NIST

"ONR-Sponsored Research in Ultrasonic Measurements at NIST: 1982-92"

**N. N. Hsu
G. V. Blessing
F. R. Breckenridge**

U.S. DEPARTMENT OF COMMERCE
Technology Administration
National Institute of Standards
and Technology
Manufacturing Engineering Laboratory
Automated Production Technology Division
Gaithersburg, MD 20899

Report to
Office of Naval Research
Physics Division Code 1112
800 North Quincy Street
Arlington, VA 22217-5660

NIST Principal Investigator: Franklin R. Breckenridge
ONR Scientific Officer: Logan E. Hargrove

December 1992



U.S. DEPARTMENT OF COMMERCE
Barbara Hackman Franklin, Secretary

TECHNOLOGY ADMINISTRATION
Robert M. White, Under Secretary for Technology

NATIONAL INSTITUTE OF STANDARDS
AND TECHNOLOGY
John W. Lyons, Director

ABSTRACT

This report summarizes the research in ultrasonic measurements at the National Institute of Standards and Technology (NIST) which was supported in part by the Physics Division of the Office of Naval Research from 1982 to 1992. This represents work accomplished since the last such summary report, NBSIR 82-2529, entitled "Ultrasonic Research Summary Report and Literature Guide to the National Bureau of Standards/Office of Naval Research Program." References to the published literature documenting this new work are included.

Accession For	
THIS ORIGIN	☒
DATE 1995	☐
DATE 1996	☐
DATE 1997	☐

By *perform 50*

DATE *1995*

A-1

INTRODUCTION

The ultrasonic research work summarized here was performed in the Ultrasonic Standards Group of the Automated Production Technology Division at the National Institute of Standards and Technology. It represents the highlights of the research sponsored in part by the Office of Naval Research from 1982 until 1992. Much of the work laid the foundation for subsequent calibration services, as was the case for acoustic emission and ultrasonic power.

ACCOMPLISHMENTS

The major accomplishments of the ultrasonic research sponsored by the Office of Naval Research from 1982 until 1992 and performed by the Ultrasonic Standards Group are summarized below. The list is divided into nine separate categories ordered somewhat chronologically, with some overlap occurring between categories.

I Conical Transducer Developments

- The NBS conical transducer was designed as a high fidelity, point pickup, acoustic emission piezoceramic sensor. One of the earlier versions possessed a cylindrically symmetric backing and housing which acted to dampen resonance artifacts and absorb unwanted reverberations in the mechanical system. Subsequent development led to an improved version with an irregularly shaped backing designed to smear out the reverberations that make their way back to the piezoceramic element. This resulted in the highest fidelity measurement to date of dynamic displacement by means of a piezoelectric transducer.^{1 2}
- The correspondence between the electrical and mechanical descriptors of the conical transducer used as a point-force generator and point-displacement sensor were studied. The absolute calibration of the mechanical quantities such as force and velocity of the transducer allowed this direct correspondence to be made.³
- A high fidelity piezoelectric tangential displacement transducer was developed and evaluated for acoustic emission. Modal separation between the desired tangential mode and the unwanted normal mode was shown to exceed 30 dB.^{4 5}

II Acoustic Emission Calibration Studies

- In a collaborative effort, two distinct methods of acoustic emission calibration were compared by the Nippon Steel Corporation in Japan and by the National Bureau of Standards in the United States. A comparison of the reciprocity method used in Japan with the surface-pulse method used in the United States demonstrated very good agreement for the absolute sensitivities of the six transducers calibrated.^{6 7}
- The variables and fundamental limitations that pertain to acoustic emission sensitivity measurements were identified. These studies helped to quantify the NIST acoustic emission calibration precision, and led to meaningful comparisons between calibration results obtained using the NIST-based ASTM practice entitled "Standard Method for Primary Calibration of Acoustic Emission Sensors" and other calibration schemes.^{8 9}

III Acoustic Emission Sources

- Many techniques to produce rapid transient disturbances in elastic media have been used by acoustic emission workers. The ideal source would be a "point," have a mathematically simple waveform, and possess a relatively large amplitude which could be determined *a priori*. In a study to compare several of the techniques, various sources using mechanical, electrical, and chemical devices were evaluated for their particular merits.¹⁰
- A Mil-Standard handbook was written to provide field operation assurance for acoustic emission system operation by means of simulated acoustic emission events. The recommended means was breaking pencil lead using the Hsu pencil source.¹¹

IV Deconvolution Methodology Applications

- Measurements were successfully made at a remote location to determine the accurate dynamic force waveform of an impact on a plate structure.¹²
- Considering the acoustic emission output from a receiving transducer to be the convolution of the source waveform with the Green's function of the medium and the response function of the receiver, the deconvolution approach may be used to extract information about the source or the medium knowing the other two functions. The precision in the results that may be obtained by deconvolution was studied in terms of practical experimental limitations with real transducers.¹³

V Mathematical Analyses

- The capability of the deconvolution procedure for flaw characterization when using the inverse Gaussian function as the modeled probe source was evaluated and reported. This capability was based on a time domain deconvolution method for determining the impulse response of linear time invariant systems wherein the inverse Gaussian pulse is used to approximate the Dirac delta function.^{14 15}
- A new mathematical technique was developed for the experimental determination in the time domain of the impulse response of linear systems. This development was pursued to address the difficulties encountered in the ill-posed deconvolution problem using a Green's function approach. The technique centered around the use of specifically designed probe waveforms that are approximations to the Dirac delta function or the Heaviside step function. This allowed for continuous deconvolution, a powerful option in the presence of noise, by smoothing out the singularities in the Green's function of the system.^{16 17}
- The finite element method was used to study transient wave propagation in a plate. This study provided a basis for the impact-echo technique as a nondestructive test for flaw detection in concrete. The surface displacement

calculations due to point impact on a plate were in good agreement with those obtained using the Green's function solution.¹⁸

- A recently developed signal processing technique of B. Kidem using higher-order crossings was evaluated and adapted to acoustic emission signal discrimination. The mathematical concepts have unique physical significance to the physical problems of elastic wave propagation.¹⁹

VI Computer Software Developments

- The inverse problem in acoustic emission was addressed. Specifically, a procedure for determining the force-time function of a point force of unknown nature as applied to a solid was described and implemented in computer code.^{20 21}
- The mechanics part of acoustic emission detection was evaluated in a fundamental study, and practical applications for the technique were presented. A computer program was developed based on the Green's function formulation to predict the acoustic emission waveforms knowing the source and the medium's elastic properties for the case of an infinite plate.^{22 23 24}
- Computer algorithms were derived for the dynamic Green's function which can be used to determine the response of ultrasonic receivers to the scattered energy in specific materials insonified by the output of known sources. One specific configuration, involving two transducers in a liquid medium facing a solid specimen, was emphasized for its practical application to materials testing.²⁵

VII Solid Materials Applications

- The point source-point receiver methodology was successfully applied to the study of flaws in hardened concrete. A dropping steel ball was the source and a conical broadband displacement transducer was the receiver. With the help of numerical solutions for the response of an infinite plate to surface impact in order to interpret experimental signal traces, the location and extent of simulated flaws embedded within the concrete were determined.²⁶
- An approach to characterize the ultrasonic wave field (inside a solid) produced by a piezoelectric transducer was demonstrated. The steps of this approach consisted of (a) the photoelastic visualization of the moving pulse in a transparent solid, (b) a point displacement field measurement at the plate epicenter, and (c) dynamic transient wave field analysis using a finite element technique.²⁷
- A simple technique was reported, in which the echo waveform generated by a point impulse and received by a point normal displacement transducer was used to determine the longitudinal, shear, and Rayleigh wave speeds. The NBS conical transducer was used as an example for a point source generator and point displacement detector.²⁸

- The influence of interface conditions on the behavior of transient waves were studied for a structure consisting of an isotropic layer overlay on an isotropic half-space. The generalized ray expansion technique with the Willis inversion method was used. The theory predicts results that are highly dependent upon the properties of the interface bond. Experimental waveforms can, therefore, elucidate the condition of a bond. ²⁹

VIII Ultrasonic Power Sources

- Quartz transducers designed and fabricated at NIST as stable transmitters of ultrasonic power were evaluated as potential power standards. An international intercomparison of measurements of the power emitted by these standards was made, and the results reported by NIST serving as the pilot laboratory. ³⁰
- The NIST ultrasonic absolute power transfer standard, Standard Reference Material 1855, was developed and offered for distribution in order to provide the medical community in particular with a means to evaluate the radiation output of its clinical ultrasonic equipment. The contribution of this reference standard to the medical profession is recognized by its inclusion in a recent text on ultrasonic exposimetry. ^{31 32}

IX Miscellaneous

- The various ultrasonic measurement services offered by NIST, and undergoing continuous improvement over the past decade with support from the ONR program for research in ultrasound, were reviewed and summarized at the recent National Conference of Standards Laboratories in Washington, DC. ³³

BIBLIOGRAPHY

1. D. Eitzen, F. Breckenridge, R. Clough, N. Hsu, T. Proctor, J. Simmons, C. Stockton, and H. Wadley, "Fundamental Developments in Acoustic Emission Measurements: The NBS Programs," *Proceedings of Quantitative NDE in the Nuclear Industry*, R. B. Clough, ed. Metals Park, OH: American Society for Metals; 1983.
2. T. Proctor, "More Recent Improvements on the NBS Conical Transducer," *J. Acoustic Emission*, Vol. 5(4); 134-142; 1986.
3. S. Fick, N. Hsu, and T. Proctor, "The Design and Calibration of a Novel Piezoelectric Point Contact High Fidelity Ultrasonic Transducer," *Proceedings of 11th World Conference on Nondestructive Testing*, November 1985.
4. T. Proctor, "A High Fidelity Piezoelectric Tangential Displacement Transducer for Acoustic Emission," *J. Acoustic Emission*, Vol. 7, No. 1, 1988; 41-48.
5. T. Proctor, "Transducer for Measuring Transient Tangential Motion," United States Patent No. 4,782, 701 issued Nov. 8, 1988.
6. F. Breckenridge, T. Watanabe, H. Hatano, "Calibration of Acoustic Emission Transducers: Comparison of Two Methods," *Proceedings of the 6th International AE Symposium*, 31 October-3 November, 1982, Susono, Japan, 448-458.
7. M. Ohisu and K. Ono with Appendix by F. Breckenridge and T. Watanabe, "A New Method of Acoustic Emission Transducer Calibration," *J. of Acoustic Emission*, 3(2): 59-68; 1984 April-June.
8. D. Eitzen and H. Wadley, "Acoustic Emission: Establishing the Fundamentals," *J. Res. Nat. Bur. Stand. (U.S.)*, Vol. 89(1): 75-100; 1984 January-February.
9. D. Eitzen, and F. Breckenridge, "Acoustic Emission Sensors and Their Calibration," *Nondestructive Testing Handbook*, Second Edition, Chapter 5, Columbus, OH: American Society for Nondestructive Testing; 1988, 122-134.
10. F. Breckenridge, T. Proctor, N. Hsu, S. Fick, and D. Eitzen, "Transient Sources for Acoustic Emission Work," *Proceedings of the 10th International Acoustic Emission Symposium*, Sendai, Japan, 1990 Oct. 20-25, Progress in Acoustic Emission V, The Japanese Society for NDI; 1990, 20-37.
11. MIL-HDBK-786, Military Standardization Handbook, Field Assurance of Acoustic Emission System Operation Using Simulated Acoustic Emission Events, 1 October 1987.
12. T. Proctor and S. Fick, "Remote Dynamic Contact Force Measurement Using the NBS Conical Transducer," (to be published).

13. F. Breckenridge, T. Proctor, N. Hsu, and D. Eitzen, "Some Notions Concerning the Behavior of Transducers," *Proceedings of the 8th International Acoustic Emission Symposium*, Tokyo, Japan, 1986, Oct. 20-24, Progress in Acoustic Emission III, The Japanese Society for NDI; 1986, 675-684.
14. D. Eitzen, N. Hsu, T. Proctor, and A. Carasso, "Deconvolution by Design: An Approach to the Inverse Problem of Ultrasonic Testing," Technical Activities 1984 - Office of Nondestructive Evaluation, Nat. Bur. Stand. (U.S.). NBSIR 84-2944; 1984 November, 48-49.
15. A. Carasso, and N. Hsu, "The Inverse Gaussian Pulse in the Experimental Determination of Linear System Green's Functions," *Transactions of the Second Army Conference on Applied Mathematics and Computing*. Rensselaer Polytechnic Institute, Troy, NY, 1984 May, ARO Report 85-1, U.S. Army Research Office, Mathematical Science Division, P. O. Box 12211, Research Triangle Park, NC 27709; 1985, 389-404.
16. A. Carasso and N. Hsu, "Probe Waveforms and Deconvolution in the Experimental Determination of Elastic Green's Functions," *SIAM Journal on Applied Mathematics*, Part A, 45(3): 369-382; 1985 June.
17. A. Carasso and N. Hsu, " L^∞ Error Bounds in Partial Deconvolution of the Inverse Gaussian Pulse," *SIAM Journal on Applied Mathematics*, 45(6): 1029-1038; 1985 December.
18. M. Sansalone, N. Carino, and N. Hsu, "A Finite Element Study of Transient Wave Propagation in Plates," *J. Res. Nat. Bur. Stand. (U.S.)*, 92(4): 267-278; 1987 July-August.
19. N. Hsu and D. Eitzen, "Higher-Order Crossings - A New Acoustic Emission Signal Processing Method," *Progress in Acoustic Emission IV, Proceedings of the 9th International Acoustic Emission Symposium*, 1988 November 14-17; Kobe, Japan. Japanese Society for NDI, 1988; 59-66.
20. N. Hsu, D. Eitzen, "Experimental Determination of a Point Impact Force-Time Function," (to be published in *Experimental Mechanics*).
21. N. Hsu and D. Eitzen, "Analytical Approach to Acoustic Emission Signal Processing: Problems and Progress," *Proceedings of the Seventh International Acoustic Emission Symposium*; Sendai, Japan, 1984 October, 23-26. Progress in Acoustic Emission II, The Japanese Society for NDI; 1984, 326-334.
22. N. Hsu, "Fundamental Studies of AE and Their Practical Applications," The 006 Research Committee Special Publication No. 93, Japanese Society of Nondestructive Inspection, Tokyo, Japan; 1990, 1-12.
23. N. Hsu, "Plate Green's Function - A Computer Program and Its Application to Acoustic Emission," *J. of Acoustic Emission*, 5(3): S28; 1986 July-September.

24. N. Hsu and K. Yamaguchi, "A Rational Approach to Acoustic Emission Signal Analysis and System Calibration," *Proceedings of the 10th International Acoustic Emission Symposium*, Sendai, Japan, 1990 Oct. 22-25, Progress in Acoustic Emission V, The Japanese Society for NDI; 1990; 59-66.
25. N. Hsu, S. Fick, and G. Blessing, "Green's Function of a Liquid/Solid Interface and Application to Fluid Coupled Ultrasonic Materials Testing," (to be published in the 1992 *Ultrasonic Symposium Proceedings of the Institute of Electrical and Electronics Engineers*).
26. N. Carino, M. Sansalone, N. Hsu, "Flaw Detection in Concrete by Frequency Spectrum Analysis of Impact-Echo Waveforms," (to be published in *International Advances in Nondestructive Testing*).
27. N. Hsu, G. Chen, and M. Sansalone, "Characterization of a Piezoelectric Transducer Coupled to a Solid," *1987 Ultrasonic Symposium Proceedings*, IEEE Cat. #87CH2492-7, 689-692; 1987.
28. N. Hsu and D. Eitzen, "Point Source/Point Receiver Ultrasonic Wave Speed Measurement," *Proceedings of 1987 Ultrasonic International Conference*, 1987 July 6-9; London, England; 509-513.
29. S. Ren, N. Hsu, and D. Eitzen, "Transient Green's Tensors for a Layered Solid Half-Space With Different Interface Conditions," *The Journal of the Acoustical Society of America*, Sup. 1, Vol. 83, Spring 1988.
30. C. Tschiegg, M. Greenspan, and D. Eitzen, "Ultrasonic Continuous Wave Beam-Power Measurements; International Intercomparison," *J. Res. Nat. Bur. Stand. (U. S.)*; 88(2): 91-103; 1983 March-April.
31. S. Fick, "The NIST Power Reference Source," (to be published in *Ultrasonic Exposimetry*, CRC Press, eds. M. Zisken and P. Lewen).
32. S. Fick, F. Breckenridge, C. Tschiegg, and D. Eitzen, "An Ultrasonic Absolute Power Transfer Standard," *J. Res. Nat. Bur. Stand. (U.S.)*; 89(2); 209-212; 1984 March-April.
33. S. Fick, "Ultrasonic Measurement Services at NIST," *Proceedings of National Conf. of Standards Labs.*, Washington, DC, 1992 August.

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per report, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.

1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE NOV 1992	3. REPORT TYPE AND DATES COVERED Final Report July 1982 - Nov. 1992	
4. TITLE AND SUBTITLE ONR-SPONSORED RESEARCH IN ULTRASONIC MEASUREMENTS AT NIST: 1982-1992			5. FUNDING NUMBERS PE 61153N GO N0001490F0001 TA 4126303	
6. AUTHOR(S) N. H. Hsu, G. V. Blessing, F. R. Breckenridge				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) NIST Gaithersburg, MD 20899			8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) Office of Naval Research Physics Division - Code 1112 800 North Quincy St. Arlington, VA 22217-5660			10. SPONSORING / MONITORING AGENCY REPORT NUMBER	
11. SUPPLEMENTARY NOTES The principal investigator, Franklin R. Breckenridge, retired from NIST on 10/4/91 To be published as a NIST Internal Report				
12a. DISTRIBUTION / AVAILABILITY STATEMENT Approved for public release. Distribution unlimited.			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) This report summarizes the research in ultrasonic measurements at the National Institute of Standards and Technology (NIST) which was supported in part by the Physics Division of the Office of Naval Research from 1982 to 1992. This represents work accomplished since the last such summary report, NBSiR 82-2529, entitled "Ultrasonic Research Summary Report and Literature Guide to the National Bureau of Standards/Office of Naval Research Program." References to the published literature documenting this new work are included.				
14. SUBJECT TERMS ultrasonics, acoustic emission, ultrasonic calibration, ultrasonic standard			15. NUMBER OF PAGES 10	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED	18. SECURITY CLASSIFICATION OF THIS PAGE UNCLASSIFIED	19. SECURITY CLASSIFICATION OF ABSTRACT UNCLASSIFIED	20. LIMITATION OF ABSTRACT	