

REPORT DOCUMENTATION PAGE

Form Approved

OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.

1. AGENCY USE ONLY (Leave blank)	2. REPORT DATE 12/31/96	3. REPORT TYPE AND DATES COVERED Final 8/15/95 - 8/14/96
----------------------------------	----------------------------	---

4. TITLE AND SUBTITLE Diode-Pumped Optical Parametric Oscillator and Optical Frequency Comb Generation at 1.5 um	5. FUNDING NUMBERS 4 F49620-95-1-0505
---	---

6. AUTHOR(S) Dr. Ngai C. Wong	3484/US 61103D
----------------------------------	-------------------

7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Research Laboratory of Electronics Massachusetts Institute of Technology 77 Massachusetts Avenue Cambridge, MA 02139	8. PERFORMING ORGANIZATION AFOSR-TR-97-97 0053
---	--

9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) AFOSR/NE 110 Duncan Avenue, Suite B115 Bolling AFB, DC 20332-0001	AGENCY REPORT NUMBER F49620-95-1-0505
--	--

11. SUPPLEMENTARY NOTES
The view, opinions and/or findings contained in this report are those of the author(s) and should not be construed as an official Department of the Army position, policy, or decision, unless so designated by other documentation.

12a. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution unlimited.	12b. DISTRIBUTION CODE
--	------------------------

1. 19970117 067 (imum 200 words)
An instrumentation grant for the purchase of an tunable diode laser-amplifier, a rf synthesizer, and a rf spectrum analyzer is used to significantly enhance current research and support new investigations in optical parametric oscillators and wide-span optical frequency comb generation. Areas of research that benefit from the new capabilities include precision frequency metrology, optical communications, and multi-wavelength information processing. The fabricated diode laser at 790 nm has been utilized to generate tunable 1.6 μm light using difference-frequency mixing in a quasi-phase matched periodically-poled lithium niobate substrate. It will also be used to pump an optical parametric oscillator for the generation of tunable 1.5-1.6 μm radiation in the mW power range. The spectrum analyzer and synthesizer are to be used for evaluating the beat-note and phase noise characteristics of optical parametric oscillators and optical frequency comb generators.

14. SUBJECT TERMS	15. NUMBER OF PAGES
	16. PRICE CODE

17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED	18. SECURITY CLASSIFICATION OF THIS PAGE UNCLASSIFIED	19. SECURITY CLASSIFICATION OF ABSTRACT UNCLASSIFIED	20. LIMITATION OF ABSTRACT UL
---	--	---	----------------------------------

FINAL REPORT

Diode-Pumped Optical Parametric Oscillator and
Optical Frequency Comb Generation at $1.5 \mu\text{m}$

U. S. Air Force Office of Scientific Research
Grant F49620-95-I-0505

Covering the Period
August 15, 1995 - August 14, 1996

Submitted by

Ngai C. Wong
Principal Investigator

December 19, 1996

Research Laboratory of Electronics
Massachusetts Institute of Technology
Cambridge, Massachusetts 02139

Contents

1	Statement of Work	2
2	Research Summary	3
2.1	Equipment Purchase	3
2.2	Benefits to Current Research	3
2.3	Benefits to Future Research	5
	References	6

1 Statement of Work

An instrumentation grant for the purchase of a tunable diode laser-amplifier, a rf synthesizer, and a rf spectrum analyzer is used to significantly enhance current research and support new investigations in optical parametric oscillators and wide-span optical frequency comb generation. Areas of research that benefit from the new capabilities include precision frequency metrology, optical communications, and multi-wavelength information processing. The fabricated diode laser at 790 nm has been utilized to generate tunable 1.6 μm light using difference-frequency mixing in a quasi-phase matched periodically-poled lithium niobate substrate. It will also be used to pump an optical parametric oscillator for the generation of tunable 1.5–1.6 μm radiation in the mW power range. The spectrum analyzer and synthesizer are to be used for evaluating the beat-note and phase noise characteristics of optical parametric oscillators and optical frequency comb generators.

2 Research Summary

Under AFOSR DURIP-95 Grant F49620-95-I-0505 "Diode-Pumped Optical Parametric Oscillator and Optical Frequency Comb Generation at 1.5 μm ," we have purchased or fabricated the requested equipment items and initiated two research projects that cannot be pursued without the new instruments. In this final report we shall summarize how the new equipment items are to be used in supporting current research and enabling our new investigations.

2.1 Equipment Purchase

Under the instrumentation grant, we purchased three equipment items. The first item is a high-stability, 2-GHz rf synthesizer: HP8643A with options 001 and 002. The second item is a low-noise, 26.5-GHz microwave spectrum analyzer: HP8563E. The third item is a fabricated equipment for a diode laser-amplifier. The diode laser system is based on a design by Dr. Leo Hollberg of the National Institute of Standards and Technology (NIST) at Boulder, Colorado. It consists of a master laser at a center frequency of 790 nm that is used to injection lock a SDL 500-mW diode laser amplifier. The diode system yields a high-power tunable laser source centered at 790 nm. Some of the parts and especially the laser scanning and servo control electronics were purchased from NIST. Phillip Nee, a graduate student, went to NIST to assemble and set up the diode laser system.

2.2 Benefits to Current Research

The rf spectrum analyzer and synthesizer has been used to improve our measurement capability in optical frequency comb (OFC) generation [1] and in phase locking of a optical parametric oscillator (OPO) [2, 3, 4]. In OFC generation, the 26-GHz spec-

trum analyzer is used for monitoring the coupling efficiency of the resonant electro-optic modulator at the modulation frequency of 17 GHz. In addition, the spectrum analyzer makes it possible to detect the beat frequencies between an unknown optical frequency and a sideband of the OFC. The 2-GHz rf synthesizer is used to fill an important gap in our rf source capability that now extends to 26 GHz. It will be used for demodulation of beat notes between the signal and idler outputs of a phase-locked OPO and also in the beat measurements using an OFC. Both the OPO and OFC generation projects are related to ultrahigh precision frequency measurements for use in areas such optical frequency counting and synthesis [5, 6], and optical frequency referencing for dense optical communication networks.

The tunable diode laser-amplifier has been utilized to generate tunable 1.6 μm light by use of difference-frequency mixing in a periodically-poled lithium niobate (PPLN) wafer [7] that is quasi-phase matched for inputs at 790 nm and 1.55 μm . It is currently used in a double difference-frequency mixing experiment for demonstrating an exact 3:1 frequency ratio [8]. The first stage involves the mixing of the diode laser at 798 nm and the second harmonic of a diode-pumped YAG laser at 532 nm in a cesium titanyl arsenate (CTA) crystal to generate an output at 1596 nm [9]. The second stage uses the 798 nm laser and the 1596 nm output from the first stage in a PPLN wafer to generate another 1596 nm output. The two 1596-nm outputs will then be detected using a high speed photodetector to measure their beat note. By tuning the 798 nm diode laser to set the beat note to zero, an exact 3:1 frequency ratio between the two input lasers can be obtained. These experiments are related to optical frequency counting and synthesis and the generation of compact tunable 1.5–1.6 μm source.

2.3 Benefits to Future Research

The new equipment makes possible some new research in nonlinear optics and optical information processing. The diode laser will be used to pump a PPLN-based OPO with cw outputs at 1.5–1.6 μm in the mW range. This diode-pumped OPO source will be useful as a compact tunable source in fiberoptic communications and in high precision measurements. Another important research area is the investigation of a diode-pumped optical parametric amplifier (OPA) for use as an optical frequency shifter in dense wavelength division multiplexed (WDM) communication networks and in multi-wavelength information processing. This OPA-based frequency shifter should have a large bandwidth of ~ 15 THz and high conversion efficiency.

The tunable OPO source will also be used as an input to an OFC at 1.5 μm for the generation of multi-terahertz-span frequency markers. The rf synthesizer and spectrum analyzer will be used for measuring the characteristic of the OFC output.

References

- [1] L. R. Brothers, D. Lee, and N. C. Wong, "Terahertz optical frequency comb generation using a resonant phase-velocity-matched electro-optic modulator," *Opt. Lett.* **19**, 245-247 (1994).
- [2] D. Lee and N. C. Wong, "Tunable optical frequency division using a phase-locked optical parametric oscillator," *Opt. Lett.* **17**, 13-15 (1992).
- [3] D. Lee and N. C. Wong, "Stabilization and tuning of a doubly resonant optical parametric oscillator," *J. Opt. Soc. Am. B* **10**, 1659-1667 (1993).
- [4] Elliott J. Mason, "Self-phase locking in a type-II phase matched optical parametric oscillator," master thesis, M.I.T., 1996.
- [5] N. C. Wong, "Optical frequency counting from the UV to the near IR," *Opt. Lett.* **17**, 1155-1157 (1992).
- [6] N. C. Wong, "Optical-to-microwave frequency chain utilizing a two-laser-based optical parametric oscillator network," *Appl. Phys. B* **61**, 143-149 (1995).
- [7] N. C. Wong, E. Mason, and P. Nee, "Metrological applications of frequency conversion in $\chi^{(2)}$ media," *Quantum Semiclass. Opt.*, to appear.
- [8] N. C. Wong, B. Lai, P. Nee, and E. Mason, "Experimental progress toward realizing a 3:1 optical frequency divider," *Proceedings Fifth Symposium on Frequency Standards and Metrology*, Bergquist, ed., (World Scientific, 1996), pp. 319-326.
- [9] B. Lai, N. C. Wong, and L. K. Cheng, "Continuous-wave tunable light source at 1.06 μm by difference-frequency mixing in CsTiOAsO_4 ," *Opt. Lett.* **20**, 1779-1781 (1995).