

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.0 EXECUTIVE SUMMARY

1986

1.1 INTRODUCTION

This Energy Savings Opportunity Survey (ESOS) at Ft. Bliss, Texas was prepared by Engineering Design & Management, Inc., St. Louis, MO., under contract with the Department of the Army, Fort Worth District, Corps of Engineers.

In summary, the ESOS can be divided into six essentially separate studies. These are:

- 1) Re-evaluate previous ECIP on family housing ceiling insulation.
- 2) Examine 60 to 400 Hz converters for opportunities to reduce utility costs. Review will include examination of alternative technologies, as well as optional utilization of existing stock.
- 3) Examine the possibility of adding additional storage to potable water system to allow pumping during "off peak" hours as defined by local utility. Savings will occur as demand savings.
- 4) Study three "typical" buildings on base for savings due to fenestration improvements. These improvements would include exterior shading, double pane glazing, reflective films, and window area reduction.
- 5) Evaluate the feasibility of down-sizing existing transformers and/or connecting additional load to improve transformer utilization and reduce transformer core energy losses.
- 6) Evaluate the feasibility of implementing several common ECOs at the base. These ECOs would include wall and roof insulation, timeclocks, etc.

*Remarks  
to  
Records  
Unit  
plus*

**DISTRIBUTION STATEMENT R**  
Approved for public release  
Distribution Unlimited

19971023 164

*UNCLASSIFIED*




DEPARTMENT OF THE ARMY  
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS  
P.O. BOX 9005  
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO  
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.  
Distribution A. Approved for public release.

  
Marie Wakefield,  
Librarian Engineering

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.2 BUILDING DATA

The studies that comprise this ESOS cover a wide range of topics, only three of which deal with buildings. In summary:

| <u>ECO</u> | <u>BLDG #</u> | <u>NAME</u>                                 | <u>FUNCTION</u>     | <u>SF</u> | <u>COMPARED BUILDINGS</u>  |
|------------|---------------|---|---------------------|-----------|--|
| 1          | 339 & 340     | MFH   | Single Family       | 1110      | 339 to 343,<br>1468 to 1473  |
| 1          | 317 & 318     | MFH   | Single Family       | 980       | 317 to 338, 344 to<br>351, 353 to 357,<br>1400 to 1413, 1442<br>to 1454                |
| 1          | 408 & 526     |   | Single Family       | 1400      | 400 to 404, 407 to<br>412, 426 to 429,<br>522, 523, 526 to<br>530, 536 to 544          |
| 1          | 413 & 525     |   | Single Family       | 1426      | 301, 303, 406,<br>413, 525, 531  |
| 1          | 1458 & 1460   |   | Single Family       | 1178      | 1457 to 1467, 1474<br>to 1479, 1481 to<br>1488, 2100 to<br>2104, 7183 to<br>7192, 7194 |
| 3          | 112           | Director of<br>Security/<br>Chaplain Admin. |                     | 7500      | (1)  |
| 3          | 515 & 504     | Air Def. Admin.<br>School                   |                     | 5900      | (1)<br>(1)   |
| 3          | 777 & 1014    | -   | Barracks            |           | (1)  |
| 6          | 2             | General Admin. &<br>Instruction             | ClassRooms          | 258,638   | None   |
| 6          | 746           | CW Branch                                   | Training/<br>Admin. | 15,000    | None   |
| 6          | 2322          | -   | Strategy/<br>Admin. | 9,520     | None   |

(1) ECOs proved to be non-feasible. No extrapolation required.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.3 PRESENT ENERGY CONSUMPTION

1.3.1 TOTAL ANNUAL ENERGY USED -

From DEIS II Report FY 86

Non-MFH

| <u>Electricity</u> |        |         |         | <u>Natural Gas</u> |         |         |
|--------------------|--------|---------|---------|--------------------|---------|---------|
| MWH                | MBTU   | \$      | \$/MBTU | MBTU               | \$      | \$/MBTU |
| 110810             | 378195 | 7780132 | 20.63   | 712501             | 2014202 | 2.66    |

MFH

| <u>Electricity</u> |       |         |         | <u>Natural Gas</u> |         |         |
|--------------------|-------|---------|---------|--------------------|---------|---------|
| MWH                | MBTU  | \$      | \$/MBTU | MBTU               | \$      | \$/MBTU |
| 22110              | 75458 | 1608768 | 21.33   | 395686             | 1681715 | 4.12    |

Total

| <u>Electricity</u> |        |         |         | <u>Natural Gas</u> |         |         |
|--------------------|--------|---------|---------|--------------------|---------|---------|
| MWH                | MBTU   | \$      | \$/MBTU | MBTU               | \$      | \$/MBTU |
| 132920             | 453653 | 9388980 | 20.70   | 1108187            | 3695917 | 3.34    |

1.3.2 ENERGY CONSUMPTION OF BUILDINGS IN THIS STUDY

Fuel records for Ft. Bliss are available on a base-wide basis only. That is, individual buildings are not metered, and therefore data for individual buildings in a fuel-by-fuel basis are unavailable.

This study also consisted of studying selected ECOs for implementation. It did not examine all sources of energy into a building, nor did it allow for a computerized energy simulation that could be compared to metered usage.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.4 HISTORICAL ENERGY CONSUMPTION

| <u>Year</u> | <u>Electricity</u> |        | <u>Natural Gas</u> |
|-------------|--------------------|--------|--------------------|
|             | MWH                | MBTU   | MBTU               |
| FY 86       | 132920             | 453653 | 1108187            |

Prior years are not available at time of report printing.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.5 RE-EVALUATED PROJECTS RESULTS - MFH ROOF INSULATION

This study re-examined the possibility of adding additional "blown-in" insulation to selected MFH units at this base.

Ten units representing five basic construction types were studied. Two units of each construction type were analyzed, and the results of each pair were averaged to represent the construction type as a whole. The prior study indicated that the addition of "blown-in" insulation in the ceiling spaces of these facilities was non-feasible.

Significant data used in analyses:

|                             | <u>Prior<br/>Study</u> | <u>EDM, INC.</u> |
|-----------------------------|------------------------|------------------|
| Inside Design Temp (deg. F) | 75                     | 65               |
| Calculation Method per      | 1973 ASHRAE            | 1985 ASHRAE      |
| Insulation Cost             | \$0.0483/in SF         | \$0.09/In SF     |
| Fuel Cost (1)               | \$1.89/1000 CF         | \$4.25/1000 CF   |

(1) 1.035 MBTU/1000 CF

The analysis indicated that this ECO was feasible for three of the five buildings.

| <u>Bldg.</u>  | <u>Each Building</u> |                      | <u>Models Plus<br/>Compared Bldgs</u> |                      | Simple<br>Payback | SIR   |
|---------------|----------------------|----------------------|---------------------------------------|----------------------|-------------------|-------|
|               | Const.<br>Cost (\$)  | NG Svgs<br>(MBTU/Yr) | Const.<br>Cost (\$)                   | NG Svgs<br>(MBTU/Yr) |                   |       |
| 339,340       | 815.79               | 11.55                | 8,974                                 | 127.09               | 17.20             | 1.20  |
| 317,318       | 720.25               | 8.61                 | Non-feasible                          |                      | 21.09             | 1.00  |
| 408,526       | 1200.41              | 18.82                | 37,213                                | 584.56               | 15.53             | 1.33  |
| 413,525       | 1222.71              | 19.17                | 8,559                                 | 134.22               | 15.53             | 1.33  |
| 1458,1460     | 865.77               | 9.25                 | Non-feasible                          |                      | 0.90              | 22.98 |
| Project total |                      |                      | 54,746                                | 845.89               | 15.76             | 1.31  |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.6 ENERGY CONSERVATION ANALYSIS

1.6.1 ECOs INVESTIGATED

1.6.1.1 400 Cycle Converters

In excess of 100 converter sets were examined at six discrete geographic locations. This study included examination of alternative technologies as well as optimizing the utilization of existing sets.

Contacts with several major manufacturers of solid-state converters revealed that they were unwilling to provide budget pricing information without research and development time, as well as specifications. None of the manufacturers contacted presently manufacture equipment suitable for this use.

The converters that are presently being used are motor-generator (MG) sets. These devices are typically quite old. For this reason, operators do not load them more than approximately 50 percent. Above this level there is a rather abrupt decrease in reliability. For this reason, it is not possible to connect several launchers to a MG to fully load it and take advantage of increased efficiency at full load.

In addition to the reliability problem, connecting multiple launchers to a single MG is also hampered by the cross-talk that can occur between launchers connected to a single MG. A further complication is the fact that transmission losses through conductors at 400 Hz is very high. Therefore, launchers would have to be set up quite close together. For these reasons, connecting multiple launchers to a single MG was not examined.

The potential solution that was examined was the replacement of existing MG sets with new, more efficient MG sets. Efficiency increases of 22 to 28% can be expected depending on MG size.

Summary of Economic Analysis by site is as follows:

| <u>Site</u>    | <u>First Cost</u> | <u>Savings<br/>(MBTU/Yr)</u> | <u>Simple<br/>Payback</u> | <u>SIR</u> |
|----------------|-------------------|------------------------------|---------------------------|------------|
| 5800 Area      | 190,866           | 341                          | 27.15                     | 0.49       |
| 700 Area       | 1,852,858         | 684                          | 128.60                    | 0.10       |
| McGregor Range | 1,423,673         | 278                          | 247.07                    | 0.05       |
| 1000 Area      | 381,454           | 81                           | 228.84                    | 0.06       |
| 3700 Area -    |                   |                              |                           |            |
| Tobin Wells    | 2,050,082         | 471                          | 193.04                    | 0.07       |
| Hawk Park Area | 1,202,523         | 1208                         | 36.94                     | 0.36       |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.6.1.2 Water Distribution/Savings

A study was performed to examine the feasibility of reducing electric utility demand costs by eliminating pumping demand during peak periods. This can be accomplished by adding additional storage and utilizing off-peak pumping to fill them, or by adding diesel power plants to reduce demand.

For the storage option, several different alternatives were examined as possible solutions. The alternatives refer to various combinations of tank size and location, the purpose of which is to determine optimal conditions for demand savings. The alternates "A" and "B" relate to different amounts of storage and savings at the same location. Note that in this portion of the study, all savings come as demand savings not energy savings. Therefore, ECIP criteria are not met.

Summary of Water Distribution/Storage Data

| <u>Alternate</u> | <u>Tank Size (MG)</u> | <u>Location Adjacent To Bldg.</u> | <u>Const. Cost (\$)</u> | <u>Yearly Demand Savings (\$)</u> | <u>Simple Payback</u> | <u>SIR</u> |
|------------------|-----------------------|-----------------------------------|-------------------------|-----------------------------------|-----------------------|------------|
| 1A               | 2.75                  | 7090                              | 1,002,421               | 56,592                            | 25.09                 | 0.48       |
| 1B               | 1.20                  | 7090                              | 561,650                 | 36,218                            | 19.42                 | 0.61       |
| 2A               | 1.50                  | 7090                              | 670,356                 | 28,409                            | 34.66                 | 0.35       |
| 2B               | 0.60                  | 7090                              | 349,616                 | 21,618                            | 19.47                 | 0.61       |
| 3                | 0.30                  | 7241                              | 251,667                 | 15,091                            | 19.00                 | 0.62       |
| 4                | 0.20                  | 7776                              | 213,733                 | 8,054                             | 31.29                 | 0.38       |
| 5                | 0.20                  | 11172                             | 213,733                 | 11,318                            | 21.20                 | 0.56       |

MG = Million Gallons

Summary of Diesel Power Plant Option:

| <u>Const Cost (\$)</u> | <u>Savings (MBTU/Yr)</u> |           | <u>Demand Savings (\$)</u> | <u>Simple Payback</u> | <u>SIR</u> |
|------------------------|--------------------------|-----------|----------------------------|-----------------------|------------|
|                        | <u>Elec.</u>             | <u>NG</u> |                            |                       |            |
| 309,629                | 12,118                   | (12,118)  | 86,032                     | --                    | -6.42      |

1.6.1.3 Fenestration

Five buildings were examined for the installation of various ECOs that would limit the contribution of the windows to the heating and cooling load of the buildings. These ECOs are:

1. Add solar film.
2. Replace glazing with insulating glass.
3. External shading
4. Close 50% of window openings.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

Solar Film

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |     | SIR   | Simple Payback |
|----------|------------------------|-------------------|-----|-------|----------------|
|          |                        | Elec              | NG  |       |                |
| 515      | 20144                  | 2                 | -14 | -0.01 | --             |
| 777      | 30988                  | 10                | -54 | -0.01 | --             |
| 112      | 4229                   | 1                 | - 2 | 0.01  | 606.29         |
| 504      | 20144                  | 1                 | -18 | -0.03 | --             |
| 1014     | 30988                  | 13                | -34 | 0.06  | 168.09         |

Insulating Glass

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|----------|------------------------|-------------------|----|------|----------------|
|          |                        | Elec              | NG |      |                |
| 515      | 15445                  | -1                | 33 | 0.10 | 234.83         |
| 777      | 23760                  | -2                | 61 | 0.12 | 189.23         |
| 112      | 3243                   | -0.4              | 6  | 0.06 | 542.33         |
| 504      | 30988                  | -1                | 36 | 0.05 | 457.29         |
| 1014     | 15445                  | 6                 | 67 | 0.34 | 52.36          |

External Shading

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |     | SIR   | Simple Payback |
|----------|------------------------|-------------------|-----|-------|----------------|
|          |                        | Elec              | NG  |       |                |
| 515 (1)  |                        |                   |     |       |                |
| 777      | 23038                  | 9                 | -51 | -0.01 | --             |
| 112 (1)  |                        |                   |     |       |                |
| 504 (1)  |                        |                   |     |       |                |
| 1014     | 23038                  | 10                | -49 | 0.01  | 268.83         |

50% Closure

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|----------|------------------------|-------------------|----|------|----------------|
|          |                        | Elec              | NG |      |                |
| 515 (1)  |                        |                   |    |      |                |
| 777      | 39751                  | 10                | 33 | 0.11 | 139.96         |
| 112 (1)  |                        |                   |    |      |                |
| 504 (1)  |                        |                   |    |      |                |
| 1014     | 39751                  | 13                | 62 | 0.16 | 97.77          |

(1) Building is an historical structure. This ECO was not examined for this building due to its effect on the appearance of the building.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.6.1.4 Transformer Study

Six pad-mounted transformers were examined for this study. Recorders were attached to the transformers in order to determine the maximum load imposed on the transformers. This peak load would be compared to the transformer nameplate in order to determine the feasibility of improving transformer utilization and reducing transformer core losses.

The Contractor determined that it is not economically feasible to replace an oversized transformer with a properly sized transformer.

Transformer losses are comprised of core losses and winding losses. The core losses are related to the amount and type of core in the transformer, and therefore do not vary with transformer loading, but with transformer size. Winding losses vary with the load squared. For example, if the load on a transformer would double, the effective winding loss would go up by a factor of four.

Savings due to a reduction of transformer size would therefore be the difference between the energy saved in core losses and the energy costs in increased winding losses. This analysis indicates that this balance is negative and a properly sized unit would consume more energy than an oversized unit. This conclusion is not meant to imply that transformers should all be oversized. It is important to note that first costs were not studied here. The point is, that if a transformer is oversized for a certain load, it is not economically feasible to replace it with a properly sized unit for no other reason than energy savings.

In one case (building 5800), two transformers were studied at a single building. Both transformers were under loaded. The study determined that if the loads could be connected, energy savings were available. This is possible because the removal of one of the transformers deletes its associated core loss entirely. The increase in winding losses for the more fully utilized transformer is not sufficient to negate the savings in core losses. This type of transformer arrangement should be studied further to determine if it could be implemented on a base-wide basis.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.6.1.5 Annex A ECOs

Three buildings were examined at the base in order to determine if implementing various ECOs are economically feasible. These ECOs are:

1. Add weatherstripping to windows/doors.
2. Add vestibule to frequently used doors.
3. Add wall insulation.
4. Add roof insulation.
5. Replace single pane windows with double pane.
6. Reduce glass area by 50%
  - insulated panels
  - infill windows
7. Replace incandescent lighting with more efficient source.
8. Replace standard efficiency lamps with high efficiency type (fluorescent).
9. Replace lamps with more efficient source.
10. Add time clocks to DHW systems.
11. Add night setback to heating systems.
12. Add time clocks to cooling systems.
13. Add oxygen trim controls to boilers.
14. Add controls for multiple boiler optimization.
15. Add fans to destratify air in high bay areas.
16. Steam trap inspection program.

Weatherstripping

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |        | SIR  | Simple Payback |
|----------|------------------------|-------------------|--------|------|----------------|
|          |                        | Elec              | NG     |      |                |
| 2A       | 12,146                 | 0.7               | 31.7   | 0.07 | 123.12         |
| 2B       | 1,116                  | 0.9               | 31.7   | 0.82 | 10.87          |
| 2C       | 5,500                  | 0.2               | 9.5    | 0.05 | 190.31         |
| 2D       | 5,454                  | 0.2               | 9.6    | 0.05 | 182.43         |
| 2E       | 5,856                  | 0.2               | 9.6    | 0.05 | 195.87         |
| 746-1    | 1,312                  | 1.29              | 48.9   | 1.06 | 8.39           |
| 746-2    | 1,312                  | 1.29              | 48.9   | 1.06 | 8.39           |
| 746-3    | 117                    | 0.36              | 16.2   | 3.86 | 2.29           |
| 2322-1   | 1,535                  | --                | 209.67 | 3.34 | 2.76           |
| 2322-2   | 196                    | 0.10              | --     | 0.08 | 98.50          |

Vestibule

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |      | SIR  | Simple Payback |
|----------|------------------------|-------------------|------|------|----------------|
|          |                        | Elec              | NG   |      |                |
| 2A       | 20,388                 | 1.9               | 31.5 | 0.11 | 166.33         |
| 2B       | 16,321                 | 2.5               | 40.3 | 0.18 | 103.01         |
| 746-1    | 17,677                 | 2.0               | 41.5 | 0.37 | 49.83          |
| 2322-1   | 4,546                  | --                | 3.2  | 0.04 | 570.25         |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

Wall Insulation

| Building | Construction Cost (\$)                 | Savings (MBTU/Yr) |       |      | Simple Payback |
|----------|--|-------------------|-------|------|----------------|
|          |  | Elec              | NG    | SIR  |                |
| 2A       | 32,672                                 | 5.7               | 249.2 | 0.46 | 42.75          |
| 2B       | 41,107                                 | 6.2               | 202.2 | 0.31 | 61.94          |
| 2C       | 34,149                                 | 5.0               | 255.3 | 0.45 | 43.82          |
| 2D       | 34,217                                 | 6.6               | 255.8 | 0.46 | 42.03          |
| 2E       | 33,323                                 | 4.9               | 249.6 | 0.45 | 43.77          |
| 746-1    | 11,397                                 | 3.5               | 108.2 | 0.60 | 32.68          |
| 746-2    | 11,397                                 | 3.0               | 108.2 | 0.59 | 32.68          |
| 746-3    | 1,522                                  | 0.2               | 14.4  | 0.55 | 36.36          |
| 2322-1   | Present insulation meets DOD standards |                   |       |      |                |
| 2322-2   | 5,867                                  | 0.6               | 30.5  | 0.47 | 41.29          |

Roof Insulation

| Building | Construction Cost (\$)                 | Savings (MBTU/Yr) |      |      | Simple Payback |
|----------|--|-------------------|------|------|----------------|
|          |  | Elec              | NG   | SIR  |                |
| 2A       | 38,042                                 | 0.9               | 38.6 | 0.06 | 315.50         |
| 2B       | 50,868                                 | 2.8               | 95.5 | 0.12 | 163.61         |
| 2C       | 79,272                                 | 1.5               | 80.4 | 0.06 | 324.69         |
| 2D       | 79,272                                 | 2.0               | 80.4 | 0.06 | 311.96         |
| 2E       | 79,272                                 | 1.5               | 80.4 | 0.06 | 324.69         |
| 746-1    | 5,614                                  | 0.1               | 4.9  | 0.05 | 375.60         |
| 746-2    | 5,614                                  | 0.1               | 4.9  | 0.05 | 375.60         |
| 746-3    | 1,735                                  | --                | 1.0  | 0.03 | 580.33         |
| 2322-1   | Present insulation meets DOD standards |                   |      |      |                |
| 2322-2   | 11,474                                 | 1.8               | 88.6 | 0.47 | 42.18          |

Double Glazing

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |       |      | Simple Payback |
|----------|------------------------|-------------------|-------|------|----------------|
|          |                        | Elec              | NG    | SIR  |                |
| 2A       | 75,200                 | 4.2               | 111.0 | 0.15 | 133.56         |
| 2B       | 3,820                  | 0.2               | 6.7   | 0.11 | 174.23         |
| 2C       | 107,084                | 3.8               | 196.9 | 0.11 | 178.50         |
| 2D       | 106,578                | 4.9               | 192.3 | 0.11 | 174.47         |
| 2E       | 113,249                | 4.0               | 204.8 | 0.11 | 181.25         |
| 746-1    | 6,952                  | 0.6               | 21.7  | 0.19 | 99.66          |
| 746-2    | 6,952                  | 0.6               | 21.7  | 0.19 | 99.66          |
| 746-3    | 2,669                  | 0.1               | 7.7   | 0.17 | 116.43         |
| 2322-1   | 12,219                 | --                | 15.7  | 0.07 | 291.95         |
| 2322-2   | 11,587                 | 0.1               | 6.7   | 0.25 | 79.65          |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

Glass Area Reduction - Insulated Panels

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |       | SIR  | Simple Payback |
|----------|------------------------|-------------------|-------|------|----------------|
|          |                        | Elec              | NG    |      |                |
| 2A       | 36,361                 | 8.5               | 130.6 | 0.26 | 69.77          |
| 2B       | 1,848                  | 0.7               | 5.5   | 0.27 | 63.93          |
| 2C       | 51,778                 | 9.3               | 188.1 | 0.25 | 75.09          |
| 2D       | 51,533                 | 12.3              | 187.5 | 0.26 | 68.77          |
| 2E       | 54,766                 | 10.1              | 194.4 | 0.25 | 75.49          |
| 746-1    | 3,368                  | 2.1               | 20.0  | 0.50 | 34.85          |
| 746-2    | 3,368                  | 2.1               | 20.0  | 0.50 | 34.85          |
| 746-3    | 1,292                  | 0.5               | 7.8   | 0.44 | 41.84          |
| 2322-1   | 5,908                  | --                | 12.0  | 0.11 | 185.28         |
| 2322-2   | 774                    | 0.3               | 5.2   | 0.47 | 38.85          |

Glass Area Reduction - Infill Windows

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |       | SIR  | Simple Payback |
|----------|------------------------|-------------------|-------|------|----------------|
|          |                        | Elec              | NG    |      |                |
| 2A       | 19,965                 | 8.5               | 130.6 | 0.47 | 38.31          |
| 2B       | 1,015                  | 0.7               | 5.5   | 0.49 | 35.14          |
| 2C       | 28,431                 | 9.3               | 188.1 | 0.45 | 41.23          |
| 2D       | 28,298                 | 12.3              | 187.5 | 0.48 | 37.76          |
| 2E       | 30,071                 | 10.1              | 195.4 | 0.45 | 41.45          |
| 746-1    | 1,851                  | 2.1               | 20.0  | 0.90 | 19.14          |
| 746-2    | 1,851                  | 2.1               | 20.0  | 0.90 | 19.14          |
| 746-3    | 708                    | 0.5               | 7.8   | 0.80 | 22.90          |
| 2322-1   | 3,245                  | --                | 12.0  | 0.20 | 101.75         |
| 2322-2   | 425                    | 0.3               | 5.2   | 0.86 | 21.30          |

Replace Incandescent Lighting with More Efficient Sources

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|----------|------------------------|-------------------|----|------|----------------|
|          |                        | Elec              | NG |      |                |
| 2        | 3,996                  | 2.52              | -- | 0.42 | 29.93          |
| 746      | 1,432                  | 0.4               | -- | 0.33 | 36.85          |
| 2322     | 15,636                 | 2.46              | -- | 4.56 | 2.93           |

Replace Standard Efficiency Lamps with High Efficiency Type

| Building  | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|-----------|------------------------|-------------------|----|------|----------------|
|           |                        | Elec              | NG |      |                |
| 2         | 15,466                 | 181               | -- | 1.38 | 4.16           |
| 746-1,2,3 | 2,348                  | 37                | -- | 1.86 | 3.09           |
| 746-3     | 490                    | 4                 | -- | 1.08 | 5.35           |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

Replace Lamps with More Efficient Source

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|----------|------------------------|-------------------|----|------|----------------|
|          |                        | Elec              | NG |      |                |
| 746-1,2  | 17,684                 | 89                | -- | 3.95 | 3.09           |

Time Clock on DHW Systems

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR   | Simple Payback |
|----------|------------------------|-------------------|----|-------|----------------|
|          |                        | Elec              | NG |       |                |
| 2(1)     | 4,382                  | 101               | 79 | 7.34  | 1.92           |
| 2(2)     | 991                    | 101               | 1  | 28.16 | 0.48           |
| 2(3)     | 3,392                  | --                | 79 | 1.27  | 16.29          |

- (1) Includes reduction of DHW supply temperature, addition of booster heater and time clock.
- (2) Time Clock Only
- (3) Reduction of DHW supply temperature and addition of booster heater.

Night Setback - Heating

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |       | SIR   | Simple Payback |
|----------|------------------------|-------------------|-------|-------|----------------|
|          |                        | Elec              | NG    |       |                |
| 2A       | 7,667                  | --                | 392.0 | 1.83  | 7.38           |
| 2B       | 1,743                  | --                | 214.7 | 4.42  | 3.06           |
| 2C       | 1,743                  | --                | 446.9 | 9.18  | 1.47           |
| 2D       | 5,303                  | --                | 389.1 | 2.63  | 5.14           |
| 2E       | 2,891                  | --                | 452.4 | 5.60  | 2.41           |
| 746-1    | 866                    | --                | 125.8 | 5.21  | 2.59           |
| 746-2    | 866                    | --                | 125.8 | 5.21  | 2.59           |
| 746-3    | 324                    | --                | 80.6  | 8.95  | 1.51           |
| 2322-1   | 324                    | --                | 117.3 | 12.93 | 1.05           |
| 2322-2   | 216                    | --                | 60.4  | 9.95  | 1.36           |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

Time Clocks - Cooling

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR   | Simple Payback |
|----------|------------------------|-------------------|----|-------|----------------|
|          |                        | Elec              | NG |       |                |
| 2A       | 269                    | 22.6              | -- | 17.79 | 0.57           |
| 2B       | 269                    | 12.4              | -- | 9.28  | 1.09           |
| 2C       | 538                    | 25.8              | -- | 10.05 | 1.01           |
| 2D       | 538                    | 22.4              | -- | 8.51  | 1.19           |
| 2E       | 538                    | 26.1              | -- | 10.05 | 1.01           |
| 746-1    | 807                    | 6.3               | -- | 1.55  | 6.53           |
| 746-2    | 807                    | 6.3               | -- | 1.55  | 6.53           |
| 746-3    | 135                    | 4.0               | -- | 6.16  | 1.63           |
| 2322-1   | Space is not cooled    |                   |    |       |                |
| 2322-2   | 135                    | 3.3               |    | 4.62  | 2.18           |

Revise Oxygen Trim Controls

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |       | SIR  | Simple Payback |
|----------|------------------------|-------------------|-------|------|----------------|
|          |                        | Elec              | NG    |      |                |
| 2        | 32,664                 | --                | 606.2 | 0.66 | 20.33          |
| 746      | 16,332                 | --                | 112.9 | 0.25 | 54.63          |

Boiler Optimization

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |       | SIR  | Simple Payback |
|----------|------------------------|-------------------|-------|------|----------------|
|          |                        | Elec              | NG    |      |                |
| 2        | 5,716                  | --                | 242.5 | 1.52 | 8.89           |

Prevent Air Stratification

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |       | SIR  | Simple Payback |
|----------|------------------------|-------------------|-------|------|----------------|
|          |                        | Elec              | NG    |      |                |
| 746-1    | 1,620                  | - 2.03            | 30.63 | 0.69 | 40.65          |
| 746-2    | 1,620                  | - 2.03            | 30.63 | 0.69 | 40.65          |

Steam Trap Inspection

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |       | SIR  | Simple Payback |
|----------|------------------------|-------------------|-------|------|----------------|
|          |                        | Elec              | NG    |      |                |
| 2A       | 2,557                  | -                 | 143.4 | 1.37 | 6.73           |
| 2B       | 637                    | -                 | 45.5  | 1.75 | 5.28           |
| 2C       | 882                    | -                 | 36.69 | 1.02 | 9.03           |
| 2D       | 1,017                  | -                 | 52.33 | 1.26 | 7.35           |
| 2E       | 1,017                  | -                 | 52.33 | 1.26 | 7.35           |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.6.2 RECOMMENDED ECOs

The following projects are feasible projects and will be incorporated into funding documents as part of this contract. Funding documents are provided under separate cover.

Weatherstripping

| Building  | Construction Cost (\$) | Savings (MBTU/Yr) |       | SIR  | Simple Payback |
|-----------|------------------------|-------------------|-------|------|----------------|
|           |                        | Elec              | NG    |      |                |
| 746 zn 3  | 117                    | 0.36              | 16.2  | 3.86 | 2.29           |
| 2322 zn 1 | 1,535                  | -                 | 210.0 | 3.34 | 2.76           |

Replace Standard with Energy Efficient Lamps

| Building              | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|-----------------------|------------------------|-------------------|----|------|----------------|
|                       |                        | Elec              | NG |      |                |
| 2, zones<br>A,B,C,D,E | 15,466                 | 181               | -  | 1.38 | 4.16           |

Replace Incandescent Lighting with Fluorescent

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|----------|------------------------|-------------------|----|------|----------------|
|          |                        | Elec              | NG |      |                |
| 2322     | 15,636                 | 246               | -  | 4.56 | 2.92           |

Replace Fluorescent with Metal Halide

| Building | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|----------|------------------------|-------------------|----|------|----------------|
|          |                        | Elec              | NG |      |                |
| 746      | 17,684                 | 89                | -  | 3.95 | 3.09           |

Reduce DHW Supply Temperature & Add Time Clocks

| Building              | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR  | Simple Payback |
|-----------------------|------------------------|-------------------|----|------|----------------|
|                       |                        | Elec              | NG |      |                |
| 2, zones<br>A,B,C,D,E | 4,382                  | 101               | 79 | 7.34 | 1.92           |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

Install Night Setback - Heating

| Building                  | Construction Cost (\$) | Savings (MBTU/Yr) |      | SIR   | Simple Payback |
|---------------------------|------------------------|-------------------|------|-------|----------------|
|                           |                        | Elec              | NG   |       |                |
| 2, zones<br>A, B, C, D, E | 19,349                 |                   | 1895 | 3.51  | 3.85           |
| 7463-1, 2, 3              | 2,056                  | --                | 332  | 5.79  | 2.33           |
| 2322-1, 2                 | 540                    | --                | 178  | 11.78 | 1.14           |

Install Time Clocks - Cooling

| Building                  | Construction Cost (\$) | Savings (MBTU/Yr) |    | SIR   | Simple Payback |
|---------------------------|------------------------|-------------------|----|-------|----------------|
|                           |                        | Elec              | NG |       |                |
| 2, zones<br>A, B, C, D, E | 2,152                  | 109               | -  | 10.57 | 0.95           |
| 746, zones<br>1, 2, 3     | 1,749                  | 17                | -  | 1.97  | 5.13           |
| 2322, zn 2                | 135                    | 3                 | -  | 5.09  | 1.99           |

Boiler Optimization

| Building                  | Construction Cost (\$) | Savings (MBTU/Yr) |     | SIR  | Simple Payback |
|---------------------------|------------------------|-------------------|-----|------|----------------|
|                           |                        | Elec              | NG  |      |                |
| 2, zones<br>A, B, C, D, E | 5,716                  | -                 | 243 | 1.52 | 8.88           |

Steam Trap Inspection

| Building                  | Construction Cost (\$) | Savings (MBTU/Yr) |     | SIR  | Simple Payback |
|---------------------------|------------------------|-------------------|-----|------|----------------|
|                           |                        | Elec              | NG  |      |                |
| 2, zones<br>A, B, C, D, E | 6,110                  | -                 | 330 | 1.32 | 6.98           |

1.6.3 NON-FEASIBLE ECOs

All projects in Section 1.6.1 whose SIR is less than one are, by definition, economically non-feasible. However, several projects listed in the Scope of Work were disqualified for various reasons. These potential ECOs are listed below:

Loading Dock Seals - Building architecture and use are not consistent with the implementation of this ECO.

Air Curtains - Building architecture and use are not consistent with the implementation of this ECO.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

Reduce Lighting Levels - Measured footcandle readings taken during field survey were below allowable standards.

Radiator Controls - Existing heating units are thermostatically controlled.

Revise or Repair Building HVAC Controls -  
Time clocks and night setback have been studied as upgrades to the existing control system. It was not possible for the Contractor, within the scope of the contract, to effect a detailed testing of individual control components.

Infrared Heaters - Building functions under study will not utilize benefits of infrared heaters.

Chiller Replacement - Buildings studied as part of this contract do not have chillers.

Waste Heat Recovery - No opportunities for this ECO were found during the field surveys.

1.6.4 ECIP PROJECTS DEVELOPED

Two ECIP projects were developed under this contract.

1. Roof Insulation at MFH - add blown-in insulation as required to meet DOD 4270.1-M criteria.

|                              |                        |
|------------------------------|------------------------|
| Estimated Project Costs      | \$64,900               |
| Estimated Project Savings NG | 850 MBTU/YR \$3,500/YR |
| Simple Payback               | 17.6 Years             |
| SIR                          | 1.3                    |

2. Annex A ECO's - Implement common ECO's with positive payback.

|                           |                   |
|---------------------------|-------------------|
| Estimated Project Costs   | \$92,627          |
| Estimated Project Savings | \$24,135          |
| Simple Payback            | Less than 4 Years |

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.7 ENERGY AND COST SAVINGS

1.7.1 TOTAL POTENTIAL ENERGY AND COST SAVINGS

Savings potential from implementing the projects in Section 1.6.4 are as follows:

|            | <u>Energy (MBTU/Yr)</u> |           | <u>\$</u>   |           |
|------------|-------------------------|-----------|-------------|-----------|
|            | <u>Elec</u>             | <u>NG</u> | <u>Elec</u> | <u>NG</u> |
| Project #1 | --                      | 850       | --          | 3,500     |
| Project #2 | 746                     | 3,283     | 15,400      | 8,735     |

1.7.2 PERCENTAGE OF ENERGY CONSERVED

When analyzing the effects of these ECOs on base-wide consumption, it is necessary to keep in mind that this ESDS was conducted on a very small percentage of this facilities' inventory.

|            | <u>Total</u> |           | <u>Electricity</u> |           | <u>Natural Gas</u> |           |
|------------|--------------|-----------|--------------------|-----------|--------------------|-----------|
|            | <u>MBTU</u>  | <u>\$</u> | <u>MBTU</u>        | <u>\$</u> | <u>MBTU</u>        | <u>\$</u> |
| Base Total | 1561740      | 13084897  | 453653             | 9388980   | 1108187            | 3695917   |
| Project #1 | 850          | 3500      | --                 | --        | 850                | 3500      |
| Project #2 | 4029         | 24135     | 746                | 15400     | 3283               | 8735      |

As indicated in paragraph 1.3.2, energy consumption records are not available for individual buildings at this base.

Estimated savings therefore will be calculated as a percentage of the energy originally consumed for that purpose. For example, lighting savings will be given as a percentage of the electricity initially used for lighting only. Initial consumption would not include electricity required for coffee makers, pencil sharpeners, etc.

Initial consumption and anticipated savings for each programmed project are:

Project #1 - Insulate Military Family Housing

|                     |               |     |
|---------------------|---------------|-----|
| Initial Consumption | -NG (MBTU/Yr) | 991 |
| Savings             | -NG (MBTU/Yr) | 846 |
| Savings             | -%            | 85  |

Note that the basis for the initial consumption is the roof only.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

Project #2 - Annex A ECOs

| Bldg. | INITIAL CONSUMPTION |                   | SAVINGS         |                   | SAVINGS % |           |
|-------|---------------------|-------------------|-----------------|-------------------|-----------|-----------|
|       | NG<br>(MBTU/Yr)     | ELEC<br>(MBTU/Yr) | NG<br>(MBTU/Yr) | ELEC<br>(MBTU/Yr) | NG        | ELEC      |
| 2     | 4990                | 1769              | 2468            | 391               | 49        | 22        |
| 746   | 1203                | 323               | 348             | 106               | 29        | 33        |
| 2322  | <u>849</u>          | <u>326</u>        | <u>388</u>      | <u>249</u>        | <u>46</u> | <u>76</u> |
|       | 7042                | 2418              | 3283            | 746               | 47        | 31        |

Note that the savings listed for Project #2 includes all feasible ECOs listed in the funding documentation except for gas savings associated with domestic hot water. Due to the difficulties associated with calculating the total energy actually consumed in the production of domestic hot water, that information has been omitted from this summary information. Per the guidance given in CR82.030 Standardized EMCS Energy Savings Calculations, domestic hot water algorithms calculate savings only.

ENERGY SAVINGS OPPORTUNITY SURVEY  
FORT BLISS, TEXAS

1.7 ENERGY AND COST SAVINGS

1.7.1 TOTAL POTENTIAL ENERGY AND COST SAVINGS

Savings potential from implementing the projects in Section 1.6.4 are as follows:

|            | <u>Energy (MBTU/yr)</u> |           | <u>\$</u>   |           |
|------------|-------------------------|-----------|-------------|-----------|
|            | <u>Elec</u>             | <u>NG</u> | <u>Elec</u> | <u>NG</u> |
| Project #1 | --                      | 850       | --          | 3500      |
| Project #2 | 746                     | 3,283     | 15,400      | 8735      |

1.7.2 PERCENTAGE OF ENERGY CONSERVED

When analyzing the effects of these ECO's on base wide consumption, it is necessary to keep in mind that this ESOS was conducted on a very small percentage of this facilities inventory.

|            | <u>Total</u> |           | <u>Electricity</u> |           | <u>Natural Gas</u> |           |
|------------|--------------|-----------|--------------------|-----------|--------------------|-----------|
|            | <u>MBTU</u>  | <u>\$</u> | <u>MBTU</u>        | <u>\$</u> | <u>MBTU</u>        | <u>\$</u> |
| Base Total | 1561740      | 13084897  | 453653             | 9388980   | 1108187            | 3695917   |
| Project #1 | 850          | 3500      | --                 | --        | 850                | 3500      |
| Project #2 | 4029         | 24135     | 746                | 15400     | 3283               | 8735      |