

USARIEM Technical Report T01-13

**SOLAR LOAD INPUTS FOR USARIEM THERMAL STRAIN  
MODELS AND THE SOLAR RADIATION-SENSITIVE  
COMPONENTS OF THE WBGT INDEX**

William T. Matthew  
William R. Santee  
Larry G. Berglund

Biophysics and Biomedical Modeling Division

**DISTRIBUTION STATEMENT A**  
Approved for Public Release  
Distribution Unlimited

June 2001

U.S. Army Research Institute of Environmental Medicine  
Natick, MA 01760-5007

20010718 088

# REPORT DOCUMENTATION PAGE

*Form Approved*  
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.

1. AGENCY USE ONLY (Leave blank)	2. REPORT DATE June 2001	3. REPORT TYPE AND DATES COVERED Technical Report	
4. TITLE AND SUBTITLE SOLAR LOAD INPUTS FOR USARIEM THERMAL STRAIN MODELS AND THE SOLAR RADIATION-SENSITIVE COMPONENTS OF THE WBGT INDEX		5. FUNDING NUMBERS	
6. AUTHOR(S) WILLIAM T. MATTHEW, WILLIAM R. SANTEE AND LARRY G. BERGLUND		8. PERFORMING ORGANIZATION REPORT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) U.S. Army Research Institute of Environmental Medicine Kansas Street Natick, MA 01760-5007t		10. SPONSORING / MONITORING AGENCY REPORT NUMBER	
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) U.S. Army Medical Research and Materiel Command Fort Detrick, MD 21702-5007		11. SUPPLEMENTARY NOTES	
12a. DISTRIBUTION / AVAILABILITY STATEMENT Approved for public release; distribution unlimited		12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words)  This report describes processes we have implemented to use global pyranometer-based estimates of mean radiant temperature as the common solar load input for the Scenario model, the USARIEM heat strain model, and for the computation of the solar radiation sensitive components of the Wet Bulb Globe Temperature (WBGT) index. For estimating mean radiant temperature from weather station pyranometer data we propose:  $T_{mrk} = [T_{dbk}^4 + (Py(1 + a_{gr}) + \epsilon_{gr} \cdot \sigma (T_{grk}^4 - T_{dbk}^4)) / 2\sigma]^{1/4} \quad ^\circ K$ where $T_{mrk}$ is the mean radiant temperature in $^\circ K$ , $Py$ is the Pyranometer reading in $W \cdot m^{-2}$ , $T_{dbk}$ is dry bulb temperature in $^\circ K$ , $T_{grk}$ is ground surface temperature in $^\circ K$ , $\epsilon_{gr}$ is ground surface emissivity, $a_{gr}$ is ground surface albedo, and $\sigma$ is the Boltzman constant, $5.67 \times 10^{-8} W \cdot m^{-2} \cdot ^\circ K^4$ .  To replace the category-based solar load inputs to the USARIEM heat strain model, we propose a continuous function:  $R_{sol} = -0.071(T_{mr} - T_{db})^2 + 10.432(T_{mr} - T_{db}) \quad \text{Watts}$ where $R_{sol}$ is the total radiant load impinging on the outer surface of clothing in Watts, $T_{mr}$ is the mean radiant temperature in $^\circ C$ , and $T_{db}$ is dry bulb temperature in $^\circ C$ .			
14. SUBJECT TERMS Mean Radiant Temperature, WBGT, Thermal Strain Models, Solar Load		15. NUMBER OF PAGES 22	
17. SECURITY CLASSIFICATION OF REPORT U		16. PRICE CODE	
18. SECURITY CLASSIFICATION OF THIS PAGE U	19. SECURITY CLASSIFICATION OF ABSTRACT U	20. LIMITATION OF ABSTRACT U	

## **Disclaimer**

**Approved for public release; distribution is unlimited. The opinions or assertions contained herein are the primate views of the author(s) and are not to be construed as official or as reflecting the views of the Army or the Department of Defense**

**Citations of commercial organizations and trade names in this report do not constitute an official Department of the Army endorsement or approval of the products or services of these organizations.**

## **DTIC AVAILABILITY NOTICE**

**Qualified requestors may obtain copies of this report from Commander, Defense Technical Information Center (DTIC), (formally DCC), Cameron Station, Alexandria, Virginia 22314**

## TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
LIST OF FIGURES.....	iv
LIST OF TABLES.....	iv
EXECUTIVE SUMMARY.....	1
INTRODUCTION.....	2
OVERVIEW.....	2
Scenario Model.....	2
USARIEM Heat Strain Model.....	2
Statement of the Problem.....	3
OBJECTIVES AND APPROACH.....	3
Objectives.....	3
Approach.....	4
METHODS.....	4
ANALYTICAL PROCEDURES AND SENSOR SYSTEMS.....	4
RESULTS.....	5
USARIEM MODEL AND PYRANOMETER DATA.....	5
MEAN RADIANT TEMPERATURE.....	5
USARIEM MODEL AND MEAN RADIANT TEMPERATURE.....	9
Effective Radiant Flux.....	10
COMPUTATION OF THE WBGT COMPONENTS.....	12
Natural Wet Bulb Temperature.....	13
Black Globe Temperature.....	14
DISCUSSION.....	15
MODEL INTEGRATION.....	15
EXPLOITING EXISTING INFRASTRUCTURE.....	15
CONCLUSIONS.....	15
REFERENCES.....	17

## LIST OF FIGURES

<u>FIGURE</u>	<u>PAGE</u>
1 $R_{sol}$ : A polynomial fit of category-based solar load to pyranometer readings .....	5
2 Schematic of radiation received by an above ground object.....	6
3 Effects of ground temperature on estimated mean radiant temperature at constant 30 ° air temperature.....	8
4 $R_{sol}$ : A polynomial fit of category-based solar load to $T_{mr} - T_{db}$ .....	9
5 Comparison of Effective Radiant Flux (ERF) and $R_{sol}$ as a function of $T_{mr} - T_{db}$ .....	10
6 Difference between ERF and $R_{sol}$ as a function of $T_{mr} - T_{db}$ .....	11
7 Adjustment factor for ERF as a function of $T_{mr} - T_{db}$ .....	11
8 Modified ERF as a function of $T_{mr} - T_{db}$ .....	12

## LIST OF TABLES

<u>TABLE</u>	<u>PAGE</u>
1. Category-based classification schedule for USARIEM model solar loads.....	3
2 Albedos for some natural surfaces (From Holman, 1997).....	7
3 Absorptivities / emissivities of various surfaces to solar and long wave radiation ( From Holman, 1997).....	7

## EXECUTIVE SUMMARY

This report summarizes work we have undertaken to assemble a suite of practical mathematical tools that allow a consistent translation of standard weather station data to physiologically relevant input streams for our thermal strain prediction models. Although weather station measurements of air temperature, relative humidity/dew point, and wind speed can be input with minimal pre-processing into most thermal strain models, the solar radiation component, typically measured in Watts/m<sup>2</sup> by an up-looking pyranometer, can not. This report draws extensively on previously published work and describes processes we have currently implemented to use global pyranometer-based estimates of mean radiant temperature as the common solar load input for the Scenario model, the USARIEM heat strain model, and for the computation of the solar radiation sensitive components of the Wet Bulb Globe Temperature (WBGT) index.

The Mean radiant temperature approach averages multiple directional radiant load components to provide a single uniform surface temperature of an imaginary spherical enclosure surrounding the object. For estimating mean radiant temperature from weather station pyranometer data we propose:

$$T_{mrk} = [T_{dbk}^4 + (Py(1 + a_{gr}) + \epsilon_{gr} \cdot \sigma (T_{grk}^4 - T_{dbk}^4)) / 2\sigma]^{1/4} \quad ^\circ K$$

where  $T_{mrk}$  is the mean radiant temperature in  $^\circ K$ ,  $Py$  is the Pyranometer reading in  $W \cdot m^{-2}$ ,  $T_{dbk}$  is dry bulb temperature in  $^\circ K$ ,  $T_{grk}$  is ground surface temperature in  $^\circ K$ ,  $\epsilon_{gr}$  is ground surface emissivity (0.7 to 0.9),  $a_{gr}$  is ground surface albedo (0.05 to 0.4), and  $\sigma$  is the Stefan Boltzman constant,  $5.67 \cdot 10^{-8} W \cdot m^{-2} \cdot ^\circ K^{-4}$ .

There is a need to replace the category-based solar load inputs to the USARIEM heat strain model. We propose a continuous function, based on mean radiant temperature that provides a smoothed best fit to the categories across the natural solar radiation domain:

$$R_{sol} = -0.071 \cdot (T_{mr} - T_{db})^2 + 10.432 \cdot (T_{mr} - T_{db}) \quad \text{Watts}$$

where  $R_{sol}$  is the total radiant load impinging on the outer surface of clothing in Watts,  $T_{mr}$  is the mean radiant temperature in  $^\circ C$ , and  $T_{db}$  is dry bulb temperature in  $^\circ C$ .

Proposed methods for computing the black globe and natural wet bulb temperature components of the WBGT index from mean radiant temperature and the other standard weather measurements are described and documented with appropriate literature citations.

## INTRODUCTION

### OVERVIEW

Strategies for quantifying solar load are incorporated in human thermal strain prediction models and environmental stress indexes such as the wet bulb globe temperature (WBGT) index. The complex asymmetrical characteristics of most naturally occurring radiant fields has led to the application of a range of sensor systems as potential measurement solutions (2, 3, 4, 12, 13, 17). Sensors such as the black globe temperature thermometer and more elaborate multi-directional radiation sensing systems provide the basis for evaluating solar load. Although a simple global pyranometer sensor is frequently available on standard military and civil weather stations, the black globe thermometer and more sophisticated directional thermal radiation sensing systems are not. There is therefore a continuing need to assemble practical methods to translate what is available from standard weather stations to a physiologically relevant context. Simplified methods to produce an accepted intermediate metric would provide a common thread that facilitates a consistent, coherent computation of solar load components as they are represented both in the indexes and the more sophisticated thermal strain prediction models. This report draws extensively on previously published work and describes processes we have currently implemented to use global pyranometer-based estimates of mean radiant temperature as the common solar load input for the Scenario model, the USARIEM heat strain model, and for the computation of the solar radiation sensitive components of the WBGT index.

#### **Scenario Model**

Mean radiant temperature is the solar load input parameter for the Scenario model (7, 8, 9). Derivation of mean radiant temperature from the pyranometer reading completes the radiant load input stream requirements for Scenario.

#### **USARIEM Heat Strain Model**

Input of the solar load component of heat stress for the original USARIEM model (15) is based on user specification of one of four broad solar categories: Darkness, Cloudy, Partly Cloudy, or Full Sun. Internally, the category is then related to two factors,  $S_{rF}$  and  $C_{dF}$ , the numerical product of which provides a quantitatively discreet "band" intended to represent the total solar radiation (Watts) impinging on the outer clothing surface. This value is subsequently multiplied by a solar efficiency factor,  $U$ , that accounts for the effects of clothing and wind speed on solar load actually received by the body (3). The category approach is a reasonable and pragmatic solution to situations where direct quantitative measurements of the radiant components are unavailable and reflects the philosophy of the calculator-based instantiation of the model which depended entirely on externally obtained environmental measurements or approximations.

Recently, the USARIEM model has been implemented in a hand held Heat Stress Monitor (HSM) as well as the command and control oriented MERCURY test bed system (10, 11). Both of these systems have access to direct or derived measures of ambient solar radiation. In order to exploit these data and automate the model input process, we developed schedules that allow consistent selection of the appropriate solar category. Table 1 shows the categories and the schedule by which they were initially selected: in MERCURY from a pyranometer measurement of global solar radiation, and in the HSM from mean radiant temperature ( $T_{mr}$ ) derived from air temperature ( $T_{db}$ ), wind speed ( $V_a$ ) and black globe ( $T_g$ ) measurements.

**Table 1. Category-based classification schedule for USARIEM model solar loads.**

Category	SlrF ( W )	CldF	SlrF•CldF ( W )	Pyranometer (W/m <sup>2</sup> )	$T_{mr} - T_{db}$ ( °C)
Darkness	0.0	4.0	0	<150	<10
Cloudy	50.0	3.5	175	150 to 399	10 to 24.9
Partly Cloudy	90.0	3.0	270	400 to 700	25 to 45
Full Sun	150.0	2.5	375	>700	>45

### **Statement of the Problem**

It was found during sensitivity studies using the USARIEM model implementation for the Heat Stress Monitor (HSM), that the category approach creates disturbing discontinuities in work/rest cycle and maximum safe work time outputs when the solar load suddenly shifts to a new category. We therefore decided to replace the category based solar load input schedule with a continuous function that would, in addition, more fully exploit the currently available solar load- related measurements available to both the HSM and MERCURY's successor system, the Operational Medicine Environmental Grid Applications (OMEGA) Test bed.

### **OBJECTIVES AND APPROACH**

#### **Objectives**

The fundamental objective is to document processes we have used to derive mean radiant temperature from global pyranometer data sets. The mean radiant temperature approach averages multiple directional radiant load components to provide a single uniform surface temperature of an imaginary spherical enclosure surrounding the object. A key objective for the USARIEM heat strain model applications in the HSM and OMEGA is to document methodology for an empirically derived continuous solar load input parameter,  $R_{sol}$ , that is based on mean radiant temperature,  $T_{mr}$ , and essentially overlays that model's category-based solar load inputs. The intent is to preserve, for

better or worse, the quantitative trends explicit in the category-based handling of solar load and to achieve a historically consistent but significantly smoother quantitative representation of this model input across the solar load domain. The primary objective for the WBGT index components is to document those mathematical relationships we have adopted for estimating black globe and natural wet bulb temperatures using  $T_{mr}$ .

### **Approach**

The approach is to employ regression analysis to establish a smooth fit to the category products using  $T_{mr}$  as the common intermediate parameter for solar load inputs to both the HSM and OMEGA model instantiations. Because  $T_{mr}$  is easily derived from the HSM's black globe, air temperature and wind speed measurements using standard published equations (1), this report will focus on methodologies for approximating  $T_{mr}$  from pyranometer data. A significant collateral benefit of pyranometer-derived  $T_{mr}$  is that, in conjunction with the other standard meteorological measurements of air temperature, humidity, and wind speed, it is possible to estimate black globe temperature ( $T_g$ ), and the naturally convected wet bulb temperature ( $T_{nwb}$ ) which are the two primary components of the WBGT index. In spite of known limitations, WBGT continues to be the preferred heat stress management tool within the military preventive medicine community. Its inclusion as an ancillary product in more rational predictive model output streams (14) is desirable because the ability to demonstrate inadequacies of this culturally entrenched frame of reference is essential to wider acceptance of rational models. Our approach, based on pyranometer-derived  $T_{mr}$ , is thus intended to provide a coherent sensor fusion methodology for linkage of standard meteorological sensor systems to the WBGT and to the more rigorous thermal strain prediction models.

## **METHODS**

### **ANALYTICAL PROCEDURES AND SENSOR SYSTEMS**

This work is intended to document the historical and analytical basis for changes in the solar load related software modules currently or soon to be instantiated in USARIEM's thermal strain predictive models. The methodologies developed in the results section are based on analysis of data obtainable from sensor systems commonly available on weather station platforms: Air temperature, relative humidity, wind speed, and solar radiation sensors comprise the core suite of sensors for current thermal strain prediction models. The analytical focus is the extraction of physiologically-relevant solar load information from pyranometer data. In clear sky situations, readings from these sensors range typically from slightly below 0 at night to more than  $1000 \text{ W}\cdot\text{m}^{-2}$  at mid day. Data from up-looking pyranometers are available from automated weather station systems such as the Remote Automated Weather Stations (RAWS) system at Eglin AFB, Florida and USARIEM's new portable RAWS system that supports OMEGA and the Warfighter Physiological Status


Monitoring (WPSM). Statistical evaluations and regression analyses required for this effort were accomplished using tools available in Microsoft Excel/Office 2000<sup>TM</sup>

## RESULTS

### USARIEM MODEL AND PYRANOMETER DATA

A direct relationship between the pyranometer reading and the  $SlrF \cdot CldF$  product was derived using a polynomial regression fit as shown in Figure 1. As a smoothed representation of the  $SlrF \cdot CldF$  product, the variable  $R_{sol}$  quantifies the extra radiation impinging on the outer surface of the clothing in Watts, for conditions where air and radiant temperature differ. It is important to note that  $R_{sol}$  reflects significant assumptions about the effects of high sun angles on projected area of a standing person.

Figure 1.  $R_{sol}$  : A polynomial fit of category-based solar load to pyranometer readings.




### MEAN RADIANT TEMPERATURE

The pyranometer and air temperature measurements from the Remote Automated Weather Stations (RAWS) are used as the basis for estimating  $T_{mr}$ . Using the pyranometer reading to compute a mean radiant temperature provides significant advantages over the direct empirical fit described above. It allows consideration of other indirect but related radiant load components and has more general utility as an input parameter for predictive models such as Scenario and for the WBGT derivation algorithms. Because it is unrealistic to assume that all

of the radiant load is coming from the sky hemisphere and is measured by the up-looking pyranometer, additional measurements or reasonable assumptions are in order to account for reflected solar radiation and upwelling long wave radiation from the heated ground surface. An isotropic mean radiant field is estimated, as the sum of the  $4\pi$  contributions of each of these elements. Note that temperature units for dry bulb temperature, ground temperature, and mean radiant temperature calculations are degrees Kelvin ( $^{\circ}\text{K} = ^{\circ}\text{C} + 273.15$ ).

Figure 2 is a schematic of a mean radiant temperature ( $T_{\text{mrk}}$ ) representation of the radiation received by an above ground radiantly black object at air temperature ( $T_{\text{dbk}}$ ). The object receives direct and ground reflected solar radiation and long wave radiation from the ground.

**Figure 2. Schematic of radiation received by an above ground object.**



The angle of incidence of the direct solar beam radiation is  $\theta$ . The direct ( $I_d$ ) and diffuse ( $I_{\text{dif}}$ ) solar radiation are incident on the projected up-looking horizontal area ( $A_{\text{up}}$ ) of the object. The total intensity received is  $(I_d \cdot \cos \theta + I_{\text{dif}})$  which is assumed to equal the incident radiation intensity ( $P_y$ ) measured by a skyward looking horizontal pyrometer.

The solar radiation reflected from the ground to the underside of the object is  $A_{\text{down}} \cdot I_r$ , where  $I_r$  is the direct and diffuse solar radiation reflected by the ground. It is represented as  $a_{\text{gr}} \cdot P_y$  where  $a_{\text{gr}}$  is the ground's albedo or its hemispherical solar reflectance. Representative values for the albedo of some common surfaces, from Holman (6), are given in Table 2.

**Table 2. Albedos for some natural surfaces (From Holman, 1997).**

Surface	Albedo
Water	0.3-0.4
Black dry soil	0.14
Black moist soil	0.08
Gray dry soil	0.25-0.30
Gray moist soil	0.10-0.12
Desert loam	0.29-0.31
Bright fine sand	0.37
Snow	0.4-0.85
Green grass	0.26

Further, the underside of the reference object may also receive radiant heat ( $q_{gr}$ ) from the ground.

$$q_{gr} = \epsilon_{gr} \cdot \sigma (T_{grk}^4 - T_{dbk}^4) \quad \text{Watts} \quad (\text{Eq.1})$$

where  $\epsilon_{gr}$  is the long wave (low temperature) emissivity of the ground. For opaque materials absorptivity equals emissivity and some representative values from Holman (6) are listed in Table 3.

**Table 3. Absorptivities / emissivities of various surfaces to solar and long wave radiation ( From Holman, 1997).**

Surface	solar	long wave
Aluminum, highly polished	0.15	0.04
Copper, highly polished	0.18	0.03
Tarnished	0.65	0.75
Cast iron	0.95	0.21
Stainless steel, no. 301, polished	0.37	0.60
White marble	0.46	0.95
Asphalt	0.90	0.90
Red brick	0.75	0.93
Gravel	0.29	0.85
White paint	0.12-0.16	0.90-0.95

The radiant energy depicted in Figure 2 can be mathematically represented as:

$$(A_{up} + A_{down}) \cdot \sigma (T_{mrk}^4 - T_{dbk}^4) = A_{up} (I_d \cdot \cos \theta + I_{dif}) + A_{down} (I_r + q_{gr}) \quad (\text{Eq.2})$$

The projected areas facing up and down must be equal ( $A_{up} = A_{down} = A$ ) simplifying Eq. 2 to:

$$2A \cdot \sigma (T_{mrk}^4 - T_{dbk}^4) = A(l_d \cdot \cos \theta + l_{dif}) + A (l_r + q_{gr}) \quad (\text{Eq.3})$$

Then substituting the Pyrometer reading (Py) and simplifying:

$$2\sigma (T_{mrk}^4 - T_{dbk}^4) = Py (1 + a_{gr}) + \epsilon_{gr} \cdot \sigma (T_{grk}^4 - T_{dbk}^4) \quad (\text{Eq.4})$$

or

$$T_{mrk} = [T_{dbk}^4 + (Py(1 + a_{gr}) + \epsilon_{gr} \cdot \sigma (T_{grk}^4 - T_{dbk}^4)) / 2\sigma]^{1/4} \quad ^\circ\text{K} \quad (\text{Eq.5})$$

where:

$T_{mrk}$  = mean radiant temperature,  $^\circ\text{K}$

$Py$  = pyranometer reading,  $\text{W}\cdot\text{m}^{-2}$

$T_{dbk}$  = dry bulb temperature,  $^\circ\text{K}$


$T_{grk}$  = ground surface temperature,  $^\circ\text{K}$

$\epsilon_{gr}$  = ground surface emissivity

$a_{gr}$  = ground surface albedo

$\sigma$  = Stefan Boltzman constant,  $5.67 \times 10^{-8} \text{W}\cdot\text{m}^{-2}\cdot^\circ\text{K}^{-4}$

**Figure 3. Effects of ground temperature on estimated mean radiant temperature at constant 30  $^\circ$  air temperature.**



Ground surface temperature measurements are provided by RAWS systems and reasonable approximations for bare ground albedo and long wave emissivity can


be obtained from Tables 2 and 3. Note that if the ground albedo is assumed to be 0 and the ground temperature equals air temperature eq. 5 simplifies to:

$$T_{mrk} = (T_{dbk}^4 + Py) / 2\sigma)^{1/4} \quad ^\circ K \quad (Eq.6)$$

### USARIEM MODEL AND MEAN RADIANT TEMPERATURE

Using  $T_{mr} - T_{db}$  categories from Table 1, regression analysis yields a continuous, smoothed function that overlays the USARIEM model's category-based solar load as shown in Figure 4.

Figure 4.  $R_{sol}$ : A polynomial fit of category-based solar load to  $T_{mr} - T_{db}$ .



Polynomial regression yields:

$$R_{sol} = -0.071 (T_{mr} - T_{db})^2 + 10.432 (T_{mr} - T_{db}) \quad \text{Watts} \quad (Eq.7)$$

The continuous variable  $R_{sol}$  here represents a "plug-in" replacement for the  $SlrF \cdot CldF$  product in the USARIEM heat strain model algorithm that, along with the solar efficiency factor,  $U$ , is used to compute the actual radiant load on the body. While it appears to be a reasonable approximation of the USARIEM model's handling of solar load, it is probably appropriate to characterize the magnitude of departures from a more generalized rational estimate such as Gagge's Effective Radiant Flux (ERF).

### Effective Radiant Flux (ERF)

Effective Radiant Flux (Santee and Gonzalez, 1988) is similar to  $R_{sol}$  in that it represents solar load as a function of air temperature and mean radiant temperature, but it also includes terms for clothing absorptivity and radiating surface area. We compute whole body ERF as follows:

$$ERF = \sigma \cdot \alpha \cdot A_r / A_D \cdot (T_{mrk}^4 - T_{dbk}^4) \cdot A_D \quad \text{Watts} \quad (\text{Eq.8})$$

Where,

$T_{dbk}$  = dry bulb temperature, °K

$\alpha$  = absorptivity of clothing, here 0.9

$\sigma$  = Stefan Boltzman constant,  $5.67 \times 10^{-8} \text{ W} \cdot \text{m}^{-2} \cdot \text{°K}^{-4}$


$T_{mrk}$  = mean radiant temperature, °K

$A_D$  = Dubois body surface area, here  $1.8 \text{ m}^2$

$A_r / A_D$  = ratio of radiating surface to total body surface area, 0.72

Figure 5 shows the relationship between ERF and the  $SlrF \cdot CldF$  product.

**Figure 5. Comparison of Effective Radiant Flux (ERF) and  $R_{sol}$  as a function of  $T_{mr} - T_{db}$ .**



Aside from the fact that clothing effects on net solar load burden in the USARIEM model are computed following the estimate of  $R_{sol}$ , it is clear that significant implicit assumptions about view angle, solar altitude, and posture are aggregated in the category factors. The difference between the computed ERF and  $R_{sol}$  is shown in Figure 6.

Figure 6. Difference between ERF and  $R_{sol}$  as a function of  $T_{mr} - T_{db}$ .




Figure 7. Adjustment factor for ERF as a function of  $T_{mr} - T_{db}$ .





Figure 7 depicts the polynomial regression function that yields an adjustment factor/multiplier for ERF that quantifies the difference between ERF and  $R_{sol}$  across the solar load domain. The ERF multiplier ranges from 1.4 to roughly 0.45 at the highest solar load.

The expression modifying ERF and relating ERF to  $R_{sol}$  thus becomes:

$$\text{Modified ERF} = R_{sol} = \text{ERF} \cdot (0.00005 (T_{mr} - T_{db})^2 - 0.0161 (T_{mr} - T_{db}) + 1.4) \text{ Watts} \quad (\text{Eq.9})$$

Figure 8 shows the modified ERF across the solar load domain.

**Figure 8. Modified ERF as a function of  $T_{mr} - T_{db}$ .**



Although the preceding exercise characterizes the relationship between ERF and  $R_{sol}$ , and would allow direct compatibility with the USARIEM heat strain model input stream, applications in OMEGA and the Heat Stress Monitor will use the exclusively empirical fit described previously, Eq. 7:

$$R_{sol} = -0.071 (T_{mr} - T_{db})^2 + 10.432 (T_{mr} - T_{db}) \text{ Watts}$$

### COMPUTATION OF THE WBGT COMPONENTS

The addition of a Wet Bulb Globe Temperature (WBGT) capability for OMEGA does not represent a cutting edge technological improvement for thermal injury risk assessment. It does, however, provide a useful resource to support comparative and analytical evaluations of this widely used heat stress

index. It also provides an important frame of reference and credible historical thread for potential OMEGA users who are currently committed to WBGT-based heat stress management doctrine (16).

Part of the appeal and resilience of WBGT methodology is the simplicity of the basic measurements and the computation of the index. The WBGT index for outdoor environments is computed as follows:

$$\text{WBGT} = 0.7T_{nwb} + 0.2T_g + 0.1T_{db} \quad \text{°C or °F} \quad (\text{Eq.10})$$

Where:

$$\begin{aligned} T_{nwb} &= \text{Natural Wet Bulb Temperature} && \text{°C or °F} \\ T_g &= \text{6 inch Black Globe Temperature} && \text{°C or °F} \\ T_{db} &= \text{Air Temperature} && \text{°C or °F} \end{aligned}$$

Because two components of the WBGT, naturally convected wet bulb temperature,  $T_{nwb}$ , and black globe temperature,  $T_g$ , are not measured by standard weather stations, these values must be derived from the available measured data. The original conceptual advantage of WBGT in terms of simplicity is certainly lost when these components must be derived from standard measures using iterative computational methods, but the processes can be automated in software. It should be noted that recent development of a regression based equation that uses weather station data to compute an Environmental Strain Index (ESI) has demonstrated very high correlation with measured WBGT values (12). This may ultimately prove to be an acceptable substitute for the more computationally demanding solutions described below.

### Natural Wet Bulb Temperature

In the current implementation of OMEGA, the naturally convected wet bulb temperature is computed using an iterative process to solve a previously described equilibrium state equation (5). A first guess for  $T_{nwbk}$  ( $T_{nwbk-TEST}$ , starting typically at  $T_{dbk}$ ) is substituted into equation 11 and both sides evaluated.  $T_{nwbk-TEST}$  is incrementally decremented until both sides converge on a value that satisfies the equality, and  $T_{nwbk-TEST}$  equals the true  $T_{nwbk}$ . The process uses the derived Mean Radiant Temperature ( $T_{mrk}$ ), and the air temperature ( $T_{dbk}$ ), wind speed ( $V_a$ ), and relative humidity (RH) measurements. From Gonzalez et al.:

$$h_c(T_{dbk} - T_{nwbk}) + \epsilon_{nwb} \cdot \sigma (T_{mrk}^4 - T_{nwbk}^4) = h_e(P_{snwb} - (RH/100) \cdot P_{sdb}) \quad (\text{Eq.11})$$

Where:

$$\begin{aligned} h_c &= \text{convective heat transfer coefficient, } W \cdot m^{-2} \cdot \text{°K}^{-1} \\ T_{dbk} &= \text{dry bulb temperature, } \text{°K} \\ T_{nwbk} &= \text{natural wet bulb temperature, } \text{°K} \\ \epsilon_{nwb} &= \text{emissivity of the surface of the wetted wick, } \sim 0.5 \\ \sigma &= \text{Stefan Boltzman constant, } 5.67 \times 10^{-8} W \cdot m^{-2} \cdot \text{°K}^{-4} \\ T_{mrk} &= \text{mean radiant temperature, } \text{°K} \end{aligned}$$

$h_e$  = evaporative heat transfer coefficient,  $W \cdot m^{-2} \cdot Torr^{-1}$   
 $P_{snwb}$  = saturation water vapor pressure at  $T_{nwb}$ , Torr  
 RH = % RH  
 $P_{sdb}$  = saturation water vapor pressure at  $T_{db}$ , Torr

The convective heat transfer coefficient is computed from wind velocity,  $V_a$ , in  $m \cdot s^{-1}$ :

$$h_c = 42.024 V_a^{0.466} \quad W \cdot m^{-2} \cdot ^\circ K^{-1} \quad (Eq.12)$$

And the evaporative heat transfer coefficient is related to the convective heat transfer coefficient by the Lewis relation:

$$h_e = 2.2 h_c \quad W \cdot m^{-2} \cdot Torr^{-1} \quad (Eq.13)$$

Saturation water vapor pressures at  $T_{nwb}$  and  $T_{db}$  are computed using a base 10 version of Antoine's equation for temperatures in  $^\circ C$  (Santee and Gonzalez, 1988).

$$P = 10^{(8.10765 - 1750.286/(T+235))} \quad Torr \quad (Eq.14)$$

### Black Globe Temperature

In the current implementation of OMEGA, black globe temperature is computed using a previously described equilibrium state equation for the globe, where radiative heat gain equals convective heat loss (ASHRAE, 1984):

$$h_{rg} (T_{mrk} - T_{gk}) = h_{cg} (T_{gk} - T_{dbk}) \quad (Eq.15)$$

or

$$T_{gk} = (h_{cg} \cdot T_{dbk} + h_{rg} \cdot T_{mrk}) / (h_{cg} + h_{rg})$$

Where:

$T_{gk}$  = black globe temperature,  $^\circ K$   
 $h_{rg}$  = linear radiation transfer coefficient for globe  
 $= \epsilon_g \cdot \sigma (T_{mrk} + T_{dbk}) \cdot (T_{mrk}^2 + T_{dbk}^2)$ ,  $W \cdot m^{-2} \cdot ^\circ K^{-1}$   
 $h_{cg}$  = convective heat transfer coefficient  
 $= 6.32 D^{-0.4} \cdot V_a^{0.5}$ ,  $W \cdot m^{-2} \cdot ^\circ K^{-1}$   
 $\epsilon_g$  = emissivity of black globe,  $\sim 0.95$   
 $\sigma$  = Stefan Boltzman constant,  $5.67 \times 10^{-8} W \cdot m^{-2} \cdot ^\circ K^{-4}$   
 $T_{dbk}$  = dry bulb temperature,  $^\circ K$   
 $T_{mrk}$  = mean radiant temperature,  $^\circ K$   
 $D$  = diameter of globe, m  
 $V_a$  = air velocity,  $m \cdot s^{-1}$

## **DISCUSSION**

### **MODEL INTEGRATION**

As the federation of warfighter predictive/performance models required to support Army science and technology objectives becomes more tightly integrated, there is a growing need to define and document practical methods for handling environmental measurements. The ability to leverage existing meteorological resources as input streams for model test and evaluation expands research opportunities, allows early identification of meteorological data gaps or sensor inadequacies, and ultimately contributes to the effective definition of meteorological requirements for highly integrated operational systems such as Land Warrior.

### **EXPLOITING EXISTING INFRASTRUCTURE**

Our efforts here focus on the solar radiation component of the natural environment and the derivation of a commonly accepted, physiologically relevant metric that would support a range of indexes and thermal strain prediction models. The methodology proposed for derivation of  $T_{mr}$  from pyranometer data represents a considerable compromise from the most robust biophysical evaluations. Nevertheless, it does provide a practical solution to a data gap that is not likely to be otherwise resolved in the near future. Pyranometers, based on silicon photodiode technology, are widely used solar radiation sensors. Data from up-looking pyranometers are available from automated weather station systems such as the Remote Automated Weather Stations (RAWS) system at Eglin AFB, Florida and USARIEM's new portable RAWS system that supports OMEGA and the Warfighter Physiological Status Monitoring (WPSM) project.

## **CONCLUSIONS**

There is a growing need to exploit existing standard weather station data resources to support emerging requirements for real time-modeling of Warfighter thermal, hydration, and performance status.

Combined with standard measurements of air temperature, humidity, and wind speed, a practical method to derive mean radiant temperature from weather station pyranometer readings provides a basic input stream for thermal strain prediction models and provides opportunities for physiologically relevant sensor fusion.

The proposed expression relating pyranometer readings to mean radiant temperature provides a common thread for consistent utilization of standard meteorological data for automated input of solar load to the Scenario and USARIEM heat strain models.

The proposed expression relating pyranometer readings to mean radiant temperature provides a common thread for consistent utilization of standard meteorological data for rational estimation of the individual components of the traditional Wet Bulb Globe Temperature (WBGT) index.

The proposed continuous function relating mean radiant temperature to the category-based solar load input in the USARIEM heat strain model provides a practical solution for linkage of that model to standard weather data resources.

## REFERENCES

1. ASHRAE. High Intensity Radiant Heating. In: 1984 *ASHRAE Fundamentals Handbook*, American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc., Atlanta, GA, p.18.8-9, 1984.
2. Blazejczyk, K, H. Nilsson, and I. Holmer. Solar heat load on man. *Int. J. Biometeorol.* 37:125-132, 1993.
3. Breckenridge, J.R. and R.F. Goldman. Solar heat load in man. *J. Appl. Physiol.* 31(5): 659-663, 1971.
4. Gonzalez, R.R. Infrared Radiation and Human Thermal Comfort. In: *Microwaves and Thermoregulation*. Academic Press, p.109-137, 1983.
5. Gonzalez, R.R., G.N. Sexton, and K. B. Pandolf. Biophysical evaluation of the Wet Globe Temperature Index (Botsball) at high air movements and constant dew point temperature. In: *Proceedings of the Fourteenth Commonwealth Conference on Operational Clothing and Combat Equipment*. Australia, 1985.
6. Holman, J.P. *Heat Transfer*, McGraw-Hill, NY: p. 470-486, 1997.
7. Kraning, K.K. *A computer simulation for predicting the time course of thermal and cardiovascular responses to various combinations of heat stress, clothing, and exercise*. Natick, MA: USARIEM Technical Report No. T13-91, June 1991.
8. Kraning, K.K. *Validation of mathematical models for predicting physiological events during work and heat stress*. Natick, MA:USARIEM Technical Report No. T95-18, 1995.
9. Kraning, K.K. and R.R. Gonzalez. *SCENARIO: A military/industrial Heat Strain Model modified to account for the effects of aerobic fitness and progressive dehydration*. Natick, MA: USARIEM Technical Report No. T97-1, 1997
10. Matthew, W.T., J.A. Gonzalez, R.R. Gonzalez, G. Bates and C. Gazey. *Field Testing of a Prototype Heat Stress Monitor: System Performance and Applicability to Commercial Mining in Australia*. Natick, MA: USARIEM Technical Report T99-7, June 1999.
11. Matthew, W.T. *MERCURY User's Guide- Version V1.11alpha*. Natick, MA: USARIEM Technical Note TN007, June, 2000.
12. Moran, D.S., K.B. Pandolf, W.T. Matthew, and R.R. Gonzalez. *An Environmental Strain Index (ESI) as a substitute for the Wet Bulb Globe*

*Temperature (WBGT)*. Natick, MA: USARIEM Technical Report T 01/05, February, 2001.

13. Woodcock, A.H, R.L. Pratt, and J.R. Breckenridge. *Theory of the Black Globe Thermometer*. Natick MA: Study Report BP-7, Quartermaster R &E Command, U.S. Army Natick Labs, 1960.
14. Gonzalez, R.R., T.M. McClellan, W.R. Withy, S.K. Chang, and K.B. Pandolf. Heat Strain Models Applicable for protective clothing systems: comparison of core temperature response. *J.Appl. Physiol.* 83 (3) 1017-1032, 1997.
15. Pandolf, K.B., L.A. Stroschein, L.L. Drolet, R.R. Gonzalez, and M.N. Sawka. Prediction Modeling of Human Responses in the Heat. *Comput. Biol. Med.* 6:319-329, 1986.
16. FM 21-10, MCRP4-11.1D Field Hygiene and Sanitation. Headquarters, Department of the Army and Commandant of Marine Corps, Washington, DC, 21 June 2000.
17. Roller, W.L. and R.F. Goldman. Prediction of solar load on man. *Journal of Applied Physiology*, 24:717-721, 1968.
18. Santee, W.R. and R.R. Gonzalez. Characteristics of the thermal environment. In: *Human Performance Physiology and Environmental Medicine at Terrestrial Extremes*, edited by K.B. Pandolf, M.N.Sawka, and R.R. Gonzalez. Indianapolis, IN: Benchmark Press, 1988.