

## Estimation of Pulse Availability

Gary A. Pryor

U.S. Army Training and Doctrine Command, Fort Leonard Wood, Missouri

*Operational availability,  $A_o$ , is an important consideration during the evaluation of system effectiveness and sustainability.  $A_o$  is commonly used and widely understood as a measure of steady-state system availability. However, a related term “pulse availability,”  $A_p$ , has recently and more prominently been used in statements of requirements for some military systems under development.  $A_p$  is a subset of  $A_o$  and applies to a shorter and usually more intensive usage period, known as a “pulse.” Various techniques are published on the estimation, calculation, and measurement of  $A_o$ ; however, little if any can be found on the calculation and estimation of pulse availability,  $A_p$ . This article presents a straightforward approach for estimating  $A_p$  which will aid in the specification and evaluation of  $A_p$  requirements.*

**Key words:** Availability, downtime, uptime, maintenance time, failure, time to restore, operational time.

**O**perational availability,  $A_o$ , is widely used as a readiness related objective in the specification of requirements for military systems. In general terms,  $A_o$  is the proportion of time a system is either operating or is capable of operating (called “uptime”), while being used in a specific manner in a typical maintenance and supply environment. In other words,  $A_o$  is the ratio of “uptime” to “total time.” For complete definitions and discussion of  $A_o$ , see Pryor (2008).

Pulse availability,  $A_p$ , is a subset of operational availability that applies when the period of interest is not the steady-state availability, but system availability during a short, usually intensive period of operations.

Figure 1 shows a typical “failure–restore” cycle, which can be used to model steady-state operational availability. This cycle is theoretically repeated continuously because a system operates, experiences a failure, and accumulates downtime associated with maintenance and logistics delays until it is restored to an operational state.

Availability must be looked at differently when the period of interest is not steady state, but a shorter period, such as a period of intensive usage. Pulse availability,  $A_p$ , is usually higher than the steady-state  $A_o$  for the same operating tempo. When a failure occurs during the pulse, some of the downtime associated with the restoration of the system may extend outside of the pulse and is not counted as downtime for the pulse. One such possible example is illustrated in

Figure 2. The amount of any increase in  $A_p$  over  $A_o$  depends primarily on the length of the pulse, the expected downtime per failure, and the steady-state  $A_o$ .

### Estimation of operational availability

Two related  $A_o$  equations were described in previous published work by the author (Pryor, 2008) and are shown here as Equations 1 and 2. The specific equation or methodology used to determine  $A_o$  is of no importance; but Equations 1 and 2 are shown as one possible source.

$$A_o = \frac{1 - \text{OPR} \times \text{CMR}_{\text{ESS}}}{1 + \text{OPR}(\text{MCMT} + \text{ALDT})/\text{MTBF}}, \quad (1)$$

$$A_o = \frac{1}{1 + (\text{MCMT} + \text{ALDT})/\text{MTBF} + \text{CMR}_{\text{ESS}}} \quad (2)$$

where

ALDT = administrative and logistics delay time (per failure) in hours.

CMR<sub>ESS</sub> = clock hour maintenance ratio—essential (maintenance time not associated with a critical failure that causes downtime; expressed as maintenance clock hours per operating hour). Includes both essential scheduled (preventive) maintenance and unscheduled (corrective) maintenance.

MCMT = mean corrective maintenance time (per failure) in hours.

# Report Documentation Page

Form Approved  
OMB No. 0704-0188

Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.

1. REPORT DATE <b>JUN 2009</b>		2. REPORT TYPE		3. DATES COVERED <b>00-00-2009 to 00-00-2009</b>	
4. TITLE AND SUBTITLE <b>Estimation of Pulse Availability</b>				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) <b>U.S. Army Training and Doctrine Command, Fort Leonard Wood, MO, 65473</b>				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT <b>Approved for public release; distribution unlimited</b>					
13. SUPPLEMENTARY NOTES					
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON
a. REPORT <b>unclassified</b>	b. ABSTRACT <b>unclassified</b>	c. THIS PAGE <b>unclassified</b>			




Figure 1. Steady-state failure-restore cycle.

MTBF = mean time between failure (representing “critical” failures that cause the system to be nonoperational) in hours.

OPR = operating rate (ratio of operating time to total time; i.e., a system that operates 12 hours per day would have an OPR of 50 percent).

If  $CMR_{ESS} - [(1 - OPR)/OPR] \leq 0$ , then Equation 1 can be used; otherwise use Equation 2. (Equation 2 is used for continuously operating or high op-tempo systems.)

**Estimation of pulse availability**

$A_p$  will always be greater than or equal to the steady-state  $A_o$  because some of the downtime that was induced during the pulse will extend outside of the pulse, and therefore is not counted against the pulse  $A_o$ . The difference between  $A_p$  and steady-state  $A_o$  varies depending on the reliability relative to the pulse; the relative duration of the downtime; and, of course, the planned usage during the pulse.

If the MTBF is significantly greater than the length of the pulse, there is a high chance of completing the pulse without a failure. Then, a failure will occur only during a small percentage of pulses, and only that small percentage of pulses will experience any downtime

during the pulse. For this case there will not be much difference between the  $A_p$  and the steady-state  $A_o$ .

If the MTBF is such that there is a good chance of experiencing one or more failures during the pulse, and if the average downtime is also high (relative to the pulse), then a significant portion of downtime can be expected to extend beyond the pulse, and the  $A_p$  will differ significantly from the steady-state  $A_o$ .

As shown in Figure 3, for situations where many failure-restore cycles occur during the pulse (i.e., very long pulses or low MTBF combined with low downtimes), then many failure-restore cycles occur during the pulse. In that case, because there are multiple failures and repairs during the pulse, most of the associated downtime occurs during the pulse and only downtime from the last failure can extend beyond the pulse. In this case, there will be some but perhaps not a significant difference between the  $A_p$  and steady-state  $A_o$ .

We begin by modifying the normal  $A_o$  equation to include only the uptime and downtime, which occurs during the pulse, as shown in Equation 3.

$$A_p = \frac{Uptime_p}{Uptime_p + Downtime_p}, \tag{3}$$

where  $Uptime_p$  ( $UT_p$ ) is the uptime within the pulse; and  $Downtime_p$  ( $DT_p$ ) is the downtime within the pulse. As we have discussed previously, the difference between  $A_o$




Figure 2. Uptime and downtime for pulse availability calculation.




Figure 3. Pulse with many failure-restore cycles.

and  $A_p$  lies in the fact that some amount of the expected downtime extends beyond the pulse. The downtime that extends beyond the pulse is designated as  $DT_{OP}$ .

In general, the percentage of time we can expect to be operational is  $A_o$ , and the amount of time we can expect to be operational during the pulse,  $UT_p = A_o \times PT$ . Similarly, the amount of downtime we can expect during a pulse is  $DT_p = (1 - A_o) \times PT$ , less some amount of downtime normally expected that falls outside the pulse ( $DT_{OP}$ ).

If a system is in a failed state at the end of a pulse, we will assume that there is an equal chance of being at any point in the restore process. So, given that the system is in a failed state, the average amount of downtime extending beyond the end of the pulse is one-half of the restore time, or  $(MCMT + ALDT)/2$ . By definition,  $1 - A_o$  is the probability that the system is nonoperational at any given time, including the end of the pulse. So, there is a  $1 - A_o$  probability that an  $(ALDT + MCMT)/2$  amount of downtime will fall outside the pulse. This means that

$$\begin{aligned}
 DT_p &= \text{estimated downtime for pulse less expected} \\
 &\quad \text{downtime outside of pulse} \\
 &= [(1 - A_o) \times PT] \\
 &\quad - [(1 - A_o)(MCMT + ALDT)/2].
 \end{aligned}$$

There is however one limitation arising from our assumption with respect to the average amount of downtime extending beyond the pulse. If the time to restore (TTR) is large with respect to the pulse time and we end the pulse in a failed state, then the system is much more likely to be early in the restore process and our assumption that one-half of the restore time extends beyond the pulse is not valid. Take for example a pulse time of 72 hours and a TTR of 200 hours. Using the previous assumption, we would effectively be reducing the pulse downtime by one-half of 200 hours, or 100 hours—longer than the actual pulse itself! To

overcome this anomaly, we limit the time to restore to no more than the pulse time itself. Simulation results have borne out that no matter how high the restore time, once it exceeds the pulse time the resultant  $A_p$  is not affected. In that case, once a failure occurs, the failed system will not be returned to operation during the pulse. Now we can substitute into Equation 3:

$$\begin{aligned}
 A_p &= \frac{UT_p}{UT_p + DT_p} \\
 &= \frac{A_o \times PT}{A_o \times PT + (1 - A_o)PT - (1 - A_o)(MCMT + ALDT)/2};
 \end{aligned}$$

dividing numerator and denominator by PT and simplifying,

$$\begin{aligned}
 A_p &= \frac{A_o}{A_o + (1 - A_o) - [(1 - A_o)(MCMT + ALDT)/2]/PT}, \\
 A_p &= \frac{A_o}{1 - [(1 - A_o) \times TTR/2PT]}, \tag{4}
 \end{aligned}$$

where PT = pulse time period (hours),

$$\begin{aligned}
 TTR &= MCMT + ALDT \\
 &\quad \text{if } (MCMT + ALDT) \leq PT \quad \text{or} \\
 TTR &= PT \quad \text{if } (MCMT + ALDT) > PT
 \end{aligned}$$

Note that Equation 4 is valid only when  $A_o > 0.50$ .

Verifying the output by comparing to Monte Carlo simulation results, it turns out that Equation 4 provides a good estimate of  $A_p$  except in cases of very low  $A_o$ . When  $A_o$  is less than 50 percent, Equation 4 begins to deviate significantly from simulated results. However, such low values of  $A_o$  are generally not acceptable and therefore not applied in real world situations.

The previous discussion relating to instances of long TTR leads to another simple methodology for estimating  $A_p$  in cases where the average time to restore exceeds the pulse time. If, as in the case of long TTR, we know

Table 1. Comparison of Equation 4 output to simulation results.

MTBF (h)	OPR	$A_o$ (Equation 1)	$A_p$ (Equation 4)					
			PT = 7,200 h		PT = 720 h		PT = 72 h	
			Calc.	Sim.	Calc.	Sim.	Calc.	Sim.
100	10/24	0.745	0.746	0.746	0.756	0.757	0.872	0.857
100	20/24	0.594	0.595	0.595	0.608	0.607	0.773	0.752
500	10/24	0.936	0.936	0.936	0.939	0.940	0.971	0.968
500	20/24	0.880	0.880	0.880	0.886	0.886	0.944	0.941

that systems will not be returned to operation during the pulse, we can use reliability, the probability of completing the pulse without a failure, to estimate the  $A_p$ .

**Estimation of pulse availability for long times to restore**

As stated previously, when the average time to restore is longer than the pulse time, a failed system will (on average) not be returned to operation during the pulse. Thus, we can compute the  $A_p$  using mission reliability as described further on. The exact reliability distribution used to calculate the pulse mission reliability does not matter; similar calculations can be performed for any distribution. But, for simplicity, we will use the exponential distribution.

We are interested in the probability of completing the pulse without a failure. This value will be designated as pulse reliability ( $R_p$ ).

The derivation is straightforward and independent of the number of systems operating during the pulse,

but it is more intuitive if we let  $N$  be the number of systems beginning the pulse.

For a group of  $N$  systems,  $UT_p$  is equal to the number of systems that make it through the pulse ( $N \times R_p$ ) multiplied by the pulse time  $PT$ ; summed with the number of systems that failed to make it through the pulse [ $N(1 - R_p)$ ], multiplied by the uptime they accomplished prior to failure,  $UT_{FAIL}$ .

$$UT_p = [N \times R_p \times PT] + [N(1 - R_p) \times UT_{FAIL}]$$

$UT_{FAIL}$  is easy to estimate for the exponential distribution because it assumes a constant failure or hazard rate, which means that failures are equally likely to occur at any time during the pulse. Given that a system has failed during the pulse, this lets us estimate the average time to failure as simply one-half of the  $PT$ . So,  $UT_{FAIL} = PT/2$ .

Now,

$$UT_p = (N \times R_p \times PT) + N(1 - R_p) \times PT/2,$$

Table 2. Comparison of Equation 4 and 5 to simulation results.

Avg. time to restore (TTR)	MTBF/OPR (h)	$A_o$ (Equation 1)	$A_p$ (Equation 4)	Sim. result	$A_p$ (Equation 5)
25	12	0.324	0.345	0.344	0.500 (poor match)
25	60	0.706	0.724	0.726	0.545 (poor match)
25	120	0.828	0.840	0.841	0.651 (poor match)
25	600	0.960	0.963	0.963	0.893 (poor match)
82	12	0.128	0.170	0.163	0.500 (poor match)
82	60	0.423	0.506	0.496	0.545 (poor match)
82	120	0.594	0.672	0.658	0.651
82	600	0.880	0.911	0.909	0.893
162	12	0.069	0.129	0.083	0.500 (poor match)
162	24	0.129	0.229	0.168	0.501 (poor match)
162	48	0.229	0.372	0.314	0.525 (poor match)
162	72	0.308	0.471	0.438	0.568 (poor match)
162	96	0.372	0.542	0.543	0.612 (poor match)
162	120	0.426	0.597	0.582	0.651 (poor match)
162	180	0.526	0.690	0.685	0.725 (marginal)
162	240	0.597	0.748	0.748	0.774 (marginal)
162	360	0.690	0.816	0.819	0.835
162	480	0.748	0.856	0.869	0.870
162	600	0.787	0.881	0.887	0.893
162	1,200	0.881	0.937	0.942	0.943

Table 3.

Avg. time to restore (TTR)	MTBF/OPR (h)	Sim. result	$A_P$ (Equation 5)
82	600	0.907	0.893
162	600	0.892	
242	600	0.887	
322	600	0.893	
402	600	0.891	

$$A_P = \text{Uptime} / \text{Totaltime},$$

$$A_P = \frac{(N \times R_P \times PT) + N(1 - R_P) \times PT / 2}{N \times PT}.$$

Divide numerator and denominator by  $N$  and  $PT$ , and we get

$$A_P = R_P + (1 - R_P) / 2. \tag{5}$$

Note that Equation 5 is valid for exponentially distributed failures; average time to restore greater than pulse time; and mean calendar time between failure greater than pulse time.

If one assumes that system failures follow the exponential distribution, Equation 5 can be used to quickly estimate pulse availability for systems with long times to restore (relative to the pulse time). Also, analysis of Monte Carlo simulation results indicates that Equation 5 provides a poor approximation when the mean calendar time between failure (MTBF/OPR) is less than  $PT$ .

### Comparison of pulse availability estimations to simulation results

A rigorous proof of these formulas is not provided. However, it will be shown that they compare favorably to results of Monte Carlo simulations performed by the author. The author is confident that these results can be replicated by others willing to do so.

Table 1 shows results from the use of Equations 1 ( $A_o$ ) and 4 ( $A_P$ ) as compared with Monte Carlo simulation results for various inputs. The MTBFs vary between 100 hours and 500 hours; daily OT varies between 10 hours per day and 20 hours per day; pulse times vary between 72 hours, 720 hours, and 7,200 hours. For all cases, ALDT = 80 hours and MCMT = 2 hours. Each simulation result shown represents the average from a group of 10 systems operating for the specified pulse, repeated 1,000 times.

As can be seen, the  $A_P$  simulation results are within a few percentage points of the calculated values. Note that the simulated and calculated results from the higher MTBF are more comparable with each other. And, as

expected, when the pulse time increases, the calculated  $A_P$  (Equation 4) approaches the steady-state  $A_o$  (Equation 1) and very closely matches the simulation results.

Table 2 compares the results of Equations 1, 4, and 5 with simulation results for a variety of cases.

It can be seen that Equation 5 does not match the simulated  $A_P$  for cases where either the TTR is less than the pulse time, or when the MTBF/OPR is less than the pulse time. Table 3 shows simulation results for increasing TTR—showing as expected no affect on  $A_P$  when the TTR is increased well above the  $PT$ .

### Conclusion

The equations and methodologies in this article describe an original approach to estimation of pulse availability. The outputs of Equations 4 and 5 closely match results of Monte Carlo simulations written to specifically measure  $A_P$  over typical operating cycles. The only limitations are that Equation 4 is valid only when the operational availability is above 0.50 (hardly an actual limitation). Equation 5 is valid when the failure distribution is exponential; and the reliability (MTBF) and average time to restore are both high relative to the pulse time. Although various techniques are available to predict  $A_o$ , very little can be found on estimation of  $A_P$ , and the author hopes to fill that void with a simple and straightforward approach. □

*GARY A. PRYOR is a civilian employee of the U.S. Army TRADOC Army Capabilities Integration Center, serving as a RAM engineer supporting the U.S. Army Maneuver Support Center (MANSCEN), Fort Leonard Wood, Missouri. He received a bachelor of science degree in aeronautical and astronautical engineering from the Ohio State University; and a master of science degree in computer science from the University of Missouri, Rolla (now the Missouri University of Science and Technology). He has been working for the Army in the RAM engineering field since 1983. He is a current member of the Society of Reliability Engineers (SRE); and was an ASQC Certified Reliability Engineer from 1990–2002. His contributions to the RAM field include the development, support, and free distribution of the “Reliability Test Planner” software application. E-mail: gary.pryor@us.army.mil*

### References

Pryor, G. A. 2008. Methodology for estimation of operational availability as applied to military systems. *The ITEA Journal of Test and Evaluation*. 29(3), pp. 420–428.