



Emergency Planning For Water Supply Interruptions At Medical Facilities

James F. Harris - NAVFAC


Dave Hildebrand – AH ENV

5/6/2009

Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE 06 MAY 2009		2. REPORT TYPE		3. DATES COVERED 00-00-2009 to 00-00-2009	
4. TITLE AND SUBTITLE Emergency Planning For Water Supply Interruptions At Medical Facilities				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Naval Facilities Engineering Command, 1100 23rd Ave, Port Hueneme, CA, 93043				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution unlimited					
13. SUPPLEMENTARY NOTES Presented at the NDIA Environment, Energy Security & Sustainability (E2S2) Symposium & Exhibition held 4-7 May 2009 in Denver, CO.					
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT Same as Report (SAR)	18. NUMBER OF PAGES 31	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			

Outline of Presentation:

- **Introduction**
- **Background**
- **Approach**
- **Results**
- **Conclusions**
- **Application to other Navy Medical Facilities**



5/6/2009

For Emergency Water Supply Interruptions:

- Alternative supplies may not be available
- Limited information water on demands for critical functions
- Impacts of loss of water supply can be greater than loss of power



Reported Water Supply Interruptions at Medical Facilities [10yrs]:

Hours	No. of Facilities
0-6	14
7-12	8
13-24	2
27-72	4
>72	5

Emergency Planning for Water Supply Interruptions:


- **Estimate water required for various hospital functions**
- **ID critical functions that need to remain in operation**
- **ID functions that can be curtailed and how to curtail them**
- **Estimate quantity/quality required for essential functions**
- **ID alternative supplies and how to access them**

Pilot Project:

- **NMC, Portsmouth VA**
- **Address potential loss of water supply at facility**
- **Evaluate methods for other Navy Medical Facilities**

5/6/2009





5/6/2009

NMC Portsmouth:

- **Oldest operating hospital in the Navy**
- **112-acre complex**
- **Includes:**
 - **Main hospital**
 - **Logistics & administrative offices**
 - **Public works**
 - **Central energy plant**
 - **Gymnasium & other support buildings**

5/6/2009




Approach:

- **Site visits**
- **Departmental Interviews**
- **Collection & review of existing information**
- **Flow metering of targeted areas**
- **Development of emergency plan**



5/6/2009



Department Interviews – Results:

- **Bldg 2: Acute Care Facility = core functions**
- **Bldgs: 249 & 250 – Information Technology**
- **Bldg 20: Central Energy Plant**




Table 5-1. Summer Month Water Demand

Demand	Water Demand (gpd)
Industrial (Building 20)	212,000
Sanitary (Buildings 2 and 3)	169,000 ¹
Medical Processes (Buildings 2 and 3)	36,000 ¹
Cafeteria/Food Service (Buildings 2 and 3)	9,000
Laundry	0 ²
Total	426,000

5/6/2009

Table 5-2. Initial Assessment of Critical Demands - Building 2

Department	Floor	Demand (gpd)	% of Total Demand
Sterilization	3 rd	11,000	5.2%
Galley	1 st	9,000	4.2%
Operating Rooms	3 rd	9,000	4.2%
Emergency room	1 st	8,000	3.8%
All laboratories	1 st	7,500	3.5%
Nephrology/dialysis	2 nd	6,600	3.1%
Critical care/ICU	3 rd	5,000	2.4%
Neonatal infant care unit (NICU)	4 th	4,400	2.1%
Gastroenterology clinic	2 nd	1,200	0.6%
Post anesthesia care unit (PACU)	3 rd	1,200	0.6%
Compo B (complicated labor & delivery)	4 th	1,000	0.5%
Dental/Oral maxifacial	2 nd	900	0.4%
Critical care step down unit (SDU)	3 rd	650	0.3%
PACS computers	1 st	150	0.1%
Total		65,600	30.9%

5/6/2009

Metering of Critical Areas




5/6/2009




Table 5-3 Building 2 – Demand Estimates and Metered Consumption


ACF Department	Estimated Demand (gpd)	Metered Consumption (gpd)	% Difference from Estimate
Galley	9,600	9,000	6.3 %
Laboratory	7,500	2,335	69.3 %
Dental/Oral Maxifacial ¹	1,900	900	42.1 % ¹
Dental Laboratory	-	200	-
Pediatric ICU	2,060	12,800	-521.4 %
ICU	850	5,000	-481.4 %
Labor & Delivery 4M	1,300	7,200	-453.8 %
Labor & Delivery 4M	1,200	660	41.7%
Post Partum	2,370	1,300	45.8 %
Subtotal	26,820	39,400	-46.9 %
Total ²	120,540	212,270	43.2%
Unaccounted water		91,730	


5/6/2009



5/6/2009







Legend:

-  Portable Flow Meter
-  Domestic Cold Water Main
-  Hot Water Main


Metering results point to:

- **Piping drawings may not be accurate**
- **Large amount of unaccounted for water**
- **Valve isolation within a building not practice**
- **Most reliable information is water entering building**
- **Common issue with both military an civilian medical facilities**

Emergency planning focus:

- **Valve isolation of buildings**
- **Lock off non-critical functions within buildings**

Diagram of Distribution System



Use DS valves to limit available water supply to critical [core function] buildings.

Results for NMC Portsmouth

Table ES-2. Estimated Reservoir Operational Duration

Area Supplied With Water	Average Summer Consumption (MGD)	Days of supply when Reservoir at 2 MG	Days of supply when Reservoir at 1.68 MG	Days of supply when Reservoir at 1 MG	Days of supply when Reservoir at 0.5 MG
NMCP Complex	0.433	4.6	3.9	2.3	1.2
Building 2	0.210	9.5	8.0	4.8	2.4
Building 20	0.212	9.4	7.9	4.7	2.4
Buildings 2 and 20	0.422	4.7	4.0	2.4	1.2
Building 2 Critical and Building 20	0.278	7.2	6.0	3.6	1.8

5/6/2009

Other considerations:

- **Cooling towers are largest water users [increase cycles of conc.?)**
- **Waterless alternatives [handwashing, etc]**
- **Helicopter landing site considerations**
- **Flush valves may need to be closed manually**
- **ID tanks/connections/methods to received supplemental supplies if available**

Conclusions:

- **Water audit successfully identified critical water users, steps required to limit water use & development of emergency water conservation steps**
- **Implementation of emergency water conservation measures & valve isolation can extend the operation of critical functions.**
- **Valve isolation of complete buildings & locking off non-critical functions within a building is generally most practical.**
- **Valve isolation within a building generally not practical.**

Application to other Navy Medical Facilities

Basic steps:

- **Step 1 – Estimate water usage**
- **Step 2 – Identify critical functions**
- **Step 3 – Develop conservation plans**
- **Step 4 – Identify alternative water supplies**
- **Step 5 – Evaluate the information**
- **Step 6 – Develop emergency water conservation plan**

Application to other Navy Medical Facilities

Estimating water use considerations:

- **Heavy reliance on DS meters & meters on lines entering buildings**
- **Confirm calibration of meters**
- **Limit use of portable meters [sub metering]**

Alternative Water Supplies:

- Wells
- Storage tanks [onsite & offsite]
- Tanker trucks [certified food grade only]
- Talk to water supplier

5/6/2009



Down the Road...

Navy approach to emergency planning for water supply interruptions at medical facilities is now forming the basis for nationwide guidance that is being prepared jointly by AWWA, CDC and Homeland Security