

CHARACTERIZATION OF COMPOSITE ROD-PINCH-DIODE RADIOGRAPHIC SOURCES AT 5 TO 6 MV ON ASTERIX *

D. Mosher⁺, R.J. Allen, R.J. Commisso, S.B. Swanekamp^a, F.C. Young^a, and G. Cooperstein

Plasma Physics Division, Naval Research Laboratory, Washington, DC 20375, USA

C. Vermare, J. Delvaux, Y. Hordé, E. Merle, R. Nicolas, D. Noré, O. Pierret, Y.R. Rosol, Y. Tailleux, and L. Véron

Polygone d'Expérimentation de Moronvilliers, Moronvilliers, France

F. Bayol, A. Garrigues, C. Delbos, and G. Nicot

Centre d'Etudes de Gramat, Gramat, France

B. Oliver^b, D.V. Rose^b, D. Rovang, and J. Maenchen

Sandia National Laboratories, Albuquerque, NM 87185, USA

Abstract

Composite-rod-pinch loads on Asterix consisting of hollow aluminum tubes supporting either 1-cm-long, 1-mm-diam blunt-end or tapered gold slugs, or 1.5- to 2-mm-diam gold spheres are characterized. Composite-slug loads have slightly-lower doses than the 1.6- or 2-mm-diam standard rod pinches reported elsewhere and smaller spot sizes, leading to higher measured radiographic figures-of-merit (FOM). The FOM for the gold-sphere loads is substantially-smaller than for the slug loads.

I. INTRODUCTION

The rod-pinch diode provides an intense, pulsed, small-diameter, megavolt-bremsstrahlung source for point-projection radiography for which the impedance and spot size are partially decoupled.[1-3] The rod pinch (RP) has been evaluated at 5-6 MV on the Asterix generator [4,5], delivering 100 kA to the diode. The standard RP configuration, consisting of a few-mm-diam tungsten or gold anode rod protruding through, and a few-cm beyond an annular carbon cathode, is discussed elsewhere, along with the experimental setup and diagnostics.[5] Here, composite-RP loads consisting of hollow aluminum tubes supporting either 1-cm-long, 1-mm-diam gold slugs (blunt-end or tapered) or 1.5- to 2-mm-diam gold spheres are characterized (Fig. 1). Tips protrude 16 to 22 mm beyond the cathode. Eleven composite-RP shots were conducted during the experiment, a subset of which are discussed here. Composite-rod-pinch electrical coupling, dose, angular dose distribution, and spatial source x-ray

distributions from on- and off-axis rolled-edge-measurements are contrasted with those from standard-configuration loads.[5]




Figure 1. Tapered standard (top) and composite RP loads

Asterix loads require a rod diameter of at least 1.6 mm under the cathode for good electrical coupling and high dose.[3,5] Smaller diameter in the tip region is required to reduce the spot size and increase the radiographic figure of merit (FOM). The FOM is the dose divided by the square of the LANL-definition source diameter (SD) [2] as viewed from a point on the rod axis (0° angle). The composite RP, first demonstrated in lower-voltage Asterix experiments [6,7], provides small spot size with a 1-mm-diam gold tip and good electrical coupling by transitioning to an aluminum tube under the cathode. The 1.96-mm-OD, 1.4-mm-ID, lower-atomic-number tube minimizes radiation from radii larger than the tip.

Dose is observed [5] and predicted [8,9] to increase with viewing angle. When viewed from 90°, the standard and gold-slug RPs emit over a cm-long region, so that the higher off-axis dose will not be useful for radiography unless a smaller off-axis spot size can be achieved. The gold-sphere-composite loads are designed to address this

* Work supported by the Commissariat à l'Energie Atomique/DAM, the Centre d'Etudes de Gramat/DGA, and Sandia National Laboratories/DOE.

⁺ email: mosher@suzie.nrl.navy.mil

^a Titan/Jaycor, McLean, VA 22102.

^b Mission Research Corporation, Albuquerque, NM 87110.

Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE JUN 2003		2. REPORT TYPE N/A		3. DATES COVERED -	
4. TITLE AND SUBTITLE Characterization Of Composite Rod-Pinch-Diode Radiographic Sources At 5 To 6 Mv On Asterix				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Plasma Physics Division, Naval Research Laboratory, Washington, DC 20375				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release, distribution unlimited					
13. SUPPLEMENTARY NOTES See also ADM002371. 2013 IEEE Pulsed Power Conference, Digest of Technical Papers 1976-2013, and Abstracts of the 2013 IEEE International Conference on Plasma Science. IEEE International Pulsed Power Conference (19th). Held in San Francisco, CA on 16-21 June 2013. U.S. Government or Federal Purpose Rights License, The original document contains color images.					
14. ABSTRACT Composite-rod-pinch loads on Asterix consisting of hollow aluminum tubes supporting either 1-cm-long, 1-mm-diam blunt-end or tapered gold slugs, or 1.5- to 2-mm-diam gold spheres are characterized. Composite-slug loads have slightly-lower doses than the 1.6- or 2-mm-diam standard rod pinches reported elsewhere and smaller spot sizes, leading to higher measured radiographic figures-of-merit (FOM). The FOM for the gold-sphere loads is substantially-smaller than for the slug loads.					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT SAR	18. NUMBER OF PAGES 4	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			

need. Such a load would be useful for multiple-source radiography geometries that illuminate the target from different directions, and to preserve high radiographic resolution at the edge of extended objects centered on axis.

II. DISCUSSION AND CONCLUSIONS

Figures 2 and 3 show the 0° and 90° (axial) line spreads (LSs) for standard 1.6-mm-diam Au-rod shots: 7182 with a blunt-end tip, and 7184 with a tip tapered to a point over 10 mm. The 90° data are acquired from 80° rolled-edge data corrected to 90°. The 0° LSs of Fig. 2 have shapes suggested by electron deposition in the rod tip: uniform x-ray emission from a cylinder for 7182, and from a cone for 7184.[1,5] For the cylinder (a disc viewed on-axis),

$$LS(y) = \sqrt{1 - (y/R)^2} \quad (1)$$

where R is the radius of the cylinder. For the cone,

$$LS(y) = \sqrt{1 - (y/R_0)^2} - (y/R_0)^2 \ln \left[(R_0/y) + \sqrt{(R_0/y)^2 - 1} \right] \quad (2)$$

where R_0 is the radius of the cone base. Fits from Eqns. (1) and (2) are shown in Fig. 2. Values of R and R_0 in excess of the 0.8-mm rod radius are attributed to hydrodynamic expansion.[9] The LS shape differences lead to a smaller SD for a tapered tip (1.7 mm) than for a blunt tip (2.1 mm) with the same rod diameter.

Tip profiles in Fig. 3 are shown below the line spreads on the same axial scale. The spike near the blunt tip is due to electron impact on the front face as predicted in particle-in-cell (PIC) simulations of high-voltage rod-pinch flows [8]. Peak emission for the tapered tip is further back because of the small conical emitting volume near the end. It is speculated that the higher mass of the blunt tip allows more complete electron absorption over a shorter axial pinch length, producing a narrower axial LS. For either tip, the axial extent of emission is too large for radiography at large angles to the rod axis. The axial LSs of Fig. 3 are typical for both standard and composite RPs.

The impedance histories for three tapered-gold-tip RPs are shown in Fig. 4. The histories are shifted to align the times of peak x-radiation (arrow). The figure shows the reduced coupling characteristic [4] of the 1-mm-diam standard RP (7175), while the impedances of the 1.6-mm-diam standard (7184) and 1-mm-diam composite (7185) RPs are nearly identical with about 50-Ohm impedance during the radiation pulse.




Figure 2. 0° line spreads for standard 1.6-mm-diam RPs




Figure 3. 90° line spreads for standard 1.6-mm-diam RPs




Figure 4. Impedance vs time for three tapered gold RPs

The reduced impedance of the 1-mm-diam standard RP can be explained in the following way. The impedance scales like $\ln(R_C/R_A)$, where the cathode and anode radii vary due to electrode-plasma expansion at speeds $V_{C,A}$.

$$R_C(t) = R_{C0} - V_C t \quad ; \quad R_A(t) = R_{A0} + V_A t \quad (3)$$

Typically, $R_{C0}/R_{A0} = 11$ provides good coupling in 6-MV Asterix experiments, and all shots discussed here have that value. For small R_{A0} , and V_A of about 1 cm/ μ s [2], R_C/R_A can change by a large factor during the power pulse. Impedance collapse can also be accelerated by the higher beam heating and faster plasma expansion of a smaller-diameter rod. Increasing R_{C0}/R_{A0} to improve the coupling has limited value because impedance is not well behaved for ratios above 16.[1,2]

Figure 5 shows the 0° line spreads for the geometries of Fig. 4. The 1-mm-diam standard and composite RPs have comparable SDs that are substantially smaller than that of the 1.6-mm-diam standard RP. For 7175 and 7185, the line spreads show a base width about 0.5-mm larger than the Au tip, suggesting hydrodynamic expansion [10], and for the composite, radiation from the Al tube. The radiographic properties of the three RP configurations are compared in Table 1. Shot 7191, the same geometry as 7184, had a 16-mm extension beyond the cathode (7184 had 22 mm) and smaller SD. The composite geometry has a dose in air comparable to that of the 1.6-mm-diam standard RP and the spot size of the 1-mm-diam standard, resulting in the largest FOM of all the tested geometries.




Figure 5. 0° line spreads for tapered rod pinches

Table 1. Tapered rod pinch properties

shot	dose (rad)	SD (mm)	FOM (rad/mm ²)
7185	23.7	1.32	13.6
7184	27.6	1.70	9.6
7175	13.8	1.32	7.9
7191	27.4	1.55	11.4

Figure 6 compares a standard 1.6-mm-diam gold blunt-tip RP (7182) with a gold blunt-tip composite (7188), and Table 2 compares their radiographic properties. The table also shows the properties of a higher-dose standard 1.6-mm-diam tungsten blunt-tip RP (7183). Again, the composite achieves a higher FOM with lower dose because of the reduced SD.




Figure 6. 0° line spreads for blunt-tip RPs

Table 2. Blunt-tip rod pinch properties

shot	dose (rad)	SD (mm)	FOM (rad/mm ²)
7182	28.5	2.10	6.5
7183	34.8	2.00	8.7 (W)
7188	20.6	1.39	10.7

The angular variations of dose for the RP geometries discussed above are shown in Fig. 7. The TLD (circles) and PIN-diode (squares) doses are normalized to their values at 20° , where both measurements are made. Both standard [5] and composite RPs show similar scalings, with doses at 90° a factor 1.6 to 2.1 higher than at 0° . PIC computations [9] of TLD dose vs angle for two rod diameters (dashed lines) [8] agree with the measurements. In order to utilize the higher dose at large angles, the off-axis spot size (Fig. 2) must be greatly reduced. To this end, 1.5- to 2-mm-diam gold-sphere composites were tested.

Figure 8 compares the 0° and 90° line spreads for a gold spheroid with 2-mm vertical diam and 1.5-mm axial diam. Table 3 compares their properties. The 90° LS shows the front-surface peaking observed with blunt-tip loads, and its SD is increased by weak emission from the aluminum tube at axial positions less than 15 mm. Emission from the aluminum tube may be due to insufficient gold mass to effectively absorb the electron beam, which then migrates back to the tube. Enhanced beam heating of the tube may lead to increased anode expansion, thereby producing the impedance collapse observed with these loads. Gold-sphere loads behaved similarly in Gamble II

plasma-filled RP experiments.[11] The 0° LS is well represented by that expected for a uniformly-emitting sphere with a radius R slightly-larger than that of the gold spheroid viewed from the rod-pinch axis.

$$LS(y) = 1 - (y/R)^2 \quad (4)$$

The increased dose and decreased spot size at 90° produce an FOM about 2.5-times greater than that at 0°.




Figure 7. Angular variations of TLD (circles) and PIN-diode (squares) dose. Dashes are predictions from PIC simulations for two rod diameters.




Figure 8. 0° and 90° LS for a gold-shot composite RP

Table 3. Gold-sphere composite properties at 0° and 90°

angle	dose (rad)	SD (mm)	FOM (rad/mm ²)
0 deg	10.2	2.16	2.2
90 deg	16.4	1.70	5.7

In summary, composite-slug loads have slightly-lower doses than the best-performing standard RPs and smaller spot sizes, leading to higher measured radiographic FOM. For both standard and composite RPs, tapered tips have higher FOMs than blunt tips. The Au-sphere dose and FOM was smaller than for the slug loads, due perhaps to their limited mass and radiating volume. However, limited-mass loads such as the spheres show promise for off-axis radiography, multiple-source radiography geometries that illuminate the target from different directions, and to preserve high radiographic resolution at the edge of extended objects centered on axis. For limited-mass loads, the challenges are: to efficiently couple electron-beam energy to the tip, to minimize deposition in the support tube, and to maintain good impedance behavior. PIC simulations will aid in achieving these objectives.

III. REFERENCES

- [1] R.J. Commisso et al., "Experimental evaluation of a megavolt rod-pinch diode as a radiography source," IEEE Trans. Plasma Sci. **30**, 338-350(2002).
- [2] F.C. Young et al., "Rod Pinch Diode Operation at 2 to 4 MV for High Resolution Pulsed Radiography," Phys. Plasmas **9**, 4815-4818(2002), and references therein.
- [3] G. Cooperstein, et al., "Theoretical modeling and experimental characterization of a rod-pinch diode," Phys. Plasmas **8**, 4618-4636(2001).
- [4] R.J. Commisso, et al., these proceedings.
- [5] F.C. Young, et al., these proceedings.
- [6] F. Bayol, et al., "Evaluation of the rod-pinch diode as a high-resolution source for flash radiography at 2 to 4MV," Proc. 2001 IEEE PPPS Conf. **1**, pp. 450-453.
- [7] R.J. Commisso, et al., "Characterization of the Rod-Pinch Diode at 2 to 4 MV as a High-Resolution Source for Flash Radiography," AIP Conf. Proc **650**, p. 183-6.
- [8] S.B. Swanekamp, et al., these proceedings.
- [9] D.V. Rose, et al., "Coupled particle-in-cell and Monte Carlo transport modeling of intense radiographic sources," J. Appl. Phys. **91**, 3328-3335(2002).
- [10] D. Mosher, et al., "An Electron-Beam-Heating Model for the Gamble II Rod Pinch," AIP Conf. Proc **650**, 2002, p. 199-202.
- [11] B.V. Weber, et al., "The Plasma-Filled Rod-Pinch Diode: a New Technique to Concentrate MeV Electron Beams to Ultra-High Power- and Energy-Densities," AIP Conf. Proc **650**, 2002, p. 191-194.