

UNCLASSIFIED

AD NUMBER

ADB009650

LIMITATION CHANGES

TO:

Approved for public release; distribution is unlimited.

FROM:

Distribution authorized to U.S. Gov't. agencies only; Test and Evaluation; FEB 1976. Other requests shall be referred to Air Force Weapons Laboratory, Attn: DYT, Kirtland AFB, NM 87117.

AUTHORITY

AFWL ltr, 7 Nov 1986

THIS PAGE IS UNCLASSIFIED

AD Boo 9650

AUTHORITY:

AFWL etc.

7 Nov 86



②

AIRBLAST CALCULATIONS FOR ADVANCED MISSILE SYSTEM (MX) SUPPORT

Charles E. Needham
Cydney Westmoreland

February 1976

Final Report

Distribution limited to US Government agencies only because test and evaluation of military systems is discussed in the report (Feb 76). Other requests for this document must be referred to AFWL (DYT), Kirtland AFB, NM, 87117.

Prepared for

SPACE AND MISSILE SYSTEMS ORGANIZATION
Los Angeles, CA 90009

AIR FORCE WEAPONS LABORATORY
Air Force Systems Command
Kirtland Air Force Base, NM 87117

AD No. ADB009650
DDC FILE COPY



UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER AFWL-TR-75-297 ✓	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) AIRBLAST CALCULATIONS FOR ADVANCED MISSILE SYSTEM (MX) SUPPORT	5. TYPE OF REPORT & PERIOD COVERED Final Report	6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) Charles E. Needham, Cydney Westmoreland	8. CONTRACT OR GRANT NUMBER(s) SAMSO-PO-6-MNM-08 AF-672A	9. DISTRIBUTION STATEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 63305F; 672A0201
9. PERFORMING ORGANIZATION NAME AND ADDRESS Air Force Weapons Laboratory (DYT) ✓ Kirtland AFB, NM 87117	10. REPORT DATE February 1976	11. NUMBER OF PAGES 128
11. CONTROLLING OFFICE NAME AND ADDRESS Air Force Weapons Laboratory (DYT) Kirtland AFB, NM 87117	12. SECURITY CLASS. (of this report) UNCLASSIFIED	13. DECLASSIFICATION/DOWNGRADING SCHEDULE
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office) Space and Missile Systems Organization Los Angeles, CA 90009	15. DISTRIBUTION STATEMENT (of this Report) Distribution limited to US Government agencies only because test and evaluation of military systems is discussed in the report (Feb 76). Other requests for this document must be referred to AFWL (DYT), Kirtland AFB, NM, 87117.	
16. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
17. SUPPLEMENTARY NOTES		
18. KEY WORDS (Continue on reverse side if necessary and identify by block number) Airblast; Advanced missile system (MX); Airblast propagation in tunnels; Theoretical airblast calculations		
19. ABSTRACT (Continue on reverse side if necessary and identify by block number) A series of theoretical calculations of the air blast resulting from a 1 megaton (MT) detonation has been conducted. The calculations include the free air environment and propagation through a smooth tunnel with various inlet pressures. One calculation also included corrugated walls. The various results are compared.		

DD FORM 1 JAN 73 1473


EDITION OF 1 NOV 65 IS OBSOLETE

UNCLASSIFIED 013 150

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)



UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

PREFACE

The calculations presented in this report compliment and supplement systems calculations initiated at TRW. Special appreciation is given to Mr. Allen Kuhl (TRW) for his cooperation and to Capt T. Tolman (AFWL/SA) for his guidance.

CONTENTS

Section		
I	INTRODUCTION	7
II	SMOOTH TUNNEL PROPAGATION	8
III	THE TWO-DIMENSIONAL CALCULATION	18
	APPENDIX A	
	1-D Waveform Comparisons	23
	APPENDIX B	
	Tabulated Inlet Conditions	81
	APPENDIX C	
	Plots of the 2-D Calculation	84

ILLUSTRATIONS

Figure

1	O.P. versus Distance - $P_o = 10^5$ psi	10
2	O.P. versus Distance - $P_o = 10^4$ psi	11
3	O.P. versus Distance - $P_o = 600$ psi	12
4	O.P. versus Distance - $P_o = 100$ psi	13
5	O.P. versus Distance - $\Delta R = 6$ cm	14
6	O.P. versus Distance - Corrugation Effects	21

TABLES

Table

1	1-D Input Parameters	9
2	Overpressure for Various Inlet Conditions	16
3	Peak Pressures in Corrugated Tube	20

SECTION I

INTRODUCTION

Several questions have been raised regarding the propagation of air blast through tunnels with various input and surface conditions. A series of experiments was conducted to investigate this problem during the Pre Dice Throw 100 ton TNT event by TRW Systems. In addition TRW and the Air Force Weapons Laboratory (AFWL) have made several hydrodynamic calculations in support of the experiments and the underlying question of blast propagation in general.

The subsequent sections of this report include a summary of the AFWL calculations.

SECTION II

SMOOTH TUNNEL PROPAGATION

Four calculations have been completed for a smooth walled tunnel. In each case the input boundary conditions at the tunnel entrance were taken from the AFWL 1 KT Standard (ref. 1) scaled to 1 MT. The calculations were carried to a distance of 3.2 km, which corresponds to a free air overpressure of less than 10 psi. The inlet peak overpressure levels were 10^5 , 10^4 , 600, and 100 psi. Table 1 contains the initial conditions for each of the four calculations. All calculations were made with a one-dimensional, Eulerian, second order accurate, hydrodynamics code (DYTSAP). The zone size in the vicinity of the shock front was held constant at 2 meters. Figures 1 through 4 are plots of the peak overpressure versus distance from burst point for the four inlet pressure levels above.

The 1 KT standard used as boundary conditions is an analytic fit with discontinuous shocks. Hydrodynamic codes define the shock over a minimum of three zones, thus the shock front for these calculations is spread over approximately 6 meters (m). The effect of this interface between analytic and zone definition is an artificial drop in the peak overpressure immediately upon entering the hydro grid. As a check on this phenomenon, an additional calculation was made with 0.06 m zones (figure 5). The fine zone calculation exhibited the same drop in

-
1. Needham, C. E., Air Force Weapons Laboratory (1 KT) Nuclear Blast Standard, AFWL-TR-73-55, Air Force Weapons Laboratory, Kirtland AFB, NM, April 1975.

Table 1

1-D INPUT PARAMETERS

<u>Problem</u>	<u>13.0011</u>	<u>13.0012</u>	<u>13.0013</u>	<u>13.0014</u>
Yield	1	1	1	1
Starting time (sec)	5.1×10^{-1}	9.3×10^{-2}	7.3×10^{-3}	1.0×10^{-3}
Distance of left mesh edge from burst center (M)	9.39×10^2	4.54×10^2	1.694×10^2	7.96×10^1
Initial peak pressure (Pascals)	6.8×10^5 (Approx. 100 psi)	4.129×10^6 (Approx. 600 psi)	6.8×10^6 (Approx. 10^4 psi)	6.5×10^8 (10^5 psi)
Number of cells	900	900	900	900
Width of cells (M)	2.	2.	2.	2.




Figure 1. O.P. versus Distance - $P_0 = 10^5$ psi




Figure 2. O.P. versus Distance - $P_0 = 10^4$ psi




Figure 3. O.P. versus Distance - $P_0 = 600$ psi




Figure 4. O.P. versus Distance - $P_0 = 100$ psi




Figure 5. O.P. versus Distance - $\Delta R = 6$ cm

peak overpressure but only a small percentage of that of the 2 m zone calculation. As the two calculations progress, the overpressure distance curves merge, and by a distance of 500 m no significant differences can be found. The conclusion is that the correct amount of energy is entering the calculational mesh but takes a small amount of time (about 20 zones) to adjust to the new conditions.

Table 2 compares the various results with one another and with the free air case at 1 and 3 kilometers from the burst point.

Table 2

OVERPRESSURE FOR VARIOUS INLET CONDITIONS

<u>P</u> <u>(Pascals)</u>	<u>P (Pascals)</u> <u>at R = 1 km</u>	<u>P (Pascals)</u> <u>at R = 3 km</u>
6.8×10^8 (10^5 psi)	1.2×10^7	3.5×10^6
6.8×10^7 (10^4 psi)	4.3×10^6	1.2×10^6
4.13×10^6 (600 psi)	1.0×10^6	3.2×10^5
6.5×10^5 (100 psi)	4.9×10^5	1.5×10^5
Free air	4.8×10^5	6.0×10^4

The table shows that a factor of three increase in pressure results at a distance of 3 kilometers when the inlet pressure is increased from 10^4 to 10^5 psi. The pressure at 3 km for 10^4 inlet pressure is 20 times as great as that of free air at the same point. The overpressure impulse is more than 200 times that of free air. Similar comparisons can be made using table 1 for other inlet pressures. Plots of the pressure waveforms for these four problems are contained in Appendix A. A tabulation of inlet parameters for the 10^4 and 10^5 psi waveforms is given in Appendix B.

SECTION III

THE TWO-DIMENSIONAL CALCULATION

One calculation was made in two-dimensional cylindrical geometry to study the effects on air blast of corrugations on the inner surface of the tunnel wall. The calculational mesh was 28 radial by 800 axial zones for a total of 22,400. The radial zone dimensions were 6 cm near the outer edge of the tunnel with gradually increasing size to 15 cm at the center of the tunnel. The 800 axial zones were initially 12 cm, and the problem was rezoned such that the shock front always traveled through 12 cm zones. The tunnel had an outside diameter of 4.68 m. Attached to the wall were perfectly reflecting rings extending 0.24 m into the tunnel and 0.6 m of outer wall between rings or 2.04 m from center to center. At the tunnel entrance 10^4 psi input from a 2-MT free air burst was used as a boundary condition. The calculation has been run a distance of 180+ meters down the tunnel.

Waveform plots indicate multiple shock enhancement on the axis of symmetry. Overall decay of the shock front pressure appears to be matching that of the free air curve and is significantly more rapid than the 1-D (smooth walled) calculation. The enhancement of reflected shocks is a significant factor. A train of shock waves of gradually decreasing peak pressure follow the main shock at a nearly constant time interval between 1 and 1.5 ms. The impulse is at least as great as that of the 1-D calculations.

The inlet temperature, after shock passage, is in excess of 25,000°K. This high temperature gas is pulled into the tunnel behind the shock and is further shock heated to temperatures over 30,000°K.

Table 3 gives the maximum pressure reached at several points in the tunnel. In almost all cases the peak pressure reached is not the first shock but the second or third. Figure 6 is the pressure-distance curve inside the corrugated tunnel. Also included are curves from the free air case and the smooth tunnel calculation. Appendix C contains a number of plots of a small portion of the length of the tunnel during shock passage. The multiple shock enhancement is clearly shown.

Table 3

PEAK PRESSURES IN CORRUGATED TUBE

Range from burst (meter)	<u>Peak pressure (dynes/cm²)</u>		
	<u>Tunnel center</u>	<u>Between center and outer edge</u>	<u>Near out- side edge</u>
214.3	6.77E8	6.80E8	1.05E9
224	7.81E8	3.85E8	4.43E8
234	5.55E8	3.80E8	3.97E8
244	4.40E8	3.85E8	3.61E8
253	3.76E8	3.32E8	4.74E8
263	3.15E8	2.96E8	3.33E8
273	3.21E8	2.66E8	2.41E8
284	3.17E8	2.60E8	6.04E8
294	2.89E8	2.32E8	3.71E8
304	2.43E8	2.00E8	2.43E8
314	2.84E8	2.53E8	2.64E8
324	2.54E8	2.14E8	1.78E8
334	2.13E8	1.76E8	1.22E8
344	1.83E8	1.47E8	1.17E8
353	1.40E8	1.36E8	1.76E8
363	1.31E8	1.25E8	5.87E7





Figure 6. O.P. versus Distance - Corrugation Effects

APPENDIX A

1-D WAVEFORM COMPARISONS


This appendix contains comparisons of overpressure waveforms inside the tunnel with free air waveforms at the corresponding times.

OVERPRESSURE




AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI


VELOCITY




AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI



AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI


OVERPRESSURE




AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 100 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 600 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI



AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI


OVERDENSITY




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI



AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI




AFWL COMPARISON OF 2 MT FORCED AND FREE AIR WAVEFORMS 1.E4 PSI


OVERPRESSURE



AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI


OVERPRESSURE




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL CALC OF 1 MT 1-D AND FREE AIR 1.E4 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI




AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI



AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI



AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI



AFWL COMPARISON OF 1 MT FORCED AND FREE AIR WAVEFORMS 1.E5 PSI

APPENDIX B

TABULATED INLET CONDITIONS

This appendix contains tabulated values of the inlet conditions for the 10^4 and 10^5 psi conditions. All units are CGS.

INPUT CONDITIONS FOR SMOOTH TUNNEL CALCULATIONS
YIELD = 1.000E+03 RADIUS = 7.960E+03

TIME	OVERPRESSURE	VELOCITY	OVERDENSITY	ENERGY DENSITY
1.000E-03	6.425E+09	2.147E+06	4.376E-03	2.314E+12
1.004E-03	5.793E+09	2.137E+06	8.183E-03	2.702E+12
1.008E-03	5.336E+09	2.128E+06	7.936E-03	2.555E+12
1.012E-03	4.992E+09	2.119E+06	7.813E-03	2.439E+12
1.016E-03	4.631E+09	2.105E+06	7.546E-03	2.363E+12
1.020E-03	4.331E+09	2.086E+06	7.206E-03	2.300E+12
1.024E-03	4.086E+09	2.060E+06	6.725E-03	2.301E+12
1.028E-03	3.853E+09	2.004E+06	5.794E-03	2.457E+12
1.112E-03	3.630E+09	1.908E+06	4.401E-03	2.888E+12
1.168E-03	3.418E+09	1.807E+06	3.180E-03	3.473E+12
1.226E-03	3.221E+09	1.712E+06	2.240E-03	4.222E+12
1.286E-03	3.039E+09	1.624E+06	1.512E-03	5.113E+12
1.350E-03	2.864E+09	1.539E+06	9.312E-04	6.118E+12
1.418E-03	2.697E+09	1.458E+06	4.699E-04	7.437E+12
1.488E-03	2.543E+09	1.382E+06	1.144E-04	9.005E+12
1.562E-03	2.397E+09	1.310E+06	-1.677E-04	1.091E+13
1.640E-03	2.259E+09	1.242E+06	-3.906E-04	1.303E+13
1.722E-03	2.123E+09	1.177E+06	-5.660E-04	1.578E+13
1.808E-03	2.005E+09	1.115E+06	-7.036E-04	1.909E+13
1.898E-03	1.890E+09	1.057E+06	-8.112E-04	2.267E+13
1.992E-03	1.781E+09	1.002E+06	-8.953E-04	2.724E+13
2.090E-03	1.681E+09	9.500E+05	-9.609E-04	3.258E+13
2.194E-03	1.583E+09	9.003E+05	-1.013E-03	3.823E+13
2.302E-03	1.493E+09	8.536E+05	-1.053E-03	4.521E+13
2.416E-03	1.403E+09	8.090E+05	-1.085E-03	5.225E+13
2.536E-03	1.327E+09	7.665E+05	-1.110E-03	6.084E+13
2.660E-03	1.252E+09	7.269E+05	-1.129E-03	6.882E+13
2.792E-03	1.180E+09	6.887E+05	-1.144E-03	7.835E+13
2.930E-03	1.112E+09	6.527E+05	-1.156E-03	8.653E+13
3.074E-03	1.049E+09	6.185E+05	-1.165E-03	9.581E+13
3.226E-03	9.890E+08	5.861E+05	-1.172E-03	1.028E+14
3.384E-03	9.320E+08	5.556E+05	-1.178E-03	1.087E+14
3.550E-03	8.790E+08	5.266E+05	-1.183E-03	1.154E+14
3.724E-03	8.300E+08	4.991E+05	-1.186E-03	1.187E+14

INPUT CONDITIONS FOR SMOOTH TUNNEL CALCULATIONS

YIELD = 1.000E+03 RADIUS = 1.596E+04

TIME	OVERPRESSURE	VELOCITY	OVERDENSITY	ENERGY DENSITY
7.300E-03	0.	0.	0.	2.043E+09
7.520E-03	6.792E+08	7.064E+05	9.436E-03	3.426E+11
7.560E-03	6.300E+08	7.022E+05	9.044E-03	3.333E+11
7.600E-03	5.837E+08	6.980E+05	8.669E-03	3.261E+11
7.640E-03	5.533E+08	6.939E+05	8.309E-03	3.180E+11
7.700E-03	5.091E+08	6.878E+05	7.797E-03	3.093E+11
7.760E-03	4.736E+08	6.819E+05	7.317E-03	3.039E+11
7.820E-03	4.447E+08	6.760E+05	6.866E-03	3.014E+11
7.900E-03	4.143E+08	6.683E+05	6.307E-03	3.069E+11
7.980E-03	3.906E+08	6.608E+05	5.791E-03	3.107E+11
8.080E-03	3.680E+08	6.516E+05	5.203E-03	3.194E+11
8.220E-03	3.449E+08	6.391E+05	4.474E-03	3.378E+11
8.400E-03	3.243E+08	6.237E+05	3.672E-03	3.697E+11
8.640E-03	3.055E+08	6.042E+05	2.799E-03	4.238E+11
8.960E-03	2.876E+08	5.799E+05	1.902E-03	4.964E+11
9.340E-03	2.713E+08	5.533E+05	1.125E-03	6.450E+11
9.780E-03	2.556E+08	5.252E+05	4.929E-04	8.692E+11
1.026E-02	2.408E+08	4.975E+05	2.051E-05	1.140E+12
1.076E-02	2.270E+08	4.714E+05	-3.152E-04	1.420E+12
1.130E-02	2.133E+08	4.458E+05	-5.619E-04	1.742E+12
1.186E-02	2.015E+08	4.219E+05	-7.359E-04	2.119E+12
1.244E-02	1.900E+08	3.995E+05	-8.593E-04	2.633E+12
1.306E-02	1.790E+08	3.779E+05	-9.500E-04	3.325E+12
1.370E-02	1.683E+08	3.577E+05	-1.015E-03	4.131E+12
1.433E-02	1.591E+08	3.384E+05	-1.062E-03	5.112E+12
1.510E-02	1.499E+08	3.199E+05	-1.097E-03	6.230E+12
1.584E-02	1.413E+08	3.027E+05	-1.122E-03	7.305E+12
1.662E-02	1.332E+08	2.864E+05	-1.141E-03	8.549E+12
1.744E-02	1.256E+08	2.709E+05	-1.154E-03	9.654E+12
1.830E-02	1.184E+08	2.562E+05	-1.165E-03	1.086E+13
1.920E-02	1.116E+08	2.424E+05	-1.173E-03	1.179E+13
2.014E-02	1.052E+08	2.293E+05	-1.179E-03	1.257E+13
2.112E-02	9.923E+07	2.171E+05	-1.183E-03	1.341E+13
2.216E-02	9.358E+07	2.054E+05	-1.187E-03	1.386E+13
2.324E-02	8.826E+07	1.945E+05	-1.190E-03	1.412E+13
2.436E-02	8.321E+07	1.840E+05	-1.192E-03	1.420E+13
2.553E-02	7.843E+07	1.741E+05	-1.193E-03	1.385E+13
2.682E-02	7.399E+07	1.649E+05	-1.191E-03	1.214E+13
2.812E-02	6.980E+07	1.561E+05	-1.188E-03	1.054E+13
2.950E-02	6.580E+07	1.476E+05	-1.184E-03	9.104E+12
3.094E-02	6.204E+07	1.396E+05	-1.180E-03	7.816E+12
3.244E-02	5.852E+07	1.321E+05	-1.177E-03	6.743E+12
3.402E-02	5.513E+07	1.250E+05	-1.175E-03	6.148E+12


APPENDIX C

PLOTS OF THE 2-D CALCULATION


This appendix contains histograms, vectors, and contour plots of pertinent variables for the corrugated tunnel calculation. The shocks reflected from the corrugations, one shock for each corrugation, are clearly shown. The vortex formed between the corrugations can also be seen in the velocity vector plots and on the vorticity plots. The multiple shock fronts, so clearly seen on the pressure histograms, are not numerical instabilities. This is demonstrated by the fact that in the first eight shocks nearly 100 zones are used to resolve them. instabilities would be seen in essentially every other zone.

The tunnel is oriented along the axis of symmetry of the code. Thus, on the plots, altitude refers to distance along the length of the tunnel from the opening, not from the burst center. The numbers on the right and the top of the graphs are the zone numbers for the calculational grid.

PRESSURE VERTICAL HISTOGRAM
 VERTICAL CROSS SECTION AT RADIUS 7.50E-05 KM (I= 1)




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100

GRADIENTS PRESSURE




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100

GRADIENTS PRESSURE




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100

DENSITY VERTICAL HISTOGRAM
 VERTICAL CROSS SECTION AT RADIUS 7.50E-05 KM (I= 1)




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100


VECTOR VELOCITY




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100



APWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100

VERTICAL VELOCITY VERTICAL HISTOGRAM
 VERTICAL CROSS SECTION AT RADIUS 7.50E-05 KM (I= 1)




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100


KINETIC ENERGY




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 32.000 MSEC CYCLE 733. PROBLEM 13.6100



AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100

GRADIENTS PRESSURE




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100

GRADIENTS PRESSURE




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100

VERTICAL VELOCITY VERTICAL HISTOGRAM
 VERTICAL CROSS SECTION AT RADIUS 7.50E-05 KM (I= 1)




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100


DENSITY VERTICAL HISTOGRAM
 VERTICAL CROSS SECTION AT RADIUS 7.50E-05 KM (I= 1)




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100



KINETIC ENERGY




AWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100





AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100

VECTOR VELOCITY





AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100






APWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100







APWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 34.000 MSEC CYCLE 942. PROBLEM 13.6100




PRESSURE VERTICAL HISTOGRAM
 VERTICAL CROSS SECTION AT RADIUS 7.50E-05 KM (I= 1)



AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 38.249 MSEC CYCLE 1474. PROBLEM 13.6100




GRADIENTS PRESSURE




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 39.249 MSEC CYCLE 1474. PROBLEM 13.6100

GRADIENTS PRESSURE




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 39.249 MSEC CYCLE 1474. PROBLEM 13.6100


VERTICAL VELOCITY VERTICAL HISTOGRAM
 VERTICAL CROSS SECTION AT RADIUS 7.50E-05 KM (I= 1)



AFWL HULL CALC. OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 39.249 MSEC CYCLE 1474. PROBLEM 13.6100




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
 TIME 39.249 MSEC CYCLE 1474. PROBLEM 13.6100




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 39.249 MSEC CYCLE 1474. PROBLEM 13.6100

KINETIC ENERGY




AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 39.249 MSEC CYCLE 1474. PROBLEM 13.6100


VECTOR VELOCITY



AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN
 TIME 39.249 MSEC CYCLE 1474. PROBLEM 13.6100



AFWL HULL CALC. OF 1 MT CORRUGATED TUBE 10000 PSI IN SEP 75
TIME 39.249 MSEC CYCLE 1474. PROBLEM 13.6100



AFWL HULL CALC OF 1 MT CORRUGATED TUBE 10000 PSI IN
 TIME 39.249 MSEC CYCLE 1474. PROBLEM SEP 75 13.6100

DISTRIBUTION

<u>No. cys</u>		<u>No. cys</u>	
	Hq USAF, Wash, DC 20330		RADC, Griff AFB, NY 13440
1	SAMI	1	Doc Lib
1	XOOWD	1	EMCTT-1, Mr. Entzminger
1	PRE		AFWL, Kirt AFB, NM 87117
1	PREE	1	HO, Dr. Minge
1	RDQLM	2	SUL
1	RDQPN	5	DYT, Mr. Needham
1	RDQS	1	IN
1	AFTAC/TAP, Pat AFB, FL 32925	1	SA
1	AFCEC/PREC, Tynd AFB, FL 32401	1	SAA
1	AFISC/SE, Nort AFB, CA 92409	1	SAB
		2	SAT, Mr. Sharp; Mr. Murphy
		1	DE
		1	DEV
		1	DEX
		1	DEZ
		1	DY
		1	DYS
		1	DYX
	AFSC, And AFB, Wash, DC 20331		AFATL, Eg1 AFB, FL 32542
1	DOB	1	Maj Durrett
1	SCS	1	Capt Matuska
	TAC, Lang AFB, VA 23365		AFOSR/Lib, 1400 Wilson Blvd, Arlington, VA 22209
1	LGMD	1	TAWC, Eg1 AFB, FL 32544
1	DRA		Diamond Lab, Wash, DC 20438
1	AUL/LDE, Max AFB, AL 36112	1	Lib
1	AU/ED, CE, Max AFB, AL 36112	1	ANXDO-NP, L. Belliveau
1	AFIT, WPAFB, OH 45433	1	RSIC/Ch, Doc Sec, Rdstn Ars, AL 35809
1	Tech Lib	1	BRL, Abdn Pvg Gnd, MD 21005
1	DAPD	1	AMXBR-TB, J. Meszaros
1	CINCUSAFE/INT, APO NY 09012	1	AMXBR
1	USAFA/DFSLB, CO 80840	1	AMXBR-RL
1	USAF SCLO (Maj Pierson, Ch, LO), POB 384, Toronto, ON M5K 1K7	1	J. Keefer
1	ARL/STINFO, WPAFB, OH 45433		Picatinny Ars, Dover, NJ 07801
1	AFML/Lib, WPAFB, OH 45433	1	SMUPA-TN
		1	STINFO Ofc
	SAMSO, POB 92960, WWPC, LA, CA 90009		USA Eng. WW Exp Sta, POB 631, Vicksburg, MS 39181
1	SEN	1	WESRL
1	MNNH, Maj Gage	1	WESSS
1	ADTC/Lib, Eg1 AFB, FL 32542	1	WSMR/Lib, Wht Sands, NM 88002
		1	Nav Ops/OP-75, Wash, DC 20350

No. cys

1 NRL, Wash, DC 20390
 1 Code 2070
 1 J. Boris
 NSWG, Wht Oak, Slvr Sp, MD
 20910
 1 Code 730
 1 J. Peters
 1 Exp Eff Div, Mr. Hornig
 1 NWEF/Code ADS, Kirt AFB,
 NM 87117
 DNA, Wash, DC 20305
 1 DDST, Dr. Atkins
 2 STTL
 4 SPSS, E. Sevin; Capt J.
 Stockton; Maj T. Stong;
 K. Goering
 1 SPA, Capt D. Garrison
 2 SPAS, J. Moulton; M.
 Rubenstein
 1 STAP
 1 SPLN, J. Kelso
 2 RAAE, P. Fleming; Capt
 Bauer
 1 RATN, Comdr Alderson
 1 ODDR&E/Asst Dir, Strat Wpns,
 Wash, DC 20301
 1 ARPA/LtC Whitaker, 1400
 Wilson Blvd, Arlington, VA
 22209
 2 DDC/TCA, Cam Sta, Alex, VA
 22314
 1 ERDA/Lib, J004, Wash, DC
 20545
 1 JSTPS/Maj Greene, Off AFB,
 NE 68113
 1 DIA/Mr. Castlebury, Wash,
 DC 20305
 Sandia Lab, Kirt AFB, NM
 87115
 1 Org 3141
 1 Div 1111
 1 Org 1723, G. E. Barr
 1 Div 5644, J. Reed
 3 M. Meritt; L. Vortman;
 D. Dahlgren
 1 AFCRL/OPR, Dr. Gardiner,
 Hanscom AFB, MA 01730

No. cys

1 LLL/Lib, B50, R134, Berkeley,
 CA 94720
 Sandia Lab, POB 969, Liver-
 more, CA 94550
 1 Org 8000, Dr. Cook
 1 R. Scholer
 1 T. Gold
 1 J. Mansfield
 LLL, POB 808, Livermore, CA
 94550
 1 L-51, M. Hanson
 1 TID
 1 E. E. Alexander
 LASL, POB 1663, Los Alamos,
 NM 87554
 1 Rpt Lib
 2 J-10, E. Jones; R. Gentry
 1 Dr. A. Graves
 Aerosp Corp, POB 92957, LA,
 CA 90009
 1 Lib
 1 R. L. Beck
 Brn Eng Co, 300 Sparkman,
 Huntsville, AL 35807
 1 V. Kenner, MS-44
 1 C. Wayne
 1 J. Dobkins
 McDon Doug, 5301 Balsa,
 Huntington Beach, CA 92547
 7 K. Stone; P. Lewis; D.
 Dean; T. Thomas; D. Hilde-
 brand; J. Logan; R. Zach
 1 GE TEMPO/T. Barret, 816 State,
 Santa Barbara, CA 93102
 Kaman Sci, CO Spgs, CO 80907
 2 D. Pirio; D. Sacks
 1 Kaman Av/J. Ruetenik, 83 2nd
 Ave, Burlington, MA 01803
 MartMar, POB 5837, Orlando,
 FL 32805
 4 R. Heffner; C. Washburn;
 H. Suguichi; D. Cooke
 MRC, 1 Presidio, Sta Barbara,
 CA 93101
 2 R. Christian; D. Sowle

No. cys

3 SAI, POB 2351, La Jolla,
CA 92037
C. Busch; R. Lowen;
J. Young

1 SAI/D. Hove, 101 Cont Bldg,
Ste 310, El Segundo, CA
90245

1 SAI/R. Hillendahl, POB 10268,
Palo Alto, CA 94303

1 GRC/J. Ise, Box 3587, Sta
Barbara, CA 93105

1 SAI/M. Tobrinen, Ste 808,
1901 N. Ft Myer, Arlington,
VA 22209

1 SAI/R. Clemens, 122 LaVeta
Dr NE, Albuquerque, NM
87108

1 BTL/W. Troutman, Whippany,
NJ 07981

1 Calspan/R. Deliberis, POB
235, Buffalo, NY 14221

1 ISI/W. Dudziak, 123 W.
Padre, Sta Barbara, CA
93105

1 Lockheed, 3251 Hanover,
Palo Alto, CA 94304
MITRE, Box 208, Bedford,
MA 01730

2 S. Morin; J. Brown

1 CRT/M. Rosenblatt, 19720
Ventura, Ste H, Woodland
Hills, CA 91364
R&D Assoc, POB 3580, Sta
Monica, CA 90403

4 H. Brode; C. Knowles;
J. Carpenter; R. Lelevier

1 MARA/S. Kahalas, 385 Elliot,
Newton Upper Falls, MA
02164
TRW Sys Gp, 1 Sp Pk, Redondo
Beach, CA 90278

1 Lib
2 A. Kuhl
1 J. Peterson

1 Avco/G. Grant, 201 Lowell,
Wilmington, MA 01887

No. Cys

1 IDA, 400 Arm-Nav Dr, Arling-
ton, VA 22202

1 ASD/I&L, Wash, DC 20301

1 Arm For Stf Col/Lib, Norfolk,
VA 23511

1 Ind Col Arm For, Ft McNair,
Wash, DC 20315

1 Nat War Col/Lib, Ft McNair,
Wash, DC 20315

1 USAMC/AMCRD-RP-B, Wash, DC
20315

1 USAEC/AMSEL-RD, Ft Monmouth,
NJ 07703

USNCEL, Pt Hueneme, CA 93041
Code L31
CEC Ofcr

1 MIT/Dr. Hansen, 77 MA Ave,
Cambridge, MA 02139

1 Princeton U/PPL, Dr Bleakney,
Princeton, NJ 08540
Un MI, POB 618, Ann Arbor, MI
48104

1 Rsch Soc Ofc
1 IS&T, G. Frantti

1 St Louis Un/Dr. Kisslinger,
221 N. Grand, St Louis, MO
63100

1 Boeing/R. Carlson, Seattle,
WA 98124

1 GATC/MRD Div Lib, 7501 N.
Natchez, Niles, IL 60648

1 H&N Sp Pro Div/S. Smith, 849
S. Bwdy, LA, CA 90014

1 URS, 1811 Trousdale, Burlin-
game, CA 94010

1 SWPI/M. Whitfield, 8500 Cule-
bra, San Antonio, TX 78228

1 Un IL/Dr. Newmark, Tal Lab,
R207, Urbana, IL 61803

1 IITRI, 10 W. 35, Chicago, IL
60616

1 NWC, China Lake, CA 93557

1 RAC/Lib, McLean, VA 22101

No. cys

5	Abdn Pvg Gnd, MD 21005 Ch, Tech Lib; AFLO; MCLO; NLO; CDCLO
1	NASA S&TIF, POB 5700, Bethesda, MD 20014
1	Off Rec Cy/C. Needham, AFWL/DYT

No. cys

1	USMC/Code A03H, Wash, DC 20380
1	RAND Corp, 1700 Main, Sta Monica, CA 90406
1	NASA-Langley/J. Stack, Lang Sta, Hampton, VA 23365